Official Transcript of Proceedings ACRST-3301

NUCLEAR REGULATORY COMMISSION

Title:

Advisory Committee on Reactor Safeguards

Reactor Fuels Subcommittee

Docket Number:

(not applicable)

PROCESS USING ADAMS TEMPLATE: ACRS/ACNW-005

SISP REVIEW COMPLETE

Location:

Rockville, Maryland

Date:

Wednesday, December 15, 2004

Work Order No.:

NRC-142

Pages 1-363

NEAL R. GROSS AND CO., INC. Court Reporters and Transcribers 1323 Rhode Island Avenue, N.W. Washington, D.C. 20005 (202) 234-4433

RETAIN FOR THE LIFE OF THE COMMITTEE

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

December 15, 2004

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, taken on December 15, 2004, as reported herein, is a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected and edited and it may contain inaccuracies.

1	UNITED STATES OF AMERICA
2	NUCLEAR REGULATORY COMMISSION
3	+ + + +
4	ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5	(ACRS)
6	REACTOR FUELS SUBCOMMITTEE
7	+ + + +
8	WEDNESDAY,
9	DECEMBER 15, 2004
10	+ + + + +
11	ROCKVILLE, MARYLAND
12	+ + + +
13	
14	The Subcommittee met at the Nuclear
15	Regulatory Commission, Two White Flint North, Room
16	T2B3, 11545 Rockville Pike, at 8:30 a.m., Dr. Dana A.
17	Powers, Chairman, presiding.
18	
19	COMMITTEE MEMBERS PRESENT:
20	DANA A. POWERS Chairman
21	MICHAEL T. RYAN ACNW Chairman
22	MARIO V. BONACA Member
23	ALLEN G. CROFF ACNW Member
24	RICHARD S. DENNING Member
25	F. PETER FORD Member
	NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

1	COMMITTEE MEMBERS PRESENT:	
2	STEPHEN L. ROSEN	Member
3	VICTOR H. RANSOM	Member
4	JOHN B. SIEBER	Member
5	GRAHAM B. WALLIS	Member
6	RUTH WEINER	ACNW Member
7		
8	ACRS STAFF PRESENT:	
9	MAGGALEAN WESTON	
10		
11	ALSO PRESENT:	
12	DAVID BROWN	
13	JOSEPH GIITTER	
14	STU MAGRUDER	
15	ALEX MURRAY	
16	RENE PEDERSEN	
17	BILL TROSKOSKI	
18	REX WESCOTT	
19		
20		
21		
22		
23		
24		

25

CONTENTS

2	PAGE
3	Introduction, Chairman Powers 4
4	Presentation Introduction:
5	Joe Giitter
6	Dave Brown
7	Technical Presentations:
8	Red Oil Explosions, Alex Murray 56
9	HAN Explosions, Bill Troskoski 111
10	Electrolyzer Fires, Alex Murray 128
11	Uranium Burnback, Dave Brown/Alex Murray 158
12	Applicability of TEELS, Alex Murray 173
13	Control Room Habitability, Alex Murray . 183
14	Flammable Gases, Rex Wescott 206
15	Subcommittee and NRC Discussion 261
16	DPV/DPO Discussion, Alex Murray 308
17	
18	
19	
20	
21	
22	
23	
24	
25	

WASHINGTON, D.C. 20005-3701

<u>PROCEEDINGS</u>

(8:31 a.m.)

come to order.

CHAIRMAN POWERS: The meeting will now

This is a meeting of the Advisory

Committee on Reactor Safeguards, Subcommittee on

Reactor Fuels. I'm Dan Powers, Chairman of the

Subcommittee.

In attendance for the ACRS are the members Mario Bonaca, Richard Denning, Peter Ford, Victor Ransom, Steve Rosen, Jack Sieber, Graham Wallis. We're also being ably assisted by members of the Advisory Committee on Nuclear Waste, Allen Croff, Michael Ryan, Ruth Weiner.

The purpose of the meeting is to discuss the mixed oxide fuel fabrication facility construction authorization application and the staff's draft final safety evaluation report. The subcommittee, of course, will be gathering information, analyzing relevant issues and facts in order to formulate a proposed position and action as appropriate for deliberation by the full ACRS.

Mag Weston is the cognizant ACRS staff engineer for this meeting.

The rules for participation in today's

NEAL R. GROSS

1 meeting have been announced as part of the notice of this meeting previously published in the Federal 2 Register on December 8th, 2004. A transcript of the 3 meeting is being kept and will be made available as 4 5 stated in the Federal Register notice. 6 is requested that speakers first It 7 identify themselves and speak with sufficient clarity and volume that they may be readily understood. 8 9 We have received no written comments from 10 members of the public regarding today's meeting. This is, I believe, the third meeting of 11 the Reactor Fuel Subcommittee on the MOX facility, and 12 what we're going to be looking at is the safety 13 14 evaluation report that the staff has put together on 15 this facility. In setting up the meeting, we set it up 16 not to spend a lot of time on the general layout and 17 design of the facility since most of the members of 18 the Reactor Fuel Subcommittee have been through this 19 20 facility at some length. 21 Some of the people who have not done that 22 that, I understand, have made heroic efforts to bring themselves up to speed on this, and I thank you very 23 much for doing that. 24 25 What we would like to get out of this

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

subcommittee meeting is a strategy of action preparation for presentations to the full committee. So we really are trying to put together a proposed position and plan of action for that full subcommittee meeting that we now anticipate will take place in So there are some, especially tomorrow, protracted periods for subcommittee discussions.

Now, the members have received, I'm told, 2,700 pages of information, some of which is brand new, 555 pages of which is brand new, and some of which has been amended from what they've seen in the past, and I think there is no chance that members have digested all of that in completion, except for Mr. Sieber, who I know is encyclopedic in his knowledge on the subject.

So in setting up our proposed actions, we may well have to allow time to plunge in to examine material more carefully. One of the possibilities, of course, is that we may need to get together again to refine our positions, but I would very much like to come out of this meeting with a pretty good outline of what a letter on this facility would actually look like.

I don't intend to actually craft language, but an outline I would like to get, and that may

1 involve members of the subcommittee taking assignments 2 to develop a paragraph here and there, and the like. 3 Are there any comments from other members? 4 (No response.) 5 CHAIRMAN POWERS: Seeing no one anxious to 6 speak on this hot topic on a chilly day, I think we 7 can go ahead with the meeting. Is David going to start off or is Joe? 8 9 Joe is going to start off. MR. BROWN: 10 CHAIRMAN POWERS: Okay, Joe. Joe, you're 11 on. 12 Thank you. MR. GIITTER: My name is Joe Giitter. I'm the Chief of 13 the Special Projects Branch, which is doing the safety 14 15 review of the mixed oxide fuel fabrication facility. The last time we met with you was in 16 November of 2003, over a year ago, and at that time we 17 18 had just learned from DCS, the applicant, that they 19 had been directed by DOE to make another significant change in the construction authorization request for 20 the proposed facility. 21 22 That change involved reducing the boundaries of the controlled area from an area that 23 corresponded to roughly the Savannah River site 24 boundary, which was about five miles from the facility 25

at its closest point down to an area 160 meters from the stack.

In June of this year, the NRC received a revised construction authorization request from the applicant to reflect these changes.

Another change since we last met with you is we have a new project manager, Dave Brown. Mr. Brown this morning will provide an overview and status update on the MOX program, and he'll describe in more detail the staff's review of the applicant's revised CAR.

The staff has completed a draft of the final safety evaluation report, which was provided to you on November 26th. The draft FSER contains no remaining open items and the staff has concluded that applicant has the safety requirements met of construction necessary for the issuance а authorization.

As you will recall from the last meeting, there were about a dozen open issues remaining, primarily in the area of chemical safety. Today we will discuss in more detail the basis for closing those open items. We plan to issue a final SER in February and request a letter from the full committee to the Commission supporting the staff's conclusions

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 by that time.
2 W
3 committee in
4 Powers.
5 F
6 afternoon, Mn
7 reviewers for
8 issues, two of
9 handled through

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

We are planning to brief the full

committee in February, as you had indicated, Dr.

Following our presentation and later this afternoon, Mr. Murray, one of the chemical safety reviewers for the MOX facility will discuss the open issues, two of the issues that he has that have been handled through the differing professional view and opinion process.

As you are aware, the agency recently modified handling differing its process for professional views and opinions. One change is that the Office of Enforcement is now the focal point differing within the agency for coordinating professional opinions.

Rene Pedersen, the DPO Program Coordinator from the Office of Enforcement will be here this afternoon to answer any questions about the new process and will also be prepared to discuss the status of the DPS file related to the MOX fuel fabrication facility.

And that concludes my opening remarks.

CHAIRMAN POWERS: Let's see. You indicate that you have no open items.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

1	MR. GIITTER: That's correct.
2	CHAIRMAN POWERS: Could I call your
3	attention to page 5.0-15 of the SER, last line on the
4	page?
5	MR. GIITTER: I'm aware of that. There
6	are some areas within the draft FSER where it still
7	states that there are open items, and that was an
8	oversight on our part.
9	CHAIRMAN POWERS: You recognize that it
10	makes a fair amount of challenge for us to review a
11	document on which we have statements to the effect
12	that they don't meet a particular part of the 10 CFR
13	regulations?
14	I mean that's fairly challenging for us to
15	read the material and then say, "Well, that doesn't
16	count," because there's not a mark on it that says
17	this is an oversight.
18	MR. GIITTER: Yes, well, we understand
19	that. We can provide a revised
20	CHAIRMAN POWERS: Can you flag those for
21	us or do something that says this statement doesn't
22	count?
23	MR. BROWN: I think we've already received
24	some of those comments back, and we can certainly do
25	that. Just make sure that you're aware of editorial

1 changes. CHAIRMAN POWERS: I mean, I come to that 2 sentence and said, "Good. I don't have to read this 3 anymore," and put it aside. 4 5 MR. BROWN: Right. MR. BROWN: We'll definitely work with Mag 6 7 to make sure, especially when we're changing the 8 meaning of the sentence, that you're aware of it. 9 CHAIRMAN POWERS: Actually it produced a 10 much different response from me. I don't have to read this. I have to come up with what are they asking me 11 for, to resolve these issues for them one way or 12 another? 13 14 I mean, this particular statement creates a lot of work. 15 Yes, I apologize for those 16 MR. BROWN: 17 statements. We will certainly keep you informed as we 18 go through the process of making those final edits 19 until February. I want to thank you, Dr. Powers and the 20 members for this opportunity to speak with you. 21 22 This is, as we pointed out, our 23 opportunity to ask you for your endorsement of our 24 safety evaluation. I do want to provide a brief, but 25 fairly comprehensive overview of the project,

1 especially for those of you who may be new to the 2 project. I'll talk about briefly why we're here and 3 the status of the project and the progress of the 4 project since roughly 2000. 5 The purpose is, as we stated, to seek your endorsement of the staff safety evaluation, unlike the 6 7 previous two meetings where we were merely providing you information on the status of the staff's review. 8 9 CHAIRMAN POWERS: Yes. You understand 10 that the ACRS will not give you an endorsement at this meeting? 11 12 MR. BROWN: Yes, I do. CHAIRMAN POWERS: That the subcommittee 13 will only evaluate the material, draft a position --14 15 MR. BROWN: I understand. CHAIRMAN POWERS: -- and come up with a 16 17 strategy? And this perhaps should have MR. BROWN: 18 been clear to say to provide information towards 19 I realize this is an 20 seeking your endorsement. 21 ongoing process. 22 I'm not quite sure how I DR. WALLIS: would give an endorsement. I read all of these pages. 23 I was looking for technical information with equations 24 25 and criteria and things like that, and I didn't find

	13
1	it.
2	CHAIRMAN POWERS: Well, you're
3	DR. WALLIS: So I don't know what I'm
4	endorsing.
5	CHAIRMAN POWERS: You're looking too early
6	in the process.
7	DR. WALLIS: Too early in the process?
8	CHAIRMAN POWERS: Yeah. You will see
9	equations and whatnot in the integrated safety
10	assessment for the license application.
11	DR. WALLIS: Later?
12	CHAIRMAN POWERS: Yeah. This is just
13	establishing the design basis.
14	MR. ROSEN: I look at this as an immense
15	number of promises for the future.
16	MR. BROWN: There are many of those,
17	commitments for future license application, which we
18	are expecting this spring, and I'll get into that as
19	I complete my presentation, how we're doing things in
20	two stages, as it were.
21	CHAIRMAN POWERS: And if you want
22	quantitative performance criteria, 10 CFR 70.6.1 and
23	4.
24	MR. BROWN: Yeah, 70.61
25	CHAIRMAN POWERS: Sixty-one and 64 or

1 something like that? 2 MR. BROWN: I'm sorry? 3 MR. GIITTER: Seventy, sixty-four baseline design criteria, which is akin to the general 4 5 design criteria in Part 50. 6 DR. WALLIS: I guess we might get into 7 some of the technical issues later then. MR. BROWN: Oh, we will. Yeah, I'll try 8 to conclude my remarks as briefly as I can, but we'll 9 10 get right into the technical issues. DR. BONACA: The other place where I have 11 12 difficulty with this was in some of the areas where, you know, the applicant claims preventative actions as 13 14 a means of providing defense and protection, and it's not clear to me when I read it if those actions are 15 16 going to be automatic or built into the process so that there are physical reasons why you will not have 17 a challenge, or if they are tied to human action. 18 Now, then I have difficult in the sense 19 20 that what does it take to approve a construction 21 process. Okay? I mean, if I'm saying that certain 22 considerations to prevent an explosion seem to be 23 appropriate or there is no statement that says it will be considered, you know, this is good enough to 24 25 approve the construction process, does it mean that

1 means of deliberate action is going acceptable or is it going to be an issue to be dealt 2 3 with at the operation review phase? 4 MR. BROWN: No, rarely did we accept the commitment that any means of preventing the accident 5 would be acceptable. We did require pretty detailed 6 7 information on what the system structure or component was that prevented the accident or would prevent and 8 what its function is and then an additional level of 9 detail is what is its design basis. 10 DR. BONACA: No, I understand that. 11 12 MR. BROWN: What pressure would not be What temperature would not be exceeded? 13 DR. BONACA: It troubled me the fact that 14 there was no discussion of operators involved. 15 couldn't tell how these actions would be accomplished. 16 I mean some of them may be automatic. Some of them 17 18 may be -- that's a fundamental issue, too, the risk. 19 I understand your comment. MR. BROWN: Certainly our preference is that engineered controls 20 be selected over human controls. 21 22 DR. BONACA: Yeah, and we will have some opportunity as you go through the open items to --23 MR. BROWN: I think as we go through each 24 one we'll see specific instances where you be able to 25

1 raise that point. I believe it will answer your 2 question. I believe the Code of 3 CHAIRMAN POWERS: 4 Federal Regulations require a bias in favor of things other than administrative controls. 5 6 MR. BROWN: that's right. There is a 7 preference actually stated in our regulations. 8 I'll say that what we're doing here is the 9 Department of Energy is implementing this agreement 10 with Russia to disposition 34 metric tons so that the point here is that the Department of Energy is the 11 owner of the mixed oxide fuel plant. 12 regulating it, and then there's a third party, the top 13 14 bullet here. The Department of Energy and National 15 Nuclear Security Administration selected Duke Cogema 16 Stone and Webster to design, build, and operate this 17 They are the applicant, and they would be a 18 19 future licensee, not the Department of Energy. And when the program was first conceived, 20 there was the concept of an immobilization plant where 21 22 about eight and a half metric tons of plutonium was to be immobilized, not turned into MOX fuel. As of April 23 2002, now all 34 metric tons will be converted to MOX 24 which means there are now two plutonium 25 fuel,

1 disposition facilities. 2 One is the pit disassembly and conversion facility, again, owned by DOE, designed, built and 3 operated by a DOE contractor, not DCS, and then the 4 mixed oxide fuel fabrication facility. 5 The pit disassembly and conversion 6 7 facility would receive weapon components, convert those components to plutonium dioxide, which is then 8 feed material for the MOX facility, which would be 9 10 next door. CHAIRMAN POWERS: Is the pit disassembly 11 12 and conversion facility -- does it actually exist? MR. BROWN: It does not exact yet either. 13 In fact, the plan is that the initial feedstock for 14 15 the MOX facility would be existing plutonium dioxide surplus, and that the pit disassembly and conversion 16 17 facility will actually be brought on line after the 18 MOX plant to provide the remainder of the 34 metric 19 tons. 20 CHAIRMAN POWERS: I suppose then it is 21 fairly difficult at this stage to assess whether an 22 event at the PDCF affects activities at the MFFF. At this point, you know, we 23 MR. BROWN: have not identified and the CAR does not identify 24 events at the proposed PDCF. We would expect that to 25

1 be considered in the future integrated safety analysis 2 that will be provided next spring with the license 3 application. And it would be expected to consider all 4 5 nearby industrial facilities, nuclear and industrial 6 facilities. 7 This is just essentially an rendering of what I just said, which is essentially 8 9 the blue boxes on the left are the DOE owned and 10 regulated activities, and then the mixed oxide fuel fabrication facility DOE owned, but NRC regulated, and 11 12 then, of course, the reactors are commercially owned 13 NRC regulated. 14 MR. ROSEN: Is your slide right? You've 15 got -- oh, okay, yes. The NRC's regulation is on the 16 yellow. 17 MR. BROWN: Right. DR. WALLIS: So how many tons are going 18 19 into Catawba and McGuire? Well, what it is is the 20 MR. BROWN: 21 conversion of 34 metric tons of plutonium that's 22 plutonium metal. DR. WALLIS: That's from each? 23 MR. BROWN: To fuel. 24 25 DR. WALLIS: Is it 34 or 68?

1	MR. BROWN: Thirty-four total So each
2	reactor, I don't know that it's divided perfectly in
3	half, but let's say that it is. So each reactor gets
4	17.
5	DR. WALLIS: Gets 17.
6	MR. BROWN: Certainly more than one core
7	reload. It goes on for several years, many years.
8	CHAIRMAN POWERS: And the facility itself
9	has a finite lifetime, is my understanding.
10	MR. BROWN: Yes. The reactor facilities.
11	CHAIRMAN POWERS: I mean the fabrication
12	facility. Once this campaign is over, that facility
13	is to be retired?
14	MR. BROWN: The facility will be
15	deactivated, in the DOE parlance, and then they could
16	be turned back over to DOE for decommissioning.
17	DR. WALLIS: Well, they might even be some
18	more excess plutonium by then.
19	MR. BROWN: We could speculate, yeah, that
20	there would be more mission for this facility later
21	down the road, especially given the additional
22	unilateral strategic arms reductions.
23	CHAIRMAN POWERS: It seems to me that
24	understanding the design lifetime in the facility is
25	important, and then understanding the design basis.

1	MR. BROWN: It is certainly a
2	consideration, especially where aging effects have to
3	be considered on materials. And so, you know, if, for
4	example, it was intended that the vessel would not
5	need any maintenance for the duration of the mission,
6	you would have to take that into consideration, sure.
7	This is a flow chart that's indicating
8	roughly how we're performing this review. You'll see
9	on the top row there that, you know, the third box
10	from the left is ACRS review, and that's where we are,
11	the first review by the ACRS of the staff's review of
12	the construction authorization.
13	We plan to issue the EIS and the SER in
14	January-February of 2005, and then we will continue on
15	with the construction hearing at that point.
16	DR. WALLIS: When is it that we get to
17	look at these equations?
18	MR. BROWN: I think the more your review
19	of our evaluation of the integrated safety analysis
20	is
21	DR. WALLIS: Down there.
22	MR. BROWN: in a corresponding
23	position, you know. You followed our construction
24	authorization review and
25	DR. WALLIS: This was already being built

1 by then? MR. BROWN: 2 It will have been probably 3 partially built. I doubt that it will have been 4 completed by that point, although I'm speculating 5 somewhat. We're anticipating a two-year review starting this spring, and with a construction start 6 7 later than early summer of 2005, it's possible we could finish the license review before they finish 8 9 building the plant. It would be helpful to me to 10 MR. ROSEN: 11 have more than just the postage stamp size picture of this slide. Right now all we have is that. 12 13 MR. BROWN: Only that. 14 MR. ROSEN: It's pretty hard to read. 15 MR. BROWN: Okay. I can certainly for the record provide the larger slides. I'll work with Mag 16 17 on that. 18 MR. GIITTER: We can probably get copies 19 at the break and give them to you. MR. ROSEN: Yeah, just of this one is all. 20 MR. GIITTER: 21 Sure. MR. BROWN: As we indicated in that flow 22 23 charge, there will be two approvals, the construction permit and then the license to possess and use 24 licensed material. 25

What's required for a construction permit is what I've cited there on that regulation. The applicant must provide a safety assessment of the design bases of principal structure, systems and components, a description of the quality assurance program, and we, NRC, have written an environmental impact statement based on the applicant's environmental report.

For the purpose of this review, we've adopted the Part 50 definition of design basis, and this is really what has guided these years of review of the construction authorization. We're proving the function that a structured system and component has and the values for controlled parameters.

So, for example, the function might be to prevent a rupture of a vessel. The control parameter is pressure. Design basis value might be 100 psi. That's the extent of the information we would be approving at this point, and that, for example, would not include the location of the vessel, its size, its shape and that sort of thing.

DR. WALLIS: Well, is there anything in this which gives assurance that these controlling parameters can control what's going on in this structure, system, or component?

	23
1	MR. BROWN: That's of course, what the
2	applicant must do. They must be able
3	DR. WALLIS: But we don't at this time get
4	that assurance?
5	MR. BROWN: We don't have
6	DR. WALLIS: Sort of promise that they'll
7	be able to do it; is that what we get?
8	MR. BROWN: Well, in some cases these
9	things are well known. For example, an acceptable
10	design basis can be an industry code and standard.
11	It's a consensus standard.
12	DR. WALLIS: There may be some things that
13	are well known, but there may be other things where
14	the chemical reactions are rather complicated and
15	controlling them may not be as simple as simply
16	specifying some numbers.
17	MR. BROWN: Right, and we will have
18	examples of those, too, as we go on where, for
19	example, the values for the control parameters are
20	based on industry experience and some research. Given
21	even that, the applicant has committed to do
22	additional research to support those values.
23	DR. FORD: The chemical plant, nuclear
24	plant, you have all underground, time dependent
25	materials degradation issue, which must impact,

1 therefore, on the design basis. Where do we hear 2 about those specifics? 3 What's your materials degradation mechanism and how does that impact on your margins, et 4 5 cetera, according to your design basis? When do we hear about that? 6 7 MR. BROWN: Where the materials degradation is an important part of the reliable 8 9 function of a principle SSC, that's when we would look for those details. 10 In some cases, for example, what I mean by 11 is if the safety function is to contain a 12 potential release, say, resulting from a corrosion 13 14 event, what we're focused on is that mechanism, that 15 SSC that's containing the release in a process cell and we may not be focused just on the corrosion of the 16 17 pipe in the process cell. 18 In other words, we'd be looking at --19 DR. FORD: I'm still stuck trying to hear the answer to my question. When are we going to hear 20 being exposed to the specific data upon which you 21 22 determine how quickly it is that a component is going 23 to degrade? MR. BROWN: Well, most of that information 24 will be -- that sort of detailed information will be 25

provided in the integrated safety analysis with the 1 license application this spring. 2 3 MR. GIITTER: I think it's important to point out, too, that what we're looking at, Part 70, 4 5 was developed with a one step licensing process in 6 mind, and Dave is going to talk about that, but what 7 we're doing here with the MOX facility is unique. We're actually doing a two-step licensing process 8 9 under a regulation that was intended to be used for a 10 one-step licensing process. So at this point the only thing the staff 11 12 is doing and the applicant has to provide us with is the design basis for the principal structure, systems, 13 14 and components that are really controls to insure that 15 the facility will be designed against 16 phenomena and accidents. And Dave will talk about that in more 17 detail in a minute. 18 19 DR. FORD: But are there any lessons being learned from the chemical industry, for instance? 20 21 They're very sophisticated when it comes down to 22 evaluating materials degradation and how that impacts on the design of their plant. 23 Are there lessons learned being taken from 24 25 that industry to this?

1 MR. MURRAY: Yes, if I could just comment 2 very quickly. I'm Alex Murray. I'm the lead chemical 3 safety reviewer. 4 Just to let you know, there are several 5 codes and standards which have been identified as design bases for addressing corrosion concerns. Those 6 7 codes and standards have methodologies for deriving specific corrosion monitoring, maintenance, and/or 8 9 replacement programs. For the construction permit stage, they 10 tend to be top level. Is this sort of thing generally 11 done in the chemical process industries or the nuclear 12 13 industry? Are known corrosion phenomena being addressed? 14 15 And overall, at a design basis level the staff has concluded they are, and this is written up 16 in the draft FSER. 17 DR. FORD: So it details such as titanium 18 19 versus carbon steel, for instance? Titanium versus 304/316 20 MR. MURRAY: stainless steel would be a good one, yes. 21 22 DR. FORD: And that would be spelled out at this stage or not until the spring of next year? 23 Top level selection of 24 MR. MURRAY: materials for components has been spelled out in the 25

l l	il and the second of the secon
1	construction permit. Specific details, such as time
2	of surveillance, such as actual corrosion rates,
3	presence or absence of corrosion type probes,
4	corrosimeters, and so forth on the staff would expect
5	those in the license application in this coming
6	spring.
7	DR. FORD: Okay. So we won't see that
8	data until then.
9	MR. MURRAY: You will not see specific
10	data. You will see there are specific controls in the
11	revised application, which the applicant has
12	identified for addressing corrosion concerns.
13	For example, the destruction of the silver
14	II species so that it is not capable of corroding
15	stainless steel components downstream, as an example.
16	Does that answer your question?
17	DR. FORD: It answers my question, but it
18	really does worry me that it's fairly late in the
19	proceedings that we start to look at the details of
20	the degradation mechanisms. Forget anything else, and
21	from a business point of view, it's pretty darn late
22	for people to be making decisions about
23	CHAIRMAN POWERS: Business points of view,
24	of course, are outside our domain.
25	DR. FORD: Pardon?

1 CHAIRMAN POWERS: Business points of view 2 are outside our domain. 3 Oh, I recognize that, Dana, DR. FORD: 4 absolutely, but it does come into our personal 5 thinking as to how you evaluate this. Yes, and I think with this 6 MR. MURRAY: 7 being a two step approach, a construction permit 8 followed by an operating license application, I think 9 we get, if you will, the best of both worlds. We get 10 initial general look at does this seem an 11 qualitatively in alignment with what industry actually 12 does, with the top level corrosion phenomenon, et Details will come forward in the license 13 14 application. 15 DR. FORD: Jolly good. MR. SIEBER: Actually this kind of a plant 16 17 is not a new concept. It seemed to me that solvent extraction and Purex type plants have been around for 18 19 some years. 20 CHAIRMAN POWERS: And they pre-date me. I know that. 21 22 SIEBER: Well, unfortunately they 23 don't pre-date me. 24 (Laughter.) 25 MR. MURRAY: They pre-date me, too, but

1	I'm only 29.
2	MR. BROWN: Thanks, Alex.
3	MR. MURRAY: You're welcome.
4	MR. BROWN: I just wanted to point out
5	quickly that you may ask the question: why don't we
6	identify what's a principal structure system and
7	component and what isn't. In the safety assessment if
8	the event is not unlikely, if it's a likely event,
9	which for this applicant is always their first
10	assumption, that this event could happen, and as a
11	high consequence, then that, of course, appears in the
12	bin in the upper right.
13	And the goal is then to drive it down to
14	the lower left. Then
15	DR. WALLIS: I'm sure we asked you before
16	what likely and unlikely mean.
17	MR. BROWN: Yes. And for this application
18	that's defined qualitatively, unlikely is
19	DR. WALLIS: Is it once a week, once a
20	year, once a century?
21	MR. BROWN: Not likely to occur during the
22	operation of the plant. It is unlikely.
23	DR. FORD: Is that 40 years?
24	MR. BROWN: In this case the actual
25	mission will be finished in something under 14 years.
ľ	NEAL D. CDOSS

1	DR. FORD: So highly unlikely means it
2	wouldn't occur if the plant were run for 1,000 years
3	or something?
4	MR. BROWN: Well, highly unlikely would
5	be, again, defined qualitatively as, you know
6	DR. WALLIS: Qualitatively doesn't mean
7	anything to me though.
8	MR. BROWN: And we've had this discussion
9	before.
10	DR. WALLIS: Sure, we have.
11	MR. BROWN: You're right. We're not
12	requiring a quantitative
13	DR. WALLIS: So you refused to define
14	"likely."
15	MR. BROWN: I'm sorry?
16	DR. WALLIS: You define consequence here
17	with numbers.
18	MR. BROWN: WE did.
19	DR. WALLIS: But you don't define
20	likelihood.
21	MR. BROWN: And that is how the regulation
22	is written.
23	DR. WALLIS: Us there something tabu about
24	that? The word "probability" is impermissible?
25	MR. GIITTER: It's permissible to use a
	NEAL D. CDOCC

1 quantitative approach if you read Part 70, and the 2 guidance associated with Part 70 in NUREG 1718, which 3 was developed specifically for MOX. 4 However, the applicants also are allowed 5 the option of using a qualitative approach, and in 6 fact, most of the fuel cycle -- in fact, all of the 7 fuel cycle licensees have taken qualitative or semi-8 qualitative approach. And part of that is you just don't 9 10 the type of data that you would have with a reactor facility and a fuel cycle facility. You rely more 11 12 heavily on administrative controls, on human action 13 than you would in a nuclear power plant. 14 DR. BONACA: That's why I had difficulty 15 when I was reading. DR. WALLIS: Well, it's appropriate, I 16 think, at the level of 10 CFR 70, that there be some 17 It's very appropriate. 18 vaqueness. But when you're looking at a specific 19 20 plant, maybe you need to be more definite about how 21 you interpret those terms. 22 MR. BROWN: At this point we have accepted the qualitative definitions. That doesn't preclude, 23 Giitter points out, that later in 24 25 integrated safety analysis there are other methods for

22

23

24

25

safety analysis that are more quantitative, and in this case, DCS may use those to make their case.

DR. BONACA: For reactor facilities, you know, the '60s and '70s they used also qualitative definitions frequently and frequent and so on, but there were some of understanding. For example, frequent meant -- infrequent meant that it would happen maybe once in the life of the plant.

MR. BROWN: That would correspond to our--

DR. BONACA: I'm trying to understand the difference between highly unlikely and unlikely. I mean for unlikely would you have an expectation that possibly it could happen once in the life of a plant?

MR. MURRAY: There is guidance on likelihoods provided in the standard review plan for MOX which is NUREG 1781 and also in the standard review plan for fuel cycle facilities in general, which is NUREG 1520. Very round numbers, unlikely means basically one event, one potential event, in round numbers 100 years to perhaps 1,000/10,000 years, and the upper bound for highly unlikely is generally given a numerical number somewhere ten to the minus four, ten to the minus fifth per year or one in 10,000 to one in 100,000 years.

DR. BONACA: Okay.

NEAL R. GROSS

1	MR. MURRAY: That's in the guidance. It's
2	not in the regulation. That gives you some feel for
3	it.
4	DR. BONACA: Some feel for it. Okay. So
5	unlikely you said it's possible once in the life of
6	the plant. Maybe.
7	MR. BROWN: Well, for this application
8	it's not likely to occur
9	MR. MURRAY: In the plant, yes.
10	MR. BROWN: during the life of the
11	plant.
12	DR. WALLIS: That's a dangerous definition
13	because an accident which destroys the plant is only
14	going to occur once in a life of the plant.
15	MR. MURRAY: Well, that's why the guidance
16	does give some numerical bounds.
17	DR. WALLIS: I like your numbers. Thank
18	you.
19	MR. MURRAY: Oh, you're welcome, sir.
20	MR. BROWN: And so where we are is we did
21	get this construction authorization request in 2001.
22	We have had issued two draft safety evaluation
23	reports, and last year we met with the full committee.
24	There were 11 remaining open items in the draft safety
25	evaluation report, and at that point there was also,

as Mr. Giitter pointed out, DOE had just announced it was going to change its controlled area boundary, which was significant because that was a point at which the doses were calculated for the safety assessment.

And so you know, that is a picture of the entire Savannah River site in South Carolina. I realize it's not terribly easy to get the perspective from that scale, but that's roughly 300 square miles of territory, and so a member of the public, that evaluation point was some five miles away from the facility, but now the controlled area boundary is essentially contiguous with the site boundary.

The site is the box on the left side. That's the MOX fuel fabrication facility site. The site down to the lower and to the right is the pit disassembly and conversion facility site. The MOX site is about 41 acres. So that now is the controlled area, and the evaluation point for an individual at that controlled area boundary is only 160 meters away rather than five miles.

So they made that announcement in November of last year and by June of this year had revised the construction authorization request. There was one additional principal system structure component as a

result of the change, which is now the process cell exhaust system, is a PSSC. The reason there was only one change is because there was already a large amount of margin in the safety assessment. So moving the boundary really did not result in significant changes to the outcome of the safety assessment. There were some other changes. DCS took the opportunity from November to June of this year to remove the uranium oxide dissolution system. The original concept was for depleted uranium oxide to be delivered to the plant, and where it needed or DCS needed to make up uranyl nitrate solutions, they would just simply dissolve the dioxide. Now rather than do that, they will receive uranyl nitrate as a reagent. There's an additional unit for dealing with the waste solvent from the Purex cycle. They did slightly modify their chemical inventory list, and as a result of some refinements in the process chemistry, of course, that results in an update in your waste stream inventory. So that was updated. By the time of the June 2004 CAR, we had So those are now closed several of the open items.

reflected in the June 2004 CAR as I've listed here,

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

and, of course, I've made some other corrections.

At this point if we do approve the CAR, in February we will start construction inspections. have been working with regional office to set up a construction inspection program, and of course, really DCS will be treated as a licensee. Even though they have a construction permit, for all other purposes they're essentially treated as a licensee.

Shortly after that, they plan to follow a license application and ISA summary and all the other application materials that would be required for facility security and so forth.

So without further delay, I'd be happy to answer any additional questions. I'll allow the technical review staff to give their presentations, starting with Mr. Murray. Are there any other questions for me at this point?

CHAIRMAN POWERS: It's important understand the basic philosophy here, that under shall we say ordinary circumstances you would never see this stage of the operation. You would see the stage where they are granted a license to receive and hold special nuclear materials. So this is kind of a sneak peek in on the process in which we're really focusing on what the hazards are and what the design bases for

a material or any steps taken to control those hazards.

Now, it seems to me, Dave, it might be useful to point out that in your slide where you had the unlikely and likely in consequences, those are consequences, unmitigated consequences that are used to assess whether mitigation or prevention is needed.

MR. BROWN: That's right. I mean, your determination of what's acceptable and not acceptable is based on, first, the unmitigated consequences. In other words, you're analyzing a preliminary design based on what's there, and then if you're in the not acceptable bin, you're adding system structures and components to produce the risk of that hazard, those new things or the principal structure systems and components.

CHAIRMAN POWERS: It seems to me that it's also useful to explore just a little bit what the safety philosophy is because the regulations require a defense in depth type of approach, and that gets crated in the structure of the facility. So it is not uncommon for the applicant, when he identifies something as being unacceptable to take a preventive approach because his inherent mitigation is already built into the structure of the facility.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

So it can appear in the responses that there's an imbalance between prevention and mitigation, but that's because the mitigation has already been built into the construction of the facility.

MR. BROWN: Right. It really does become an issue of, I think, as you said, philosophy. For example, when we're looking at a particular event, it may be that in a way, the safety assessment is written it looks as though only a preventive feature is credited to, for example -- where do I -- in other words, to get to that bin. In other words, there doesn't appear to be any credit taken for mitigative features in the facility, but under the defense in depth concept, there really are in almost all cases mitigative features, and namely, for this facility that's the confinement ventilation system, the HEPA filters, if you will, and the tertiary confinement of materials.

For disbursable materials in this plant, there will be at least three boundaries of confinement. So the fact that I may have only credited philosophically, you know, the preventive feature does not in anyway mean that there aren't other features present. That's right.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 And usually what it the is is 2 filters, if you will, the confinement barriers are 3 also credited, but for other events, and what we'll see in the future I would think with the integrated 4 5 safety analysis is a little more integration of those 6 things, where we understand the effects of -- you 7 know, that certain components will be there to prevent all sorts of different hazards. 8 9 CHAIRMAN POWERS: Allen. 10 DR. CROFF: One thing I was unable to find 11 in reading through this mass of paper is what I'll 12 call the operation and maintenance philosophy and how 13 that is factored into the design of this plant, and that's in consideration of occupational dose, in ALARA 14 15 and how the plant is designed to facilitate that. 16 Is that in there or do we know this 17 philosophy and how they're approaching it? 18 MR. BROWN: We do know it, 19 Chapter information is contained in 9 of the 20 construction authorization request for radiation 21 protection. It is also contained elsewhere. DR. CROFF: Which would mean? 22 23 MR. BROWN: Because a fundamental design 24 philosophy for this plant is that it's highly 25 automated. Unlike many existing U.S. plutonium

processing facilities, such as in the DOE complex where there is much more hands on operation and gloveboxes really mean gloveboxes with glove portals, this plant doesn't have that look to it. Gloveboxes contain automated systems that are monitored at remote locations by and large.

DR. CROFF: And maintenance?

MR. BROWN: One of the things that they did describe in Chapter 15 of the CAR is their commitment to management measures. You know, a part of maintaining these principal structure systems and components, which by the way when we receive a license application, that name will change to items relied on for safety, and that's just an artifact of our regulations. We call them something different for construction, but they're essentially the same thing in the license application. They're just called items relied on for safety.

One of the management measures that would be appropriate for items relied on for safety is maintenance and surveillance, and DCS will provide most of that detail later with the license application.

DR. CROFF: I understand that. I do remember Chapter 15 in reading through that, and it

б

was pretty -- well, it was pretty terse, to be charitable, in terms of the maintenance philosophy, basically saying, "We're going to have a maintenance plan."

But my point is ALARA and the routine occupational doses received during operation and maintenance is a function of how the plant is designed, how cells are laid out, whether they have to enter them, the extent of clean-out, and can they clean them out, and worrying about that later when the die is cast on construction on the plant design, you've sort of got to do what you've got to do when the plant is built.

And I'm just not seeing that as a consideration. It's focused on safety, which means accidents for the most part, not routine operation and ALARA. Maybe it's an artifact of this two step thing, but they're going to be a long ways down the road before they worry about it.

MR. BROWN: Well, they're certainly considering that in design, and there are commitments to ALARA design methodologies, and they're described in the CAR, but you kind of hit on it. It's not effective, the two-step process. What we're focused on now are accidents and the effects of natural

phenomena hazards on the facility.

DR. CROFF: It seems that the focus maybe needs to be on considering everything that's a concern when the die is cast on the construction and design.

I understand that opinion.

DR. RYAN: Just a follow-up question on waste management. As I understand reading through everything, the hand-off is DOE will manage the waste produced by the facility. It seems like that's sort of a curtail to me. How do you know that they're going to be capable and robust and keep the waste moving so that it doesn't choke out the plant or cause a back-up or cause interruption of service? That's one.

And the second is in licensing the facility, how do you assure yourself that the waste management plan is going to work and that they've done other things that won't have a backward impact on the facility itself.

MR. BROWN: Well, at this point the waste management systems in the plant have to be considered as part of this safety review for the effects of potential accidents and natural phenomena, but the regulations allow for transfer of custody of that waste from our licensee back to DOE, at which point it

1	does become DOE's responsibility.
2	I understand your question. There could
3	be problems which could affect, you know, future
4	operation of the plant, but unless I can tie that to
5	safety at the plant, we didn't raise that as an issue
6	now.
7	DR. RYAN: And maybe I didn't bore into
8	the details enough to understand this, but it wasn't
9	clear to me that the facility, that which the NRC is
10	going to license, is going to process all of the waste
11	to come endpoint ready for disposal.
12	MR. BROWN: Okay.
13	DR. RYAN: I understand that they're not.
14	MR. BROWN: They're not going to process
15	all of the waste suitable for the endpoint.
16	DR. RYAN: There seemed to be a mix that
17	they were going to take care of some things, but
18	perhaps not others.
19	MR. BROWN: Right.
20	DR. RYAN: And it's those wastes that are
21	going to be sent out for processing and preparation to
22	DOE that just put the question in my mind: well, what
23	if that doesn't work right?
24	And that's certainly something that
25	DR. RYAN: I mean, is that going to say,

1 "Okay, you can't produce anymore waste now. We're not ready to receive it"? 2 It seems to me that hand-off isn't as 3 clear it needs to be for the NRC to feel 4 5 comfortable in taking an action to move forward. MR. BROWN: Well, at this point, the best 6 7 description of all of that sort of the waste disposal 8 because actually in our draft EIS, which is assumed to 9 be final, where we look at the waste management 10 impacts, because under NEPA, you know, we did take 11 that broader view and looked at were there going to be unacceptable or high impacts of adding this waste to 12 the existing Savannah River site waste management 13 14 program. 15 in any detailed DR. RYAN: But not I mean you haven't revised SRS' 16 quantitative way. area dose assessments or any of that sort of thing. 17 18 MR. BROWN: No, not us. DR. RYAN: The devil is in the details on 19 all of that. 20 MR. BROWN: We did it in a way to insure 21 22 ourselves that there was sufficient waste management 23 capacity at Savannah River site. Something you may recall is initially when 24 25 we received this application, the plan was to send the

1	high alpha activity waste, the highest radioactivity
2	liquid waste, to the Savannah River site tank farms,
3	which were already nearing capacity at that point,
4	which is why, partly why, they now have this new
5	concept which is the waste solidification building
6	which will treat that waste and not send that waste to
7	the tank farms.
8	So DOE is certainly well aware of the
9	issues they have to deal with, as we are.
LO	DR. RYAN: And I understand that, and you
11	know, they are complicated, and there's more than one.
12	But the question still remains in my mind and maybe
13	the information is out there to answer it, but how
14	confident are we that there isn't a choke point that
15	will cause the "don't produce anymore waste" light to
16	go on?
17	And, again, I'm not saying it's not there.
18	I'm just asking that question. How is that hand-off
19	made?
20	CHAIRMAN POWERS: I'm struggling with, I
21	mean, so what. I mean, you just stop producing,
22	right?
23	DR. RYAN: Well, does that raise any
24	safety issues? Does that raise any
25	CHAIRMAN POWERS: Yeah, I guess that's

1 what I'm asking. Does it raise any safety issues? 2 DR. RYAN: And I think it has got to be 3 viewed as a system, not just as a bunch of components. 4 CHAIRMAN POWERS: Dr. Weiner. 5 I just have a couple, and I DR. WEINER: 6 recognize that you've discussed the chemical hazards 7 in the document, but I was wondering if there is a 8 parallel matrix to this one for chemical hazards 9 because you're putting your workers at considerably 10 greater chemical risk than at radiological risk. 11 MR. BROWN: Thank you for pointing that 12 out. is There is 13 Yes the answer. an essentially identical matrix with the chemical hazards 14 15 entered on the left there. then that's the slide I should have used. It would have been clearer. 16 17 DR. WEINER: The second question is how is 18 this nitrate solution going to be transported into 19 If you're accepting uranyl nitrate your process. 20 solution, where does that come from and how is it 21 transported? 22 MR. BROWN: Well, at this point -- Alex, correct me if I'm wrong -- it will be transported by 23 I don't know who the supplier is at this 24 truck. 25 You know, that's not information that we've point.

1 asked for at this point, but it will be transported to a secured warehouse on the MOX facility site and then 2 from there also transported by truck to the MOX 3 facility. 4 5 DR. WEINER: I'm concerned about the 6 safety of transporting nitrates. That's the burden of 7 my question. MR. BROWN: Okay. 8 9 MR. MURRAY: Just to let you know, they 10 would be transported under existing DOT and NRC I don't think that we went into too regulations. 11 great a depth into the specific details, but they 12 would be essentially purchased like an outside 13 14 reagent. 15 DR. WEINER: So it would be transported under the DOT hazardous materials packaging. 16 Exactly, probably in a Type 17 MR. MURRAY: A container, yes. 18 I would imagine Type A 19 DR. WEINER: Yes. container, but they have special ones for nitrate. 20 And then this is just a question, and I 21 22 suppose it should be directed at DOE, not you. is a pit disassembly facility in operation today at 23 Is it out of the question to have the 24 Pantex. 25 disassembled pits transported?

1 I mean, we do have experience transporting 2 pits and disassembled pits. Why are we spending 3 zillions of dollars to build a pit disassembly 4 facility when one exists? 5 BROWN: And I can't answer that 6 question. 7 CHAIRMAN POWERS: It does seem somewhat out of our jurisdiction. 8 DR. WEINER: Yeah, I'm sure it is. I said 9 it was probably a question for DOE, not for you. 10 11 there isn't -- well, it is out of our jurisdiction. 12 CHAIRMAN POWERS: Mr. Rosen. 13 MR. ROSEN: Yes, Dana. In the document I 14 was looking at presumption or philosophy that's given 15 You're dealing with two very serious risks. here. One is the risk of nuclear criticality safety, and the 16 other one is a risk of fire. 17 18 And in the document there's a paragraph. 19 I forget exactly where it is, probably in the NCS 20 section, that says if we have a problem where we're comparing those risks, we're going to make sure that 21 22 the nuclear criticality safety doesn't occur, and that is embodied by the fact that, you know, you end up 23 with not using water to prevent moderation excursions, 24

excessive moderation excursions.

And so there are cases where you're going to have to make a choice and use these clean agent suppression systems to put first out where you don't want to use water. On the surface of it, if you don't think about it too much, I think you come to that conclusion very easily. You want to have it.

In one case I guess you're protecting the workers, in the case of nuclear criticality safety. In the other case, you'd mainly be protecting the public, that is, from a fire, the effects of a fire.

And it isn't obvious to me just from reading what I've read that that choice is a simple one. Maybe that's too complex a question for this, and yet at some point I would feel it needs to be addressed, some sort of analysis provided for when you decide clearly not to suppress a fire by the most effective means, which is water.

MR. BROWN: I don't know exactly where that statement is. I hope it doesn't convey the point that, you know, we need to worry about crit. safety. Therefore, we're going to have to let the fire happen. You know, both risks have to be reduced to acceptable levels, but you know, what was probably intended there was that we need to make sure when we're righting the fire we're not causing another event.

1 And so they'll have to show that that 2 clean agent system adequately reduced the risk. 3 MR. ROSEN: Well, you know, clean agent 4 systems may be good at suppressing a fire, but they don't take much heat out, and when oxygen gets back 5 6 into a compartment where you've suppressed it with a 7 clean agent fire, it's likely to flash. And that's the concern. 8 9 MR. BROWN: Okay. 10 Dave, just a point of CHAIRMAN POWERS: 11 clarification. It seemed to me with the new site 12 boundary that a recreated accident assumed much 13 greater consequences than it did when we had the longer four mile boundary. 14 15 I think I saw 900 millirem at the site 16 boundary as the bounding recreate accident dose. 17 MR. BROWN: Okay. Yeah. since that 18 accident is mostly dosed from the least noble gases in 19 volatile fission products, sure, it would have gone up by the proportion of how the atmospheric dispersion 20 21 is, now less at that point. 22 CHAIRMAN POWERS: I mean, you go from having basically an alpha hazard with your fire to now 23 24 having a gamma hazard. 25 Yeah, that is considered as MR. BROWN:

1 part of the hazard safety assessment, sure. 2 CHAIRMAN POWERS: That's a significant 3 change. MR. BROWN: 4 Yeah. 5 CHAIRMAN POWERS: You go from having an inhalation toxicology to having an exposure kind. 6 7 MR. ROSEN: I'm interested in this area, and anything you can do to help me through the 8 9 difficulties I have with this would be helpful. Okay. Yeah, I do want to go 10 MR. BROWN: back and take a look at -- and I'll talk to our expert 11 12 about --DR. FORD: This seems to be a fairly 13 fundamental question though. I would have thought it 14 15 would be answered, the question about using water to fires and thereby the possibility of 16 out 17 moderating the --MR. BROWN: Yeah, what I'd like to go back 18 19 and check, the feature most relied on for fire safety are the fire barriers, passive barriers to the spread 20 21 the fire, and then for areas where there's of disbursable material there's also the clean agent 22 23 suppression system. What I would like to maybe examine a 24 little bit more is this question of, well, yes, the 25

1 clean agent system is not as effective as water in 2 removing heat. Is that still okay? Because I have a 3 two-hour fire barrier there or three hour fire barrier there that can withstand the full heat of the fire. 4 5 MR. ROSEN: Yeah, and I think I agree with 6 you that it can withstand the fire effects and prevent 7 the spread of a fire, but you still have the fire in 8 that area, and it needs to ultimately cool that area. 9 And that's where you end up with this, I think, 10 discussion. MR. GIITTER: I just wanted to remind you, 11 12 that the integration of those two 13 criticality safety and fire protection, is going to happen in greater detail as part of the ISA process. 14 15 So, you know, that's something that the applicant will 16 have to address in their license application. We will 17 be looking much closer at later on. MR. TROSKOSKI: And that process will also 18 19 consider the past operating events that we have had, including -- I'm sorry. Bill Troskoski. I'm one of 20 21 the chem. safety reviewers. The ISA process in addition will also 22 23 consider the operating events that have occurred in the industry and the lessons learned from those,

including the fires at Rocky Flats.

24

1	CHAIRMAN POWERS: I don't want to rely
2	totally on the future to resolve this question. I
3	think I need to understand it philosophically here,
4	not necessarily in quantitative detail, but
5	philosophical approach. I mean now you look at this
6	particular kind of accident because this was one we
7	raised what, a year and a half ago or something like
8	that?
9	MR. MURRAY: And just to let you know,
10	Chris Tripp, the criticality safety reviewer, will be
11	discussing criticality safety tomorrow morning.
12	MR. BROWN: That would be a good time to
13	bring that up again.
14	MR. ROSEN: Well, I'm more interested in
15	the fire safety.
16	MR. BROWN: Okay.
17	MR. ROSEN: It ends up being a fire safety
18	issue.
19	MR. BROWN: That's right.
20	MR. ROSEN: So Mr. Wescott
21	MR. BROWN: He will be here this
22	afternoon.
23	MR. ROSEN: And I need to talk to him.
24	MR. MURRAY: Yes, Rex will be here this
25	afternoon.

for the 1 CHAIRMAN POWERS: And just members' information, I have asked that Dr. Diamond at 2 the DNL look at the criticality portions of this, both 3 the SER and the CAR, and he'll provide us a report 4 prior to our February meeting. 5 Well, thank you. MR. BROWN: 6 7 CHAIRMAN POWERS: Vic. In terms of the safety DR. RANSOM: 8 aspects and design philosophy, are things like this 9 10 red oil explosion and HAN explosions and even the recriticality considered design basis accidents? 11 That MR. BROWN: They are essentially. 12 vocabulary just isn't in the Part 70 regulations. 13 14 that's just not a term we use. DR. RANSOM: I know you spoke in terms of 15 confinements and often our closed reactors have 16 venting systems, and the design of those presumably 17 18 would hopefully lead to mitigation. 19 MR. BROWN: Yeah. Ι think what effectively happens is as the applicant goes through 20 and identifies all of the hazards in all of the 21 22 hundreds of rooms of a plant, it effectively comes out looking like several hundred, if not thousands, of 23 all of which have to be design basis events, 24 considered in their integrated safety analysis. 25

1 DR. RANSOM: The other one would be what 2 is the history of these kinds of systems. I mean, the 3 French have built them. 4 MR. BROWN: Right. 5 And maybe others, too, and DR. BONACA: I'm wondering is this facility going to be similar or 6 7 based on a lot of that history. 8 MR. BROWN: This facility, as the name of 9 the future licensee implies, is Duke Cogema Stone & 10 Webster, and Cogema is a significant partner in this 11 enterprise, and is using their experience at the La 12 Hague reprocessing plant and the systems installed there for the design of the aqueous polishing step in 13 14 the U.S. MOX plant and is also using their experience 15 at the MELOX mixed oxide fuel plant in the south of France, which has now been operating, I think, nine 16 17 years and many of those systems are components in the U.S. MOX fuel plant. 18 19 There is a step where those designs are Americanized, if you will, to comply with U.S. codes 20 So there will be subtle changes and standards. 21 22 associated with code compliance in the U.S. 23 WALLIS: And change all dimensions to feet and inches? 24 25 (Laughter.)

1 CHAIRMAN POWERS: I will just remind those of you that are new to this that several members were 2 3 able to visit La Haque and MELOX, and I think they came away reasonably impressed with the sophistication 4 5 of the operation. Certainly it's a much more modern facility than those in the United States that I'm more 6 7 familiar with. 8 I will just add one MR. MURRAY: Yes. 9 comment on this question. As part of the staff's review, we have looked at historical events at DOE 10 and/or other facilities, and also what is currently 11 12 good practice in the industry. Sometimes the jargon "RAGAGEP" reasonably and generally accepted good 13 14 engineering practice is used, and we have looked at 15 that to get to some measure of the evaluation of the proposed controls for specific events and hazards. 16 17 BROWN: Ιf there are MR. no other 18 questions, I'll have Alex begin his first 19 presentation. Let me see if I can help you get that 20 21 started. 22 MR. MURRAY: Good morning, everybody. 23 Thank you so much for inviting the NRC team here to inform you and make presentations for today. 24 For the two people in the room who don't 25

1 know me, my name is Alex Murray. I am the lead chemical safety reviewer for the MOX program, and I'm 2 in the NMSS office. Now, I want to give some discussion about the closure of open items which we had in the revised 5 safety evaluation report or RDSER and also some of 6 7 these open items were discussed at the November 2003 ACRS meeting. I have listed the specific open items Myself, 10 we will go through today. Troskoski and Rex Wescott will be splitting the 11 presentation between us. The open items are as shown 12 and include a number of potentially high consequence 14 events which the applicant has elected to essentially 15 prevent or has identified a preventative strategy for 16 them. And then at the end of the presentation, 17 myself and Dave, we will provide brief summary. 18 Now, the first specific open item we're 19 going to discuss is CS-01, which is termed "red oil." 20 In the proposed process, there's an aqueous polishing, 21 22 which is really a single cycle Phrex extraction step for purifying the plutonium and 23

separating it from impurities.

include americium, gallium, and uranium.

3

4

8

9

13

24

25

Those impurities

1	Because this is a solvent extraction
2	process, you have two phases. You have an aqueous
3	phase, which is essentially concentrated nitric acid
4	up to about 13.6 molar.
5	You also have an organic phase, and this
6	is essentially the standard Purex extractant mixture,
7	which is tributyl phosphate in a branched dodecane
8	mixture.
9	CHAIRMAN POWERS: Alex, can I ask you a
10	question?
11	MR. MURRAY: Sure.
12	CHAIRMAN POWERS: In the document, you
13	used the term "hydrogenated propylene tetramer."
14	MR. MURRAY: Yes, that's branched
15	dodecane.
16	CHAIRMAN POWERS: And how you use branched
17	dodecane. The organic chemistry profession has gone
18	to heroic limits to standardize its nomenclature.
19	What are these things?
20	MR. MURRAY: Well, it turns out that the
21	main, if you will, component of constituent of the
22	diluent is a branched dodecane, and essentially it is
23	made, if you will, from joining propylene molecules
24	together. Okay?
25	However, it is also distilled when it is

1 So you do get some other species in manufactured. 2 there as well. So you essentially have what in the chemical process industry is called a boiling point 3 4 curve for the mixture. 5 MR. ROSEN: Do you have a chemical symbol for this thing? Could you draw it for me? I mean not 6 7 today, but I mean --8 (Laughter.) 9 MR. ROSEN: I mean, let's go back to 10 fundamentals. I think what Alex is 11 CHAIRMAN POWERS: saying is it's a mess. You get a bunch of branched 12 dodecanes and they don't want to specify it out. 13 14 mean --15 MR. MURRAY: It's a commercial product. CHAIRMAN POWERS: the DOE 16 17 literature, it's called normal paraffinic hydrocarbon, 18 and it's still a branched dodecane, but I mean, I'm 19 just surprised that there's so much diversity of nomenclature both in the SER and the CAR and the 20 viewgraphs. They're all different. 21 22 I mean, it doesn't matter. I mean, the 23 point is you've got a bunch of organic that can burn. It doesn't matter, but my 24 MR. ROSEN: chemical engineering sensibilities are offended by the 25

1 idea that I don't really know what I'm dealing with. 2 And so during the break perhaps, Alex, you could take a piece of paper and draw something and say this is --3 4 MR. MURRAY: Sure. MR. ROSEN: -- it's mostly this stuff. 5 6 MR. SIEBER: You can draw anything. 7 won't know. 8 CHAIRMAN POWERS: It's kerosene, yep. The 9 hydrogenated --10 I'll draw it properly. MR. MURRAY: 11 CHAIRMAN POWERS: -- hydrogolene propylene 12 tetramer, which is a new one to me. 13 DR. WEINER: MR. MURRAY: Yes, but it is a branched 14 15 It is comparable to the normal paraffinic dodecane. dodecane which has been used in U.S. facilities. That 16 17 is more of an exact straight chain with little 18 branching. 19 Now, red oil refers to the formation of 20 nitrated organic compounds in this mixture. So red oil is really a collective term. Okay. 21 22 not a precise term. It can refer to the mixture containing butyl nitrate. It can refer to a nitrated 23 tetrapropylene hydrogenated dodecane. So we just use 24 the collective term "red oil." 25

1 CHAIRMAN POWERS: Which is neither an oil, 2 nor is it necessarily red. 3 MR. ROSEN: Although sometimes it is. 4 (Laughter.) 5 What I've shown on this MR. MURRAY: 6 slide, I like to try and bring in some illustrations. 7 A picture is worth 1,000 word. Okay. This is from 8 some tests which were conducted in I guess it was more 9 like the mid-1990s for people by contractors in the 10 Department of Energy complex on the -- if I don't zap myself here with the laser -- on the far left, this is 11 the normal organic solvent with tributyl phosphate in 12 13 a dodecane mixture. 14 As you go from left to right over here you 15 have where the mixture has been exposed for more time 16 and/or more temperature to nitric acid, and as you can 17 see, it generally starts getting a little darker, and 18 as you go into high temperatures, high temperatures meaning reflux type conditions, 110 to 120, even 130 19 20 Centigrade, you get more rapid reaction and more of a reddish hue. 21 22 And the sample on the far right was from 23 a test where it actually underwent if you will the decomposition reaction. 24 25 CHAIRMAN POWERS: These were from the

1	tests that were done up at LANL?
2	MR. MURRAY: Los Alamos, yes.
3	DR. WALLIS: Besides color, do you have a
4	description of the kinetics of these reactions that
5	you can estimate how rapidly they will occur?
6	MR. MURRAY: There are some kinetic
7	equations out there. As part of the staff review, we
8	have looked at some of the presented equations and
9	converted these to temperature rises, potential
10	temperature rises on
11	DR. WALLIS: Yeah, particularly on the
12	right-hand end when you have potential for
13	uncontrolled reaction.
14	MR. MURRAY: Yes.
15	DR. WALLIS: It would seem that there must
16	be criteria for whether or not you can control and how
17	much margin you need to have and all of this sort of
18	stuff.
19	MR. MURRAY: We will get into that as we
20	go more into this presentation.
21	DR. FORD: When you say there's some
22	kinetic data, is there enough kinetic data so you can
23	control this adequately?
24	MR. MURRAY: I would say the majority of
25	the information for controlling red oil species and
l	

1	red oil reactions is based on empirical operational
2	experience and empirical laboratory testing. I would
3	say for the most part, fundamental analysis using
4	kinetic rate equations, continuous attack ester tank
5	reactor mechanics, for example, to a large degree has
6	not been done, historically for defining operational
7	limits or in the construction permit application.
8	DR. FORD: The way you described it, you
9	gave the impression at least that it was almost an
10	autocatalytic effect, i.e., took off in a rush.
11	MR. MURRAY: It can be thermal runaway
12	reaction.
13	DR. FORD: And, therefore, is there enough
14	time to control this before
15	MR. MURRAY: As we get more into the
16	controls and the proposed strategy in our evaluation,
17	I'll try and answer that, but I think it's very
18	important to remember the applicant has identified a
19	preventative strategy. Okay? So the applicant does
20	not want the event to occur. So you don't want to get
21	into, if you will, waiting for seconds to tick down on
22	the clock.
23	CHAIRMAN POWERS: When people look for
24	detailed understanding on this, the difficulty, I
25	think it's my impression that the fundamental

1 difficulty with red oil is that we have never been 2 able to persuade ourselves that what gets created in the laboratory is, in fact, what caused the event. 3 4 And of course, the difficulty is the event 5 is only detected after you've blown up your facility, 6 and so it's hard to find what actually did the blowing 7 up. And so you've never persuaded yourself that this 8 red stuff is, in fact, whatever caused the event. 9 DR. WALLIS: Well, this makes it difficult 10 to scale up and all that kind of thing if you don't 11 have some sort of equations or --12 CHAIRMAN POWERS: No, it doesn't, Graham. 13 DR. WALLIS: It doesn't? 14 CHAIRMAN POWERS: This is where I think 15 just what Alex said. It is like most chemical 16 processes in this world. Most industrial chemical 17 processes are not based on equations. They're based on when I do it this way, I get the right stuff. 18 19 I do it any different way I blow up my facility, and that is true of, I would dare say, 95 percent of the 20 21 chemical processes run worldwide. 22 Is that a fair --23 MR. MURRAY: I would say it's a very large 24 percentage. I'm not sure exactly 95 percent, but it's 25 getting there.

1	CHAIRMAN POWERS: It's awfully close to
2	that.
3	DR. WALLIS: So it's the same as we read
4	about on page 602 of our criticality safety where it's
5	said to be based on skill of the craft and said to
6	require intuitive understanding of neutron physics.
7	That seems to me
8	(Laughter.)
9	DR. WALLIS: pretty hopeful. I mean,
10	I would like to have more than an intuitive
11	understanding of neutron physics in order to
12	understand criticality.
13	MR. MURRAY: Well, as we get more into
14	this discussion, I think that what is presented will
15	help.
16	DR. WALLIS: So you are going to reassure
17	us, are you?
18	MR. MURRAY: Well, perhaps when we get to
19	the end you'll be assured.
20	DR. WALLIS: Or are you going to convince
21	us?
22	DR. RANSOM: Are these vapor phase or
23	liquid phase on interphasial reactions?
24	MR. MURRAY: They are liquid phase
25	reactions primarily, and I want to emphasize
J	

1 "primarily." They tend to occur more violently around 2 the interface between the organic phase and the 3 phase, okay, and normally with few exceptions, in all of these processes the organic 4 5 phase is lighter and is on the top. 6 DR. WALLIS: So mixing comes into it, does 7 it? 8 MR. MURRAY: Mixing can come into it, yes. 9 DR. WALLIS: Do you think it's stirred up 10 by its own reaction? MR. MURRAY: Yes. Now, one thing to keep 11 Gaseous phase reactions can contribute to 12 the brisance, the explosiveness, of the event if those 13 14 gaseous phase products are not removed. These species 15 can include butyl alcohol, butyl nitrate, some others, 16 sometimes butane. Okay? So they can be quite flammable in case your species evolve, and if they are 17 confined within the vessel, they contribute to the 18 19 event. DR. FORD: Just in terms of the process, 20 the discussion process, it's my understanding right 21 22 now all you're doing is identifying an issue and how 23 qualitatively you're going to control it. specifics of how you're going to control it, whether 24

you approve of the Cogema's strategy for managing this

issue, that doesn't come until some time next year, 2 and that's when we will be asked to make comments about the adequacy of that control? 3 4 MR. MURRAY: For most of the open items 5 which we are discussing today, there are some specific 6 control parameters identified. All right? 7 will happen with the regards to what license 8 application, we expect that the identify principal 9 structure systems and components will be fleshed out 10 in more detail from a systems level to more of a 11 component level: how many thermocouples or RGDs do 12 you have monitoring the process? Where are they Are they adequate to give an accurate 13 located? 14 temperature measurement and so forth? 15 DR. FORD: That will come later. 16 MR. MURRAY: That will be later, but we 17 have some specific parameters identified already. Also, with this being the construction 18 19 authorization phase, we are not looking at set points. 20 We have looked at the set point methodology, which is part of the design basis. 21 22 Well, let me move on. Just to get some 23 feel, I'm a chemist, chemical engineer, and -- I'm 24 sorry. Is there a question? 25 DR. BONACA: No, no. I said, "There you

1 go, " meaning you were asking about some. 2 This is just a sample, a MR. MURRAY: 3 diagram which shows sample reaction pathways, and I'll 4 just point out to you tributyl phosphate is the actual extractant in the diluent mixture. 5 It can go under 6 various reactions to form DBP and MBP, which are 7 dibutyl and monobutyl phosphate esters, respectively. 8 All right. These compounds all over here can react further in the presence of heat and nitric 9 acid and radiation to go to the C4 species, even to 10 some of the C3 species. Okay? 11 In the end, if you have a red oil event, 12 you're essentially taking the organic and converting 13 14 it to a mixture of the gases, all right, nitrogen, CO, 15 CO₂, some of the nitrogen oxides. This is exothermic? 16 DR. WALLIS: 17 MR. MURRAY: And it is exothermic, yes. So you have both the energy release, which heats up 18 19 the mixture, and you also have the evolution of significant quantities of gaseous species, which also 20 contributes to, if you will, the event. 21 22 And I will say there are some other 23 reactions beyond these, but this is a pretty good 24 summary. MR. ROSEN: This is another one of those 25

1 slides I'd like to have that I can't quite see. 2 MR. MURRAY: The reaction pathway one? 3 DR. WALLIS: It's not just exothermic. It makes a lot of gases. 4 5 MR. MURRAY: Right. 6 DR. WALLIS: So there's going to be a 7 pressurized --MR. MURRAY: Exactly, exactly. You get a 8 9 double whammy, if you will. 10 Okay. Let's see. This is a little hard to read in the handout. So I just wanted to identify 11 12 generically in the process where this is a potential concern, where potential red oil events can occur. 13 14 They are primarily in areas where you have the solvent 15 and the solvent extraction processes. However, one thing from operating plant 16 experience is the solvent can move around 17 18 accumulate in other areas, such as what is termed in this facility the oxalic mother liquor recovery area, 19 20 into the precipitation steps, even to acid recovery 21 and waste. 22 And on this slide I have summarized the 23 safety issue, and what I want to point out is these species -- it turned out pretty well. 24 That actually from the American Institute of Chemical 25

1 Engineers on overheated reactor. 2 These red oil species can undergo 3 exothermic reactions, and they can do it with 4 relatively small quantities. Estimates for some of 5 the advance up in quantities, well under 100 gallons. 6 One of them it is postulated might have been around 50 7 gallons. 8 These are --Okay. 9 And the more you have, the DR. WALLIS: 10 worse it is then. 11 MR. MURRAY: Yes, yes. That's correct, 12 but --DR. WALLIS: Why does quantity come into 13 14 I mean, if it's an exothermic reaction and the it? 15 right conditions, it's going to happen. This is the amount that MR. MURRAY: 16 17 participates in the event. All right? It's not, if 18 you will -- if you have more quantity of material, 19 you can have more exothermicity, more of a pressure rise and, if you will, more of an explosion. 20 However, the significant thing for our 21 22 purposes here is that the quantities which are formed 23 and reacted in historical incidents and events are comparable to quantities at their proposed facility or 24 25 quantities which could form at the proposed

1	facilities.
2	MR. ROSEN: But Graham's point is still of
3	interest to me. If you just had a little cup of this
4	stuff someplace, it would experience a reaction.
5	MR. MURRAY: Yes.
6	MR. ROSEN: It might not be important,
7	but
8	MR. MURRAY: Right. And if you have 1,500
9	gallons of the material, you can blow out four foot
10	thick shield plugs and do quite a bit of damage.
11	DR. WALLIS: If you were doing research,
12	you might do it with a small quantity.
13	MR. MURRAY: Exactly.
14	(Laughter.)
15	MR. MURRAY: Preferably a very small
16	quantity.
17	CHAIRMAN POWERS: I believe that in the
18	solvent recovery facility in Purex, they came to the
19	conclusion they were probably getting the events on
20	time.
21	MR. MURRAY: Yes.
22	CHAIRMAN POWERS: And it was only when
23	they shut down for a clean-out of a facility
24	accumulated a lot of it and then started up that they
25	got an event that anybody knew was actually
- 1	1

1 happening. 2 MR. MURRAY: Yes. I should just clarify 3 the point. In Purex time systems, red oil reactions happen all the time, except they happen at a slow 4 5 rate, and the relative concentrations of the degraded 6 products and other species are relatively small. 7 classic It's kinetic of type 8 consideration: higher concentrations, higher 9 temperatures, higher nitric acid concentrations. 10 Ultimately those can, if you will, increase the kinetic rates to a point where they become a concern. 11 12 MR. ROSEN: And in the process of getting 13 to the garden variety end products you end up with, which no one would be concerned about: 14 nitrogen, 15 carbon dioxide, et cetera. 16 MR. MURRAY: Exactly, exactly. 17 MR. ROSEN: And you have all of the fun. 18 MR. MURRAY: Yes. 19 MR. ROSEN: The end products don't matter 20 much to you is what gets you there. 21 MR. MURRAY: It is what gets you there, 22 and if those end gaseous species cannot escape. 23 CHAIRMAN POWERS: And, Mr. Croff, this is an area that you might be particularly interested in 24 25 because I think you can track every single major event

to some change in operations, either stopping them, 1 starting them, a different way of doing things than 2 coming back. 3 So operations does seem to affect this 4 5 process. DR. FORD: So many of those instances have 6 7 had a human factor route to them? I don't know if I would say 8 MR. MURRAY: 9 exactly a human factor route, but they have tended to involve unnoticed accumulation of organic material in 10 a tank vessel or evaporator, and often that involves, 11 if you will, human monitoring by chemical sampling 12 analysis, sometimes as simple as looking at the two 13 14 phases showing on the site glass or on the remote TV 15 camera, what have you. Okay. Just in simple terms, if you remove 16 aqueous phase from a solvent extraction system, say 17 18 it's at 60 degrees Centigrade, okay, a not uncommon temperature, and you put it into a vessel, again, just 19 the aqueous phase, as that aqueous phase cools down, 20 organic materials that have dissolved in that aqueous 21 22 phase become less soluble. So they tend to separate out and coalesce as a separate organic layer on top of 23 the aqueous phase in that tank or vessel. 24

And in many of the Purex type facilities

1	around the world, it is that type of phenomena which
2	has contributed to these events.
3	CHAIRMAN POWERS: I think that everyone
4	that I can bring to mind something got changed.
5	MR. MURRAY: Yes.
6	CHAIRMAN POWERS: Some disruption.
7	Weekends seem to be particular
8	MR. MURRAY: And shift changes, yes, yes.
9	DR. WALLIS: Can you control this
10	reaction? It seems to be what they're going to do.
11	There's no defense in depth, and if it does run away,
12	it gets vented into something where you can keep it
13	under wraps. It's vented in some way?
14	MR. MURRAY: Well, ultimately this is a
15	reaction which occurs within vessels, piping,
16	evaporators, all of those, if you will, vent either
17	through the off gas treatment system or there's a
18	vessel vent system as well.
19	DR. WALLIS: So if the reaction got out of
20	control, stuff would come pouring out the vent. Is
21	that what would happen?
22	MR. MURRAY: And that is one of the
23	reasons why the applicant has selected a preventative
24	strategy, yes.
25	MR. ROSEN: And that stuff pouring out the

1	vent is hot and being blasted, and it's likely to be
2	a fire, ignition source; am I correct?
3	MR. MURRAY: It could be.
4	MR. SIEBER: Could.
5	MR. MURRAY: It could be, yes. It is
6	likely to be hot.
7	DR. FORD: But the preventative action is
8	primarily engineering monitoring systems, i.e., remove
9	all human dependencies.
10	MR. MURRAY: It's a combination of what I
11	would call engineered controls and administrative
12	controls.
13	MR. MURRAY: And do we know of the
14	reliability of those engineered controls? Is there a
15	database from the chemical industry, for instance?
16	MR. MURRAY: The staff as part of its
17	review and analysis, we have looked at some of the
18	ranges of reliability for some of the proposed
19	controls and have made some conclusions regarding
20	those controls.
21	DR. FORD: And will that in much more
22	detail come into the part that's going to be done next
23	year?
24	MR. MURRAY: Yes, it will have to come
25	into more detail and be integrated safety analysis,

which will be -- the summary of which would come in with the license application.

And here I'm discussing the applicant's

And here I'm discussing the applicant's safety approach. First off, the applicant has identified this as a high consequence event, and they have selected a preventative strategy to render the event highly unlikely, in effect, stop the event from occurring.

All right, and I want to point out that when we received the initial application, which is almost four years ago now, at that time there was only one PSSC or control identified with one safety function.

In the revised application, which we received this past June, there have been additional PSSCs added and additional safety functions identified, and also there's a commitment to further research and experiments to understand the phenomenon better.

DR. FORD: Now, when you say it's a preventive strategy, vent highly unlikely, you mentioned earlier on that was about a frequency of ten to the minus four per plant year. Was there any PRA done to justify that conclusion that you have gotten there?

1 MR. MURRAY: We did not do PRAs. We have 2 used some top level fault tree types of analyses. We have used some of the guidance from the appendix in 3 4 the MOX standard review plan to get some, if you will, gauge of how responsive, how reliable some of these 5 proposed controlled strategies, these PSSCs and safety 6 functions can be. 7 DR. FORD: Well, a more PRA-type exercise 8 9 be done next year? That is entirely up to the 10 MR. MURRAY: 11 applicant. The applicant has the option of doing this in a qualitative mode similar to what they've done 12 They can do it in a semi-quantitative mode or 13 14 they can do it in a quantitative mode. I think we'd 15 have to wait until next year. DR. FORD: Is there some reason why we're 16 not insisting that they use a PRA? 17 MR. GIITTER: The regulation --18 19 CHAIRMAN POWERS: Peter, you need to look at the regulation. What Alex described is called an 20 integrated safety analysis. This is not PRA land, and 21 22 so if you contest that, you contest a battle that 23 we've already been through at some length, and the Commission has made a decision. 24 Okay? So they are 25 the people you should interrogate, I think.

1 DR. FORD: I recognize there's two worlds 2 live in here. There's the world that 3 formulated when the regulations were written versus 4 what is technically state of the art. Well, now, hold it. 5 CHAIRMAN POWERS: 6 Integrated safety assessment is recognized as the 7 state of the art within the chemical community. You 8 sit next to a guy that's got PRA on the brain usually. There are other people who have to deal with safety 9 10 and have found effective ways of doing it. 11 DR. FORD: Yeah, I know, and I accept 12 It's just that sprinkled in here we have talked 13 about what was the definition of highly unlikely before, and we got one out of here, and thank you. 14 15 MR. MURRAY: You're welcome. 16 DR. FORD: But I'm trying to delve down to 17 find out how much quantitative knowledge --18 MR. ROSEN: I applaud your question line, 19 Peter, but you're almost to the bottom of what they're willing to do in terms of heading in that direction, 20 21 and Lord knows for me I would certainly encourage 22 more, but that's what the regulations embody and rely on and require, is what you're hearing. 23 DR. FORD: 24 Okay. 25 MR. GIITTER: I would just add that Part

70 is performance based and risk informed regulation. It was recently promulgated in 2000. So as Dr. Powers indicated, it is state of the art in terms of looking at risk for fuel cycle facilities. They are different beasts than reactors. I want to remind you of that, although in terms of complexity, the MOX facility certainly is probably the most complex fuel cycle facility that we're currently looking at from a safety perspective.

DR. FORD: I guess I'm kicking against the system here just to see how much it will give. If this thing blew up, heaven forbid, we would be crucified if we didn't kind of come up with that you didn't apply knowledge from, for instance, other industries, et cetera, to this chemical plant. I'm kicking at that.

CHAIRMAN POWERS: I think you're taking an inferior position. There has been over the last 25 years a huge, enormous effort that makes the PRA effort pale in comparison as far as number of dollars spent on developing strategies for handling, assessing the safety of operations in chemical processes.

In fact, the American Institute of Chemical Engineers maintains a center on exactly this.

I think Alex is more familiar with it than I am.

NEAL R. GROSS

1	MR. MURRAY: Yes.
2	CHAIRMAN POWERS: There are shelves of
3	books on how to do this sort of thing. Now, that
4	particular community has struggled with the fact that
5	every single chemical process is different, and that
6	PRA methodologies just don't seem to interface well in
7	that, and they've taken a somewhat different tact.
8	Now, I look at it, and I say, well,
9	they're really only missing a final integration step,
10	and it would look and smell and walk and talk much
11	like a PRA, but it's a reasonably sophisticated field,
12	and, I mean, to say, well, it's not identical to the
13	reactors and, therefore, it's not state of the art is
14	fairly unfair, I think.
15	Some of these, they have a very, very much
16	more sophisticated view on how to handle worker safety
17	than we do in the reactors area.
18	MR. SIEBER: Right.
19	CHAIRMAN POWERS: It's much better, I
20	think. It's a nice societal risk assessment.
21	Well, enough said. Go ahead.
22	MR. MURRAY: Okay.
23	DR. DENNING: Could I interrupt just a
24	bit? But perhaps you would like to first.
25	DR. WEINER: I just had a quick question.

WASHINGTON, D.C. 20005-3701

How can you really justify classifying this reaction as highly unlikely by putting mitigating efforts on it when it is, in fact, a reaction that has occurred quite frequently over and over again? I mean, if you say that your unlikely range is everything from once in 100 years to once in 10,000 or whatever it was, and your highly unlikely range is really a highly unlikely range of ten to the minus four, I would not classify this as highly unlikely.

And I'm concerned that that gives a false impression that, yeah, we know what we can do to virtually absolutely prevent this from happening.

MR. MURRAY: First off, let me say this is the applicant's proposed safety approach. As we get into the staff's evaluation of it, I think you will see that that is more of a preventative type approach, and we tend to -- we, the staff, who have reviewed this -- tend to agree that the proposed approach has the ability; it hasn't been demonstrated yet, but it has the ability to achieve unlikely likelihoods, if you will, to prevent this event.

In the license application, which Okay. we're expecting next year, they have to supply the The applicant has to give the proof, if you will.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

demonstration by either heuristics, by more detailed 1 analyses be they hazard indices or a layer 2 protection analysis of some type to give us the 3 confidence, the assurance, if you will, that, yes, not 4 only did you say you have the ability to get to a 5 highly unlikely, if you will, prevention of this 6 7 potential event, but, yes, you've given us enough information to give assurance that that is, indeed, 8 9 the case. Alex, I'm sorry. If I may 10 MR. BROWN: interrupt, in your next slide you do talk about open 11 I think it's important to emphasize we're 12 not preventing the red oil reaction. We're preventing 13 14 an explosion or rupture of vessels resulting from the uncontrolled reaction. 15 MR. MURRAY: Yes, that's a good point. 16 I think that's an important MR. BROWN: 17 point. 18 DR. DENNING: The point that I wanted to 19 make was that I think with regard to the discussion of 20 probabilities, I think the really important issue here 21 is one of we put a lot of emphasis now on the 22 reliability of the PSSC, and if we're not very 23 quantitative about that, and it's very difficult to 24 know is the PSSC really adequate in reducing the 25

frequency adequately of events.

And so one of the questions I have for you is when the applicant went here from one PSSC with a single safety function to three PSSCs with different safety functions, is the reason because that they didn't develop enough believe that the one PSSC was adequate to provide the kind of reliability of prevention that we're looking for?

How do you really make this judgment of how much credibility we really need for that PSSC, particularly if we mix in administrative controls into that which have a lot of uncertainty associated with it?

MR. MURRAY: Well, let me see if I can answer that this way. As part of the staff's review, okay, when we first started this almost four years ago, we noted there was just a single control for this phenomenon. All right. We looked at the presented information from the applicant. We looked at open literature information. We conducted some of our own analyses which are more akin to a layer of protection analysis or a hazard indice sum, if you will, and we concluded that with the information presented at that time, the applicant could not assure us that their proposed safety strategy could prevent this event.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

Now, as part of the interactions over the past four years between the NRC staff and the applicant staff, the applicant has also reviewed this phenomena in more detail, and they came to the conclusion that more controls were needed, partly based on simple analyses, partly based upon more interactions with DOE facilities and French facilities as to how, if you will, what is the good engineering practice for addressing these types of events.

Okay. So it's a combination of many things.

DR. BONACA: Well. one observation I wanted to make is regarding the statement we heard It is very important, and I think it has here. confused me from the beginning. I mean, you presented us a MOX regulatory frame work in which you did essentially classified as highly unlikely and likely, and not the initiator, but the actual endpoint, which the release, okay, the exposure, public dose credited at 25 rems is almost akin to say that for current reactors you're using the criteria of LERF, large early release, and anything that is before that, they call it preventative rather than we don't. a mixture of preventative and mitigative.

And I think it's important that that point

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

be clarified for us because, you know, then I 2 understand what you're saying there, and this becomes It could be a highly unlikely much more credible. event. Well, I think Mario has made MR. ROSEN:

1

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

an excellent point. I would want to follow what Rich was saying before about thinking about the reliability of these safety functions, both human and equipment. If you're going to present the safety function and take credit for it, making something highly unlikely, and that function has a hardware component, especially active hardware, something that has to change state, like a valve that has to open or close or something like that.

Then I cannot see how I can agree to any kind of number, any kind of functional criteria for it or performance criteria for it unless you tell me something about its quantitative abilities, its -excuse me -- split fraction at the point of whether it opens or closes, something about its reliability.

You're forced if you're going to use safety functions of PSSCs and their active components to talk in that language or else it's pretty much meaningless.

> I just want to say that as MR. MURRAY:

NEAL R. GROSS

1 part of the staff's review, we did look at, if you 2 will, ranges of reliability for some of the proposed 3 safety strategies. Again, as part of a construction 4 organization review, we'll looking for approaches that have the ability to meet the regulations and the 5 6 license application. The applicant has to provide the 7 proof, if you will, the demonstration. 8 Right, and I understand that MR. ROSEN: when you come back the second time to the ACRS you'll 9 10 have all of that looked at, and you'll be able to tell 11 If we put our hand on a valve on a drawing us. 12 someplace and ask you, "Is this important, Alex?" and you say, "Yes, it makes the event highly unlikely," 13 then how reliable is this thing? 14 15 And it's a .99 reliability or a reliability, and what is your basis for saying so? 16 You have the data. 17 18 MR. MURRAY: Yeah. 19 MR. ROSEN: And if so, let me see it. know how this goes. 20 21 MR. MURRAY: Yes, yes. MR. GIITTER: Dr. Rosen, again, all we are 22 23 required to do at this stage is to have a reasonable assurance, and I think that's where the staff is at at 24 this point in time. And whether the applicant comes 25

87 1 the future with a detailed quantitative evaluation, which they can do, or a qualitative 2 evaluation, we still have to be able to have a high 3 4 degree of assurance that the IROFs are reliability and available to prevent the undesirable consequence. 5 MR. ROSEN: Does that mean that you'll 6 7 look at that data before you come in here and ask for it, look at the reliability data for active components 8 that are used in this facility? 9 Yes. 10

MR. MURRAY:

MR. ROSEN: Okay. Good.

MR. BROWN: If I may point out just one more thing, too, one of the things we did approve already is the applicant's quality assurance program plan, which is for plutonium processing facility for an NRC license has to comply with the Part 50, Appendix B criteria, and so you know, one of the things that falls out of that is the items relied on for safety are designated quality level one and have all of the associated, you know, quality assurance measure applied to them.

A lot of that detail is part of the design process now and will help determine later what additional surveillance requirements, maintenance measures are required to maintain high reliabilities.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1 A pump on its own may have only an average with additional 2 reliability, but surveillance 3 requirements, again, those details are to be provided 4 later in the license applications. It may be made 5 more reliable, that sort of thing. 6 MR. MURRAY: Let me continue on. I just 7 to point out on this slide some of the 8 definitions for the two cases that the applicant uses. 9 The applicant has defined open and closed systems. 10 an open system there's a vent provided, and its main function is pressure release. The vent doesn't allow 11 12 over pressurization of the vessel from the full 13 runaway reaction of --14 DR. WALLIS: So what goes out the vent? 15 Is it a single phase or is it a mixture? MR. MURRAY: It would be a single phase. 16 17 DR. WALLIS: Because this reaction if it's 18 energetic enough is going to make a foaming or two-19 phased homogeneous mixture which will swell up and go out the vent. 20 The applicant has committed 21 MR. MURRAY: 22 as part of the experimental studies to investigate 23 that phenomenon. 24 It's very difficult to be DR. WALLIS: 25 sure that you won't get this sort of homogeneity when

1 you get a reaction which is happening throughout the 2 mixture. 3 MR. MURRAY: Yes, they have --DR. WALLIS: It's like opening a shaving 4 5 cream. 6 MR. MURRAY: Yes, yes. Now, there have 7 been tests conducted which have been sponsored by the 8 Savannah River company where these tests showed -- and 9 I'll get to it in a moment -- where venting was a very 10 effective means to prevent, if you will, the incident from propagating into an event. 11 12 MR. ROSEN: And you can show that when you vent through a relief valve that the valve is capable 13 14 of not only passing fully homogenized, gaseous material, but also can tolerate the two-phased flow, 15 16 and the forces that can be caused on a component from 17 two-phased flow because I presume these valves are 18 relied on to close at some point, to shut off and retain some of the inventory. 19 That sort of more detailed 20 MR. MURRAY: 21 information would be with the license application, not 22 as part of the construction authorization, which we're 23 discussing now. DR. WALLIS: When this stuff comes out of 24 25 this relief valve, what does it go into?

1	MR. MURRAY: It goes into the off-gas
2	treatment system for red oil.
3	DR. WALLIS: A gas treatment system?
4	MR. MURRAY: There's an off-gas treatment
5	system.
6	DR. WALLIS: I could see this stuff
7	pouring out and then continuing to react. I don't
8	know what its kinetics are. If it's hot enough
9	MR. MURRAY: Again, at the construction
10	authorization stage we're just looking at the design
11	bases, the PSSCs. Does the proposed safety strategy
12	have the ability to render this highly unlikely?
13	DR. WALLIS: This is based on some
14	experience that this sort of thing
15	MR. MURRAY: Often it's based on
16	experience, yes.
17	Now, a key thing about an open system is
18	if everything in that vessel container or pie were the
19	organic phase, the open system can adequately vent it
20	without any pressurization of that container or
21	vessel.
22	For a closed system, however, there's a
23	vent provided, but it has a different function. It is
24	a pathway for evaporative cooling. In essence, some
25	of the aqueous phase, as well as some of the

intermediate species from the breakdown of tributyl 1 2 phosphate are vented through this vent. They carry a 3 certain amount of enthalpy or heat with them, and that 4 allows the system as a whole to cool. 5 MR. ROSEN: It's a pressure relief valve. 6 Is that what it is, when you have a closed 7 system? 8 MR. MURRAY: In a closed system, it could 9 be a pressure relief valve. 10 MR. ROSEN: Or ruptured disk? MR. MURRAY: Or ruptured disk. That sort 11 of specificity we'd expect in the license application. 12 Out of curiosity, it would 13 DR. RANSOM: 14 sound like an open system was better, but there must be some reason why they selected a closed system. 15 MR. MURRAY: Yes. The applicant expects 16 17 most of the vessels or containers, if you will, to be open systems. As part of our interactions with the 18 19 applicant, we had asked the question: can we have all 20 of the vessels as open systems? 21 And the applicant said, no, there will be 22 a few systems which we would designate as a closed Details would be provided at the ISA stage 23 with the license application. 24 25 But the great majority of the vessels or

systems would be open.

Okay. Let me just discuss the PSSC. The first one is the off-gas treatment system. This provides venting and avoids pressurization of the vessel itself and allows a path or evaporative cooling.

In the open system, it has a safety function to avoid pressurization, and a design basis has been identified by the applicant. Okay? And I'll get to that in a little more detail in a moment, but that basically defines the size of the vent on the vessel.

For a closed system, the applicant has based it upon the safety function upon evaporative cooling, and it is essentially a 20 percent margin above the energy put into the system, and that is energy which comes from the steam heating, which is used, if you will, in the evaporator, say, to concentrate the material, recover nitric acid, and also the heat or enthalpy which comes from the red oil reactions themselves.

DR. FORD: Are these numbers here your specifications or their specifications? How are they arrived at?

MR. MURRAY: These are numbers from the

NEAL R. GROSS

1	applicant. They are design bases. Okay? They're not
2	specifications.
3	DR. FORD: Okay, and you're approving
4	these at this time or is it do you approve them at
5	this time or do you just do it enough to have
6	reasonable assurance that you have safety, or have you
7	done it?
8	MR. MURRAY: We do this as reasonable
9	assurance.
10	DR. FORD: And how is that arrived at?
11	MR. MURRAY: We're getting there.
12	DR. FORD: Okay.
13	MR. MURRAY: First I wanted to go through
14	the PSSCs proposed by the applicant. The second PSSC
15	is the safety control subsystem. This is essentially
16	an active engineer control, and I've listed the
17	parameters here, limiting steam temperature. Okay?
18	This value comes from experience. Limit
19	organic compound residence time.
20	DR. WALLIS: How hot does it have to get
21	before it's in trouble? Is it 134 or 150 or 200 or
22	what?
23	DR. BONACA: Very close.
24	MR. MURRAY: We'll get to that in about
25	four slides.
į	1

1	DR. WALLIS: Okay.
2	MR. MURRAY: Stay tuned with me.
3	MR. ROSEN: Not much.
4	DR. WALLIS: I think it's not much.
5	MR. MURRAY: For closed systems, okay, the
6	process safety control system would limit the
7	temperature of that reacting mixture to 125 degrees
8	C., and it also would limit the temperature-ramp rate
9	to nothing greater than two degrees Centigrade.
10	DR. WALLIS: Presumably if you use
11	evaporative cooling, you're going to have to make up
12	whatever you evaporate.
13	MR. MURRAY: Yes. That's why it's called
14	aqueous phase addition.
15	DR. WALLIS: Aqueous phase addition,
16	right. Put water in and take steam out. Is that
17	MR. MURRAY: In essence, yes. And as the
18	water evaporates into steam, it absorbs energy from
19	the mixture and cools it down.
20	MR. ROSEN: And the controllers that do
21	these are solid state controllers, the PLCs or things
22	like that, right?
23	MR. MURRAY: That's correct.
24	MR. ROSEN: Which have a reliability which
25	we know, and this will be discussed because these are

1 items relied on for safety in the ISA, I presume. 2 MR. MURRAY: Yes, in more detail in the 3 ISA. That is correct. 4 Okay. Let me just mention the third 5 control, and this is essentially a chemical safety 6 control, which is more of an administrative control. 7 It has been found from both experiments, 8 plus investigation of past incidents also 9 accidents with red oil, that organic compounds which 10 are cyclical in nature, cyclohexane derivatives, for 11 example, can contribute significantly to the event by 12 lowering the initiation temperature. To address that concern, the applicant has 13 a safety function for this chemical safety control to 14 15 prevent any cyclical compounds from being in the diluent and, if you will, getting into the system to 16 17 react. 18 DR. FORD: Do you know why they lower the 19 initiation temperature? If you look at the --20 MR. MURRAY: The reason why I'm asking the 21 DR. FORD: 22 question, is there something else that could do the 23 same thing? MR. MURRAY: There are some degradation 24 25 products which can do the same thing as well, but

1 those are removed in the solvent treatment system at the proposed facility. You know, dibutyl phosphate, 2 for example; it would be some of the butyl compounds. 3 Okay. So the solvent is treated before it 4 is reused in the Purex process, and that's where those 5 6 are removed. Okay? 7 DR. WALLIS: In my experience in consulting with disasters in chemical plants is that 8 there's an awful lot of shakedown. 9 You build the thing, and then you do a lot of experimentation, and 10 then you fill it with things and you change the 11 temperatures and pressures until everything works 12 right, and then you find, gee, whiz, we're making some 13 Therefore, you'd better do 14 cyclical organics. 15 something about it. Is this what happens here, is sort of a 16 year or two of shakedown at the facility, or is it 17 something that you just build and it works? 18 MR. MURRAY: I will hypothesize that this 19 facility will have a shakedown period and that the NRC 20 staff would be involved with inspections during that 21 22 shakedown period. This is where you get some DR. WALLIS: 23 more assurance that these things really work --24 25 MR. MURRAY: Yes.

	97
1	DR. WALLIS: and that 125 degrees C. is
2	okay and all of that?
3	MR. MURRAY: Right.
4	MR. ROSEN: But is there a way to do it
5	without plutonium and uranium dioxide powder?
6	MR. SIEBER: Yes, that's the way you do
7	it.
8	MR. MURRAY: Yes, that's how you do it.
9	MR. ROSEN: So the shakedown period is
10	non-radioactive. It's cold.
11	MR. MURRAY: The shakedown period will
12	again, this is something which would come in as part
13	of a future phase of this program, but the shakedown
14	period usually will start with non-radioactive
15	species, and it might end, say, with the introduction
16	of something like uranium just to check out how well
17	the process would work with, if you will, some real
18	radioactive material.
19	It is possible in the future the applicant
20	might even decide to use some compound or element
21	which has similar chemical properties as plutonium
22	just to check out the facility.
23	MR. ROSEN: In the reactor world which
24	we're burdened with there's something called a start-
25	up test program which sounds analogous to your

1	shakedown period. It's part of the the start-up
2	test program is part of the application, which the
3	staff reviews.
4	Is there an analogous section of the ISA
5	with the shakedown program in it that you review and
6	approve?
7	MR. MURRAY: The integrated safety
8	analysis will have to look at start-up of the process,
9	steady state operation, upsets in the process, ranges
10	that the process or facility would experience, and
11	shutdown.
12	MR. ROSEN: Not quite the answer to my
13	question.
14	MR. MURRAY: I'm sorry.
15	MR. ROSEN: No, I think you almost hit it.
16	You said start-up of the operation. Did you mean
17	routine start-up or first time start-up?
18	MR. MURRAY: It should address both.
19	MR. ROSEN: Okay.
20	MR. MURRAY: Again, you know, the devil is
21	in the details, but those details should come in with
22	the license application next year.
23	DR. DENNING: Let me just challenge one
24	response you had to Graham in terms of whether you
25	really addressed what he was saying, and that was

1	Graham said that in the start-up period you'll do
2	things like determine the acceptability of like the
3	125 C. limit, and I don't think you really do. I
4	don't think in the start-up period you really do
5	anything that really determines what's the
6	acceptability of the limits or reliability of
7	MR. MURRAY: Well, let me just clarify
8	something. The applicant has committed to an
9	experimental program to essentially define and, if you
10	will, make sure that the temperature value 125 degrees
11	Centigrade, for example, is reasonable and appropriate
12	as a design basis.
13	MR. ROSEN: I'll push your button. That
14	is not my slide there?
15	MR. MURRAY: Okay. Here it is. This is
16	a commitment they've made. The applicant will define
17	the reaction kinetics in more detail, quantitatively,
18	determine effects of impurities, and then from that
19	experimental data probably as part of testing
20	establish some operational limits and set points.
21	DR. WALLIS: How long is this going to
22	take?
23	MR. MURRAY: That has not been discussed
24	yet.
25	DR. WALLIS: Quite often research seems to

1	be done to confirm something you've already decided,
2	and you find the plant is running before you've
3	actually finished the research.
4	MR. MURRAY: It is our understanding from
5	our discussions with the applicant that this is a near
6	term research experimental program.
7	DR. WALLIS: It may be very hard. You
8	said that we don't really know these reactions. They
9	my turn out to be very tough.
10	MR. MURRAY: It could be difficult.
11	DR. WALLIS: So this is going to hold up
12	the whole plant?
13	MR. MURRAY: If problems are encountered
14	during the test program, it is possible, but that is
15	hypothetical at this time.
16	DR. FORD: What would trigger, if you go
17	back one slide, just following up on Professor Wallis'
18	question
19	CHAIRMAN POWERS: Let me interrupt just
20	for one second. We are running behind time. This is
21	the only opportunity we have to plunge into the
22	details. So I don't want to cut off, but I would like
23	to stay focused on the issue at hand here, which is
24	the construction permit. And if you need to

understand the limits of the construction permit to

understand what's going on in the licensing permit, 1 that's fine, but if you're just curious, I would 2 3 prefer to stay on schedule. 4 DR. FORD: I withdraw my question. 5 MR. MURRAY: Okay. That's fine. 6 Let me get into the start, evaluation, and 7 conclusions, if I could please, and first off, for 8 open systems, the staff agrees that a preventative 9 strategy is the best approach, okay, due to the 10 potential severity of the vent, and we've noted and 11 have analyzed the multiple PSSCs and safety functions identified by the applicant. 12 One key point I want to make is the design 13 14 basis for the vent **PSSC** is well within the 15 experimental range which has been determined by tests conducted for the Department of Energy. 16 17 this, that system cannot over pressurize. 18 Okay. Again, this is predicated upon the 19 fact that the vent is designed properly. I want to emphasize that. Details would have to be in the ISA 20 21 stage. 22 Because the system cannot pressurize, it 23 is physico-chemically limited to the normal boiling point of the mixture. It cannot go above that, and 24 25 that is up around 120 degrees Centigrade.

well below the red oil runaway temperature conditions which start at around 130 or so degrees centigrade, and this has been accepted by the staff.

And if I go to the next slide, as you can see, the blue line on this curve was determined by experimental studies conducted on behalf of the Department of Energy. A key point to point out here is that somewhere just beyond this organic mass vent area ratio of about 32 kilograms per square centimeter, there's a very rapid rise in the pressures which were measured.

And because of this, the Department of Energy and its contractors have identified this value of about 32 as being the boundary between safe and unsafe for red oil reactions. All right?

MR. ROSEN: Without uncertainty? There's no uncertainty on that 32, or is it a degree or four degrees or nine or do you have any sense of it?

MR. MURRAY: This data as regards uncertainty, these were a series of tests. Okay? I don't think the researchers went into great detail about uncertainties. From our perspective, I would just like to point out, again, we're looking to the ability of the proposed strategy to, if you will, keep the system safe, render the event highly unlikely.

1 I think it's important to realize that 2 what the applicant has proposed is considerably away 3 from this range here and well into the recommended 4 safe range. And it would seem even if there are some 5 uncertainties into where this line is exactly drawn, 6 it would seem that they would still be in the safe 7 range. 8 It looks like it ought to be MR. ROSEN: 9 based on what --10 MR. MURRAY: Yeah. 11 MR. ROSEN: -- but on the other hand, I 12 don't know what the experiments were, and so I have no 13 sense of whether 12 versus 32 is a good number. 14 the uncertainties are 20 on 32, it isn't. The 95 15 percent confidence limit is 20 on that 30. Then it 16 isn't. 17 So I would recommend --MR. MURRAY: That sort of detail we would 18 19 expect to see in the integrated safety analysis as 20 part of the operating license review. Now, this information I would like to 21 22 point out is all in the open literature. 23 everything which we are discussing today is in the 24 open literature. This was actually from a paper 25 authored by Paddleford and Fauske.

1	DR. BONACA: If they use the expression,
2	that to me would read that they had some consideration
3	of uncertainty in that ramp. That's a good question.
4	MR. MURRAY: Again, I think uncertainty is
5	a very good question, but I think at this stage with
6	the other information presented in the literature,
7	this gives the staff assurance that what the applicant
8	has proposed has the ability to render the event
9	highly unlikely.
LO	Again, more specifics. Details which
۱1	demonstrate that the applicant has rendered this event
L2	highly unlikely would have to be in the license
L3	application.
L4	Okay. Let me move on.
15	Let me just mention about closed systems.
۱6	Now, in closed systems, the applicant has identified
L7	a solution temperature of not exceeding 125 degrees
18	Centigrade.
۱9	DR. WALLIS: I think it has to have a
20	tolerance on that or accuracy or something. Because
21	if you can only measure it within five degrees C, then
22	you could well be up to the initiation level.
- 1	MD MIDDAY, What some of anogificity on
23	MR. MURRAY: That sort of specificity on
23	tolerance, how quickly can controls react, you know,

1 considered in the set point analysis in the license 2 application. 3 So, for example, if the applicant were using a certain type of temperature detector, for 4 5 example, which had an error bound of plus or minus 6 three degrees C., they would have to adjust their, if 7 you will, set point appropriately. 8 If they went with an RTD, a very nice, accurate one, that only allowed .1 degrees Centigrade 9 10 variation. That would have less of an effect upon the set point. 11 In addition, I just want to note 12 This is approximately five 13 about the temperature. 14 degrees Centigrade below the DOE safe initiation 15 limit, and somewhere around ten degrees Centigrade 16 below runaway reaction temperatures based on Savannah 17 And, again, that information is River site data. published. 18 19 Also, there are controls Okay. on 20 exposure of the organic materials, both TBP 21 diluent to, if you will, the temperatures 22 conditions which can lead to red oil, and these 23 controls from the staff analysis indicate that these would prevent participation of these other, if you 24 25 will, species, again, cyclical compounds being one

1 example, from participating in the red oil reactions. 2 Hence, that should not depress any of the 3 reaction initiation temperatures below 130 degrees 4 Centigrade. Most of these systems don't 5 DR. WALLIS: really have an initiation temperature. They have the 6 7 criterion for runaway, which has something to do with the rate at which things change with temperature. 8 MR. MURRAY: Yes, yes, but in the chemical 9 10 process industry parlance, for example, that 11 normally identified or rolled into the single 12 Alvina (phonetic) initiation of an 13 temperature; that if you are below that temperature, even though you could have, if you will, thermal 14 15 release or enthalpy from reactions, the system as a 16 whole can cool down and the temperature will not keep 17 increasing. 18 DR. WALLIS: We went into this whole thing 19 with spent fuel pools. There really isn't 20 initiation temperature for an overheating event. 21 There's the initiation condition in which temperature 22 plays some role, and I guess this is all going to be figured out properly somehow? 23 MR. MURRAY: The details would have to be 24 25 in the license application.

1	DR. WALLIS: Be careful about saying that
2	temperature is the only thing that matters.
3	MR. MURRAY: Well, that's why one of the
4	controls is keeping out these other organic materials,
5	because if they are present, they can depress that, if
6	you will, initiation temperature significantly, you
7	see.
8	Moving right along, temperature ramp
9	control. That essentially addresses the concern from,
10	if you will, runaway reaction enthalpy or heat of
11	reaction effects
12	DR. DENNING: Is the temperature ramp
13	control system a PSSC then?
14	MR. MURRAY: This is identified as a
15	safety function for the safety control system. It is
16	a PSSC, yes. Again, this is at a small system level
17	for the construction authorization, whereas for the
18	license application, there would be more at the
19	component level.
20	And let me just also mention there would
21	be an aqueous phase addition system which would
22	provide, if you will, water to evaporate and help cool
23	the system. All right? And this is controlled,
24	again, by that process safety control subsystem.
25	The staff also looked at the commitment

1 that the applicant has made to do further reaction 2 Part of it is related to the fundamental 3 understanding of the kinetic reactions, kinetic rate 4 equations involved in red oil phenomena. Part of it 5 is also related to understanding where this initiation 6 temperature might be when other species or impurities 7 are present. 8 All right, and the staff has looked at 9 this in a total integrated perspective, and we have 10 concluded that we have assurance that the proposed 11 safety strategy, the design bases, and PSSCs can 12 prevent the event. Have there been any red oil 13 DR. CROFF: 14 events at the French plant on which this is based? 15 MR. MURRAY: I'm not aware of 16 significant incidents or accidents being reported from 17 French facilities, and the applicant, as part of the 18 application or any subsequent information they have 19 submitted on the docket have not cited any French 20 experience. There surely must be 21 CHAIRMAN POWERS: 22 French interest because we had a young man come and 23 give us some discussion on research he was doing in 24 red oil from France, and it was

sophisticated research program he outlined for us. I

1	think the subcommittee wished him good luck and said,
2	"Fat chance," because I think, again, the fundamental
3	problem is you can do all of the laboratory research
4	in the world and it's very difficult to assure
5	yourself that what you have in the laboratory is what
6	was in the pot.
7	DR. WEINER: How uniform is the
8	temperature in these reaction vessels?
9	MR. MURRAY: That sort of detail we would
10	expect to come in the license application. Okay? For
11	what we've looked at for the construction
12	authorization phase, we've looked at this very top
13	level. The single temperature parameter would apply
14	to everything that's in the vessel.
15	Okay. In the real world, we know there
16	are such things a temperature gradients, and again, I
17	will hypothesize that as part of the license
18	application and the set point methodology, the
19	applicant will have to take that into effect for
20	defining its temperature and other set points.
21	DR. RANSOM: Have all of the DPOs or DPVs
22	that were raised been resolved?
23	MR. MURRAY: That discussion we'll have
24	starting at 4:30.
25	CHAIRMAN POWERS: You really shouldn't ask

1 the staff to speak to this issue. It has been 2 separated out --MR. MURRAY: 3 Yes. 4 CHAIRMAN POWERS: -- into a separate, and 5 we'll get to explore it a little bit. MR. MURRAY: 6 Yes. 7 CHAIRMAN POWERS: Thank you very much. That was nice. 8 What I would like to do is take about a 15 9 10 minute break. We are running about a half an hour 11 behind, which is an inevitable feature of subcommittee 12 meetings, and I'll ask that everybody have forbearance for us on this. 13 This is the only time the members will get 14 15 a chance to explore these things in detail. When you come to a full committee meeting, we're constrained by 16 17 the time schedule much more rigorously than I'm going 18 to constrain us here. But you may want to inform 19 subsequent speakers that we're running a little bit 20 behind. I'm not going to make any effort to catch up on it, save to ask the members to focus on the issue 21 22 at hand, but if you need to go a little broader to understand and put it in context, feel free because 23 otherwise you'll never get your questions answered, 24

and then you will bring them to the full committee.

1	DR. BONACA: The positive thing, the
2	philosophy that we're addressing these other issues,
3	so hopefully we
4	CHAIRMAN POWERS: Yeah, I think this first
5	one on red oil, first of all, it is the most curious
6	and interesting phenomenon, but the philosophical
7	approach needs to be understood, and that might be a
8	good understanding here. It's very important here for
9	us to understand the philosophy. So don't be afraid
10	to wax philosophical.
11	And so let's resume at 11 o'clock.
12	(Whereupon, the foregoing matter went off
13	the record at 10:48 a.m. and went back on
14	the record at 11:05 a.m.)
15	CHAIRMAN POWERS: Let's reconvene.
16	Bill, get ready to teach us about HAN.
17	I take it in the SER when it refers to
18	hydroxy nitrate it really means hydroxylamine nitrate.
19	MR. TROSKOSKI: Yes, sir, it does.
20	Absolutely, it means what you would have right here.
21	CHAIRMAN POWERS: And you might want to go
22	through and check it. It's different nomenclature in
23	different places.
24	MR. TROSKOSKI: Sure. HAN is
25	hydroxylamine nitrate. There's an excellent DOE
	NEAL R. GROSS

technical report out on the subject. It's EH-0555.

I believe it's still on the Internet, and it's a good introduction.

Basically, we're in the aqueous polishing system, and it's a Purex system that's been around for quite a few years, almost as long as some of us. Right now what has happened in the process is you dissolve the plutonium material with the impurities in nitric acid. You contacted it with the organic phase, which has the tributyl phosphate. The tributyl phosphate grabs both the uranium and the plutonium, then you're going to separate the organic phaseout, and you're going to hit it with another dilute nitric acid solution containing HAN hydrazine, and the purpose of the HAN and hydrazine is basically to extract the plutonium by changing its valence from four to a three where it's soluble again in the aqueous phase.

So the plutonium now leaves the organic. It goes back to the acid phase, and then you can go and further concentrate it. You've now left basically most of the impurities behind, and you've got the high priority product that you're after.

A similar process is also used to recover unstripped plutonium in the last stage of the

NEAL R. GROSS

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

plutonium barrier prior to sending the solvent back to 1 2 the regeneration process. Hydrazine has a couple of functions. 3 4 stabilizes the HAN and it also reduces some plutonium 5 while four to three. One of its functions is that it 6 reacts very quickly with nitrous acid, which is the 7 prime intermediate that we're concerned about with 8 these types of reactions. 9 Within the process itself, you can expect 10 to see HAN in both the purification systems and the 11 solvent recovery systems. HAN is not a benign chemical. It's a very 12 reactive chemical. It almost could be classified as 13 14 an explosive under the right conditions. It can 15 undergo very rapid autocatalytic decomposition, much 16 more so than even red oil. 17 Red oil you can kind of control it by controlling the off-gas because about 90 percent of 18 19 the energy release in a red oil reaction comes from 20 the chemical intermediates that are put off. But HAN is just much quicker by orders of magnitude. 21 So pressure control is not a viable option here. 22 23 There are large quantities of 24 involved, noncondensables with this type of reaction. 25 Consequently pressure excursions for any kind of

closed vessel or pipe are of a concern, and we do have
a number of incidents that have happened both at
Hanford and Savannah River site that are detailed in
the DOE report where these have ruptured various
process vessels.

The quantities of HAN that they intend to

The quantities of HAN that they intend to use at the MOX facility are comparable with what they have used before at both Savannah River and at Hanford.

The applicant has identified this as a high consequence event, as well they should. They've selected a preventive strategy to render this event highly unlikely.

The original application had some of the DOE recommendations that you've had in the 0555 report, but not all of them. During subsequent meetings with the staff, subsequent questioning, they have revised their approach until they have provided multiple parameters and controls. It has most, but not all of the recommendations, and they basically have tailor suited it to their process.

Now, the safety strategy that they have are based on two different cases. In one case, you're going to have vessels where you have HAN and hydrazine, but not MOX addition, and what you want to

1 do in a case like that is to avoid the decomposition 2 reaction together. 3 In Case 2, they are going to want to destroy HAN and hydrazine before further processing. 4 5 So that's why they have the NOX addition. 6 will react with it, and you'll get nitrogen, oxygen, 7 water and other gases there with very additional liquid waste that you'd have to process. 8 9 So they induce the composition to avoid 10 recycling accumulation of the HAN in other parts of the process where you would not want it. 11 Now, for Case 1, where they want to avoid 12 reaction altogether, 13 the decomposition they've 14 developed a kinetic model based upon multiple reaction 15 mechanisms. The model will involve five partial 16 differential equations that are coupled, that have to 17 be solved simultaneously. 18 They used kinetic parameters from the 19 literature from a variety of sources that have been 20 printed throughout the years. They solved the model 21 using a commercial software program. It provided 22 predicted regions of stability and safe design base limits. 23 The applicant committed to confirmatory 24 25 testing to substantiate the model, and a lot of the

1	safety bases and safety limits are concentrations and
2	temperatures that are in good agreement, in general,
3	with the instability index that DOE has developed
4	Yes.
5	MR. SIEBER: Yes, before you move on, what
6	are the parameters of importance that would lead to
7	MR. TROSKOSKI: I'll get to that.
8	MR. SIEBER: stability?
9	MR. TROSKOSKI: That would lead to
10	stability?
11	MR. SIEBER: Yes.
12	MR. TROSKOSKI: Yes. I'll get that in
13	just a second.
ŀ	
14	MR. SIEBER: All right.
14 15	MR. SIEBER: All right. MR. TROSKOSKI: Excellent. For the
15	MR. TROSKOSKI: Excellent. For the
15 16	MR. TROSKOSKI: Excellent. For the control case, what they want to do is maintain
15 16 17	MR. TROSKOSKI: Excellent. For the control case, what they want to do is maintain temperature below 50 degrees C. Temperature, of
15 16 17 18	MR. TROSKOSKI: Excellent. For the control case, what they want to do is maintain temperature below 50 degrees C. Temperature, of course, is a big input for any kind of reactor
15 16 17 18	MR. TROSKOSKI: Excellent. For the control case, what they want to do is maintain temperature below 50 degrees C. Temperature, of course, is a big input for any kind of reactor reaction kinetics.
15 16 17 18 19	MR. TROSKOSKI: Excellent. For the control case, what they want to do is maintain temperature below 50 degrees C. Temperature, of course, is a big input for any kind of reactor reaction kinetics. MR. SIEBER: Okay.
15 16 17 18 19 20 21	MR. TROSKOSKI: Excellent. For the control case, what they want to do is maintain temperature below 50 degrees C. Temperature, of course, is a big input for any kind of reactor reaction kinetics. MR. SIEBER: Okay. MR. TROSKOSKI: You want to maintain
15 16 17 18 19 20 21 22	MR. TROSKOSKI: Excellent. For the control case, what they want to do is maintain temperature below 50 degrees C. Temperature, of course, is a big input for any kind of reactor reaction kinetics. MR. SIEBER: Okay. MR. TROSKOSKI: You want to maintain concentrations of key parameters at certain levels.

1 You want to have HAN at a certain amount, 2 and then the last one I think we can clarify a little bit more. Limit the time in nitric acid and radiation 3 4 fields. What that really means is when you mix HAN 5 with nitric acid, there have been events before where over a period of time a vessel has been left for 6 7 months or years, and the nitric acid has evaporated off. So it has concentrated the HAN to a very 8 9 critical level where you have the reaction that 10 occurred. The other thing for radiation is since 11 12 going to have a HAN-hydrazine mixture, hydrazine is a nitrous acid scavenger which would kill 13 the process, but hydrazine is also susceptible to 14 15 radiolysis from contact with plutonium. So you need to limit the time that it is in contact with that so 16 17 that you don't decrease the concentration of the 18 hydrazine. 19 MR. SIEBER: Is it an oxygen scavenger, 20 too? MR. TROSKOSKI: Hydrazine? 21 22 MR. SIEBER: Yeah. PARTICIPANTS: Yes. 23 MR. TROSKOSKI: Yes? 24 25 DR. FORD: You showed some very specific

1 limits, design base data. What is the extent of the data upon which those are based? 2 It comes from various 3 MR. TROSKOSKI: literature sources. 4 5 DR. FORD: So you've looked at that database and assured yourself that having those 50 6 7 degrees C. maximum, for instance, is adequate safety 8 margin? MR. TROSKOSKI: Well, I believe it's the 9 10 next slide. Well, did review the literature we 11 equations, and we developed an exercise to similar 12 model, and by that I mean there are differential 13 14 equations in the literature input. We used a I think Polymath 5.1, 15 different commercial program. my colleagues did, and they ran a series of runs on 16 that to find the regions of stability, instability, 17 and the margin for the design basis. 18 And as a result of that, what we've found 19 is that there is substantial margin in each of the key 20 You'll notice on the bottom the 21 parameters there. 22 HN3. We're assuming a design basis of zero molar concentration. That's because it's also a nitrous 23 scavenger, and that's a conservative assumption. 24 25 They're ignoring that. It adds extra margin.

1	But there is a substantial margin in each
2	of the parameters.
3	DR. WALLIS: Of course, 25 percent is
4	completely inappropriate in the first line. You could
5	have used Kelvin or something.
6	DR. WEINER: Yes.
7	MR. TROSKOSKI: Yes, yes. Guilty as
8	charged, sir.
9	DR. WEINER: Absolutely.
10	DR. FORD: So just to follow up a wee bit
11	on that
12	MR. TROSKOSKI: Sure.
13	DR. FORD: sine it does relate to the
14	design basis criteria, these staple values, that's a
15	mean, is it, of the database? A staple value of 53,
16	that's not a mean because it's a less than sign.
17	I'm trying to get just what is the real
18	margin.
19	CHAIRMAN POWERS: My understanding is
20	you're talking about a mathematical model.
21	MR. TROSKOSKI: Yes, a mathematical model.
22	We used
23	DR. FORD: It's a mathematical model based
24	on a very scattered database presumably.
25	MR. TROSKOSKI: Yes. Yes, it is.

1	DR. FORD: Okay, and so if you take the
2	database
3	MR. TROSKOSKI: How scattered is it?
4	DR. FORD: how scattered is it around
5	this mathematical model?
6	MR. BROWN: I did some of the computer
7	runs for this. Being a mathematical model, the
8	results produced by the model are very have no
9	uncertainty associated with them. It's just very
10	distinct values.
11	So in other words, at 64 degrees the
12	reactions were indicated as unstable. But at 63 it
13	was stable.
14	DR. FORD: I recognize that, but were the
15	data points, you know, below 63 in which it was
16	unstable?
17	MR. TROSKOSKI: Were the data points below
18	63?
19	DR. FORD: Were there data points? I
20	recognize that these are a model.
21	MR. MURRAY: Let me try and help and
22	explain this. Okay? If you go and look at the
23	available experimental data, that is, in the
24	literature, okay, there is a significant quantity of
25	information. Okay? Many experiments, many data
	1

points.

erudite work.

One of the concerns that the staff had with all of that data was that the testing tended just to look at one or two of the phenomena in a multiphenomena model, if you will, real system. All right, and we found from looking at it and running, if you will, our own simulation that, yeah, we were generally in agreement, I'll use the term "alignment" if you will, with both the results of the different literature articles, something like 25 major research articles, okay, things like industrial engineering chemistry, transcripts of the Faraday Society and all that sort of stuff, you know, a lot of very good,

All right, but there isn't one single source which looked, if you will, at the complete phenomena.

All right. Now, we found that the model predictions, they were generally in agreement if we look at some of the specific test data that was there. We did not explicitly look at uncertainty. One of the reasons has to do with the fact that the applicant has committed to confirmatory testing to actually generate uncertainties.

When they do that testing and we on the

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1	staff review that, then we'll have a much better idea
2	of the uncertainties around these parameters and what
3	needs to be done to, if you will, develop set points.
4	Okay. Either set points accommodate the
5	uncertainties both in the original data and also in
6	the monitoring
7	DR. FORD: I understand what you did.
8	MR. MURRAY: Yes.
9	DR. FORD: And it's done in many other
10	fields also, but I still don't have a feeling as to if
11	you had presumably this model would give you an
12	algorithm of the unstable temperature as a function of
13	all the other variables. You could
14	MR. MURRAY: You can numerically generate
15	that, yes.
16	DR. FORD: So if you could just give me a
17	feeling. If you then plotted, predicated instability
18	temperature versus observed data, what would the
19	correlation factor be?
20	MR. MURRAY: I don't think we have that
21	information at this time. What we have found is that
22	the results in the model at the simulations, if you
23	will, agree with some specific test points, for
24	example, the test data that is in the EH report.
25	But in terms of actual correlation

1 factors, is it always 20 percent below, you know, does 2 it vary with other parameters, you know, five percent percent 3 at low nitric, 20 at high nitric concentrations? We do not have that information. 4 But we've been told that the 5 DR. FORD: 6 passing grade, if you like, for this is to have 7 regional assurance of safety. 8 Right. MR. MURRAY: 9 DR. FORD: So can we be reasonably assured that there will not be a data point which shows 10 instability below 63 degrees Centigrade if you play 11 around with your other parameters, which are all 12 within the conceivable operating descriptor. 13 14 MR. MURRAY: Again, with the available information that we have, both test data and running 15 the mathematical model, we have reasonably assured --16 17 it's not proved; it's not demonstrated -- but we have 18 reasonable assurance that there won't be, if you will, a temperature below 63 degrees C. where it can become 19 20 unstable. The proposed strategy appears to have the 21 22 ability to render the event highly unlikely, and again, that's the criteria for construction. 23 MR. TROSKOSKI: Be careful of just picking 24 25 the temperature out alone because it's an interaction

between the concentration of the other chemicals, also the ratio between some of the other chemicals.

If one looks to the DOE instability index plot that they've got in 0555, they plot temperature verse the instability index, and that's basically a function, a logarithmic function of your nitric acid concentration and your nitric acid to your HAN ratio, and then also it takes into effect an R as a catalyst of concentration there, and it actually comes up with a slope, and they have test data that they have plotted up above the slope, and there's a good scatter there as you can see.

And when we compared the values that we came up with here with those, we found in general pretty good agreement. We didn't find anything that stuck out and raised a flag to us.

DR. FORD: Do I understand that that lefthand column there, design basis values, those are now immutable? You can't change them?

MR. TROSKOSKI: Those are what the applicant has proposed to us as a result of the testing. The two-part licensing process is a bit confusing. I understand that, but it's fully recognized and expected once they do the testing, once they do an ISA, they may end up having to go back and

1 propose changes to existing PSSCs. They may have to 2 propose new ones, and again, those would have to be 3 reviewed and approved by the staff. 4 But we fully expect as a result of the 5 testing and doing a unit level ISA on a component-by-6 component basis where you ask what happens if you have 7 a temperature excursion, a pressure excursion or you have extra volume, whatever, there may be additional 8 safety issues that will shake out then during that 9 10 process. 11 And, again, a lot of this is going to be 12 very unit design specific, and a lot of that essential design information is just not available at this time 13 for the staff to review. 14 15 DR. CROFF: What is HN3? MR. MURRAY: Hydrazoic acid. 16 MR. TROSKOSKI: It's one of the byproducts 17 18 of the hydrazine reactions. 19 MR. MURRAY: I'm sorry. Yes. You also have to be TROSKOSKI: 20 MR. 21 careful of of the constituents that some are 22 byproducts that can do other things to other parts of It's a complicated process. 23 the process. MR. SIEBER: So the acid phase is building 24 25 up with time.

1	MR. MURRAY: Are you talking about the
2	hydrazoic acid?
3	MR. SIEBER: Yes.
4	MR. MURRAY: If there weren't controls to
5	address it, the hydrazoic acid would accumulate in the
6	system.
7	MR. SIEBER: That's right. Okay.
8	MR. MURRAY: There's a separate series of
9	controls which have been proposed by the applicant
10	which the staff has reviewed, and those proposed
11	controls appear to have the ability to prevent
12	accumulation of hydrazoic acid.
13	MR. TROSKOSKI: There are other limits
14	placed on the hydrazoic acid to keep it out of an
15	explosive concentration from forming in a gas phase.
16	MR. SIEBER: Okay.
17	CHAIRMAN POWERS: Isn't it true that
18	everyone that drives a car in America is exposed to
19	the sodium salt?
20	MR. MURRAY: Hopefully, they won't have
21	many crashes, but, yes, it has been used as the gas
22	generator for airbags, yes.
23	DR. DENNING: I don't understand a zero
24	value for the design basis of HN3. Is that below
25	detectable limits or what does that mean in a design

basis?

MR. TROSKOSKI: Actually there's going to be some in there, but we used zero in the calculations because it would actually act as a nitrous acid scavenger. So it would tend to mute any hand reaction or put it further down.

So by just having the design basis of zero here in the assumption, it no longer has a positive contribution to safety.

Now, for Case 2 we're going to actually introduce NOX in a controlled manner to react with and basically destroy any remnant HAN in hydrazine.

We've got a number of controls. We've got with the off-gas system and then we have chemical safety controls, and the parameters are basically listed in the CAR table for codes. They address pressure, volume, temperature, et cetera, and generally range from ten to 20 percent.

The staff concludes that with Case 1 where there is no NOX, the model and literature do predict stability. The applicant has a commitment to finish conducting a series of confirmatory tests which we will be reviewing during the license application phase, and we believe that that's acceptable for the construction phase.

1	With Case 2, we believe that the codes and
2	standards are consistent with industry good practices.
3	The code methodology leads to design base values and
4	ranges, and again, we believe that this is also
5	acceptable for the construction phase.
6	And that would conclude my formal
7	presentation on this. Are there any additional
8	questions?
9	CHAIRMAN POWERS: That was great. That
10	was fine.
11	Are there any questions on this?
12	(No response.)
13	CHAIRMAN POWERS: Let's move to the
14	titanium electrolyzer.
15	MR. TROSKOSKI: I'll turn it over to my
16	colleague, Alex.
17	MR. MURRAY: Thanks, Bill.
18	Let us move on to the next subject then
19	oh, he found it. Hey, I'm just an engineer. These
20	things are too complicated.
21	Let us move on to the electrolyzer then.
22	The open issues identified as AP-03, and it involves
23	the potential for titanium reactions or fires in the
24	electrolyzer area.
25	Now, just by way of introduction, the

2

1

4

5

7

8

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

purification process, the Purex process requires that you work or use dissolved species. The feed material to this facility is plutonium dioxide. So it first has to be dissolved.

Plutonium dioxide, depending how it's being produced or what the grain size is and so forth, difficult to dissolve very under situations. To address this from а process perspective, the applicant has selected electrolytic method based upon the Department Energy and Pacific Northwest Lab program results and also based upon its use in the Cogema La Hague facility in France.

Now, it's important to remember that electrolysis doesn't dissolve the plutonium dioxide itself. The electrolysis just produces a very reactor species, a silver plus two ion, and it is that silver plus two ion which actually affects the dissolution, and I've given some nominal conditions there.

Because silver tow is a very aggressive species, okay, it's a very aggressive oxidant, it can be very corrosive. And the applicant has proposed the use of titanium because of its corrosion resistance to Silver II species.

And just to point out where this can

The

Its

occur, essentially there are two units, if you will, 1 operational areas, at the proposed facility which 2 contain electrolytic dissolvers. This is dissolution for the standard 4 plutonium dioxide, and this unit here can dissolve the 5 alternate feedstock materials, as well as the standard 6 plutonium dioxide. There are a total right now of 7 three electrolyzers in these two areas. 8 Now, let's get to the safety issue. 9 staff has found that, well, titanium is a great 10 material, but it also can be a reactive metal. 11 use basically depends upon the conditions that it is 12 exposed to and the presence of a very stable corrosion 13

3

14

15

16

17

18

19

20

21

22

23

24

25

normal conditions in this Under electrolyzer, however, we have some very large electrical currents. We have the presence of oxygen in various forms, and our concern, the staff's concern, has been that an electrical fault, in effect, a shorting between the electrodes could somehow initiate and involve titanium reactions.

We also, as part of our review, looked at fire protection measures, planned determined they would most likely not be effective on titanium fires, and so we also noted that a titanium

resisting film.

type event will be very difficult to predict and also to mitigate.

The applicant has identified this as a high consequence event and has selected a preventative strategy. In the original application, they had not identified any controls for this potential event. In the revised application, I should say, which involves both some other information, they've also put on the docket, the revised approach involves both passive and active engineered controls.

Now, what is an electrolyzer? In the open literature there are schematics of various designs of electrolyzers. Just to give you some idea of the concept, I found one related to the Pacific Northwest Lab experiments. Now, this is, if you will, an experimental model. It's only about a liter size, maybe four inches around and 12 inches high, but it does have similarities to what the applicant will be proposing for the actual electrolyzers.

Key parts. It is cylindrical. There's a center cathode compartment in here, right there. Okay? There's also a porous thread material which surrounds this compartment. All right? An then there's an annular anode outside of that, and then you have multiple electrical connections.

1	Here we go. There's the cathode
2	connection. There's the anode connection. Various
3	connector for gases and what have you. Insulating
4	materials between the electrodes. I can't make it out
5	too well here. Some means for annotation, cooling
6	jacket in this example around it, and the key part is
7	the Silver II reactive reagent is generated in this
8	outer jacket area here.
9	DR. WALLIS: Where does the silver come
10	from?
11	MR. MURRAY: Silver nitrate, which is
12	silver plus one, is dissolved in the nitric acid to
13	begin with, and when you run it through the
14	electrolyzer it is converted to Silver II
15	DR. FORD: I'm sorry. Tell me again why
16	is silver important.
17	MR. MURRAY: Silver as the plus II species
18	is a very aggressive species which has been found to
19	assist the dissolution of just about any type of
20	plutonium dioxide in nitric acid.
21	CHAIRMAN POWERS: Alex, they need to
22	understand that it's the plus VI state that's soluble.
23	Plus IV has a limited
24	MR. MURRAY: Yes.
25	CHAIRMAN POWERS: it's not insoluble,
ŀ	

1	but less soluble. So you've got to oxidize the stuff.
2	MR. MURRAY: Right.
3	DR. FORD: So if there were chlorides
4	impurity, the thing would go crazy.
5	MR. MURRAY: In the dechlorination unit,
6	the electrolyzer is initially controlled in a
7	different operating manner to remove the chloride
8	species, yes. That's correct.
9	DR. FORD: And presumably there's strict
10	composition controls on how much chloride you have
11	there.
12	MR. MURRAY: Yes, and those limits are
13	down as a design basis in the revised FSER.
14	DR. CROFF: How much experience have they
15	had with this dechlorinator thing? Has this actually
16	been operated on any commercial or substantial scale
17	or is this new stuff?
18	MR. MURRAY: For the dechlorinators, it is
19	the staff's understanding that they have some limited
20	experimental data from France. We have not seen that
21	data. We've looked more closely at the safety issues
22	involved. In the case of a chloride containing
23	plutonium dioxide, that is the evolution of chlorine.
24	How is it addressed?
25	Okay, and as noted in the FSER, the

1	applicant has a safety strategy to address that.
2	MR. ROSEN: Now, this thing is made of
3	glass, right?
4	MR. MURRAY: This is just an example of a
5	laboratory electrolyzer, a small one which was used
6	for testing. The proposed electrolyzer which has not
7	been designed yet I want to emphasize that from
8	the information which has been given to the staff and
9	which is mentioned in the draft FSER, it will be
10	cylindrical. There will be an inner cathode
11	compartment. There will be an outer anode
12	compartment. There'll be a porous material or frit
13	(phonetic) here.
14	The applicant has mentioned that for their
15	proposed electrolyzer this will most likely be silicon
16	nitride. They can have different electrode materials
17	and so forth.
18	MR. ROSEN: You mean the body of it will
19	be silicon nitride to replace the Pyrex?
20	MR. MURRAY: This right here.
21	MR. ROSEN: Oh, the frit. What's the
22	outer?
23	MR. MURRAY: The outer container here in
24	the applicant's proposal, that is titanium.
25	MR. ROSEN: So there's a titanium cathode,
	NEAL P. CPOSS

1	anode, and a titanium body in the applicant
2	MR. MURRAY: There's a titanium shell.
3	MR. ROSEN: Okay.
4	MR. MURRAY: The electrode materials, I
5	want to say they're platinum and tantalum, but don't
6	quote me on that.
7	MR. ROSEN: So we're worried only about
8	the shell here in the applicant's proposal, although
9	here
10	MR. SIEBER: Because it's aggressive.
11	MR. MURRAY: Yes, in this example, this is
12	purely an experimental vessel which was made out of
13	Pyrex.
14	MR. ROSEN: And the anode and cathode in
15	here were titanium.
16	MR. MURRAY: They were coated titanium, if
17	my memory is correct.
18	MR. ROSEN: And the applicant's machine is
19	going to have a titanium shell with tantalum and
20	perhaps something else.
21	MR. MURRAY: Yes.
22	MR. ROSEN: For the platinum cathodes and
23	anodes.
24	MR. MURRAY: Yes, yes.
25	MR. ROSEN: Okay.
	MEAL D. CDOSS

1	MR. SIEBER: Well, this is DOE's
2	recommended way of generating a plutonium powder in
3	the calcining process. So this must have been used
4	someplace.
5	MR. MURRAY: This was part of a large
6	experimental program which Pacific Northwest Lab had
7	going at the time, and it was
8	MR. SIEBER: At Hanford.
9	MR. MURRAY: At Hanford, and it was to
10	come up with a method for uniformly dissolving
11	plutonium dioxide.
12	MR. SIEBER: And that was in the 1970s?
13	MR. MURRAY: To about 1990.
14	MR. SIEBER: Okay.
15	MR. MURRAY: Okay?
16	MR. SIEBER: I'm familiar with that.
17	MR. MURRAY: Okay.
18	DR. FORD: Presumably when you were going
19	through the safety aspects of this you must have
20	looked at all of the variables which would give rise
21	to disintegration of the titanium anode.
22	MR. MURRAY: Yes. There is information
23	from the DOE PNL work. Some of that information is in
24	the public arena, and they do give parameters,
25	recommended parameters for controls.

1	DR. FORD: And one of the things that
2	we're looking at quite apart from the plutonium
3	dissolution was the integrity of the titanium anode as
4	a function of potential chloride concentration, salt,
5	and nitric acid concentration?
6	I keep thinking that chloride and nitric
7	acid is not a very good mixture, even for titanium.
8	MR. MURRAY: No, no.
9	CHAIRMAN POWERS: It's a wonderful
10	mixture. It's called aqua regia.
11	MR. MURRAY: That's right, royal water.
12	CHAIRMAN POWERS: It's a tremendous salt.
13	MR. SIEBER: It's a party mixture.
14	MR. MURRAY: That's right.
15	DR. FORD: So my point is that when you
16	come out with this reasonable assurance aspect, you
17	satisfied yourself that it wasn't within the
18	operational parameters, chloride concentrations,
19	polarity of nitric acid, et cetera, et cetera, that
20	you weren't going to have a problem with the titanium
21	anode dissolving.
22	CHAIRMAN POWERS: There is no titanium
23	anode.
24	MR. MURRAY: This is they're talking about
25	the shell. Okay? In this example, again, I just

1	wanted to mention look at these key attributes in
2	this experimental one. They had a titanium anode or
3	cathode excuse me in the center. Okay?
4	All right. I don't think we have any
5	specifics on what the applicant is proposing, but I
6	seem to recall that it was tantalum and platinum which
7	was presented at one of the open meetings.
8	And, again, just using this just as an
9	example to point out these key parameters.
10	DR. FORD: Again, not to jump into the
11	ISA, is it?
12	MR. MURRAY: ISA.
13	DR. FORD: ISA time period. At this point
14	we recognize it's a problem, and we're going to put
15	off control of that problem to the ISA stage; is that
16	right?
17	MR. MURRAY: No. No, we're looking for a
18	control strategy here. The applicant has proposed a
19	control strategy.
20	DR. FORD: That control strategy will
21	involve
22	MR. MURRAY: That we'll be getting to
23	shortly.
24	DR. FORD: chloride.
25	MR. MURRAY: Okay. The control strategy
	NEAL R. GROSS

1	is to address the concern about a potential titanium
2	reaction incidence/fire. All right? And how is that
3	addressed and what is our review of it? Okay?
4	Now, the applicant has proposed controls
5	for the three situations which I pointed out here:
6	maintenance, a seismic event and normal operations
7	when you have an electrical fault.
8	Just to quickly summarize the controls
9	during maintenance, these are primarily administrative
10	controls. Okay? One of the key ones is you turn off
11	the electricity to the electrolyzer.
12	MR. ROSEN: Good start.
13	MR. MURRAY: And that is an excellent
14	start, right.
15	(Laughter.)
16	MR. MURRAY: Stranger things have happened
17	in life.
18	MR. ROSEN: This is a good thing to do
19	when you're shutting a process down.
20	MR. MURRAY: Yes, absolutely.
21	MR. ROSEN: Fairly elementary.
22	MR. MURRAY: Yes. Now, I just want to let
23	you know the staff has looked at this and, first off,
24	we noted from our review of the literature and this
25	is cited in the draft FSER that administrative

controls are the general good practice, the RAGAGEP, 1 2 again, if you will -- reasonably and generally accepted good engineering practice for addressing, if 3 you will, a shutdown situation. All right? 4 5 There are parameters, DOE standards, 6 various NFPA and other industry guidance which bring 7 these type of administrative controls out in more 8 detail. That type of detail we would expect to see in the license application. 9 10 And we would conclude that the proposed controls for maintenance periods are acceptable for 11 12 the construction stage. Well, now you see, you put 13 MR. ROSEN: 14 this very vague "other controls." Is that because you 15 don't want me to ask? When anybody does that, they always get a 16 "Other requirements" and procedures, can 17 question. you give me a feeling for what those might be? 18 Are 19 they merge requirements? MR. MURRAY: In the case of, if you will, 20 21 controls during shutdown, there might be additional 22 fire protection requirements. Okay? There might be limitations on hot work, covering by putting some 23 clean-up requirement for the electrolyzer itself. 24 25 MR. ROSEN: Do they have to get inside

1	this thing during shutdowns to maintain it?
2	MR. MURRAY: It is in a large glove box.
3	Again, we do not have the details of maintenance.
4	MR. ROSEN: It's in a large glove box.
5	You've got this electrolyzer. Now do you have to open
6	the electrolyzer to get into the inside of it to
7	maintain anything in it?
8	MR. MURRAY: The staff believes that there
9	are times when, yes, that might have to be done. If
10	nothing else, just for inspections of
11	CHAIRMAN POWERS: Cathodes and anodes have
12	to be replaced all the time.
13	MR. MURRAY: Exactly.
14	CHAIRMAN POWERS: Yeah.
15	MR. ROSEN: Okay. Now we're getting to
16	the meat of it.
17	MR. MURRAY: Okay?
18	DR. FORD: I'm sorry. Could you explain
19	what administrative controls in this RAGAGEP
20	RAGAGEP
21	MR. MURRAY: Reasonably and generally
22	accepted good engineering practice.
23	MR. ROSEN: We know that most of the fires
24	have started during shutdown, and now we've got an
25	electrolyzer that we know has cathodes and anodes, and
į	

1	you have to replace them. Getting close to this. How
2	do you do that?
3	MR. MURRAY: Huh?
4	MR. ROSEN: How do you do that? It's in
5	a glovebox. So you're in an inerted environment, a
6	nitrogen environment, to begin with.
7	MR. MURRAY: This glovebox I don't think
8	is inerted.
9	MR. ROSEN: Not inerted?
10	MR. MURRAY: Not inerted. It's not a
11	CHAIRMAN POWERS: In fact, I think you
12	would not want to inert the outer shell of a titanium
13	vessel.
14	MR. MURRAY: Right.
15	CHAIRMAN POWERS: And so I don't see why
16	you would inert it.
17	MR. MURRAY: Right.
18	MR. ROSEN: Well, trying to prevent a fire
19	actually, but it may not be
20	DR. FORD: I would try to use the <u>Wall</u>
21	Street Journal headlines criterion.
22	MR. MURRAY: Okay.
23	DR. FORD: Where you can see an action
24	occurs, and they say, "Hey, they used this RAGAGEP,"
25	and I'm just trying to delve down to how detailed is
- 1	1

WASHINGTON, D.C. 20005-3701

1	this. Could it withstand the <u>Wall Street Journal</u>
2	headlines?
3	MR. MURRAY: At the license application
4	stage it must.
5	CHAIRMAN POWERS: Alex, we've got to
6	understand. What particular part of the Code of
7	Federal Regulations refers to a <u>Wall Street Journal</u>
8	headlines?
9	DR. FORD: Well, I'm just
10	(Laughter.)
11	CHAIRMAN POWERS: I mean, I just don't
12	recall that one, Peter.
13	DR. FORD: It's not.
14	CHAIRMAN POWERS: In fact, I think it
15	would be Presidential Directive 101.
16	MR. MURRAY: Okay, and we
17	DR. FORD: Because reasonably and
18	generally accepted to me means it's something that is
19	mundane, like you sweep the floor or you something
20	that is mundane.
21	MR. MURRAY: Well, no.
22	DR. FORD: Whereas this is a very highly
23	complicated
24	MR. MURRAY: Reasonably and generally
25	accepted good engineering practice can be quite
	NEAL R. GROSS

1	complex. Okay? For example, DOE has a standard on
2	handling reactive metals, and FPA has a standard for
3	handling titanium. Okay? These are the things you
4	are supposed to do, you know. You're not supposed to
5	have it energized. You're not supposed to, if you're
6	doing hot work
7	DR. FORD: So it's far more sophisticated
8	than
9	MR. MURRAY: Right, right.
10	DR. FORD: Okay.
11	MR. MURRAY: And we expect that at the
12	license application stage these types of things will
13	be written into procedures, including addressing
14	clean-out, addressing replacement of electrodes, that
15	type of thing, inspection requirements for corrosion
16	concerns, what have you.
17	DR. DENNING: As a general practice, you'd
18	like to minimize administrative controls, right?
19	MR. MURRAY: Yes.
20	DR. DENNING: I mean, that is and you
21	decided here that it is acceptable, however, to use
22	administrative controls here.
23	MR. MURRAY: This is only when it is shut
24	down. Okay? And it is our understanding from
25	discussions with the applicant, plus the information

they have provided on the docket, that it will be shut 1 2 down a relatively small percentage of the time. 3 DR. DENNING: But this is something that 4 you could automate. I mean, it isn't something that 5 you -- and maybe I'm wrong. Maybe there really is a 6 penalty here go into things that would to 7 automatically terminate the power there when you did something, opened the door, went into a certain mode. 8 9 MR. MURRAY: Right. 10 DR. DENNING: Is there a reason why? I mean, did you look into that to say why not do 11 12 something that's automatic rather than accepting 13 administrative control? MR. MURRAY: We did consider that, and we 14 15 anticipate that there may be some sort of do maintenance related interlock at a later time. such 16 17 information would be in the license application. 18 you look at the standard codes, 19 particularly the DOE and the NFPA code on titanium --20 I keep wanting to say NFPA 481, but I don't quote me 21 on that -- if you look at those, they are primarily 22 administrative. Okay? I don't recall specific interlocks mentioned. 23 However, that is an option that the 24 25 applicant has, and as we get more into review of the

detailed designs in the ISA at the license application 1 stage, we will proceed from there. 2 But you don't take the DR. DENNING: 3 position and then challenge the applicant and say why 4 -- or am I pressing this too much? Is this just not 5 an important enough administrative control? 6 7 But I would think, in general, you would say, "I don't accept administrative controls. Explain 8 to me why this has to be an administrative control." 9 Are you taking that position or just 10 because it's accepted in other areas as good practice 11 to allow it to be administrative control you would 12 allow it? 13 MR. MURRAY: At the present time we have 14 15 asked the question of the applicant: what controls would you apply during maintenance activities? Okay? 16 And we have expressed our preference for, 17 if you will, engineering controls over administrative 18 That is a preference, not a requirement. 19 controls. The applicant came back with a safety 20 controls. administrative 21 strategy based upon 22 Evaluation at this time for construction authorization is that what the applicant has proposed 23 is reasonable, consistent with good practice, and has 24 the ability to prevent the event, which is what we 25

1	need at this time.
2	Now, the question which you're asking, if
3	you were to challenge the applicant, are there
4	specific interlock type controls that should be part
5	of that administrative procedure, if you will, or the
6	control strategy for maintenance? We would have to
7	look at the license application. Okay?
8	MR. ROSEN: I think we have expressed our
9	interest in controls during maintenance, and
10	especially in the electrolyzer, and would expect to
11	see quite a bit of detail in the ISA.
12	MR. MURRAY: Yes, yes, yes. That's
13	correct.
14	MR. ROSEN: And in your review of it.
15	MR. MURRAY: Yes.
16	MR. ROSEN: Including such things as
17	sequence, sequences of operations during maintenance.
18	MR. MURRAY: Yes, yes.
19	DR. CROFF: I'd like to generalize my
20	I had previously asked about experience with the
21	dechlorinator.
22	MR. MURRAY: Yes.
23	DR. CROFF: Is there any experience with
24	the standard electrolyzer, the one that doesn't
25	dechlorinate?

1	MR. MURRAY: There is at the Cogema La
2	Hague launch, yes.
3	DR. CROFF: Okay. So they have used one
4	of these for
5	MR. MURRAY: yes.
6	DR. CROFF: Okay.
7	MR. MURRAY: It is used. I think it's in
8	a scrap recycle part of the plant.
9	DR. CROFF: Okay, and any feedback on
10	their experience? Any bad experiences?
11	MR. MURRAY: We've only had limited
12	feedback, which we did not use in the safety
13	evaluation.
14	Can we move on here?
15	CHAIRMAN POWERS: Could I just ask one
16	more question about the maintenance?
17	MR. MURRAY: Certainly.
18	CHAIRMAN POWERS: If I'm doing maintenance
19	on an electrolyzer where I have to shut off the power
20	and presumably pull cathodes, in the worst conceivable
21	event, that is, a total ignition, how much could I
22	possibly release?
23	MR. MURRAY: How much plutonium material?
24	CHAIRMAN POWERS: Yeah. Obviously I will
25	have emptied it.

1	MR. MURRAY: We would expect that the
2	administrative controls would have some requirement
3	for clean-out, yes.
4	CHAIRMAN POWERS: And if I'm cleaning it
5	out, it seems to me like I'm going to have zip
6	release.
7	MR. MURRAY: Yes.
8	CHAIRMAN POWERS: In the worst conceivable
9	event I can get, I don't think I can violate any site
10	boundaries with a cleaned out electrolyzer.
11	MR. MURRAY: Yes, yes, and if you look at
12	the DOE standard, for example, for handling titanium
13	vessels, they actually mention vessels should have all
14	material drained, and they should be cleaned out.
15	CHAIRMAN POWERS: Yeah, you almost have to
16	do it in order to do anything on the vessel.
17	MR. MURRAY: Yeah. The applicant did not
18	identify the DOE standard or NFPA
19	CHAIRMAN POWERS: That's interesting.
20	That's interesting.
21	MR. MURRAY: yeah, as a design basis,
22	but the approach is reasonable and in alignment with
23	generally accepted practice.
24	CHAIRMAN POWERS: Yeah. I don't have any
25	trouble with that.

1 MR. MURRAY: Let me move on to the seismic 2 The applicant has identified two controls 3 One is the electrolyzer structure, and the here. 4 second is what they call the seismic trip system, 5 which is part of the process safety control subsystem 6 or PSCS. 7 And I've listed the safety functions 8 there. And the staff looked at this and reviewed 9 10 it, and we note we even did a top level fault tree analysis of this, and we found that there were two 11 independent controls. also found that 12 We the frequency of potential seismic events was relatively 13 14 low, and we noted that the termination of 15 electricity prevented the event. And in conclusion, we noted that having 16 these two separate types of controls, in addition to 17 the low frequency of the initiating event, that the 18 19 approach should have the ability to render titanium event highly unlikely, and that's acceptable. 20 21 DR. WALLIS: What does "maintain geometry 22 for criticality purposes" mean? Does that have 23 anything to do with switching off for power? MR. MURRAY: The electrolyzer structure is 24 25 also identified for addressing criticality events.

1	That's
2	CHAIRMAN POWERS: It's got to be critical
3	safe
4	MR. MURRAY: Yes.
5	CHAIRMAN POWERS: configuration.
6	DR. WALLIS: You mean it could get into a
7	more critical configuration in the event of a seismic
8	event?
9	MR. MURRAY: If the vessel itself, the
10	structure itself were to fail, you could have
11	unfavorable geometry form on the floor, on the bottom
12	of the glove box conceivably.
13	CHAIRMAN POWERS: Right. I don't know how
14	they design it, but I would expect that flooding would
15	get you into a more potential criticality.
16	MR. SIEBER: I would think so.
17	CHAIRMAN POWERS: If flooding external.
18	DR. WALLIS: It's a moderator there.
19	CHAIRMAN POWERS: An additional moderator
20	I would think. I don't know what the design basis is.
21	MR. MURRAY: That's in the criticality
22	section.
23	MR. SIEBER: I would presume that they
24	would control the size of the electrolyzer so that you
25	would not have enough mass in order to have a critical

1	assembly.
2	MR. MURRAY: Again, you're getting into
3	the criticality safety area, and this component was
4	reviewed and the control strategy
5	MR. SIEBER: Well, I will be patient and
6	wait for that.
7	MR. MURRAY: Yes, but just you know
8	DR. WALLIS: So out of context really.
9	MR. MURRAY: But just to let you know,
10	appropriate design bases were identified for
11	addressing criticality concerns in this area and for
12	more details, ask Chris.
13	CHAIRMAN POWERS: The problem in
14	criticality analyses with plutonium is you get this
15	obnoxious plutonium hydroxide if your nitric acid
16	concentration drops I forget the limits like
17	about three molar, and so it's no longer a homogeneous
18	solution, and things that you thought were critical
19	safe based on geometry suddenly become not critical
20	safe. They get flooded.
21	MR. MURRAY: Yes.
22	MR. SIEBER: Well, there's some other
23	aspects, too. You really don't know what plutonium
24	isotopes you have.
25	CHAIRMAN POWERS: They probably know

1 pretty well here. 2 MR. MURRAY: Yes, yes. MR. SIEBER: Well, it's not all that clear 3 4 because it changes over time. It comes in 5 CHAIRMAN POWERS: sheet that says here are the isotopes. 6 7 MR. SIEBER: And a little box, right. MR. MURRAY: Let me just move along then. 8 Now, the controls for the electrical fault during 9 10 normal operations, the applicant has identified both 11 passive and active engineered controls. The passive 12 controls are essentially the sintered frit barrier, which is, if you will, the porous material, semi-13 porous material between the two compartments, and also 14 15 various elastomeric materials, which are listed here. 16 PTFE polytetrafluoroethylene. is 17 Sometimes the brand name is called Teflon, and as you 18 can see, these components have safety functions of 19 preventing anode/cathodes, anode/ground from contacting each other. 20 In addition, the applicant has proposed an 21 22 active engineered control, and I've listed the safety functions here. Basically these are related to 23 shutting down the electricity into the unit, and that 24 these two trip circuits would be part of the process 25

1 safety control subsystem. 2 Now, the applicant did not provide any 3 additional information, such as experience 4 France, reference or what have you. So the staff did a lot of analyses on this. 5 And we did do a top level fault tree. 6 7 used some generic information from Savannah River 8 site, Idaho, and some codes and standards, and we found that the combination of both passive and active 9 controls appeared to have the ability of making the 10 11 event highly unlikely. 12 We also found stated in the literature 13 that active engineered controls detecting 14 conditions, shutting power off, over voltage, over 15 current protection, et cetera are also, if you will, good engineering practice, which is often used in the 16 electrochemical industry, and we concluded that this 17 18 safety strategy was appropriate for the construction 19 stage. And I believe that concludes this part, 20 and we're back on schedule. 21 22 MR. ROSEN: Most remarkable, Mr. Chairman, most remarkable. 23 CHAIRMAN POWERS: I'll have to admit every 24 titanium fire I know of did not come from electrical 25

1	current. It came from hot work.
2	MR. MURRAY: If you go and look at the
3	events which have happened, okay, there have been
4	somewhere between five and ten events which involved
5	hot work, nearby sparks, in one case even a battery
6	powered device, okay, that imparted sufficient energy
7	to titanium tube materials to start the reactions, and
8	that was the staff concerns.
9	Now, the staff did consult some experts at
10	the agency here who have experience handling titanium
11	materials. We presented the electrolyzer conditions,
12	typical voltage, currents, and what have you, and they
13	expressed concerns that in that situation it would be
14	hard to argue that a titanium fire would not be
15	initiated.
16	CHAIRMAN POWERS: Yeah, I don't doubt that
17	it could. It seems to me maintenance in the glovebox
18	is one of the bigger things to worry about.
19	MR. MURRAY: Yes, yes.
20	CHAIRMAN POWERS: Any other questions to
21	Alex?
22	I presume that you're willing to cover
23	this and previous topics as well.
24	MR. MURRAY: Sure, sure.
25	(Laughter.)

1	MR. MURRAY: Any depth or any breadth
2	you'd like.
3	DR. FORD: Alex, I have a question of the
4	electrolyzer.
5	MR. MURRAY: Certainly.
6	DR. FORD: Surely, aren't you going to
7	have copious amounts of hydrogen being emitted?
8	MR. MURRAY: That will be discussed this
9	afternoon in the flammability part. Okay? We actually
10	have a nice, cute little figure to show you, which is
11	also from the Pacific Northwest Lab results, and this
12	shows hydrogen generation as a function of nitric acid
13	concentration.
14	And the applicant has proposed a strategy
15	based upon having a minimum nitric acid concentration.
16	If you take that curve at that nitric acid
17	concentration, the hydrogen generation will be below
18	the lower flammability limit by a pretty good margin.
19	CHAIRMAN POWERS: And understand now you
20	have a tradeoff in your criticality safety because the
21	plutonium hydroxide polymer can be a real pain in the
22	neck.
23	Any other questions?
24	(No response.)
25	CHAIRMAN POWERS: Well, seeing none, then

the

I'll recess this until one o'clock, I guess. 1 Thank you very much. 2 (Whereupon, 3 at 12:02 p.m., subcommittee meeting was adjourned, to reconvene at 4 5 1:00 p.m., the same day.)

1	AFTERNOON SESSION
2	(1:02 p.m.)
3	CHAIRMAN POWERS: Let's come back into
4	session.
5	I think we're moving on toward one of the
6	really exciting areas, uranium burnback, and I don't
7	know what. Have we got a speaker? Oh, Dave is going
8	to do it extemporaneously, right?
9	MR. BROWN: I will.
10	CHAIRMAN POWERS: This is one that you can
11	do extemporaneously.
12	MR. BROWN: As soon as Alex gets here,
13	I'll sit beside you.
14	The concern here is the fact that this
15	mixed oxide fuel will, of course, contain a depleted
16	uranium oxide component. That material has been
17	observed to undergo what we've called burnback, which
18	is oxidation from the UO_2 to $\mathrm{U}_3\mathrm{O}_8$.
19	The area where that is a hazard is where
20	the uranium is a powder, not yet commingled with the
21	plutonium, but it has been ball-milled to a very fine
22	particle size and, as a result, has a fairly high
23	surface area, specific surface area, if you will, and
24	most of that and I'm sorry. I said when it was not

commingled with plutonium.

25

That hazard exists

1	throughout so long as it's an unconsolidated powder
2	through the barriers of the process that are here
3	marked in red.
4	So when the powder has been consolidated
5	into a pellet, that's when essentially the hazard of
6	burnback has been removed because at that point
7	there's no longer enough specific surface area to
8	cause this high oxidation.
9	DR. WALLIS: Where is this oxygen coming
10	from?
11	MR. BROWN: The oxygen that supports the
12	burnback? From there in the vicinity of the powder.
13	I'm sorry?
14	DR. WALLIS: So it's in the air?
15	MR. BROWN: Yes, and so for example, where
16	burnback has been observed before is anywhere where
17	air has been allowed to get into that process area
18	either by opening a drum containing the powder or by
19	simply allowing air instead of allowing nitrogen to
20	get into a glovebox, for example.
21	CHAIRMAN POWERS: Alex, we were running a
22	test to see if the PM had been listening to you or
23	not.
24	MR. MURRAY: Okay.
25	CHAIRMAN POWERS: He's doing pretty well,

1 actually. He's doing real well. 2 MR. BROWN: But I will step aside. 3 (Laughter.) 4 MR. MURRAY: Maybe I should have circled the block. 5 (Laughter.) 6 7 MR. MURRAY: Thank you, Dave. Sorry about that. Trying to get a 8 9 CD burner to work and it is so far not responding. 10 POWERS: CHAIRMAN Too many safety interlocks. 11 MR. MURRAY: That must be it. 12 As Dave was just mentioning, you know, 13 burnback reactions, they do require oxygen from the 14 15 air or another source. They can occur quite rapidly and get to some reasonably high temperatures, several 16 hundred degrees centigrade, maybe even up to the 600 17 18 degrees centigrade degree range quite quickly. 19 One thing about burnback, particularly with events which have occurred historically, they can 20 initiate other reactions and/or disbursal of material, 21 22 and at the proposed max facility, the main concern is with the ball-milled material because that is a very 23 It also is being blended with fine material. 24

plutonium dioxide. So you have, if you will, a decent

25

about

the

term

1 source term there as well. 2 And one of the things to keep in mind has been found is that the burnback 3 which essentially a kinetically limited reaction. 4 for it to occur rapidly, you have to have small 5 particle sizes generally less than about ten microns. 6 7 CHAIRMAN POWERS: What do you mean by 8 kinetically limited? You're talking 9 chemical kinetics at the surface? 10 MR. MURRAY: I'm using "kinetically limited" to mean that the uranium dioxide 11 fundamentally unstable from a thermodynamic 12 13 viewpoint under normal conditions. Okay? 14 atmosphere with the 20 percent partial pressure 15 fraction of oxygen. However, if it is of a sufficiently large 16 17 particle size, if you will, the amount of material 18 that can participate in the reaction is so slow it 19 cannot, if you will, heat up and react faster which would occur if you had a finer particle size, things 20 It is fundamentally kinetically 21 of that nature. 22 limited. So, for example, if you have a very fine 23

powder, it can undergo burnback reactions if it can be initiated at room temperature. You just sufficiently

24

25

1	disturb it or in the presence of air and it will
2	react.
3	If you have material a little courser,
4	generally, say, in the 20 microns range, you generally
5	need about 60 to 100 degrees centigrade. If you're
6	dealing with something like pallets, for example, you
7	generally have to heat those up to something like 300
8	to 400 degrees centigrade.
9	DR. WALLIS: It doesn't make a difference
10	how it's disbursed if it's just in a pile like that.
11	Presumably it eats up all of the oxygen in the pile.
12	It only burns on the surface, but if you disburse it,
13	fluff it up and puff it up into a cloud
14	MR. MURRAY: Yes.
15	DR. WALLIS: it's going to react more
16	quickly.
17	MR. MURRAY: That is correct. It's a
18	little bit like a dust cloud.
19	DR. WALLIS: Yes.
20	MR. SIEBER: Yes, or coal dust.
21	MR. MURRAY: Yes, like a dust cloud, yes,
22	exactly.
23	MR. SIEBER: But you don't need an
24	ignition source.
25	MR. MURRAY: If the material is fine
	l

enough, a small enough diameter, that's correct. don't need in your resource. It purely is mass transfer limited. And I just included standard pictures of uranium dioxide and plutonium dioxide. Now, the applicant has proposed a safety approach to address this event, and this involves a preventative strategy to remove fine depleted uranium oxide particles before they can impact the HEPA filters, and if these fine particles are removed before they impact the HEPA filters, this allows the HEPA filters to continue to perform their safety functions, which is essentially a confinement barrier.

And the safety controls I just want to point out in the original application, the applicant did not have any safety controls identified in the revised CAR, revised construction authorization request, which was received this past summer. They included PSSCs to address this event, and these are two high strength metal pre-filters.

here's the description the And applicant's safety controls, two high stainless steel mesh pre-filters. They sometimes use the term "spark arresters" in the application. also have two after the air stream has passed through

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1	these metal pre-filters. They also have two HEPA
2	filter elements, all within the same housing.
3	In addition, you have the standard
4	redundancy of an air handling system.
5	DR. WALLIS: I don't understand this at
6	all. You've got a filter which collects the particles
7	of uranium oxide?
8	MR. MURRAY: Right.
9	DR. WALLIS: And the air is blowing
10	through it. So why doesn't it react and blow it on
11	the filter?
12	MR. MURRAY: Well, it can react on the
13	metal pre-filter.
14	DR. WALLIS: So you make yellow cake on
15	the filter.
16	MR. MURRAY: Right. The safety strategy
17	is to prevent the uranium dioxide particles from, if
18	you will, reaching the HEPA filter elements.
19	DR. WALLIS: You don't care if they burn
20	then.
21	CHAIRMAN POWERS: That would not be yellow
22	cake. It's uraninite.
23	MR. MURRAY: Huh?
24	CHAIRMAN POWERS: You would not make
25	yellow cake.

1	MR. MURRAY: No.
2	CHAIRMAN POWERS: You would make
3	uraninite.
4	MR. MURRAY: Yes, that's correct.
5	DR. WALLIS: Why is that high strength?
6	MR. MURRAY: To take potential temperature
7	extremes and even pressure delta pet peak
8	considerations across the metal pre-filters because
9	burnback reactions in past instances have achieved
10	temperatures as high as 600 or so degrees Centigrade.
11	You know, if you have it out of stainless steel,
12	that's a completely different matter as having it in
13	a HEPA filter.
14	Again, the key thing is prevent the
15	material from reaching the HEPA filter.
16	MR. SIEBER: That's all you protect though
17	
- /	because uranium dioxide lines are going to be
18	everyplace in the system where there's any kind of a
18	everyplace in the system where there's any kind of a
18 19	everyplace in the system where there's any kind of a leak. So the potential of rapid oxidation is always
18 19 20	everyplace in the system where there's any kind of a leak. So the potential of rapid oxidation is always going to be where the material will collect.
18 19 20 21	everyplace in the system where there's any kind of a leak. So the potential of rapid oxidation is always going to be where the material will collect. MR. MURRAY: That's right. That is
18 19 20 21 22	everyplace in the system where there's any kind of a leak. So the potential of rapid oxidation is always going to be where the material will collect. MR. MURRAY: That's right. That is correct.

1	concern is maintaining the confinement boundary is the
2	HEPA filter.
3	MR. ROSEN: So the idea is to burn right
4	there in those stainless steel pre-filters, right?
5	MR. MURRAY: Potentially, yes.
6	MR. ROSEN: I mean, the idea is to burn it
7	up before it has to get to the HEPA.
8	MR. MURRAY: That's correct, yes. Before
9	it can, if you will, impact and damage the HEPA
10	filters.
11	MR. ROSEN: So you expect this to happen
12	once in a while, to have some burnback in those
13	filters.
14	MR. MURRAY: Yes, conceivably.
15	Now, I will add and we'll get to this
16	a little more in a moment in the process, in the
17	applicant's proposed design, where powders are
18	handled, they're under nitrogen. Okay? They have not
19	identified nitrogen as, if you will, or the supply of
20	nitrogen as being a safety control.
21	As a matter of fact, as the air streams
22	come together from the different powder process
23	gloveboxes, some of the other gloveboxes are normal
24	atmosphere. So by the time the mixture reaches the
25	final plenums where the C4 HEPA filters are, you

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

actually have, if you will, an air stream or close to an air stream.

Okay, and on this slide I've used some other design basis information for the HEPA filters and the ventilation system. The pressure drop design for ten inches of water pressure or less, the fire barriers between areas and also the applicant has also identified administrative controls for inspection and maintenance of the HEPA filters.

Okay. Here I'm just giving some specifics on the two pre-filters, and as you can see, they have a design basis of removing 90 percent of the particles greater than one micro in size, and again, the safety function is a protection of the HEPAs.

Do you have a question, Dana?

CHAIRMAN POWERS: Not on this in particular, but in the SER you go on -- in fact, you don't go on, but who ever wrote this thing goes on and the potential then discusses for burnback and plutonium it's substoichiometric dioxide, and presented more as a plausibility argument than the basis of any experience, and I certainly don't know a burnback in substoichiometric plutonium dioxide, and I wondered. I mean, the reason you get burnback here is a peculiarity of the partial molar free energy of

1	oxygen going into uranium dioxide.
2	MR. MURRAY: Yes, yes.
3	CHAIRMAN POWERS: I mean taking it over to
4	first U_4O_9 and then on to U_3O_8 .
5	In the substoichiometric plutonium
6	dioxide, you've got a different situation. Unless
7	you're wildly substoichiometric and I don't know of
8	anybody that's producing wildly substoichiometric
9	plutonium dioxide you're going to go from a little
10	bit below stoichiometry to a little less below
11	stoichiometry.
12	I mean, it's not the same magnitude of
13	thermal effect. Did somebody do any sort of
14	calculations to suggest there could actually be a
15	burnback effect in substoichiometric or is it just a
16	plausibility argument? It's presented more like a
17	plausibility argument.
18	MR. MURRAY: Yes. On the south tract
19	(phonetic) of the plutonium dioxide or
20	substoichiometric plutonium dioxide, that is from
21	information supplied by Los Alamos.
22	CHAIRMAN POWERS: Okay.
23	MR. MURRAY: And it primarily relates to
24	the sesquioxide PU ₂ O ₃ up to PUO ₂ , perhaps PUO ₂ plus .05
25	or 2.05, 2.1, and from the information we found, the

1 enthalpy effect is far less. That's why they're sort 2 of handled separately in the revised -- I should say 3 in the FSER. CHAIRMAN POWERS: Yeah, it's kind of a 4 5 confused argument because it does talk about the 6 superstoichiometric material or oxygen or water 7 absorption of plutonium dioxide, but I don't know of 8 anybody that has actually produced superstoichiometric 9 plutonium dioxide. Dave Hanshe (phonetic) gets some 10 stuff that has water absorption on it, but I mean, that's not really superstoichiometric. 11 MR. MURRAY: Most of the information which 12 we found was related to other volatile species, but 13 14 the substoichiometric to slightly superstoichiometric 15 PUO₂ concern arose from one of the researchers at Los 16 Alamos. 17 CHAIRMAN POWERS: Okay. MR. MURRAY: And the applicant has an 18 19 approach for addressing those type of concerns in addition to the volatile concerns, 20 and that's 21 discussed in the FSER. 22 CHAIRMAN POWERS: Yeah. I mean, it's a little different than this. You've actually -- this 23 has actually occurred in a couple of the fuel plants. 24 25 MR. MURRAY: Events have occurred. Plus

1	the fuel cycle licensees which manufacture ${ m UO_2}$ fuel,
2	the way they process the fuel, their comment is it's
3	a process argument. They usually do a number of steps
4	which limit the reactivity of the UO_2 powders.
5	CHAIRMAN POWERS: Yeah. In fact, if you
6	processed all of your powders in air, you would never
7	get a burnback.
8	MR. MURRAY: That's right because it would
9	oxidize.
10	CHAIRMAN POWERS: Because you're doing it
11	in the inert atmosphere
12	MR. MURRAY: Right.
13	CHAIRMAN POWERS: that you even have
14	the potential of getting burnback.
15	MR. MURRAY: That's right. That's right.
16	And they usually do something to control the amount of
17	oxidation so that it just occurs at the surface as it
18	is loaded into a container, for example.
19	CHAIRMAN POWERS: Okay. Any other
20	questions about the fascinating world of burnback?
21	It's fun.
22	MR. MURRAY: Yeah.
23	CHAIRMAN POWERS: I mean, Alex did not go
24	into decrepitation and the fact that it takes these
25	ten micron particles and converts them into submicron

1	particles.
2	MR. ROSEN: It's own fuel.
3	CHAIRMAN POWERS: It kind of decrepitates.
4	I mean, there's all kinds of excitement. Plus things
5	on surfaces bounce along the surfaces and things like
6	that.
7	MR. MURRAY: Yes, an example of unique
8	phenomena which occur.
9	I just wanted to also mention that the
10	applicant has identified what they call APFs or
11	additional protective features, and for uranium
12	burnback, I have listed them here.
13	CHAIRMAN POWERS: Delivered to the site in
14	sealed drums. That's why you have the problem.
15	(Laughter.)
16	CHAIRMAN POWERS: You wouldn't have the
17	problem if they didn't do that.
18	MR. MURRAY: That's correct.
19	MR. ROSEN: You'd have the burnback
20	someplace else.
21	CHAIRMAN POWERS: Yeah, when you filled
22	the drum.
23	MR. MURRAY: Yes, sir. Again, about the
24	burnback phenomena, it's a question of where it occurs
25	and to what extent, and if it's in an area where you

can handle it and where confinement boundaries and 1 2 HEPA filters are not challenged, in effect, you've 3 prevented the event from impacting those confinement 4 barriers. 5 CHAIRMAN POWERS: The biggest change I think they made is in their choice of materials for 6 7 their HEPAs. I mean, they are relatively immune to --8 MR. MURRAY: Yeah, they're much more 9 robust. 10 CHAIRMAN POWERS: Yeah. I mean, other places where we had the old paper HEPAs, it just 11 12 really couldn't survive this kind of thing at all. 13 MR. MURRAY: Right, right. 14 CHAIRMAN POWERS: And they couldn't take That was the big problem, was they 15 any loading. couldn't take any heavy particulate loading so that 16 17 they blow out and you'd get the entire inventory of the filter. 18 19 Yes, yes, that's correct. MR. MURRAY: want to summarize the 20 just 21 evaluation. We postulated that there could be a 22 glovebox spill or fire that could disburse these fine 23 UO2 particles into the ventilation system, and the C4 ventilation system is the glovebox ventilation system. 24 25 Okay?

1	And from an analysis, we looked at ball-
2	milled material, which would be the finest material in
3	the facility, and we found that the amount which could
4	end up being deposited on the HEPAs after going
5	through the system, going through the stainless steel
6	mesh pre-filters would be something around ten to 25
7	percent of that needed to cause temperature damage.
8	And we concluded that this was an adequate
9	safety strategy. The HEPAs could survive a burnback
10	reaction, and they could continue to perform the
11	safety function.
12	Any questions?
13	CHAIRMAN POWERS: Any other questions?
14	(No response.)
15	CHAIRMAN POWERS: Well, you guys don't
16	like either ate too much lunch or just don't like
17	burnback.
18	(Laughter.)
19	CHAIRMAN POWERS: Let's go talk about
20	TEELS.
21	MR. MURRAY: Okay. The next subject area
22	we're going to look at is what are called TEELS, and
23	I'll also use the term "chemical limits," "chemical
24	consequence limits."
25	And for the revised Part 70, as was

discussed this morning, both high and intermediate consequence chemical events are identified as needing to be addressed in the application. In order to define what are high and intermediate consequence events, you have to have chemical levels or criteria, and these limits are shown as parts of the regulation where they are important and cited. These limits should address, if you will, or should be, I should say, quantitative standards that relate to acute chemical exposure levels.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

These are not long term exposure levels, not, if you will, occupancy type levels. These are levels which are appropriate for potential events and accidents.

Let me just mention what the safety issue is. These chemical limits essentially are used to determine what the safety controls and the design No, in the standard review plan for MOX, bases are. several are mentioned, AEGLs, A-E-G-Ls, which are from the EPA and National Academy of Science, and there's a number of people involved with that.

There are also ERPGs, which are emergency response planning guidelines which come from an industry group, and the SRP also mentions limits from

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

1 OSHA and NIOSH. PELs are permissible exposure levels, a little more like occupancy levels. STs are short-2 term exposure limits. Cs refers to ceiling limits. 3 4 Okay, and of course, the standard review plan says that the applicant may use an alternative, 5 6 provided that they adequately justify it. 7 Now, as part of our review of the CAR application and related information, we found that 8 there can be significant variations between all of 9 10 these limits, and that can affect the selection of safety controls. 11 12 DR. FORD: So which one do you choose? MR. MURRAY: He's a good straight man. 13 (Laughter.) 14 15 We're getting there, and MR. MURRAY: that's where we're going to. 16 17 Now, in the initial application, 18 applicant did not have any chemical limits identified. 19 Okay? In the revised application, including the application which came in in June 2004, they have 20 values in Table 8-5 of the application which are based 21 22 on a combination of TEELS, which are temporary emergency exposure limits, and ERPGs. 23 So the staff went and looked at these 24 revised application values and went from there. 25

Now, when you have these different limits, generally they have three levels. You have a Level III, which as AEGL-3, ERPG-3, TEEL-3, and these can correspond, if you will, to a high consequence type event.

You can have Level IIs, which usually correspond to a more intermediate event. I should say a high consequence event is usually life threatening or with part of the definition includes life threatening effects. An intermediate effect can be a significant injury, but the person is still able to escape from the area.

And then, of course, there's the low effect where it is more just an offensible (phonetic) odor or stinging of the eye and so forth.

This is how, this table which I'm showing here, is how the applicant has decided to, if you will, determine what are high, intermediate, and low consequence events, and they have identified them for both the worker receptor and also the IOC/public receptor. And the only difference between those two is the distance to where the receptor is assumed to be.

CHAIRMAN POWERS: Sixty meters was a difference now. There's no difference at all.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

MR. MURRAY: Yes, there's only a small
difference now. It used to be 100 meters versus four
and a half miles. Now it's 100 meters.
MR. ROSEN: For example, how long is the
longest dimension of a building?
MR. MURRAY: Hold on a second. I want to
say it's about 170 meters. Do you know, Dave,
offhand?
MR. BROWN: I don't know. I think it's a
little larger than that.
MR. ROSEN: One hundred and 70 meters. So
it's
MR. BROWN: Or round about.
MR. MURRAY: Yeah, somewhere on that
order.
MR. ROSEN: So if you release something at
one end of the building, somebody at the other end of
the building
1
CHAIRMAN POWERS: Is safer than somebody
CHAIRMAN POWERS: Is safer than somebody at the site boundary.
at the site boundary.
at the site boundary. MR. ROSEN: Right. Further away from the
at the site boundary. MR. ROSEN: Right. Further away from the source.

events by the preceding table, in actuality they are going to not exceed, if you will, the Level II values, TEEL-2s, ERPG-2 values for the worker receptors, and not exceeding the Level I values for the public receptors at 160 meters.

And if you can compare the two tables, you notice that these are essentially one step lower.

Now, the staff looked at this, and again, we noted and it's all discussed in the FSER that there are multiple limits which are available, and one of the concerns that we had was that the Level III values, which the applicant had proposed, trend toward the high ranges of all the limits which are out there in the world.

Now, when you look at the Level II limits, TEEL-2, ERPG-2, you find that these are significantly lower than these Level III limits. They all are below what are called IDLH values, immediately dangerous to life and health, and there's more consistency between the different limits.

And I point out again here the applicant's commitment to workers and not exceeding a Level II level and the public not being exposed to anything greater than the Level I.

The staff review also found out that Level

1	I values tend to approximate what we call habitability
2	limits which are put out by OSHA and NIOSH. Okay?
3	And in the end we've summed this all up in several
4	tables in the FSER. We find that their approach on
5	the limits is acceptable for the construction stage.
6	MR. ROSEN: Is the habitability limit
7	something that if you were at that limit, you could
8	live there essentially forever?
9	MR. MURRAY: Essentially indefinitely.
10	Okay. If you look at the definitions, most of the
11	Level I values, be they ERPGs, TEELs, AEGLs, they all
12	are generally identified as being, oh, there's
13	noticeable odor. There might be some discomfort, but
14	there is essentially no significant effect.
15	CHAIRMAN POWERS: I thought they were for
16	an eight-hour working day.
17	MR. MURRAY: The Level I values?
18	CHAIRMAN POWERS: The habitability limits.
19	MR. MURRAY: Habitability limits
20	CHAIRMAN POWERS: I don't think you do
21	infinite amount of time. I mean if there's any order
22	at all, you can't be there for an infinite amount of
23	time.
24	MR. MURRAY: I have to check on that,
25	Dana.

1	CHAIRMAN POWERS: I think they're for, you
2	know I mean, I think the idea was taking advantage
3	of basic workers are relatively healthy people and
4	have good recovery systems, all operational, and so
5	that it was for a finite period of time, but I could
6	be wrong. It has been a long time since I looked at
7	them.
8	MR. MURRAY: I have to check. I know
9	there are habitability limits out there which tend to
10	be long term, in essence, and also there are similar
11	limits out there which are work day limits, which are
12	eight-hour limits.
13	CHAIRMAN POWERS: Yeah, I just can't
14	remember which one's which.
15	MR. MURRAY: Yeah, I'd have to check for
16	you, Dana.
17	Okay, and any other questions on TEELS?
18	CHAIRMAN POWERS: The bottom line is
19	they've straightened this out and gotten it organized
20	so that it's a fairly coherent
21	MR. MURRAY: Yes.
22	CHAIRMAN POWERS: and meaningful set
23	now instead of that hodgepodge that came in
24	originally.
25	MR. MURRAY: Right, right. It seems that
l	

1	the approach is now better thought out, more
2	consistent, and the focus on, if you will, essentially
3	using lower values, a commitment to lower values is,
4	we think, a very positive step.
5	CHAIRMAN POWERS: Everybody wants lower
6	values on these things.
7	MR. MURRAY: Yes, yes, yes.
8	CHAIRMAN POWERS: The NRC and its reactor
9	domain has what, four years ago, I guess? Went
10	through this for the control rooms of the reactors and
11	looked at them.
12	MR. MURRAY: Yes.
13	CHAIRMAN POWERS: Did you do a cross-
14	comparison between the two?
15	MR. MURRAY: Yes, we did, okay, and we
16	found that sometimes the Level III limits will, if you
17	will, exceed those limits in Reg. Guide 1.78 on
18	control room habitability, and sometimes they'd be a
19	little bit below.
20	CHAIRMAN POWERS: I mean, the whole
21	situation on limits and chemicals is just a mess in
22	this country.
23	MR. MURRAY: Yes.
24	CHAIRMAN POWERS: And unfortunately NRC is
25	too small of a fish to put pressure on them to fix it.

1	MR. MURRAY: We're just a little guppy in
2	the big ocean.
3	CHAIRMAN POWERS: Yeah. And nobody wants
4	to fix it because they've got the set that they want
5	to live with, and they don't want anybody to change
6	it, and so it's a hodgepodge.
7	MR. MURRAY: And there's limited data for
8	making changes.
9	CHAIRMAN POWERS: That's also the problem.
10	MR. MURRAY: Yes. Okay. Any other
11	questions?
12	We'll discuss control room habitability a
13	little later on.
14	CHAIRMAN POWERS: Good. Any other
15	questions about I mean, it's an extremely
16	frustrating area because, I mean, we don't have
17	expertise in this area. You'd like to have somebody,
18	you know, like ICRP come in and lay down the law on
19	this, but as we said, there's nobody in a position to
20	do it, and NRC is just not capable of putting the
21	torque on the necessary legislators to do it, and
22	people have their own limits for their processes, and
23	they just don't want anybody to change it.
24	MR. MURRAY: Yeah.
25	CHAIRMAN POWERS: And the other problem is

1	there are more chemicals than there are limits. So
2	you end up doing strange things that you know are
3	unjustifiable because we wouldn't call them different
4	chemicals if they had all the same properties.
5	MR. MURRAY: That's right. That's right.
6	CHAIRMAN POWERS: So it's extremely
7	frustrating. But having something that hangs together
8	and makes sense is about the best you can hope for.
9	MR. MURRAY: Yes, and that's the approach
10	we've taken.
11	And, well, since we've discussed the
12	control room, here we are, discussing control room
13	habitability. And I just want to just again do a
14	quick introduction about habitability.
15	The proposed MOX facility will have
16	multiple control rooms and areas. Okay? Now, in
17	addition, the applicant has stated they will have two
18	emergency control rooms or ECRs. And I've listed the
19	two functions of those ECRs.
20	The first is to maintain a habitable
21	environment for operators, and the second is to
22	provide cooling to emergency electrical rooms.
23	MR. ROSEN: Are these emergency control
24	rooms the ones that are continuously manned or is
25	there nothing analogous to a power plant control room

in this facility, that is, one place that is continuously manned, where individuals who are competent in the whole process, keep an eye on the whole everything that's going on, or is it much more disbursed than that, nothing like that?

MR. MURRAY: Our impression, myself, other reviewers, of the proposed facility is that there will be more of what we call a distributed control strategy, whether it be, in essence, separate control rooms for specific areas of the plant, and this is what the applicant has identified in their application.

As it goes forward into final design and we receive a license application, we anticipate one or more of those areas or the emergency control rooms may be identified as continuously manned, but at the present time, if an event were to occur, the appropriate operators would go to the ECRs and perform their safety functions, which is monitoring a safe shutdown.

MR. ROSEN: Well, it gives me a little bit of concern, the idea that there's no one place where someone or other has overall integrated responsibility for the facility on a 24-7 basis. They may not be doing anything in particular in terms of process-wise,

1 but they're just watching. They know what's going on. This is they're operating. They're operating here. 2 They're operating on Level II, then this and that. 3 And so they know how many people roughly 4 there are in the facility and where they are and who 5 6 they may be. So, you know, if there's an emergency 7 they can do an accountability, get people out, know 8 who's supposed to be there, who they've gotten out, 9 who's missing and that kind of thing. 10 Any thoughts along those lines? 11 MR. MURRAY: From the staff's review of the application, revised application, plus also other 12 documentation and discussions with the applicant, our 13 14 impression is the ECRs may end up meeting that requirement. 15 But at the present time we're looking at 16 17 We don't have explicit information design bases. 18 on --19 MR. SIEBER: It doesn't say that. 20 MR. MURRAY: Exactly, exactly. 21 MR. ROSEN: And you have no criteria for 22 that kind of function. 23 MR. MURRAY: If you're talking about an accountability function, no. If you're talking about 24 25 maintaining habitability in the emergency control

1	room, we have
2	MR. ROSEN: I'm talking about
3	accountability function, overall process control over
4	the whole facility.
5	MR. MURRAY: We would expect the details
6	of that to be in the license application. We do have
7	in the instrument area and some of the human factors
8	areas, if you will, design bases which have been
9	identified by the applicant and reviewed by the staff,
10	which, again, top level sort of approach would address
11	those sorts of questions.
12	CHAIRMAN POWERS: Well, I guess the
13	question that comes to mind is suppose you have an
14	event that exceeds your expectations. Well, maybe it
15	doesn't exceed your expectations, but it hits your low
16	probability events. Low probability events do occur.
17	MR. MURRAY: Yes.
18	CHAIRMAN POWERS: Who makes the
19	declaration of a general site emergency?
20	MR. MURRAY: That would be in a procedure,
21	and procedures will be reviewed in the license
22	application.
23	CHAIRMAN POWERS: Yeah, but who does it?
24	I mean, who's going to read this procedure and follow
25	it?

1	MR. MURRAY: I would have to look at the
2	management structure, which is discussed and evaluated
3	up front in the document. Right now I don't have an
4	answer.
5	CHAIRMAN POWERS: Yeah, but the trouble is
6	I don't think I have an answer either, and I think I
7	looked at that. I mean, I think I don't understand
8	what I read.
9	MR. MURRAY: Yeah, do you recall, Dave?
10	MR. BROWN: No, I don't recall the
11	specific title of the individual who's responsible for
12	managing emergency response at the plant in the event
13	of such an emergency.
14	They have described specific features of
15	the plant, you know, such as the safe havens. There
16	are five safe havens.
17	CHAIRMAN POWERS: Yeah, I've got all of
18	that sort of stuff.
19	MR. BROWN: Nonessential personnel will
20	escape to those areas, that sort of thing.
21	CHAIRMAN POWERS: They've got lots of
22	individual things, but who makes the decision that I
23	have a general site emergency? Who makes the phone
24	call to the NRC that says, "I've got a problem here"?
25	MR. BROWN: This is something

1	CHAIRMAN POWERS: Who calls Savannah River
2	that "look out, F. Canyon. Here I come"?
3	MR. BROWN: The current plan, and as you
4	may have seen in the CAR in Chapter 14, is that this
5	facility will be integrated with the existing Savannah
6	River site facilities. The plan is that this will be
7	an annex to the site-wide emergency plan. So the call
8	would be to the Savannah River site in the operations
9	center.
10	CHAIRMAN POWERS: I know where it's going
11	to go.
12	MR. BROWN: But who, right? I understand.
13	CHAIRMAN POWERS: And the other thing is
14	I'm quite certain this facility will follow the well
15	established rule known since TMI, Chernobyl, et
16	cetera, that all major events occur after one o'clock
17	on Tuesday morning, call on the back shift.
18	So the question really boils down to: who
19	is this guy?
20	MR. ROSEN: Where does he sit?
21	CHAIRMAN POWERS: And how does he know
22	that he's got a general site emergency if he's in
23	Control Room 2 and Control Room 1 is where the event
24	is taking place?
25	MR. BROWN: Well, the control rooms, as

1 Alex suggested, are distributed so that there's a control room for the aqueous polishing side of the 2 plant, a control room for the MOX fabrication side of 3 4 the plant. So there are not two trains of the normal 5 controls. 6 CHAIRMAN POWERS: No, no, no. That's not 7 what I'm implying. I'm implying that the guy that's familiar with aqueous polishing knows when he's 8 9 getting into trouble. 10 MR. BROWN: That shift supervisor, right? CHAIRMAN POWERS: He may not understand 11 when he's getting in trouble when he has a metal fire 12 going on over in the fuel fab site. 13 14 MR. BROWN: Oh, okay. CHAIRMAN POWERS: And vice versa, and so 15 the guy in the aqueous polishing may not be the guy 16 17 that is the right guy to make the call about a general 18 site emergency because you're burning fuel. Maybe he is. Maybe this is Mr. 19 I don't know. Wonderful here, but aqueous chemists tend not to be 20 terribly familiar with condensed phased reactions and 21 22 vice versa. MR. BROWN: Right. 23 MR. MURRAY: Unless you've been burned by 24 25 both.

1	CHAIRMAN POWERS: Unless you've been
2	burned by both, exactly.
3	MR. ROSEN: So in which case you're
4	promoted to being the guy who we look to.
5	CHAIRMAN POWERS: You're the guy that
6	we're looking for, is the guy that has holes in both
7	sides of his jeans.
8	MR. MURRAY: Yes, I don't think from our
9	review of the application we have a specific, if you
10	will, title or position identified.
11	MR. ROSEN: You understand, Alex, that in
12	reactor operations, just by comparison, you've got
13	one, two, three, probably four levels of control that
14	are established, and the transfer of control from the
15	main control room during operation through these other
16	levels of control is a very choreographed protocol
17	operation.
18	MR. MURRAY: Yes, yes.
19	MR. ROSEN: And there's a great deal of
20	detail, and what we find here is we don't even know
21	where the control room is. I find that rather
22	astonishing.
23	MR. MURRAY: Well, I think what we have
24	run into is one of the artifacts of the two-step
25	licensing. You know, top level design basis
	1

1 information now, detailed procedures, identification of positions for calling or starting these emergency 2 actions would be defined in the license application, 3 but we can go back and take a look. 4 5 MR. BROWN: That's exactly right. 6 focus now is on system structures and components to 7 make sure that the systems that would alert operators of that condition are there, but we don't have 8 9 detailed information on the plant procedures, 10 including emergency procedures. CHAIRMAN POWERS: You know, you can make 11 this two-step system the last refuge of the scoundrel 12 I mean this sounds like it's fairly fundament 13 14 to me. To the structures? I don't 15 MR. BROWN: think so. 16 CHAIRMAN POWERS: I mean, to the overall 17 18 design is understanding who's in charge when. 19 DR. WEINER: Well, shouldn't there be one focal point where there is someone, some personnel 20 that have an overview of the entire process? This is 21 22 a flow. This is a chemical flow process, and to have separate control rooms with no centralized at least 23 overview, from my naive point of view, that's a 24 25 structural problem, isn't it?

1	I mean, there has to be some design that
2	looks at all of the control systems.
3	MR. BROWN: The two parts of the plant are
4	essentially separate, and they run in a batch mode.
5	So there's not really as much interaction there, I
6	think, as the question suggests. The one person is
7	concerned with plutonium purification in the aqueous
8	polishing step who provides canisters that go into
9	storage, and when those canisters are required to
10	produce MOX fuel, they are pulled out of storage for
11	that purpose.
12	So there's a clear break in the
13	operational process there, and there really are almost
14	distinct structures of the same building.
15	MR. SIEBER: It seemed to me that the
16	whole process was a batch kind of process with a lot
17	of little work stations and gloveboxes, not connected
18	together except through the ventilation system, you
19	know, and so each one of these would operate
20	independent of all the
21	CHAIRMAN POWERS: That's a non-trivial
22	connection.
23	DR. WEINER: Yes.
24	MR. SIEBER: Yeah. Well, it serves a
25	single function. Okay? So an accident in one portion
1	1

1 of the plant affects all other portions because it's 2 connected to the same internal environment. On the other hand, this piece of equipment 3 4 is not necessarily dependent on the operation of 5 another process piece of equipment. It is not a 6 process industry. It's all batches. 7 MR. MURRAY: Yes. The process is what we 8 call essentially a semi-batch process, and we do have 9 a lot of intermediate storage locations both in the 10 aqueous polishing side and in the mixed oxide powder 11 side. 12 Now, I think we'd have to go and take a look at Chapter 1 of the draft FSER to check out to 13 14 see where the administrative structure would fit in 15 here, and offhand I don't recall, to be quite honest. CHAIRMAN POWERS: Yeah, we could get 16 17 there, but I just don't understand what I'm reading, 18 I guess. 19 MR. MURRAY: We can get back to you on 20 that one. MR. ROSEN: Well, I think we're making a 21 22 list of things we kind of want to know more about, and it might be some of these things will make it into a 23 letter so that you'll have something that reminds you. 24 25 MR. MURRAY: Okay.

1 MR. SIEBER: It seems to me there was 2 no -- there's a fair amount of description of the 3 organization when they're building the plant, design part and the construction part, but there's not 4 5 a lot of description about the operating part of it. 6 CHAIRMAN POWERS: That's not terribly 7 surprising. MR. MURRAY: Again, that's because of the 8 9 two-step licensing process. 10 MR. SIEBER: Right. So I think if you hunt through what we already have, you're going to 11 12 spend a lot of time and not find any. MR. ROSEN: The question remember came up 13 14 because we're talking about two emergency control 15 We're talking about functions in spaces, and I think I know of a function, but I don't know which 16 17 space it goes into. 18 MR. MURRAY: Okay. We'll have to check 19 and get back to you. Let me continue on here. Okay. I'm just 20 going to briefly discuss the emergency control room 21 22 ventilation system or just simply ECR HVAC, and I've 23 noted here some of the parameters. Each system consists of two 100 percent capacity filter trains, 24 25 one per ECR. Each train has one intake, and in that

train a filtration unit and a booster fan. 1 2 In addition, the filter unit includes, in 3 addition to HEPAs, a Haslet (phonetic) gas removal 4 cartridge and/or a cartridge for removing volatile 5 organics. 6 Now, here is the safety issue. From the 7 staff's review, we noted that several chemicals on 8 site could affect habitability, and some are present 9 as liquids and some are essentially a liquid-gas 10 mixture. And releases of these chemicals could 11 12 prevent the ECR operators from performing their safety 13 functions. Now, the applicant has realized this, and 14 15 they have a safety approach. I've identified it here. They have decided that there will be, if you will, an 16 17 ECR HVAC system, and as I've shown here in the initial 18 application, we have the PSSC, but not a design basis, and in the FSER we have imposed a proposed permit 19 20 condition which requires a habitable design basis. Now, these are the actual controls that 21 the applicant has proposed. The ventilation system 22 23 for each ECR is identified as a PSSC.

safety function, which is to maintain habitability,

and the design bases, which are used and are listed in

24

1 the table and the FSER. IDLHs from Reg. Guide 1.78 2 Level II values, which are from Table 8-5 3 of the CAR, and Level III values if they are less than 4 the IDLH. This is what the applicant has proposed. 5 And I've also listed some other aspects of 6 the applicant's approach here, and again, it seems to 7 be a thought through from a functional perspective. You know, if you detect a hazardous chemical above 8 9 intake is isolated and allowable limits. that 10 switched to recirc. mode. If it has these chemicals 11 at both intakes to the two -- there's one intake per 12 ECR -- then the alarm sounds, and both ECRs go into recirc mode, and the operators are to don scubas. 13 And I just listed something a little bit 14 15 more about the monitoring and the applicant has stated they will have a monitoring system for those chemicals 16 which they think in a release could result 17 18 exceeding control room limits. 19 CHAIRMAN POWERS: Will they 20 oxygen? 21 MR. MURRAY: There is a separate slide 22 get to in а moment about potential They have stated as a design 23 asphyxiation. Okay?

> **NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS** 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

basis, which applies to oxygen content, and they will

do detailed analyses in the license application to

24

25

monitor

address that, but that's about two slides further on. These emergency actions, i.e., going into recirc mode as an example, will be initiated when the chemical concentrations are at or below the TEEL-3 limit in and any specific set points determined in the license application.

And this, I guess, was the next slide, not two slides down. This is the design approach that the to address Again, they will do analyses of individual rooms, and if that analysis shows that they need to have oxygen monitors or some form of habitable air monitors in that area, they will put

And for high asphyxiating or to avoid asphyxiating atmospheres, they expect the high ventilation rates will preclude the formation of, if you will, an asphyxiating atmosphere.

And they do list this publication from the CGA, which has to do with oxygen/air quality.

Does that address your question?

Yeah. CHAIRMAN POWERS: I mean that's explicitly exactly what they should be doing. with all of that nitrogen that you're using and the system asphyxiation --

(202) 234-4433

18

19

20

21

22

23

24

1 MR. MURRAY: Is a concern, yes, yes. 2 MR. ROSEN: Well, argon as well. 3 MR. MURRAY: Yes. CHAIRMAN POWERS: Argon especially. 4 Especially. 5 MR. ROSEN: Yeah, we'll touch on this a 6 MR. MURRAY: 7 little more later on. Okay? 8 Now, staff has evaluated this, okay, and 9 we noted we have a safety function for the emergency 10 control room operators. They have a safety function to maintain habitability in these emergency control 11 12 rooms, and we did look at the values which they had proposed, and we noticed that these values are not 13 14 consistent with habitable conditions. All right? 15 They tend to be Level III or in some cases So what we concluded was the Level I 16 IDLH values. values, which we were discussing a moment ago, 17 18 approximate habitable conditions, and because of that 19 the staff is proposing a permanent condition which will state that an additional function of the ECR HVAC 20 21 system is to maintain chemical concentrations below 22 Level I values for the duration of the event. And the staff has concluded as 23 Okay? stated in the draft FSER that both the safety approach 24

WASHINGTON, D.C. 20005-3701

and the permanent condition should provide adequate

1	assurances of safety.
2	CHAIRMAN POWERS: Because I don't quite
3	understand. It seems like we're coming back and
4	saying, "Look. Putting IDLH values or even anything
5	that's close to it is not really what I want my design
6	basis for my HVAC system to be."
7	And so you're saying your design basis
8	should be something like Level I.
9	MR. MURRAY: Yes.
10	CHAIRMAN POWERS: Well, that's great. Has
11	the applicant said, "Oh, yeah. Sorry about that.
12	You're right"?
13	MR. MURRAY: Do you have any feedback,
14	Dave?
15	MR. BROWN: At this point, we're
16	discussing it. We have not had a meeting to discuss
17	this one.
18	CHAIRMAN POWERS: So there's a clear
19	difference between your position and the applicant's
20	position here.
21	MR. BROWN: Yes, there is.
22	CHAIRMAN POWERS: Why isn't this an open
23	item?
24	MR. BROWN: At this point, you know, we
25	have several options with this kind of review. We

1 have approved the applicant's proposal. We approve it with conditions or we deny it, and of course, this is 2 an approval with condition. 3 4 An open item is something we would carry 5 in, say, a draft SER leading up to a final conclusion, but this is our final conclusion. 6 7 CHAIRMAN POWERS: It seems to me there's 8 compromise position, which is uncommonly not 9 adopted, and that is that your design basis is to 10 assure once concentrations from the available sources 11 exceed the IDLH, you have 30 minutes within the 12 control room in order to take some action, which often 13 involves donning scuba gear and trying to operate the facility, which obviously is a plan designed by 14 15 someone who never tried to operate a facility in scuba But, I mean, it's not uncommon to adopt that. 16 17 There are compromise positions in here to 18 achieve the same safety function. Can you walk away 19 from this facility? I'm sorry? 20 MR. MURRAY: CHAIRMAN POWERS: Can you walk away from 21 22 this facility if you shut it down? Can you walk away? MR. BROWN: No, not immediately. What do 23 you mean by that though? I'm interpreting that as 24 25 having --

1	CHAIRMAN POWERS: I do a finite number of
2	shutdown stuff. Can I walk away from the facility?
3	MR. BROWN: Right. The design is intended
4	to be such that it will bring itself to safe shutdown
5	condition automatically.
6	CHAIRMAN POWERS: And I can just take a
7	hike at that point.
8	MR. BROWN: Right.
9	MR. SIEBER: Well, it wouldn't be as leak
10	tight as if the actions like ventilation were
11	functional. But you don't have decay heat or anything
12	like that to attend to.
13	MR. BROWN: But I did not interpret that
14	question literally, which is that we could walk away
15	and leave the building vacant and shut down.
16	For example, the ventilation system is
17	designed, especially the C4 confinement system, will
18	be always operable, never shut down.
19	MR. SIEBER: Right.
20	CHAIRMAN POWERS: Yeah. I mean, I think
21	what I meant by that was, yeah, the ventilation system
22	is working. It just doesn't need me there, and I can
23	go away for some protracted period of time measured in
24	days but not in weeks and think about it and then come
25	back and handle that, and you're saying, yeah, that

1	would be fine.
2	MR. BROWN: You could do that.
3	CHAIRMAN POWERS: That's good. I mean,
4	that's a good way to design these things.
5	MR. MURRAY: Yeah, an automated system,
6	automated plant.
7	MR. MAGRUDER: This is Stu Magruder from
8	the staff.
9	I just want to jump in and try to get to
10	your question about potential compromise on this
11	issue. I guess for various reasons there has not been
12	as much dialogue on this issue as there probably
13	should have been, and now that the applicant has had
14	a chance to look at the SER or the draft SER, we're
15	starting up discussions on this. There's a potential
16	that we could publish the final SER without this
17	condition. I mean it would be our goal actually not
18	to have any conditions in the
19	CHAIRMAN POWERS: And you understand my
20	problem, if I take in front of Chairman Wallis a
21	proposed position and he says, "Oh, but the SER
22	doesn't have anything to do with this statement right
23	here," he's not going to be gracious in his comments.
24	DR. WALLIS: I'm always gracious.
25	MR. MAGRUDER: I understand.

1	CHAIRMAN POWERS: I encourage you to go on
2	and discuss these things, but do let us know if
3	anything changes because I like to stay in Mr. Wallis'
4	good graces. He is not kind when he think you've done
5	him wrong.
6	MR. MAGRUDER: No, we definitely intend to
7	keep you informed. We've discussed
8	CHAIRMAN POWERS: He tends to compare you
9	to his sophomores.
10	DR. WALLIS: Or worse.
11	MR. MAGRUDER: We will get the errata to
12	the SER staff with exactly what's going on.
13	CHAIRMAN POWERS: I encourage you to go
14	ahead and discuss this because I think there's lots of
15	room in it, and we had exactly this problem on control
16	room habitability, is the initial proposal was, oh,
17	well, let's just use these IDLHs, and then we regaled
18	the presenter with stories about trying to put on
19	scuba in 500 ppm amonia and ask him if he would like
20	to do that and show us how that worked.
21	It does not work well.
22	MR. SIEBER: I'd like to go back to Dr.
23	Powers' question just for a second about walking away
24	from the plant. My impression is that you can't just
25	decide on the spur of the moment that you're going to

1 | 2 | 3 | 4 | 5 |

walk away if you have processes, batches in operation, for example, in order to protect a solvent extraction process. You have to deal with the chemicals that are there so that you don't end up with explosive mixtures and so forth before you decide to take a hike, before you walk away.

So you can't decide on the spur of the moment, you know, we've ha a seismic event or something else happened on the Savannah River site and we want to leave. You just can't leave at that point in time without finishing certain steps that are involved in certain of these batch processes, and then you can walk away.

And I think that is a more complete answer at least in my mind than to say, yes, you can walk away because you can't at any time. You have to, you know, do some things before you leave; is that correct?

MR. MURRAY: I agree with you, and from our review of the revised application and other correspondence on the docket, that it our interpretation of what the applicant is proposing. That's why there are two emergency control rooms. That's why they want to maintain habitability, because they'll be operators in those control rooms performing

1	safety functions, monitoring, slash, shutdown, safe
2	shutdown of the facility.
3	MR. SIEBER: Yeah, and in the licensee's
4	application, there is a discussion pretty far back in
5	the application of the emergency plan. They do have
6	an emergency plan. So it's there.
7	Okay. Thank you.
8	MR. MURRAY: Oh, you're welcome.
9	Any other questions on control room
10	habitability?
11	CHAIRMAN POWERS: Have we got control room
12	habitability covered adequately?
13	(No response.)
14	CHAIRMAN POWERS: Alex, you've going to
15	get a gold star from us here. You're getting way
16	ahead of time. I mean, I think these guys took you
17	must have fed them something for lunch. I don't know.
18	MR. SIEBER: Or we're groggy.
19	CHAIRMAN POWERS: Is Rex available to talk
20	to us? I propose that we go right on to his
21	discussion rather than taking a break.
22	PARTICIPANT: Aw.
23	CHAIRMAN POWERS: You just got out of
24	lunch, and you ate too damned much there anyway. It's
25	making you sleepy, and you've giving Alex a bye here,

1 and he's going to go home and say how disappointed he was because he didn't get interrogated enough at the 2 ACRS to hardly make it worth his while. 3 4 (Laughter.) 5 CHAIRMAN POWERS: Thank, Alex. 6 a good briefing. 7 MR. SIEBER: Thank you. MR. MURRAY: Thank you. 8 9 MR. WESCOTT: Okay. I guess I'm the slide 10 controller here. 11 Okay. Good afternoon. My name is Rex 12 I'm a senior fire protection engineer and was the ISA coordinator for the MOX CAR review. 13 I'm here this afternoon to talk about the 14 15 flammability issue. Basically four open items reflect the need for flammability control. One of the items, 16 17 open items, was CS-09, which is the design basis of 18 various solvent combinations and process vessels; AP-19 02, hydrogen generation in the electrolyzers; AP-08, off-gas unit flammable gases; and AP-09, which is the 20 off-gas unit solvent flammability. 21 Flammable and combustible materials can 22 initiate fires and explosions. They can initiate 23 flash fires, combinations just above the lower 24 25 flammability limit or at the lower flammability limit.

1	They can result in deflagrations as the concentrations
2	get somewhat higher, and they can result in
3	denotations in some cases when you start getting near
4	the stoichiometric mixture of flammable gases and air.
5	CHAIRMAN POWERS: You fire protection guys
6	can't put up a viewgraph without a triangle on it; is
7	that
8	(Laughter.)
9	MR. WESCOTT: Well, I've got something,
10	but I'd rather wait until I get to the end of the
11	presentation because if I start messing with it here,
12	I don't know what's going to happen.
13	CHAIRMAN POWERS: I've just got to harass
14	the fire protection guys.
15	MR. WESCOTT: All right.
16	CHAIRMAN POWERS: Well, fire protection
17	always begins with a triangle. It says you've got to
18	have fuel, heat source, and oxidant.
19	DR. WALLIS: Is that what it means?
20	CHAIRMAN POWERS: And so I think they're
21	congenitally required to have triangles on their
22	slides.
23	MR. WESCOTT: Well, actually it's being
24	taught as a trapezoid now. You have to have that
25	other part, which is basically close enough

1 combination so that you can get a continuous chain reaction with the fuel. 2 3 CHAIRMAN POWERS: Oh, you guys, anachronistic. 4 You getting quys are too 5 sophisticated. 6 MR. WESCOTT: Okay. The applicant 7 proposed a preventive strategy and adopted NFPA-69. This is the design basis, and NFPA-69 is the NFPA code 8 9 for explosion prevention. 10 Six areas of applicability were identified where you wanted to apply NPFA-69, and these are the 11 solvent recovery area, the oxalic precipitation and 12 mother liquor units, high temperature acid recovery, 13 14 that is, high temperature equipment in the acid 15 recovery area, low temperature equipment in the acid recovery, hydrogen from radiolysis, radiolysis like in 16 the waste area, and the electrolyzer units, were the 17 six areas where NFPA-69 criteria was to be proposed. 18 19 And also the sintering furnace was another area, but we had already accepted that for maintaining 20 21 25 percent -- well, that wasn't one of the open issues 22 that was discussed last time. CHAIRMAN POWERS: Do I understand why 25 23 percent of LFL? I mean, why not delta below LFL? 24 25 MR. WESCOTT: Yeah. Well, actually in

1 some areas it is even more. I think an underground fuel storage tanks, I think they go down even lower 2 3 than 25 percent LFL. 4 I was never on one of the code committees, 5 but what often these are, they're not arbitrary, but what they are is they're numbers that seem to present 6 7 a safe margin and at the same time are doable. 8 kind of reached by consensus. 9 CHAIRMAN POWERS: I mean, the rational 10 that was adopted for the Hanford tanks, for instance, was how fast could a rise in combustible gas be, and 11 how did that compare to your ability to detect it. 12 MR. WESCOTT: Right, exactly. 13 14 CHAIRMAN POWERS: And you know, after some 15 machinations and whatnot, they said, "Well, if we were at 25 percent of LFL, sure enough, we could probably 16 detect it before we exceeded it," for most of the 17 events that they knew about. 18 19 And the one that they couldn't do that on, 20 they remediated the tank. Now, that was a fairly rationale picking of 25 percent of LFL, but other 21 22 places who adopt this number I never understand because delta before LFL is fine. You aren't going to 23 propagate, and usually those LFLs are for an upward 24 25 propagating combustion event, not for a downward

1 propagating combustion event. I think one thing that has 2 MR. WESCOTT: 3 to be said about our review process here is basically because the design wasn't completed, there's a lot of 4 5 information that still hadn't been developed. We sort of set code compliance as probably one of the major 6 7 hurdles for the CAR review. Now, when we get into the 8 actual ISA review, I think we're going to start 9 looking at things like generation rates of hydrogen, 10 what actually happens to combustible solvents. Do we really have problem? Is 25 percent safe? 11 different 12 mean there's of ways controlling it. We have a rapid generation of gas. 13 14 Maybe the off-gas system could be designed to 15 continually provide a high flow of air. You know, we didn't want to try to dictate design at this point 16 17 because we're not at the design --18 CHAIRMAN POWERS: So presumably we could 19 find it going both ways, that if you were not getting a great deal of safety benefit from being a 25 percent 20 LFL, but getting a lot of operational headache, you 21 22 could move it up. 23 That's correct. MR. WESCOTT: 24 And if you found out CHAIRMAN POWERS: 25 that your detector response was slow to the generation

1	rate, you might move it down.
2	MR. WESCOTT: That's correct, or you might
3	worry about the off-gas system as a whole so that the
4	generation in the vessel you have a number of
5	options probably to go at.
6	CHAIRMAN POWERS: Now here you get to my
7	ignorance barrier. I know that when we burn hydrogen
8	at near the LFL in any kind of volume at all that you
9	get the most incomplete burn you ever saw in your
10	life. I mean, you're lucky if you get a third of the
11	hydrogen to combust at those levels.
12	MR. WESCOTT: Yeah, it depends on how well
13	mixed it is. If it's just
14	CHAIRMAN POWERS: You could put a
15	MR. WESCOTT: It's very inefficient.
16	CHAIRMAN POWERS: You can put a whirling
17	dervish in there, and you just can't get a complete
18	combustion, but I don't know that that's the case for
19	some of these organics because I don't know what their
20	LFLs are, to begin with. And I don't know whether
21	they're more complete in their combustion at down near
22	the level.
23	MR. WESCOTT: Well, you know, I think one
24	rule of thumb is that you get more complete combustion
25	as you get closer to stoichiometric levels because if

1 you're not at the stoichiometric level, of course, 2 you've got a lot of extra gas in there that's not 3 taking part in the combustion, just keeping the 4 molecules away from one another. 5 So I think, you know, the farther you are 6 away from the stoichiometric mixture I guess the less 7 complete your combustion, but as far as LFLs, there's 8 no real good rule of thumb. I used to think hydrogen 9 had a relatively low LFL, but then you look at 10 something like acetylene, which is even lower. 11 Propane is lower. A number of gases are lower LFLs, you know. 12 CHAIRMAN POWERS: Acetylene is down like 13 14 about one percent or something like that. I think one 15 percent, something like that? 16 MR. WESCOTT: For what gas? 17 CHAIRMAN POWERS: Acetylene. MR. WESCOTT: Yeah. I didn't know it was 18 19 that low, but it's probably close, and of course you 20 could almost have 100 percent atmosphere with 21 acetylene and still get combustion. You know, you don't need much air in there. 22 23 CHAIRMAN POWERS: You don't need much air, in general things are around three or four 24 but 25 percent, aren't they, like butane?

1 MR. WESCOTT: Yeah, I think they probably 2 range from two to five to six, something like that. 3 MR. MURRAY: So a low of about two, high 4 of about seven of LFL. Yeah, yeah. 5 MR. WESCOTT: Okay. Oh. 6 Moving on past 16, we also reviewed some other 7 quidance we looked at, too. We looked at NFPA-30, 8 which is combustible liquids codes because solvents 9 really kind of come under combustible liquids as 10 opposed to flammable gases. We looked at our NUREG 1718, our SRP. 11 12 looked at the Hanford tanks and what was done there. So we took into account a number of things to come to 13 our conclusions as to what to do and what would be 14 15 acceptable to us, and we also looked at electrolysis 16 and what were the factors that go into generating 17 hydrogen through electrolysis. NFPA-69 was the main standard that we 18 19 That was, of course, the standard looked at. 20 explosion prevention systems. It provides guidance on 21 oxidation reduction and concentration reduction, suppression of deflagrations, for example, containment 22 of deflagrations, and you know, spark detection and 23 24 extinguishing. It provides a number of ways of

preventing controlling explosions.

1 What we are primarily interested in and 2 also the applicant is primarily interested in was control of the concentration of the combustible or 3 4 flammable gas. That's probably the most straightforward way of controlling or preventing 5 6 explosion. 7 CHAIRMAN POWERS: How big is the gap 8 between the flammability limits and the detonation 9 limits on these organic gases? 10 MR. WESCOTT: Like I said, it differs. 11 You get detonation of hydrogen below the 12 stoichiometric limits and detonations require some turbulence. So if you have a turbulent atmosphere, 13 14 you're more likely to get a detonation than if you 15 have a non-turbulent type of atmosphere that your gas 16 is in. 17 So I think there's a number of factors 18 that determine whether you're going to 19 deflagration versus a detonation, but probably one of 20 the biggest factors is concentration. You're not 21 going to get a detonation, say, at LFL or just, you 22 know, slightly above. 23 CHAIRMAN POWERS: Hydrogen I'm acutely familiar with, but I don't have any familiarity with 24 25 things like butane and butanol and things like that

1 about, you know, where the relative displacement between flammability and detonation limits are. 2 Yeah. MR. WESCOTT: To be honest with 3 you, the only time I've basically worked with those is 4 looking at favor cloud explosions, and you always 5 assume a detonation because that's the worst case. 6 7 Now, I know that, you know, some cases, some areas are more prone to detonation than others, 8 9 but as far as being very aware of experiments where they've actually tried to look at all of the different 10 parameters, I'm just not aware of that. 11 Some of the basic considerations if you're 12 going to get into the concentration reduction that you 13 have to look at is first to determine how much you 14 want to reduce your concentration, whether you're 15 going to shoot for 60 percent or 25 percent or 50 16 17 percent. You've got to look at variations in process, 18 temperature, pressure, and materials, all of which can affect the generation rate of hydrogen. 19 Your operating controls, and you have to 20 have a maintenance inspection and testing program if 21 22 the kind of controls you're going to put on the system are going to be reliable and maintainable. 23 Now, the MOX standard review plan Okay. 24 also has guidance in regard to explosion control. 25

Chapter 7, which deals with fire, mentions a number of 1 2 codes and standards to use, such as NFPA-70, which is 3 the national electric code; NFPA-69 and NFPA-30; a 4 number of codes that I haven't listed dealing with 5 oxygen systems and hydrogen tanks and systems and so 6 on, but there's a number of codes which all should be 7 looked at to have a good explosion prevention program at your plant. 8 9 Chapter also mentions specific 8 10 interactions which can cause problems like radiolysis 11 and degradation of organics in high radiation fields, 12 and also requires you to analyze --13 CHAIRMAN POWERS: What kind of dose rates 14 are we going to get? Well, if you're talking 15 MR. WESCOTT: 16 about americium, which is primarily an alpha producer, 17 you're not going to get any dose outside of the 18 vessel, but you are going to get all of the energy 19 contained inside the vessel. I guess you have a high 20 G factor for generating hydrogen, and you're going to 21 get relatively efficient generation of hydrogen, but I wouldn't expect any dose outside the --22 23 CHAIRMAN POWERS: So the G factor for 24 hydrogen production in water is what, .45? 25 MR. WESCOTT: I'll turn to Alex for that.

1	MR. MURRAY: It depends on the source and
2	the chemical environment. I think there have been
3	some values which have been let me speak into the
4	microphone.
5	It depends on the environment, what's in
6	solution, and nitrates do tend to suppress hydrogen
7	evolution a bit. I keep wanting to say though some
8	values which can be higher than that, but I'd have to
9	go back and check.
10	CHAIRMAN POWERS: And then how does it go
11	with kerosene?
12	MR. MURRAY: I'm sorry?
13	CHAIRMAN POWERS: What's the G value for
14	hydrogen production in kerosene?
15	MR. MURRAY: I don't think we have a clear
16	G value for that. There has been some very good work
17	on G values done and reported in the past year or 18
18	months, and basically they were coming up with lower
19	G values than have been historically applied.
20	CHAIRMAN POWERS: My impression is the G
21	value for hydrogen in organic liquids is low, relative
22	to water, but if you asked me to prove that with
23	numbers, I'd be hard pressed.
24	MR. MURRAY: I'd have to go and look at
25	the specific data, and I don't have it on the tip of

1	my hand right now.
2	MR. WESCOTT: Okay. These are
3	recommendations on hydrogen supply. They come out of
4	the NRC SRP guidance.
5	CHAIRMAN POWERS: Hydrogen has to be
6	supplied?
7	MR. WESCOTT: For the sintering furnace,
8	for example.
9	CHAIRMAN POWERS: Yeah, but I mean, they
10	come in and they mix it with argon and they're not
11	just giving the hydrogen argon?
12	MR. WESCOTT: That's correct. It's 95
13	percent argon, five percent hydrogen or yeah, five
14	percent hydrogen.
15	CHAIRMAN POWERS: But, I mean, they're
16	going to do the mixing on site. They're not going to
17	just by the mixture.
18	MR. WESCOTT: That's my understanding.
19	Alex, do you know any more about that, that it would
20	be mixed down?
21	MR. MURRAY: For the most part, they will
22	be mixing the gases in what they call the gas storage
23	area of the proposed facility. All right? They have
24	a back-up supply of a cylinder mixture of hydrogen and
25	argon that's essentially ready mix, and they also have

1 a back-up supply of argon.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Okay. The hydrogen itself comes from cylinders, I guess, truck mounted cylinders. The argon comes from cryogenic storage.

And the concept, approach, if you will, of the applicant is if they go outside the ranges of the hydrogen limit from the pre-mixing operations, they will switch to the cylinder storage. If for any reason that isn't working or they have a flammability concern, they will switch over to pure argon going to the sintering fences.

to see the trade studies because in every case that I have encountered on this, it was way easier and cheaper just to go ahead and buy the gas mixture, the argon-hydrogen mixture that was below the LFL than it was to go through the agony of showing that you never got above the LFL and/or your mixing and manipulations and things like that. I mean it wasn't even close because when your source gas is below the LFL, there's not too many ways to ever get yourself above the LFL.

It would be an interesting trade study to look at on this one, not that it's pertinent to our business.

MR. MURRAY: It's interesting.

NEAL R. GROSS

1	CHAIRMAN POWERS: It's interesting, yeah.
2	MR. WESCOTT: If you don't mind I'd like
3	to skip to the last point on the next slide, which
4	basically just shows that the SRP really recommends
5	maintaining hydrogen below 25 percent LFL and all,
6	basically whenever possible. That was one of our
7	recommendations.
8	DR. WALLIS: Could you review what you've
9	been doing here for me? Have you been looking at
10	normal operation and concentrations of things in
11	various reactors or something or are you looking at
12	accidents? I don't see any mention of any inadvertent
13	mixing of flammable things with oxidants or anything.
14	What is this guidance applied to?
15	MR. WESCOTT: Well, I think our primary
16	concern about where we might get combustion is in the
17	off-gas system, when actually this gas is coming out
18	of the process vessels.
19	DR. WALLIS: So you are mixing it.
20	MR. WESCOTT: Mixed with air, and there
21	conceivably could be an ignition source, although
22	certainly everything will be done to prevent
23	DR. WALLIS: Is that just a flare? It
24	just goes up in the air?
25	MR. WESCOTT: Well, it depends on, of

1 course, where the combustion takes place, and I think 2 probably your worst case is probably a flash fire 3 inside the system. DR. WALLIS: Have you been look at off-4 5 design conditions or something? MR. WESCOTT: Well, I think we're going to 6 7 expect that to be done in the ISA stage. 8 DR. WALLIS: So some other stage. 9 Everything is always at some other stage. 10 MR. WESCOTT: Well, this, of course, is kind of a conceptual design at this place, and we're 11 actually more interested in strategies and the design 12 bases for these strategies as opposed to actual, you 13 14 know, final design parameters. 15 DR. WALLIS: There must be monitoring throughout the whole facility that you haven't got 16 17 leaks of combustibles and all of that. That's not 18 part of this at this stage? MR. WESCOTT: Well, you know, one of the 19 things I should have said on the first slide is we 20 very carefully said flammable gases and combustible 21 22 liquids. To our knowledge, there are no flammable 23 liquids actually in the processes, you might have some in the laboratory, you know, things like alcohol and 24 25 acetone and things like that, but your primarily

are 1 liquids combustible. They're not process 2 flammable, and by that I mean that you don't have a 3 flammable vapor generation until you get up over 100 4 degrees Fahrenheit. 5 So leaks of the liquids themselves at nonelevated temperatures really don't present a fire 6 7 hazard as such. So I think that's a point that needs to be made because that's a good question. 8 9 dealing with flammable liquids, we would have concerns 10 about leaks and things outside of these particular 11 areas. CHAIRMAN POWERS: I'm struggling a little 12 bit on that. 13 14 MR. WESCOTT: Sure. 15 CHAIRMAN POWERS: I mean, I understand 16 you're arguing with. You're arguing that dodecane just doesn't produce enough vapor to amount 17 to anything at modest temperatures. 18 19 Right. MR. WESCOTT: 20 CHAIRMAN POWERS: But what you've got is 21 dodecane with tributyl phosphate in it, which is 22 rapidly becoming dibutyl phosphate and putting a little butanol into the system. 23 Now, butanol does have vapor pressure. 24 25 MR. WESCOTT: I'm not sure of the

1	chemistry. Alex, do you know the flash points of
2	change with the combinations?
3	MR. MURRAY: The applicant has identified
4	flash points for the diluent, the TBP, and the mixture
5	of the diluent and TBP. Okay? For the diluent
6	itself, it's approximately 55 or so degrees
7	centigrade. For the mixture it's approximately 57
8	degrees centigrade, and for tributyl phosphate, it was
9	quite a bit higher. I forget the exact value.
10	CHAIRMAN POWERS: Yeah, but if I take this
11	stuff and I bang it around, heat it, throw a few alpha
12	particles through it, now I've got a much more
13	complicated mixture.
14	MR. MURRAY: That's right.
15	CHAIRMAN POWERS: And in particular, it
16	has butanol in it, unavoidably has butanol in it.
17	MR. MURRAY: Right, right.
18	CHAIRMAN POWERS: It may have some other
19	various zoology of organics of small chain link in it.
20	Now it has vapor pressure, significant vapor pressure
21	at room temperature. You can smell it.
22	MR. WESCOTT: Yes, I agree.
23	CHAIRMAN POWERS: Now what's the flash
23	CHAIRMAN POWERS: Now what's the flash point?

looking at design bases. Are the design bases appropriate? NFPA-69 does give you some top level, if you will, design basis type guidance as to what would be reasonable, what would be general practice, if you will.

Maintaining vapor concentrations below 25 percent of their respective LFL is a design basis. Now, depending on what the mixture is at the plant, at the license application stage, the applicant will have to demonstrate that under all circumstances they meet the NFPA-69, which they've used as the design basis.

CHAIRMAN POWERS: But what I'm struggling with is if you tell me to keep the vapor concentration of dodecane below 25 percent of its LFL, I'm a real happy camper because it's going to be damned difficult for me to get it up to the LFL.

Okay. If you tell me to do the same thing with butanol, I have got a problem.

MR. WESCOTT: Yeah, one of the things that that NFPA-69 requires that you have to do is that you really -- and this is another reason why I think we want to wait until the design stage. You really have to know the partial pressures of all your different gases and your environment, and once you know the partial pressures, you can take a ratio of the partial

1 pressure to the LFL for all of these gases and add them up and they become the divider to the total 2 3 pressure that you have. It's a Le Chatlier's Law. And that's how you determine the LFL of 4 5 mixture, but until you know these partial pressures, there's really no way to calculate it. 6 7 CHAIRMAN POWERS: Yeah, I don't know about 8 hydrogenated propylene tetramer, but I do know about 9 dodecane butanol mixtures have been investigated for 10 their non-ideality because it was one of the many 11 pains in the neck that occurred up at the Hanford tanks, and so somebody had to go off and do it. 12 So I don't know if we can routinely do the 13 14 partial pressure calculation here or not. 15 MR. WESCOTT: You know, from most of my experience, and that's with hydrogen, and that also 16 17 involves reactors, we generally approach the problem 18 through dilution, and instead of worrying about just 19 exactly where the LFL is, we provide enough dilution, and the same with the Hanford tanks. You provide 20 enough dilution so that you're nowhere near the LFL. 21 22 And I think with some of these situations 23 maybe that's going to have to be the solution, and your main alarm is not if you've approached LFL, but 24

if you've lost air flow. You know, and then you --

25

1 CHAIRMAN POWERS: Well, I just want to ask When you take 25 percent of LFL as a design 2 3 basis for 60 percent with automatic tracking, which I 4 think is what you actually say, it's 25 percent of what. 5 Like I say, if it's 25 percent of the LFL 6 7 for dodecane, Ι mean, I've got some design flexibility, shall we say? But if it's 25 percent of 8 the actual combustibility of the liquid you would 9 really have there, which it should be, then you've got 10 11 a much more challenging thing. 12 MR. WESCOTT: Well, yes, you do. I mean, if you've got other gases that have low flammability 13 levels coming off in significant quantities at the 14 15 temperature, you've got to calculate what your LFL really is for the mixture. There's no way around it. 16 17 CHAIRMAN POWERS: So I guess what I'm 18 asking you is it's 25 percent of LFL what. Of liquid? 19 MR. WESCOTT: Of what they actually do. MR. MURRAY: What they actually have, yes. 20 MR. WESCOTT: Yeah, that's right. 21 22 MR. MURRAY: Now, if they have proposed a 23 methodology for determining LFL and LFLs of mixtures and we've looked at that. it is based on the standard 24 Le Chatlier's principle. Again, that is something 25

that is usually used in plants, process, industry plants, and you know, we have concluded that what they proposed is reasonable for mixtures.

Now, I'll also add there's a question about measuring hydrogen. The applicant has identified industry code standard, I guess I should say, for both the type of hydrogen/flammable gas censor and also its spacing. Okay? So that design basis is in there, and I believe it's for areas where either the hydrogen line runs through or a hydrogen type generation can occur.

MR. WESCOTT: Okay, and this is the hanford tank experience that we were talking about and you had mentioned that hydrogen is not to exceed 25 percent of the LFL, and this was based on, you know, the actual physics, the overturning type of thing, the rapid increase in hydrogen concentration and their interpretation of NFPA-69.

This is electrolytic hydrogen. It's hydrogen formed from electrolysis, and this shows how the concentration of nitric acid in the solution can control the hydrogen generation. As your molar concentration of acid increases, your ability to generate hydrogen basically decreases, and so that becomes the control on electrolytic production of

1 hydrogen, is maintaining the --2 DR. WALLIS: Circles don't do a very good 3 job of going through any of them relating to the curves. 4 5 MR. WESCOTT: Well, --CHAIRMAN POWERS: Actually my reaction to 6 7 that was totally different, Graham. I said for electrochemical data, that's fantastic. 8 9 (Laughter.) 10 MR. MURRAY: That was my reaction as well. MR. ROSEN: Peter, can't you get your 11 12 electro materials to behave better than that? 13 CHAIRMAN POWERS: It's especially bad with 14 stainless steel. You should have spent more of your career working in plastics, Peter. 15 Well, that's what we did 16 DR. WALLIS: 17 finally. 18 MR. MURRAY: I just want to mention this 19 curve is in the open literature. It comes from some 20 experimental work performed Pacific of the at Northwest Lab, and the important parameter here is if 21 22 you notice this is a hydrogen concentration in the 23 involved gases, and one percent is nominally 25 Okay. LFL and hydrogen under 24 percent of the LFL. 25 normal conditions is about four percent, right?

1	And you can see if you're above about a
2	two normality, two normal nitric acid solution, that
3	both of these curves are clearly below the 25 percent
4	of the LFL.
5	DR. WALLIS: But all of the data are, too.
6	MR. MURRAY: Yes, yes, yes. Now, again,
7	we're doing the construction application review. All
8	right? And we're looking at the fluidability of the
9	proposed control, which is to control the nitric acid
10	concentration, which is a catholyte, by the way; it's
11	nitric acid.
12	All right. It's very clear that, hey, if
13	I go to higher acid concentration, I am definitely
14	below the LFL based on this data. Now, for the
15	specific electrode materials, which the applicant
16	decides upon in the final design, we would look for
17	some assurance that, you know, this type of phenomena
18	still applies.
19	But it's very clear you can control
20	hydrogen generation under normal conditions by nitric
21	acid concentration.
22	DR. RANSOM: In any of these applications
23	do they consider recombiners?
24	MR. MURRAY: There's no proposed
25	recombiner in the current MOX design.

1	MR. WESCOTT: One thing I might add is
2	we're talking about concentrations basically inside
3	process vessels. We don't have any situations where
4	we've got, say, concentration inside a containment
5	structure or anything this large.
6	DR. WALLIS: Well, this figure here, this
7	is mole concentration in what?
8	MR. MURRAY: Oh, this is in the gaseous
9	base or gaseous.
10	DR. WALLIS: So what's the other phase?
11	MR. MURRAY: This is the liquid phase,
12	catholyte.
13	DR. WALLIS: What's the other gas?
14	MR. MURRAY: I'm sorry?
15	DR. WALLIS: What is the other gas?
16	MR. MURRAY: Some of the other gases they
17	get here are NOX, N ₂ O, NO ₂ . I'm sorry?
18	DR. WALLIS: There's air presumably if
19	that's what you're worried about?
20	MR. MURRAY: They do get some nitrogen,
21	okay, but understand this Y axis here refers only to
22	the gases which are evolved. It doesn't refer to any
23	cover gas. All right?
24	DR. WALLIS: So you're evolving something
25	else.

1	MR. MURRAY: Yes, nitrogen oxides and
2	nitrogen. Again, it's an artifact of using nitric
3	acid as the catholyte. If you're putting electrical
4	current across nitric acid, you do get some reduction
5	at the cathode, and some of the reactions are
6	mentioned in the FSER. All right?
7	DR. WALLIS: And this is the hydrogen
8	concentration in NOX to prevent a NOX-hydrogen
9	reaction. Is that what you're talking about?
10	MR. MURRAY: I'm sorry?
11	DR. WALLIS: Are you talking about a NOX
12	hydrogen reaction or an air hydrogen reaction?
13	MR. MURRAY: Because the ullage space
14	above the electrolyzer in the proposed plant would be
15	an airspace, okay, our concern would be for it in an
16	airspace. However, what this says here
17	DR. WALLIS: Hydrogen will react with NOX,
18	won't it?
19	MR. MURRAY: It depends on time,
20	concentration, and temperature.
21	DR. WALLIS: Right, on concentration.
22	MR. MURRAY: Yes, under certain
23	circumstances it can react with NOX.
24	CHAIRMAN POWERS: Yeah, but did Joe
25	Shepherd look at the combustion limits on there and
	NEAL D. ODOGG

1	find out that they're actually not as bad as air?
2	MR. MURRAY: I think he did, but I'd have
3	to
4	CHAIRMAN POWERS: It takes more effort to
5	react with NOX.
6	MR. MURRAY: Yeah. In the case of NOX-
7	hydrogen reactions, they tend to require a much higher
8	initiating energy, if you will, to get ignition. In
9	addition, the ranges, flammability ranges are much
10	higher.
11	CHAIRMAN POWERS: The lower flammability
12	limits like five or six percent or something like
13	that.
14	MR. MURRAY: Yeah, yeah, yeah.
14 15	MR. MURRAY: Yeah, yeah, yeah. CHAIRMAN POWERS: So, I mean, the answer
15	CHAIRMAN POWERS: So, I mean, the answer
15 16	CHAIRMAN POWERS: So, I mean, the answer is yes, but if you can meet the air criterion, you're
15 16 17	CHAIRMAN POWERS: So, I mean, the answer is yes, but if you can meet the air criterion, you're okay in $N_2\text{O}.$
15 16 17 18	CHAIRMAN POWERS: So, I mean, the answer is yes, but if you can meet the air criterion, you're okay in N_2O . MR. MURRAY: Yes. Any other questions on
15 16 17 18	CHAIRMAN POWERS: So, I mean, the answer is yes, but if you can meet the air criterion, you're okay in N_2O . MR. MURRAY: Yes. Any other questions on this Figure 4 from the electrolyzer?
15 16 17 18 19	CHAIRMAN POWERS: So, I mean, the answer is yes, but if you can meet the air criterion, you're okay in N_2O . MR. MURRAY: Yes. Any other questions on this Figure 4 from the electrolyzer? (No response.)
15 16 17 18 19 20	CHAIRMAN POWERS: So, I mean, the answer is yes, but if you can meet the air criterion, you're okay in N2O. MR. MURRAY: Yes. Any other questions on this Figure 4 from the electrolyzer? (No response.) MR. MURRAY: Okay.
15 16 17 18 19 20 21 22	CHAIRMAN POWERS: So, I mean, the answer is yes, but if you can meet the air criterion, you're okay in N2O. MR. MURRAY: Yes. Any other questions on this Figure 4 from the electrolyzer? (No response.) MR. MURRAY: Okay. MR. WESCOTT: And here's the last figure,
15 16 17 18 19 20 21 22 23	CHAIRMAN POWERS: So, I mean, the answer is yes, but if you can meet the air criterion, you're okay in N2O. MR. MURRAY: Yes. Any other questions on this Figure 4 from the electrolyzer? (No response.) MR. MURRAY: Okay. MR. WESCOTT: And here's the last figure, our conclusions, and basically the staff accepts the

1	as a design basis. Staff will review implementation
2	to check to make the proposed interlocks where they're
3	proposing a 60 percent level, for example, or 50
4	percent, can perform their safety functions adequately
5	to prevent an explosion or a fire.
6	The applicant has different strategies to
7	pursue, a number of ways of arriving at the desired
8	result. Clear calculation on an experimental basis
9	will be needed. For example, what actually is the
10	behavior in terms of vapor pressures and LFL? So the
11	actual solution that's in there.
12	DR. WALLIS: Those are the things we see
13	later?
14	MR. WESCOTT: Those are the things, right,
15	that we will be looking at during our review.
16	You know, a review, of course, is an
17	audit. I mean, we'll look at where we think the
18	problems are, but we'll probably be looking at this
19	in some detail, and we consider it acceptable for
20	construction under the proposed strategies.
21	DR. FORD: Would you mind just going back
22	to the previous diagram?
23	MR. WESCOTT: Sure. Oh, boy.
24	(Laughter.)
ı	-

1	the computer would.
2	MR. WESCOTT: Let's see. There we go.
3	Wow, I got over this one.
4	MR. MURRAY: Science is wonderful.
5	DR. FORD: In order to get a reasonable
6	efficiency in terms of the reaction you're trying to
7	do, you've got to have a certain nitric acid
8	concentration, don't you?
9	MR. WESCOTT: Yes.
10	DR. FORD: So what is that value? I think
11	I saw six molar nitric acid mentioned somewhere, I
12	think. Is that right?
13	MR. WESCOTT: I believe that's in the SER.
14	DR. FORD: So you're stuck at six molar;
15	is that right?
16	MR. WESCOTT: Could you explain what you
17	mean by "stuck at six normal"?
18	DR. FORD: In order to have an efficiency
19	in the process you're trying to do, you presumably
20	want to have as high a nitric acid concentration as
21	possible; is that right? No?
22	MR. WESCOTT: Well, you're talking
23	efficiency now. So that's sort of outside the range
24	of a safety review, but let me just comment.
25	DR. FORD: Yeah, okay.

1	MR. WESCOTT: Let me just quickly comment
2	on that. Because of the type of reactions that are
3	going on and design of typical cells like this, your
4	electrodeficiencies may be quite low, 50 percent tops,
5	something like that.
6	A lot of the electrical energy ends up in
7	either heat or other auxiliary reactions occurring at
8	the electrodes. Okay? And one of them
9	DR. FORD: I was just trying to work out
10	what the message from this diagram was in terms of
11	managing your flammability aspect. Obviously you want
12	to have as high a concentration as possible.
13	MR. WESCOTT: Exactly. If you increase
14	your asset concentration, okay, and again, this is
15	around the cathode, all right? This diagram shows
16	that you can control the evolution of hydrogen, i.e.,
17	you can keep it below the 25 percent of LFL limit. If
18	you had no air sweep or no ventilation on this system,
19	this would be the hydrogen concentration evolved in to
20	the ullage space.
21	MR. BROWN: Alex, if I may interrupt.
22	MR. MURRAY: Sure.
23	MR. BROWN: This data is for an
24	electrolyzer of some design, not necessarily of the
25	plant we're looking at. This curve would essentially

1	have to be reestablished for the final design.
2	DR. WALLIS: Yeah, i was going to ask:
3	aren't there some other variables to determine this?
4	MR. BROWN: Right. The size and shape of
5	the electrolyzer, I'm sure, the current densities, and
6	that sort of thing.
7	MR. ROSEN: What we heard earlier would be
8	tantalum and it won't even be platinum. Maybe it
9	might be
10	MR. BROWN: I believe the material
11	platinum cathode is right, as shown here. What's
12	intended by this figure is the concept of generation
13	control with nitric acid concentrations. The data
14	will be different.
15	DR. FORD: It's also telling you that if
16	the licensee wanted to use platinum, that would
17	increased the efficiency of his process. You'd say,
18	"Hold on a bit. You can't go too far in that
19	direction because you're going to increase my
20	flammability aspect."
21	CHAIRMAN POWERS: No, I wouldn't say that
22	at all. I would say, "Look. It doesn't matter
23	whether I use stainless steel or platinum." I mean,
24	these are
25	DR. FORD: As long as you blow

1 CHAIRMAN POWERS: As long as I'm below, I mean, it doesn't matter. You can never 2 I'm below. 3 get this gas to be combustible, unless I run it into 4 something that's going to freeze out whatever the 5 diluent gas is. I mean, I'm fat here. This is great because he's going to have to stay above three molar 6 7 to keep from precipitating out the plutonium dioxide 8 to begin with. 9 Now, I can imagine current density makes a difference and material makes a difference, but I 10 11 imagine geometry really making much of a difference here, can you? I mean, it doesn't seem 12 like it because it all depends on what the over 13 14 voltage of hydrogen is, the over potential on hydrogen 15 production at the electrode is. MR. MURRAY: That's correct. 16 17 DR. FORD: Your stir rate is going to 18 affect it. The hydrogen evolution is going to be 19 diffusion control to a large extent. The reason for 20 my question was --CHAIRMAN POWERS: The total amount of 21 22 hydrogen I produce, but not the gas production here. I mean, as a fraction of the gas production rate why 23 would it affect that? I'd have to think about that a 24 25 little bit.

1 DR. FORD: Well, the reason for 2 question was flammability, managing the flammability 3 aspect, you would use such data to essentially 4 yourselves that using different reassure even 5 materials, which you might use for various business 6 reasons, you're still well within your flammability 7 limit. That's essentially the message from this 8 diagram; is that right? 9 MR. MURRAY: Partially right. The main 10 message from this diagram is, yes, you can control hydrogen evolution and keep it below the LFL by 11 12 controlling the nitric acid concentration. That's the 13 main message. 14 So there will be some bumps on these curves for different electrodes. 15 Okay? I haven't seen any information on, say, tantalum. 16 Is it in the 17 middle if it's a palladium coated? Is it above 18 platinum? 19 But the basic concept that this control philosophy of using nitric acid to control hydrogen 20 21 generation is a reasonable approach. DR. DENNING: Could you take me back to --22 23 I'm trying to read the slide up here -- 66, I guess? 24 CHAIRMAN POWERS: What, are you testing? 25 It takes him quite a while. You're a little bit slow

1 on the uptake here, aren't you, Rich? DR. DENNING: Okay. These are the six 2 3 areas of applicability that you were considering. 4 Could you then interpret for us again your bottom line conclusion? 5 I have the feeling that what you've done 6 7 here is rather than looking at these areas in detail and seeing how the applicant is going to demonstrate 8 satisfaction, that what you've really developed is 9 more criteria that they have to satisfy. You don't 10 11 know exactly how they're going to do it at the moment. 12 You just have developed criteria. Is that a fair 13 comment? WESCOTT: I think that's a fair 14 MR. 15 Now, they have made proposals as to how statement. they intend to do it, and I think in many of these 16 ways they're going to be -- some of them are going to 17 18 be looking at temperature control. Of course, in the 19 electrolysis area they're looking at nitric acid I think there may be a few --20 control. DR. DENNING: Is that the way I interpret 21 22 like in number three? The PSSC is high temperature 23 control in acid recovery. Is that what you're implying here or am I not -- or is it that's the 24 25 concern?

1 MR. BROWN: That's the concern. 2 MR. WESCOTT: Yeah. 3 MR. MURRAY: This is merely a title for 4 the area of applicability. DR. DENNING: Area of applicability. 5 6 as far as the risk that they can't satisfy these, I mean, obviously DOE is the one who really has a risk, 7 and they're going to go ahead and they're going to 8 construct under the assumption that they can satisfy 9 10 the criteria that you've established, and then if they 11 can't satisfy those criteria, then they may be forced 12 to go back in and do some system redesign to be able to do that. Is that --13 MR. WESCOTT: 14 That's always possible. 15 mean, if they can't satisfy it with temperature, they may have to look at redesigning their off-gas system 16 17 to get possibly more dilution or something like that. 18 I mean that's certainly possible.. 19 DR. DENNING: It just isn't exactly clear 20 to me how far you have to go in deciding they're ready to go ahead and construct, you know, since I don't 21 22 think -- but I may be wrong -- that you've looked at 23 this in real detail because all you've done is really kind of established the criteria rather than really 24 25 looking and saying, yeah, I'm fairly confident that

1	the PSSC that they have established is going to be
2	satisfactory and meet that criteria.
3	MR. WESCOTT: That's exactly right.
4	That's the kind of conclusion we're coming to from a
5	safety assessment standpoint that we expect that they
6	will be able to satisfy the performance requirements
7	of the regulation, but we will verify that when we see
8	the final design.
9	MR. MAGRUDER: Let me just clarify a
LO	little bit. We have also to reach the conclusion that
11	we have reasonable assurance that they can meet the
12	criteria. I mean, it's not just, yes, that this is
L3	the right standard to apply, but we also have to have
L4	some confidence that what they're proposing or that
L5	there is a feasible approach to meet the requirement.
۱6	MR. WESCOTT: Right. We don't see any of
L7	these problems are requiring a total redesign of their
L8	process, you know.
L9	MR. ROSEN: On the other hand, DOE can
20	take no comfort from this approval of construction.
21	The burden is still really on them to come up with
22	designs that through the ISA process you can agree
23	meet these criteria.
24	MR. WESCOTT: Yeah. I mean, really when
25	you look at the regulation, most of the emphasis on

1 CAR review is, of course, on structural design and 2 I mean, we're trying to avoid situations 3 that can't be undone, you know, which I think is the main emphasis where process design is probably where 4 5 we don't want to force them to redesign their whole process either. 6 7 But I think we tend to feel that the designs to meet the performance requirements that we 8 9 have approved will be relatively minor differences. I will add that in some 10 MR. MAGRUDER: areas we've pressed them pretty hard to make sure that 11 we were satisfied that there is a feasible approach 12 out there, but the question is, you know, the million 13 14 dollar question is: how far do you have to go to 15 satisfy yourself that the construction is okay, as opposed to waiting for the detailed design. 16 MR. MURRAY: You know, just to clarify 17 this a little bit more, the applicant has committed to 18 an NFPA-69, a code, if you will. That code outlines 19 a number of approaches, activities with different 20 limits which would, if you will, prevent a flammable 21 22 event from occurring. All right? There is a general limit identified, which 23 is 25 percent of the LFL. In addition, there's also 24 an exception which can be up to 60 percent of the LFL 25

if automatic interlocks are available and reliable.
All right?

In the revised construction authorization request, the applicant for two of those areas of applicability wanted to propose and did propose interlocks. All right? The staff looked at what the applicant had proposed, and we had no clear calculational or other basis at this time to say that, yes, these PSSCs, these interlocks, if you will, could function the way NFPA-69 anticipates.

All right. So the staff took a step back and said, "Okay. We understand you want to follow NFPA-69. We know NFPA-69 has been applied to situations like this. We think we can accept it as a design basis, and we put the onus on the applicant that in the license application if they wish to pursue, if you will, interlocks, then they're going to have to get a very clear, calculational basis as to why those interlocks should function and, if you will, maintain safety, perform the safety function, I should say.

Does that help or did I confuse the situation more? Dana is smiling. That's a good sign.

MR. ROSEN: Well, I'm smiling because I'm thinking about the 2,700 pages we've looked at

1	supposedly, and the promises you've made about the
2	rather lengthy detail that will be included in the ISA
3	compared to what we now have. The estimate to the
4	Chairman was 27,000 pages, but maybe I'm off by a
5	factor of two.
6	MR. MURRAY: You're probably in the
7	ballpark. It will be several thousand pages in the
8	ISA at least.
9	CHAIRMAN POWERS: Yeah.
10	MR. ROSEN: Well, I'm thinking about the
11	final. Is there another document from applicant
12	that
13	CHAIRMAN POWERS: Yeah, that's the ISA.
14	MR. ROSEN: upon which yeah, the ISA
15	itself, 10,000 pages; your analysis of the ISA, 5,000
16	pages.
17	CHAIRMAN POWERS: No, they're just saying
18	it looks good to us.
19	MR. SIEBER: You mean the operating
20	license application.
21	MR. BROWN: Just to clarify
22	MR. ROSEN: Put it on a scale of three
23	significant digits.
24	MR. BROWN: There is a bit of a nuance.
25	Since the applicant is required is required to

1 complete an ISA and submit an ISA summary, so there is 2 a much more substantial ISA available for staff review that's not provided on the docket. 3 4 it's CHAIRMAN POWERS: Ι mean, also 5 available to us to review as well, but at facilities. 6 7 MR. BROWN: Correct. 8 CHAIRMAN POWERS: And as you may have 9 detected in some of the questions, I think it's 10 unavailable to actually go down and spend some while 11 looking at that to at least spot check it. MR. ROSEN: Where is that? 12 13 CHAIRMAN POWERS: It doesn't exist now. 14 MR. ROSEN: No, but where would be go? 15 CHAIRMAN POWERS: Savannah River. 16 DR. WALLIS: Can't these 10,000 pages be 17 boiled down to something we can digest. 18 MR. SIEBER: Yeah, two slides. 19 In particular, five key DR. WALLIS: 20 things like red oil runaway reactions and hydrogen 21 flammability and so on, why can't that be put into a 22 small volume in which the essence of what we need to know is contained instead of us having to dig through 23 this mountain of stuff? Trying to get somehow on a 24 25 computer that diagrams so that we can see them and not

1 spread over several pages, isn't there some 2 someone can concentrate it for us so we can look at what we need to see and not everything else? 3 4 CHAIRMAN POWERS: My experience has been 5 that, yes, no trouble at all. I could get it down 6 into the five things that you are interested in. 7 Unfortunately, the five things you're interested in 8 are not the same as the five things that Peter is 9 interested in, which are totally orthogonal to the 10 five things that Jack is interested in. 11 DR. WALLIS: But I mean things for the decision making, that's all I care about. I will be 12 interested in them if they matter. 13 It's not a 14 question of --15 CHAIRMAN POWERS: Well, I mean, the things that are put into this document, I mean, it seems to 16 17 me that one can make an argument that they all matter. DR. WALLIS: Well, let's see. 18 Which 19 things can the ACRS have any influence on that's been 20 on -- where can we add value. We're not going to add value on 10,000 pages. 21 CHAIRMAN POWERS: Well, right now we don't 22 23 have to deal with the 10,000 pages. Let's deal with our 2,700 right now. 24 25 Anything else on the flammable gas issues?

1	MR. WESCOTT: I had one slide, but I'm
2	afraid to go after it because I don't know what
3	DR. WALLIS: You have a flammable slide?
4	(Laughter.)
5	DR. BONACA: I would like to just ask one
6	more question regarding this issue. I think from this
7	conversation that we're having now, it seems as if
8	we're talking about purely conceptual design here with
9	no reference of experience or anything out there about
10	how possibly successful these measures can be.
11	But my understanding and, you know, I'm
12	not an expert in this area but my understanding is
13	there are facilities using very much these kind of
14	processes.
15	We also visited a facility in Avignon
16	which I thought
17	MR. WESCOTT: Absolutely.
18	DR. BONACA: So I mean, there is more than
19	just a sense that probably
20	CHAIRMAN POWERS: I mean, I thought that
21	that was Alex's point. A standard exists. We know
22	the standard has been applied to similar facilities.
23	Therefore, it's plausible that I mean, I think
24	that's what he said.
25	DR. BONACA: Yes, but I think you know,

(202) 234-4433

1	one of the reasons that I have been curious about this
2	as it evolved is that for normal reactor facilities,
3	we don't go through a conceptual design approval
4	phase. I don't think there is a separate phase in the
5	licensing process.
6	MR. ROSEN: There used to be a PDAR and
7	the FSAR. Now we have one COL.
8	DR. BONACA: Yeah, yeah.
9	MR. ROSEN: It's very analogous to what we
10	used to have.
11	DR. BONACA: It's very analogous probably.
12	Well, it is.
13	CHAIRMAN POWERS: I mean, it seems to me
14	that this has some advantages in that it was clear,
15	for instance, that in the original application the
16	applicant did not consider titanium fires to be a
17	hazard. And so the NRC was able to say at that stage,
18	yeah, you need to think about this. Put in some PSSCs
19	here, rather than hitting them after he had
20	essentially completed the design.
21	MR. ROSEN: Poured the concrete.
22	CHAIRMAN POWERS: And so I mean, it makes
23	sense. It's a little bit frustrating for the staff,
24	a little bit frustrating for us because every time we
25 25	ask you. okay. what was the tradeoff study on the

2

3

4

5

6 7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

particular width and dimension of the electrolyzer or something, well, nobody has that information right now. We'll get over it.

DR. BONACA: One of the encouraging things
I seem to have heard through these meeting is that
there is an expectation that the level of safety for
this facility seems to be much more automated. It
would be higher than existing facilities in the U.S.
now, and that's what I believe yours is probably, I
mean, from what I got from your comments.

MR. SIEBER: I'm not sure that gives us if you know what I mean. One of interesting things that I think sort of sums up the attitude of the applicant is that they write in their Chapter 15 of the application, which is entitled "Emergency Planning," that because of the controls that are established in the construction of the plant that the applicant intends to prove they don't need to have emergency planning, even with the shrunken uncontrolled area that they have, which I guess I keep pondering that statement over and over again to make sure in my mind. You know, that's a pretty high hurdle to put out there and prove that you don't need any kind of emergency planning.

CHAIRMAN POWERS: I can't imagine the site

NEAL R. GROSS

1	letting them do that.
2	MR. SIEBER: I think that they intend to
3	participate in the site's emergency plan, but it
4	seemed to me that from the standpoint of the hazard
5	from this facility it doesn't extend beyond the owner
6	controlled boundaries, but obviously there are other
7	things at the Savannah River plant, too.
8	CHAIRMAN POWERS: Yeah, there are a lot of
9	things going on at Savannah River.
ro	MR. SIEBER: There's more than this going
11	on there. At least there was the last time I was
12	there.
13	DR. WALLIS: There's no emergency plan for
L4	this plant?
15	MR. SIEBER: Well, Chapter 15 says the
16	applicant establish emergency planning isn't needed.
L7	DR. WALLIS: Because events are so
18	unlikely?
19	MR. SIEBER: It doesn't say "because." It
20	just says they intend to show that it is not needed.
21	MR. ROSEN: Basically they have prevented
22	all of the events is why, is what they've said.
23	MR. SIEBER: Well, to me that shows a
24	measure of confidence that I think
25	MR. ROSEN: One hundred percent of the

1	time.
2	MR. SIEBER: poses a challenge to me,
3	anyway.
4	DR. WALLIS: Well, the introduction talks
5	about things like aircraft and so on, and we don't
6	believe that would require an emergency plan.
7	CHAIRMAN POWERS: I believe actually those
8	things were screened out.
9	DR. WEINER: Yeah, they were screened out.
10	DR. WALLIS: We just don't want to
11	consider them?
12	DR. WEINER: There is a site emergency
13	plan for Savannah River, and they could at least have
14	said
15	DR. WALLIS: Well, they said that. They
16	recognized the site has an emergency plan.
17	CHAIRMAN POWERS: Let's let Rex get
18	through this. Are you done, Rex?
19	MR. WESCOTT: Yes, sir.
20	CHAIRMAN POWERS: Okay. What I propose,
21	that we go ahead and take a
22	MR. MURRAY: Dana, we just have like three
23	more slides to finish off.
24	CHAIRMAN POWERS: I know. I want to go
25	ahead and take a break.

MR. MURRAY: Okay.

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

CHAIRMAN POWERS: And come back and that will give us -- there's a method to my madness here. I'll let you go through your three sides, but I think we wanted to go through a little more discussion before we move on to the next issues.

> MR. MURRAY: Okay.

CHAIRMAN POWERS: And we've got a little I think we're still struggling a little bit philosophically here. Maybe give us a few minutes just to discuss things a little bit because we have really two chores here. One of them, which is directly pertinent to you, is to say out of all this material you've put together, plus a huge amount of introductory material that probably is necessary for the full committee, that, you know, what fraction of that should you really want to present, and I invite you to participate in that discussion.

We need to give you some sort of marching orders or guidance on that because you will have at most a two-hour period, and they will not want you to talk for more than an hour. That means a considerable condensation of this, but you're going to have to do more background material because you've got to tell people better what the facility is, even if people on

the committee know. You may have people from the public in the audience that are not going to have a clue what you're talking about, and so we need to mutually decide what that is, and then you need to make sure that we're as close to on board to your thinking and philosophy here as is feasible to get because we're going to end up drafting a letter that's going to go in front of the committee, and they're going to massage that. I doubt that the full ACRS is going to dream up a wholly orthogonal letter all by itself.

And so we want to make sure that we're in line with all of your thinking. One of the areas that I've got to know more about is we have identified at least one case where we've come in and said, "Okay. Here's our position and here's the staff's position. They're not the same," but that's not labeled an open item.

I noticed a couple of other areas where you discussed with the applicant, and you said, yeah, this was a hazardous area. You didn't mention it in your original application, but they said, "Yeah, we agree," and we'll handle it with administrative controls," even though DOE has standards.

And you point out, well, they didn't cite

NEAL R. GROSS
COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 a standard here and we think we ought to. would really prefer not to try to go find all of those 2 3 things. If we could talk about that just a little bit 4 and give me some guidance on where to look for a summary on those because we're going to have to 5 understand those pretty well. 6 7 So the method to my madness was it seemed 8 to me that followed better from your summary than to 9 do the summary and then come back. 10 MR. MURRAY: Okay, that's fine. 11 CHAIRMAN POWERS: So I thought we'd take 12 a break until 20 after, come back and do that, with the idea of bringing that discussion which could just 13 go on forever to an end at four o'clock, and then move 14 15 on to the next item on the agenda. Does that sound like a strategy? 16 Good 17 enough. 18 by the way, I iterate 19 subcommittee meetings are kind of times for 20 discussions and whatnot, and the presentations have been just right on the mark as far as technical detail 21 22 and topics and the presentations have been excellent. 23 So you're doing exactly what we need to hear. MR. MURRAY: 24 Thank you. CHAIRMAN POWERS: So 20 after. 25

(Whereupon, the foregoing matter went off 1 the record at 3:05 p.m. and went back on 2 3 the record at 3:25 p.m.) CHAIRMAN POWERS: Let's come back into 4 session. 5 6 Okay. In this session what I wanted to do 7 was to allow the staff to go through their summary slides where they think they stand, and then I'd like 8 9 to chat just a little bit about various topics that 10 people have on their mind, but mostly work to help try to define what we think ought to come forward to the 11 full committee meeting, and I'll talk about what my 12 13 view on that is, but I'll actually ask everybody 14 around the table what items they think should come 15 forward. Mr. Rosen, you had a question? 16 17 MR. ROSEN: Yeah, just a question. 18 you been sort of collecting the key points that have 19 been made around the table so you can kind of spew 20 them back to us at least? 21 CHAIRMAN POWERS: Well, what I plan to do 22 actually is tomorrow after we have a presentation on 23 criticality, we're going to go back to our technical 24 points on that. That's in our function of developing 25 an outline for a draft position for the committee to

1 | look at.

2 |

16

17

18

19

20

21

22

23

24

25

MR. ROSEN: That will be tomorrow.

3 CHAIRMAN POWERS: Yeah, I want to do that I want to spend a little while discussing 4 5 philosophical aspects of this, as well as technical details because, I mean, what we've done here is go 6 7 through really what the outstanding issues were from 8 our previous meeting on this subject, but there are, 9 in fact, 15 chapters in this that we need to think 10 about, whatnot, and we need to give the staff some 11 help because they're going to at best, I suspect get about a two-hour period. Well, we only let them talk 12 for an hour, and I don't think they can come in with 13 14 a presentation with this excerpt out of the whole So I think we need to discuss that. 15 thing.

Dave, you want to go ahead and wrap up what you presented?

MR. BROWN: Yes. Let me just finish up for Alex, and this is his summary conclusion, which is that now all of the open items are closed in chemical process safety, and that the applicant has provided reasonable assurance of protection against natural phenomena hazards and accidents.

In addition to the previous conclusion with regard to 7023(b), we have concluded that the

NEAL R. GROSS

applicant has met the baseline design criteria, which 1 is also a new feature of the revised Part 70 when it 2 was revised to be a little more risk informed. 3 4 think just overall Ι think some 5 highlights of the last four years is that the regulation was revised in September of 2000. 6 We 7 received the application just a few months after that. 8 So this was one of the first applications to go through the new risk informed Part 70 regulation. 9 10 On top of that was the special circumstances surrounding a plutonium facility, which 11 12 is a two-step licensing process. 13 But despite this being kind of a first 14 time exercise, I think that we've done a good job, 15 that the staff working together with the applicant has 16 improved safety, and that there are some changes that 17 we've asked the applicant to make to adjust some of the hazards that we've talked about here today, and 18 that overall we've added value to that process, which 19 20 I think goes strongly against any sentiment that NRC 21 rubber stamps anything. 22 So with that statement I'll conclude and be willing to answer any questions first, I guess. 23 CHAIRMAN POWERS: first 24 I guess the 25 response have is on your slide 70, "have

satisfactorily addressed by additional controls and 1 safety strategies," and I come back to the Level 2 I/Level III chemical concentration controls where you 3 said, yeah, we're going to accept this with a codicil, 4 and I'm not sure that the applicant is 100 percent 5 aware that that's what you're doing. б 7 I mean, there's not an agreement from How many other things do we have of that them. 8 9 nature? 10 MR. BROWN: Of that nature? That is something that we will continue to talk to the 11 applicant about, and we certainly will keep you 12 apprised of any changes that do result from that. 13 I am not really -- and I'm earnestly, 14 sincerely thinking back through -- there should be 15 nothing else of that nature in the --16 CHAIRMAN POWERS: Well, I know there's one 17 in which you identify a hazard. I can't remember what 18 the hazard is unfortunately right now, and point out 19 that DOE, too, thinks it's a hazard, has a standard. 20 The licensee agrees that it's a hazard, but proposes 21 22 administrative controls and doesn't cite the standard, and apparently you don't like that very much. 23 24 to look.

MR. BROWN: I'm not sure I understand what

25

1 What event was that that we're talking you mean. 2 about? I'll have to look 3 CHAIRMAN POWERS: through my notes to find it for you, but I will. 4 5 MR. BROWN: Okay. 6 CHAIRMAN POWERS: And I'm just so 7 wondering. I mean, do I have to go through and look 8 and find these not quite full agreement sort of 9 things? 10 MR. BROWN: No. The other area where we did not accept the design bases that were offered was 11 actually something Chris Tripp will talk about 12 13 tomorrow, was the criticality safety where for MOX 14 powders we did not feel that there was sufficient 15 benchmark experiments to support the subcritical 16 margin that was proposed. 17 So we added an additional one percent non-18 parametric margin. That was made clear to DCS, and it 19 has been communicated to them by letter I think about 20 April last year or April of this year I should say, 21 2004, and DCS has not approached us to have additional 22 conversations about that and seek any relief from that condition. 23 MR. ROSEN: So they're just going to leave 24 25 it in the license application the way it is and have

1	you grant a license condition?
2	MR. BROWN: This is
3	MR. ROSEN: It sounds like just holding
4	your breath until you turn bright red and die.
. 5	MR. BROWN: Well, no. The nuance here is
6	that these subcritical margins are not actually in the
7	construction authorization request. They're in a
8	related document called the criticality validation
9	report, provided on the docket, but not actually part
10	of the CAR. This condition is necessary, you know, to
11	establish that this is the limit, notwithstanding what
12	else is in your criticality validation report. We
13	would only accept this margin for MOX powders.
14	MR. ROSEN: So it's not like they're
15	standing on principle. It's just they don't know what
16	to change. You're going to require
17	MR. BROWN: They wouldn't have, yeah, a
18	change to make.
19	MR. ROSEN: They're probably going to
20	license the change, the CAR for them to change.
21	MR. BROWN: Right. I think it's fairly
22	stated that DCS and DOE do not agree with NRC on this
23	matter, and so, you know, where NRC and an applicant
24	have reached an impasse, a condition is the
25	appropriate tool

1 MR. ROSEN: Yes, yes. You grant the 2 license. 3 MR. BROWN: Grant the license with the condition required to protect safety. 4 5 CHAIRMAN POWERS: Okay. What I propose to 6 do is let's just walk around and address two things: 7 general comments you care to make and any guidance you'd like to give the staff on what they ought to 8 9 bring forward to the full committee. 10 And after I've walked around the table, I'm going to come right back to you, Dave, and your 11 12 team and ask you the same question, what you think should be discussed in the letter and what you think 13 14 you ought to present to the full committee. So it 15 will give you a chance to think about those. 16 Ruth, why don't you lead us out here? 17 DR. WEINER: Okay. I'm going to defer our 18 general ACNW comment to my chairman, when you get to 19 I'd just like to make a personal comment about him. 20 the safety margins for chemical reactions in closed 21 systems. They make a number of assumptions that I 22 think are optimistic about the way thing really work. 23 In a mixture, the temperature is not 24 uniform, and I think very close attention should be 25 paid, in particular, to any closed system that they

1 have to what kind of safety margins are being left for 2 reactions, but I will defer comment on waste to Dr. 3 Ryan. 4 CHAIRMAN POWERS: Well, why don't we just 5 jump right straight to Dr. Ryan in that case? 6 DR. RYAN: Thank you very much. 7 First of all, I think we all three 8 appreciate the fact that you're at a conceptual design 9 stage and the details are coming, as we heard on many 10 of the issues that you addressed today, and I thank 11 you for that. 12 One of the issues that I think we all think about focusing on waste is -- and I'll just read 13 14 this to you -- how has the waste management hand-off 15 to DOE/SRS been analyzed to assure that waste management processes and systems don't create any MOX 16 17 plant safety challenges? 18 In other words, if there was a phone call 19 that said a waste pipe is closed, what does that mean to you in terms of safety challenges? 20 And, again, I recognize that in an early 21 22 design stage that's kind of a very open ended 23 question, but it's something to think about as you go from this stage on into the more detailed design step. 24 25 And would interruption of

management services from the SRS/DOE site be factored 1 into the design and would immediate shutdown be 2 3 required? Could you shut down carefully over time? 4 You know, what kind of safety questions would you face 5 if you were told that that outlet can happen? 6 And you mentioned, I think, Allen comments 7 that you have acids and bases, and you know, would you have to mix them? Would you have to dump them to some 8 9 kind of collection tank? You know, are there any 10 special issues that would result from that sort of a 11 force majeure or other imposed condition on you? 12 You don't control that aspect of it. So that's something to think about, and again, we defer 13 14 to our colleagues here on the details of design. 15 Obviously they're the experts, but that's one that kind of struck all of us as you talk through it today. 16 17 CHAIRMAN POWERS: Any comment on this 18 question? 19 MR. MAGRUDER: We agree that we ought to pursue it, you know. 20 21 (Laughter.) 22 MR. MAGRUDER: I'm not sure what else to 23 say. 24 That may be CHAIRMAN POWERS: Okay. 25 enough.

1	MR. MAGRUDER: We agree. Do you want to
2	add anything?
3	MR. BROWN: Well, I'll just add and
4	perhaps repeat that, you know, we did consider the
5	safety implications of the waste that is stored inside
6	the MOX plant, and I think it has been our underlying
7	assumption that if those tanks were filled to capacity
8	they'd be forced to shut down.
9	DR. RYAN: That's not what we're saying
10	though. What we're saying is if your waste outlet
11	says you can't send this waste anymore, we've got a
12	problem. What does that do to you?
13	That happens to day. If your waste tanks
14	are near capacity and you've got a lot in process,
15	what's your excess
16	CHAIRMAN POWERS: Well, I don't know if it
17	even matters that they're near capacity. It is merely
18	that they have to stop.
19	DR. RYAN: Yes, or have you evaluated that
20	kind of scenario that would causae you to rethink do
21	we keep going or not, under whatever set of conditions
22	you had?
23	So that's a different question than what
24	you just offered as an observation.
25	CHAIRMAN POWERS: In fact, it brings up

1	the point of your waste collection tank. You have
2	this waste collection tank at the facility that
3	receives all kinds of stuff. I mean, they go to some
4	lengths to describe all of the feeds that are coming
5	into it and their diversity.
6	I mean, how do you assess the safety of
7	that in light of the fact that that's exactly the sort
8	of tank that has created so many headaches for the
9	Department of Energy, one that's receiving lots and
10	lots of diverse waste streams.
11	DR. WEINER: That raised a question which
12	is really not part of NRC's purview, but is just
13	something generally to think about, and that is the
14	extent to which a facility like this will contribute
15	to legacy wastes that we're now dealing with.
16	CHAIRMAN POWERS: Otherwise known as
17	employment for waste.
18	DR. WEINER: Keep those people at Savannah
19	River going.
20	CHAIRMAN POWERS: Keep Yucca Mountain
21	green.
22	Professor Denning.
23	DR. DENNING: I'm not going to address any
24	of the real technical issues here, but I am struck by
25	the difference that I see between what we normally do

in approving something versus what I think our charter 2 is here, and I think that our charter here is 3 substantially less than it normally is. 4 I think normally we're really being asked is something safe enough, and I think that in this 5 6 case -- and at some point I think we will address that 7 question -- but because of this two-step process, it 8 seems to me that the kind of three questions that I 9 see, and perhaps we can discuss these more when we get 10 to what our letter would actually say, but I think it 11 does have relevance to what they should be presenting 12 to us at the full committee meeting. The first is: has the staff performed a 13 comprehensive review of the hazards represented by the 14 15 facility and the design bases and PSSCs proposed by the applicant? 16 Has the staff developed appropriate safety 17 18 acceptance criteria? 19 And I think that the principal question that we have to then address based upon that is: 20 there reasonable assurance that the applicant will be 21 22 able to satisfy the safety criteria based on the 23 conceptual design? I mean, I'll look to 24 CHAIRMAN POWERS: 25 Dave, but it sounds very familiar to the language

1

we've been using. 1 2 MR. BROWN: Yeah. I don't 3 comment. 4 CHAIRMAN POWERS: I mean, it sounds like 5 we're aligned there in our thinking on what they're 6 trying to accomplish here, and I think it would be 7 useful to articulate those. I mean, we're going to serve something of an educational function to the 8 9 Commission in our advice on this, too, and we're going 10 to have to lay this out. And I think we will probably interact with 11 12 you guys on that aspect of the letter in draft form. 13 I mean, we're going to spend some time to make sure we 14 craft those words very carefully. So when it gets 15 time for that, please help us get the words in 16 precision there, and to articulate it out into three 17 questions like that might be very useful. 18 Vic, or Professor Ransom I should say. 19 DR. RANSOM: I don't have much to add. I 20 think I agree that from what I've seen, we're used to 21 looking at the details of a process and trying to evaluate whether or not there are safety concerns. 22 23 I assume in this case, too, that the 24 consequences can be made small, and that the facility 25 reviewed in France at least, you have kind of like a

1	pilot plant line which
2	CHAIRMAN POWERS: Well, it's an
3	interesting pilot plant in that it's bigger than the
4	one we're talking about.
5	DR. RANSOM: Really?
6	CHAIRMAN POWERS: Oh, yeah. The
7	throughput in France must be what, ten times this or
8	something like that?
9	MR. BROWN: With the MOX plant at least,
10	I think it has the capacity in France of 200 metric
11	tons per year. this is a 70 metric ton per year plant
12	in the U.S.
13	DR. RANSOM: I'm having a little bit of a
14	hard time getting my hands on what are the risks, you
15	know, involved in this kind of facility.
16	No other comments I don't think.
17	CHAIRMAN POWERS: Dr. Bonaca.
18	DR. BONACA: Well, referring to what
19	should be presented in February to the whole
20	committee, I think that's an interest you had. I
21	would echo somewhat what Dr. Denning pointed out. It
22	seems to me we have to go and talk about, you know,
23	the general safety assessment of the design basis.
24	You have a full chapter there in the SER,
25	Chapter 5, and you don't have to go in fanatically, as

I see the issue, but certainly talk about the issues to do with nuclear safety and chemical safety. How you have established those criteria in terms of the point we were making there.

Particularly we saw today that table of doses versus likelihood, and you referred to a NUREG that contained those as some quantitative indication.

I think it would be valuable for us to have an understanding of that.

Also you referred to the fact that we are using chemical releases to determine risk also. So also that kind of information, and I would keep the presentation at the kind of high level to give a sense of how you do have envelope to issue the conceptual basis, and then at that point I don't think you have to go into much detail, but you have to give some basic understanding of why you believe that this approach, this criteria can be met. And I would keep it at a high level because I don't think we have that much time. I think probably a couple of hours.

CHAIRMAN POWERS: Well, I mean we may make an argument for it, but I think as a planning basis, we plan on a couple of hours.

DR. BONACA: We're not doing anymore than that.

I mean, the problem is this. The facility encompasses enormous numbers of technical fields, enormous numbers of technical questions. There is no way to anticipate the particular question that's going to excite somebody. I mean, even the people that have been sitting here, they're going to continue to review the material, and you cannot prepare for everything.

So it's better to prepare for being surprised or maybe not surprised, but prepare for unanticipated questions. Make the presentation, as Dr. Bonaca said, at a fairly high level. You can list some of the particular issues as illustrations of your approach, but it's really getting across your approach, you know, not red oil is an issue.

DR. BONACA: That's right.

CHAIRMAN POWERS: But rather, here's what we did.

DR. BONACA: One last comment I wanted to make was regarding this issue of preventing versus mitigating. I haven't heard a single word in the presentation in regards to mitigation, and yet you do have mitigating features, and it seems to me that you call them preventative because anything that prevents a dose you call it preventing, but that is like saying

in a reactor ECCS is a preventive. 1 It's equipment 2 because it prevents doses from being released. 3 The reality, we consider it a mitigating system, and I think you're doing a disservice a little 4 5 bit to what has been done and proposed by ignoring that there are some theoretical issues there that you 6 7 include in your design. 8 CHAIRMAN POWERS: Yeah, I agree with you 9 that there's a definition of terms here, and I 10 particularly liked the way Dr. Bonaca characterized 11 it, and so you might want to in your introduction 12 acknowledge that there's a challenge in terminology throughout this Part 70 versus Part 50, and use that 13 14 as an illustration of, you know, when you guys are 15 looking for a balance between mitigation 16 We've got that, but the way we label 17 things it's a little different. So it might seem like we don't. 18 And just acknowledge there's a difference 19 20 in terminology and hope that the members that are maybe insensitive to that, the people here can help 21 them understand that better. 22 23 DR. BONACA: Those are my comments. 24 CHAIRMAN POWERS: Very good. Mr. Rosen. 25 Yeah, I'd like to echo what MR. ROSEN:

3

4

5

6

7

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

Mario just said about the differences in the regulatory framework. I mean, I think that the other members who haven't been involved won't really understand, won't really have in their heads the idea that this is really governed by Part 70, 7061, in particular the performance requirements.

And it might be a little tutorial on that up front may be very helpful.

The other thing I think that's of major importance, and I'm not sure whether this falls across the line into a technical question, but I'll talk about it anyway, and that is the need, I think, for a process overview in the facility, that is, -- and these issues all tie together -- a control room where the overall process is overviewed. The very existence of such a space and the function itself, and the need for someone to initiate an emergency plan which would likely come out of that space to me is either a glaring omission or either I don't understand it or maybe there isn't a need for it, but it's so different than what we're used to in the reactor world that I think it bears some exposition, either explanatory of why it's the way it is or maybe to say, well, we didn't really give the subcommittee all of the answers that maybe we could have or should have, and here are

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

some answers around the question of (a) a central control room if it's needed and (b) how one initiates an emergency plan, although the point is that the applicant is saying they don't need one.

And then that's a very big issue, and I don't see how we could reasonably go to the full committee or even mention it to the Commission without addressed that After all, the issue. having Commission has just, I think, said in the area of future reactors that emergency plans will be required even for future reactors. Here's a current system that's not a reactor, granted, but where the idea is I think it's a big there isn't going to be one. issue.

And I wanted to talk about this question of the third issue that I think is a technical issue. It's the issue of when you have an area where you need to have moderation control, need to make sure the water doesn't get into that area, that you're really basically making a choice or making, let's say, optimizing the choice, making a trade perhaps is a better way to say it, between five protection as you would normally design it in order to protect, I think, the public's health and safety versus nuclear criticality safety in the facility which is a

1	protection for the workers.
2	And you're making some sort of trade, and
3	the dimension of that trade are not exactly explicit
4	to me. Now, is that a technical issue? I don't know,
5	Dana.
6	CHAIRMAN POWERS: But I think it's a good
7	issue, and we need to explore that further. You and
8	I need to chat because we've got to understand this a
9	little better.
10	We're going to get a report from one of
11	our consultants on the nuclear criticality stuff.
12	Maybe at that
13	MR. ROSEN: We can look tomorrow.
14	CHAIRMAN POWERS: Well, we'll hear more
15	about the criticality tomorrow. We're going to get a
16	report on that material from a consultant. Once we
17	have that in hand, then we need to explore it a little
18	more, and it may be necessary for us to sit down with
19	the staff and understand this a little better.
20	MR. ROSEN: Yeah. Well, I'm not sure
21	that's something that we would want to put in the full
22	committee discussion, but there it is. It's a big
23	issue.
24	CHAIRMAN POWERS: It is, I think, a useful
25	issue to pursue because this tradeoff is always a

1	challenge here, especially with the closer site
2	boundaries. We just need to understand the issue a
3	little better.
4	MR. ROSEN: That's all I have.
5	MR. MAGRUDER: I think, Dr. Powers, I
6	think that tomorrow morning when we talk about safety
7	issues we can get into this again. I think we have a
8	better story than we presented.
9	CHAIRMAN POWERS: Sure.
10	MR. MAGRUDER: I mean, this is definitely
11	something we should talk about, but I think that for
12	this particular design it may be less of an issue than
13	we think it is.
14	CHAIRMAN POWERS: So why don't we just
15	count on that, and we'll explore it a little further.
16	I understand it may take us a little while to get up
17	to speed here because we're still collecting our
18	information on this.
19	MR. MAGRUDER: Right, right.
20	CHAIRMAN POWERS: And if its necessary for
21	us to get together again and chat, I mean, we can
22	arrange that.
23	MR. MAGRUDER: Absolutely.
24	CHAIRMAN POWERS: This should not be an
25	onerous thing to do.

13

14

15

16

17

18

19

20

21

22

23

24

25

Professor Wallis.

2	DR. WALLIS: Well, what we heard today I
3	found to be at a very high level, which is where you
4	are so far, toward about approaches and principles and
5	in general terms the methods that were to be used to
6	control these various reactions and so on. But it was
7	very hard for me to tell which of these might turn out
8	to be a technical issue because I couldn't see enough
9	detail, and I don't yet know whether the design will
10	actually be adequate. So there's obviously a long way
11	to go.
12	I was helped by the discussions today of

y of a phenomena, such as red oil and HAN and all of this kind of thing. It really helped me as opposed to trying to just read the documentation. I found what you presented today helped me there.

of presenting to the In terms committee, I'm not quite sure. Are you presenting the whole draft SER on the entire CAR, in which case you're going to talk about a lot of things besides these open issues, or are you just going to talk about the open issue resolution to the full committee?

MR. BROWN: No, I think we will have to go to an even higher level for the full committee.

DR. WALLIS: Because if you talked about

NEAL R. GROSS

just what you did today, I would suggest you use your last three slides, that you give something like three or four on the overview of your approach to things and the design approach for this facility.

And then I found that these were illustrated well by the individual topics. So I'd have another three slides on things like red oil, electrolyzer, HAN/hydrazine, control room habitation, and fires, and seven times three is 21, which is about what you need for an hour long presentation.

But I think it was useful to go into some of the specifics of these individual phenomena as they illustrated the approaches being used.

CHAIRMAN POWERS: Dr. Ford.

DR. FORD: I agree with Graham as far as the recommendations for what to be given to the full committee. However, I think I'd disagree with the majority of this on the specifics. As I understand it, we're being asked to endorse the case being made for a construction permit, which includes the validity of specific values -- and I'm quoting from here -- the specific values and ranges chosen for the controlling permitters in the design basis, and in order to endorse those, you have to get into specifics.

For instance, on the red oil issue,

there's a set point of 125 --this is Slide 16 -- of 125 degrees Centigrade. For a runaway process it is 135. I'm unsure where the data associated with that is, and what is the real margin between the data and the runaway temperature? And what is the response time for the system for a runaway process?

With regards to the HAN, Slide 23 and 25, we have a temperature instability which is some function of the nitric acid, et cetera, and hydrazine. That's a mathematical value that is being given. I do not know what the correlation between the data and that mathematically derived set point is, and are there any data -- question: are there any data showing that you could have unstable performance below the set point of the design basis value of 50 degrees Centigrade?

It seems to me a lot of detail is being left until you get to the ISA aspect. So generic questions: what happens when you get all of this data and you find those design basis values were inappropriate and you change it?

As regards the full committee meeting and things that Graham mentioned, I suspect that you might get questions relating to quantification of the frequency consequence diagram on Slide 11 in the

opening talk. It is entitled risk informing, 10 CFR, Part 70, and I suspect you might well have questions asked about the lack of use of PRA.

That's it. Thank you.

DR. DENNING: Dana, could we have just a little discussion? Because I think that Peter's view really is critical as to whether the ACRS can really even support the approval for a construction permit because if we have to do it at the level that you talked about, if we really have to know whether the 125 degrees is correct today, you know, I don't think we can do that, although perhaps we could, but we certainly didn't look into it enough.

so I think the question is: exactly what is the charter that we have? What is the ACRS really going to approve? How far do we have to go? And, of course, there's going to be judgment in that, but if we really had to go as far as you said, if they had to provide enough evidence to take us to that level, I don't think they have done that, nor do I think they can do it, and I think that this two-step process is one where we have to accept the compromise that we really aren't going to know, and there's going to be a risk that the plant is going to get built, and it's not going to satisfy the criteria.

2 | 3 | 4

So I think the focus has to be on the criteria that is established. By that I don't mean 125, but just the general concept of the maximum temperature.

DR. FORD: I agree with you entirely, but I was taking my comments, taking verbatim from the slides. It says what the purpose of the meeting was, and it's to endorse this CAR for the facility, and then it goes on to say which involves the design basis, definition of the design bases, which on Slide 10 goes specifically into specific values and ranges of values for controlling parameters.

So that's why I suggest that logical step.

Maybe I'm reading the criterion wrong, but taking it

from --

CHAIRMAN POWERS: I mean, I think you do it within context here. You say the staff is really asking is there anything wrong with our methodology to evaluate these criteria, and in general most of the criteria have been advanced by the applicant and the staff is simply reviewing them in the face of some uncertainty, okay, and the staff is asking us where we've asked the applicant to do research to support those numbers, was that the right decision, and when we have not, was that a correct decision?

NEAL R. GROSS

I don't think you're being asked to take the way out of saying in the absence of perfect information, I approve nothing. I mean, I think you're being asked given the information that's available, has staff taken a prudent course here, and understand that one of the advantages of this facility is that, of course, there is this plant that Vic talks about that has operated for some number of years. Some of these processes, for instance, the evaporators of Hanford have operated for now 15 years using less restrictive criteria than the staff has adopted.

So I see that as our charter, and not saying, "Okay. Well, I have to have perfect information."

DR. BONACA: I can give you an example of why throwing the early design of the plants. I remember commitment in the PSARs that you would have a protection system that would give you protection from over pressure transience so that you will never reach in a PWR 2750 psi, and you have certain assumptions about the functions you will use for that.

Therefore, I remember at Babcock & Wilcox the function relied on was high flux and high pressure, and then once you have begun to develop the plant we found that you had a range of reactivity

insertion rates for which you had no protection. So you had to implement a new function that you finally found. I mean, it was in a flux as the core; you implement some new element.

So there is no doubt in my mind that in this process there may be some features that the implementation process may require some modification of that kind, but it seems to me it's more of a refinement at that point than a general assessment that says, yes, a protection system that will meet certain requirements can be, in fact, implemented and is acceptable in concert.

And I view this as a conceptual design that says the approach is feasible.

DR. FORD: Well, I'm certainly not saying that they have not identified the issues. I think they have. All I'm responding to is what's on this, what they're asking us to do, and if it's not what they're asking us to do, fine.

But they do ask us to comment on the specific values of the design basis parameters, and even admittedly in the face of uncertainty. And you take that into account in terms of adequate margins, and so now I'm asking, well, how adequate is the margin, and that's where I'm coming from.

Maybe I'm being too copious on what they 1 say they want us to do. 2 3 Well, I mean, on the CHAIRMAN POWERS: 4 specific issue, again, I caution that if they had put 5 up a slide that says, "Okay. Here's what the computer 6 code calculates and here are all of the data that 7 we've collected from a bunch of laboratory tests," it 8 wouldn't help me a bit because I know that it's almost 9 impossible to reproduce in the laboratory the 10 conditions that take place in the actual evaporator. DR. 11 FORD: So then you'd be more 12 conservative presumably. 13 MR. SIEBER: Not necessarily. 14 CHAIRMAN POWERS: I would tend to go back 15 to the empirical data that says, okay, where have the 16 evaporators been operating for 25 years successfully. 17 Okay. Well, sit in that range because, you know, they 18 work fine. I mean, that's my natural tendency, is to do that. 19 20 I mean, I have not done this laboratory 21 research myself. I've held the hand of he who is doing the laboratory research, and you can never 22 23 convince yourself that you were actually reproducing 24 the conditions in the --25 DR. FORD: I drew up here a graph. This

1	is for the HAN process. These values here, 65 and 50,
2	are calculated. The points that are supposed to be
3	the experimental data points, all I'm asking is are
4	there red spots, i.e., denoting unstable behavior,
5	below that 50 degrees line which they say is an
6	adequate margin. That's all I'm asking.
7	CHAIRMAN POWERS: Well,w hat I will tell
8	you
9	DR. FORD: And if there are, then it's no
10	longer a margin.
11	CHAIRMAN POWERS: I don't know the
12	database for HAN. I know more the red oil, but on the
13	specific limits there, there are none below what's set
14	as the DOE
15	DR. FORD: Well, that's fine.
16	CHAIRMAN POWERS: There are absolutely
17	none. Never make it go there.
18	DR. FORD: Good for the rationalists or
19	are we structuralists? I'd love to see that graph.
20	Data compared with a mathematical derived model.
21	DR. WALLIS: Well, in the absence of that,
22	I'd like to know that the designers of the plant have
23	some other way of doing it. Maybe it's not this graph
24	but some other way that assures adequate safety, and
25	we never heard anything from the designers of the

plant.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

I mean, that's a problem I have with the documentation. I read your documentation and on the red oil I was told that by controlling the temperature of the residents with the organics, the off-gas system and so on, you could get the red oil to be stable.

But I said, okay, the details must be in the applicant's paper. So I go to the applicant's paper, and the applicant says exactly the same thing. There's no detail there. So in the absence of having the designer up there confronting him with "what do you mean by you can control the temperature. Show me," there's no way I can get that reassurance.

Presumably you aren't the designer. So who is it who knows the technology well enough to do it right?

Well, along those lines in DR. RANSOM: the red oil argument, they control want to temperature, but actually temperature and pressure are coupled, and they talk about open and closed systems, and so your ability to vent this thing and regulate the pressure is really coupled with the ability to regulate the temperature, and there's no detail. don't know whether they can do it or not.

MR. SIEBER: When you vent, you remove

NEAL R. GROSS

1	heat, and that's the strategy.
2	DR. RANSOM: Well, they actually argue
3	you're cooling by evaporative cooling, which means
4	you're boiling the liquid mixture, and if you increase
5	the pressure, you increase the vapor pressure of that
6	fluid, and so the boiling temperature goes up. So
7	they're all coupled together.
8	CHAIRMAN POWERS: And heat removal goes
9	down unfortunately.
10	Mr. Croff.
11	DR. CROFF: Mike covered it.
12	CHAIRMAN POWERS: Boy, you're efficient.
13	Jack.
14	MR. SIEBER: They have but one leader.
15	DR. WEINER: That's just our public
16	persona.
17	MR. ROSEN: It would be to follow their
18	example.
19	MR. SIEBER: I guess in my comments I
20	would agree with everybody, but as we went through
21	today, I kept thinking about how could you restructure
22	what you've said today in a way that I could better
23	understand it. Okay? And so I've been, as we've been
24	going on, writing down the elements of what I think a
25	person with the mental capacity to understand what's

going on here, but not an intimate familiarity with the plant or the process or the licensing might have prior to any discourse with the staff on the subject.

And it seems to me I think that there are some areas of confusion. At least the ACRS deals 95 to 99 percent of its time with power reactors. It's licensed under a different set of rules. The processes that occur in power reactors are quite different than they are in chemical plants or in processing fuel or what have you. So I think that the stage has to be set by, first, spending a couple of minutes on the Part 70 two-stage licensing process.

Next, I think that one needs to explain the overall process for the facility, you know, from the time that it leaves the DOE part until it comes out as pellets ready to go into a fuel assembly.

Okay, and in the process of doing that, I think that it's important to describe what's a batch process and what's a continuous process because it makes a difference as to how the controls are established, and the limits and the set points and the degree of the hazard present when you know these kinds of things. And a good part of this plant is a batch process plant.

Then I would -- and I agree with Dr. Ford

in this area -- I would look at the various kinds of 1 issues of concern from a safety standpoint. 2 3 one, chemical safety, and I mean by that toxicity. 4 You know, if you go to a chemical supplier and you buy 5 a drum full of something, you get an MSDS with it, but if you are the chemical processor, there's no MSDS, 6 7 and you have a lot of intermediate products in your 8 own process that have certain hazards to workers, off-9 site people, and so forth. I think those things need to be -- the 10 11 important ones need to be described in how they're 12 controlled, and you've talked about that today. 13 The second thing is process safety, which is the red oil kinds of issues, and whether they're 14 15 mitigated against or prevented. Third would be criticality safety, which 16 17 we haven't heard about yet, but I think I have some 18 concerns about it at this point, and we'll find out 19 tomorrow when we ask questions. Fourth was radiation safety both for 20 normal operations, the workers inside the facility and 21 22 under accident conditions. 23 And lastly, but not least, protection. It seems to me with all of these chemical 24 25 in there, this place is just aching to burn, so to

2 issue. 3 And in dealing with each of these, I think 4 it's important to describe whether the strategy is prevention or mitigation or both, and what controls 5 are established on each of these processes, each of 6 7 these areas that's built into the design that says I'm 8 going to avoid this by preventing it or I'm going to 9 have prevention, but in case I really don't prevent it, here's some mitigation strategies, for example, 10 your ventilation system. So your ventilation is a 11 strategy for mitigation to me. 12 I think that you need in accordance with 13 14 Dr. Ford's explanation the data that says, 15 example, in process safety: here's the stable region. Here's the unstable region. And then you have to go 16 How well do I know it? What's the 17 beyond that. 18 uncertainty? 19 Secondly, where am I going to establish my 20 process limit? And lastly, how much margin is there and 21 22 does it encompass the uncertainty that I have in my test data and in my ability to measure what's going on 23 in the process? 24 25 firmly To me that would much more

speak, and so fire protection becomes an important

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

establish whether this plant is operated within the safety parameters that the application bounds and that the staff would like to assure. I think without that, then we don't have all the technical pieces that it takes say, yes, this facility will meet to expectations with regard to safety impacts or, no, it won't and these things need to be changed. You don't have enough margin here. You need to lower this process control variable, and so forth.

and I think if you set things up like that and then establish really what integrated safety analysis is as compared to what we all know as PRAs and why it's good enough and in some cases for these kinds of facilities, it's better than a PRA, and what one hopes to establish by reviewing the ISA.

And I think that when you do that, that sort of ties together all of the parameters and control variables that you need to discuss to establish a reasonable probability the facility can be operated safely.

I don't know if you can fit all of that into two hours, but that's what I'd try to do. You have to talk fast. I mean, you've got to keep right on going.

(Laughter.)

1 MR. SIEBER: But in any event, to me --2 CHAIRMAN POWERS: You mean that they're to 3 ignore any interruptions from Professor Apostolakis? 4 MR. SIEBER: Right. Just tell him to shut CHAIRMAN POWERS: 5 6 up? 7 MR. SIEBER: And my wife always gets annoyed when I turn my hearing aid off. Perhaps that 8 9 would work for you. 10 (Laughter.) MR. SIEBER: It does work for me. 11 In any event, to me that's what ties this 12 up in a package, and the presentations I think today 13 14 were good. A lot of effort went into them, but not 15 all of the elements were there that I felt I needed to know to be able to say that this facility is a good 16 17 facility, it would be operated properly, and it 18 doesn't represent an undue hazard. 19 And I guess that's sort of the way I feel 20 about it, and you know, the application is very long and the SER is a third the size or a fourth the size, 21 22 but it's also very long and neither say as much as I 23 would have liked them to say, and I guess you almost have to wait for the sequel, which is the operating 24

license application, in order to find out --

20

21

22

23

24

25

MR. ROSEN: How does the story end.

Yeah. No, what is the MR. SIEBER: background? What are all of the little parts. You know, you make glorious statements. You know, we aren't going to do this and we aren't going to do that, and here's our limits, but you don't say how you're going to do it, and until all of these design details are there and a description of how you're going to operate the facility, until that's there you won't have every piece of the story that's necessary. You can just say, "Okay. Here's some weapons grade material. Let's make fuel out of it."

So anyway, that's sort of the way I feel about it, and I think the elements are there. I think the staff has done a really good job, and I'm impressed with the effort that the staff has put forward on this project, and I think that the applicant has done a good job, too.

On the other hand, I think that we could package it better, and for those unfortunate enough not to be on the fuels subcommittee.

I don't know if the staff has any comments or if I make any sense, but that's sort of the way I feel about it.

CHAIRMAN POWERS: Dr. Weiner.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

	293
1	DR. WEINER: I just had one brief comment.
2	The slide that you have that showed that hazard matrix
3	highly unlikely and so on, first of all, that is an
4	area where you are showing that your analysis is risk
5	informed because that's exactly what that does.
6	I'd certainly make it clear what you mean
7	by highly unlikely, and so on, and I would add to it
8	the chemical hazard matrix. It's just a suggestion.
9	I think especially if you have members of
10	the public, less involved people present at the
11	hearing, that will mean something.
12	CHAIRMAN POWERS: Okay. Dave, you're up.
13	What do you think you ought to present?
14	MR. BROWN: Well, I wanted to also mention
15	the content of the letter.
16	CHAIRMAN POWERS: Yes.
17	MR. BROWN: You know, as pointed out, we
18	can fit all of that even into two hours. We'll have
19	to see, but you know, I think it's probably useful if
20	this is if you don't object, to put some historical
21	context in on this section of that regulation, the
22	7023(b). Where did it come from? How did it come to
23	be there?
24	It turns out that that section was added
25	in the early '70s with the specific intent in mind

1 no one would build a plutonium processing 2 facility that could not be run. For example, you 3 wouldn't build a plutonium processing facility out of 4 concrete block with glass windows. That clearly would not meet any strenuous seismic design criteria. You'd 5 6 end up having to tear the building down because you 7 couldn't get a license. 8 That was kind of the intent, and as you 9 said earlier, Dana, the struggle that the staff is 10 having with that regulation is, you know, have we 11 gotten adequate assurances that this plant if it's 12 according to these design bases could be 13 operated safely, and we have made appropriate judgments that some details can be deferred later 14 15 until the final design is completed; that in no case would this plant have to be torn down to the ground 16 and rebuilt in order to get a license. 17 18 I think that's kind of, I think, a message 19 that I'd like to across. CHAIRMAN POWERS: Yes, I think that's very 20 21 useful. 22 MR. BROWN: Okay. That's my boiling it 23 down to one point. CHAIRMAN POWERS: Now, here's a man that 24 25 knows how to hone things down.

1 MS. WESTON: Dana, I'd like to weigh in on this. 2 3 CHAIRMAN POWERS: God is speaking to me. 4 (Laughter.) I'd like to weigh in on this 5 MS. WESTON: I think that it must be clearly articulated 6 7 that this is the design basis phase, and they need to make clear to the committee what that means and what 8 9 the obligation is of the licensee with regards to 10 that. I think that has led to a lot of confusion 11 12 about what is expected of the licensee. So I think that really, truly has to be clearly articulated at 13 the full committee so that everybody understands what 14 15 the playing field is and what the licensee is 16 obligated to provide at this point based on the 17 regulations, which we can't change at this point. 18 Okay? 19 CHAIRMAN POWERS: Good point. DR. RYAN: Let me pick up on that comment. 20 You know, as I walked in today, I'm thinking about 21 22 where are we in terms of percent complete. You know, 23 there's preliminary design, trial design, preconstruction, and all of that, and it might help you 24 25 to lay out that time line, you know, in some way and

1 say, you know, we're here; we're not over here, and just kind of get everybody oriented to what's going on 2 3 at this. CHAIRMAN POWERS: Okay. That's very good. 4 5 DR. RYAN: That might be helpful. 6 CHAIRMAN POWERS: You're quite right. And 7 one of those standard diagrams that DOE uses in its system engineering would really clarify things very 8 9 much. 10 Joe. MR. GIITTER: I think something that would 11 be helpful, Dr. Powers, is if you started off the 12 presentation to the full committee by summarizing the 13 14 collective view of the subcommittee, you know, based 15 on what you're going to talk about subsequent to this meeting, what you've talked about today, and I think 16 17 that will set a tone for us to step in. 18 And I agree with Mag's comments. I think we do need to redouble our efforts to make it clear 19 that this isn't a reactor. 20 This is a fuel cycle facility being licensed under what was intended to be 21 22 a one-step process, a risk informed, performance based 23 process, and what we're doing here is something different and unique, and that we're actually taking 24

this through two steps: a construction authorization

1 and then a possession in use license. I think that's a good 2 CHAIRMAN POWERS: 3 comment, Joe, and our ground rules even actually 4 prescribe that the subcommittee chairman is supposed 5 to give the full committee an appropriate background for this. 6 7 And so I will suggest that Mag and your staff work together to kind of create an outline of 8 9 what those comments should be, to put a context, and 10 I may carry a little water for you. I might use that 11 percent completion slide that Dave used just to 12 illustrate things. 13 I certainly would use the point that this is the first application of the regulation and 14 15 whatnot, and maybe we can work together and come up to 16 a background that sets the stage appropriately for 17 That would fit well with the prescriptions that you. 18 are given to the subcommittee chairman for full 19 committee meetings, and I might use language that the 20 committee kind of expects to hear and avoid new terminology for them just because it's familiar to 21 22 them. So that's a good point. 23 24 Stuart, do you have any comments? 25 MR. MAGRUDER: Nothing.

1	CHAIRMAN POWERS: I can't believe it.
2	MR. MAGRUDER: It has all been said.
3	CHAIRMAN POWERS: Somebody has got a gun
4	to your head. I know this.
5	DR. WALLIS: Dana, could we go back to
6	this risk informed, performance based remark here? In
7	terms of the red oil, I think if this were risk
8	informed decision making we would want to say what is
9	the probability of a runaway reaction which led to a
10	breach of the vessel, and we would have to look at the
11	uncertainties in the measurement of the temperatures,
12	the chemical reaction rates, the stability criteria,
13	all based on some sort of rationale, and we'd have to
14	say now with this choice of 125 degrees and these
15	controls, what is our best estimate of the probability
16	of failure.
17	And without that, I feel I'm dealing with
18	something I can't get hold of. Now are you going to
19	get to that state some time?
20	MR. MAGRUDER: Yes. That hopefully is
21	what will be in the ISA.
22	DR. WALLIS: That sort of thing will be in
23	the ISA.
24	MR. MAGRUDER: Yes, absolutely.
25	DR. WALLIS: And they may say we were
	NEAL D. ODOGG

1	wrong about 125 degrees. We should have picked 122
2	because that puts us within our criteria or something,
3	and we realize we are uncertain enough about the
4	reaction rates that we have to add some factor of
5	safety or margin or something. That will all be
6	there?
7	MR. MAGRUDER: Yes, it will. Well, where
8	they can quantify things it will be there.
9	DR. WALLIS: If it's as vague as it is
10	today, I'm not going to feel very secure.
11	MR. MAGRUDER: Hopefully you'll feel more
12	secure after you've seen the ISA.
13	CHAIRMAN POWERS: Yeah, I guess I am less
14	confident that a mechanistic understanding would come
15	about. I think if I had a vigorous interrogator
16	demanding quantitative information I would go
17	experiential.
18	I mean, I keep coming back to this all the
19	time. The system seems to be chemically complex.
20	More importantly, it seems to involve some cooperation
21	between radiolytic and thermal processes, which are
22	I mean, we're still sorting out the radiolysis of
23	water. We are not going to solve the issues of
24	radiolysis of complex compounds promptly, and I have
25	to admit that I'm must more comfortable with

1	experiential bases than maybe someone who has a strong
2	bent toward mechanistic understandings.
3	DR. WALLIS: Well, that's fine, but what's
4	the bottom line? What do you use to conclude as a
5	criterion of acceptability?
6	CHAIRMAN POWERS: Well, I mean, the thrust
7	has always been, I mean, in many of these, many, many
8	processes, if I do it this way I'm okay.
9	DR. WALLIS: It has never failed before.
10	Therefore it will be all right. Maybe it's not a very
11	broad experience?
12	DR. BONACA: I think they provided the
13	criteria, however, for the example you're making.
14	They're saying process safety control subsystems. So
15	control reactivity enthalpy by limiting steam
16	temperature. Okay?
17	Now, when they would come up with detailed
18	design after construction, they would have to explain
19	how, in fact, they're achieving this.
20	And the next one is limit organic compound
21	residence time to oxidize radiation. That's the
22	criterion that they'll have to demonstrate physically.
23	I mean, what have you done to deliver on that issue?
24	I believe that you would use this as
25	criteria to compare to, right? To make the judgment

1 whether or not this is reasonable residence time. 2 MR. BROWN: That's right. 3 DR. BONACA: What happens if, in fact, you 4 cannot limit? Do you know enough about what does it mean "limit residence time"? What's your expectation 5 6 on a jargon of that nature? 7 MR. BROWN: Using that as an example, we know enough that the hydrolysis rates and radiolytic 8 9 decomposition rates are such, especially for weapon grade plutonium with not a lot of fission products 10 11 present, are slow, and so that the order of magnitude of the time involved here is months. 12 DR. BONACA: 13 Okay. 14 BROWN: And the solvent undergoes 15 regular washing at the end of the cycle. So that's 16 why we can say without specific information on those 17 rates it's reasonable that they can obtain clean solvent using the sodium carbonate solvent washington 18 19 system. 20 CHAIRMAN POWERS: It may be that this 21 system is not even susceptible to red oil phenomenon 22 because it only has alpha emitters and there's no 23 strong gamma component to this. You don't have a lot of cesium in this. 24 25 think MR. BROWN: Yeah, it is we

_	susceptible to red our phenomenon in the hydrolysis
2	rates alone,b ut I understand your point.
3	CHAIRMAN POWERS: It could be. It could
4	be.
5	DR. BONACA: No, no. I agree that only
6	the most recent steps have been accomplished, but I
7	thought that the criteria have been put in place to
8	make a judgment once the facilities are constructed.
9	Now, it may very well be that what is being delivered
10	is not adequate, and that may be a judgment we pass at
11	that time.
12	DR. WALLIS: There seems to be an
13	assumption that if you control the steam temperature,
14	you can control sort of heat input. Well, I'd have to
15	see how that works. We have to know something about
16	how this head exchanger works and now it's controlled
17	and what the flow rates are and all kinds of stuff to
18	find out if it was really controllable that way.
19	And this idea of adding water and letting
20	it evaporate, again, you've got to calculate all of
21	that.
22	DR. BONACA: Yeah, it is, yeah.
23	DR. WALLIS: So there's a huge step of
24	faith that these methods will actually work.
25	CHAIRMAN POWERS: Okay. Well, I think
	1

1 you've gotten the guidance repeatedly now that in your 2 presentation that some sort of overall setting the 3 stage, some discussion of the two-step licensing 4 period as a background, some description of the facility itself, and then I would encourage you to use 5 the slide to illustrate the magnitude of your review. 6 7 think there's a consensus there's a 8 comprehensive review you've done. Then a variety of technical issues come 9 10 up, and I would encourage you, again, to use these as 11 illustration of your approach, avoiding plunging into 12 too much details, but focus on how you went about doing things and whatnot. And, of course, you're stuck with roughly 14 an hour of presentation here. So I mean, I will try to set it up so that you get forgiveness for just 16 listing some of the issues that you've gone into, and then pluck a few out that you think you can make your case clearly on that. DR. DENNING: Dana, an hour's presentation really seems totally inadequate to me. Is that cast Should we be considering changing that? CHAIRMAN POWERS: The ground rules, well, we're certainly trying to get a three-hour block for

them, but in general, the planning and procedures

13

15

17

18

19

20

21

22

23

24

1 committee says that if you have to go much longer than that, then you're really talking about a subcommittee 2 3 meeting and get your act together. Now, we have an advantage there. 4 There are eight members here, plus we have the advice 5 So, quite frankly, I am 6 and help from the ACNW. sympathetic to the full committee's planning and 7 procedures committee that this thing ought to be 8 sorted out such that a presentation can be made that 9 10 they can evaluate a draft position that we bring forward to them. 11 I mean, I think we ought to be able to do 12 that, and I will certainly be holding the time 13 14 schedule fairly rigorously on this. Now, if we get an extra half hour, we get an extra half hour, b ut --15 16 And I think it would help, DR. WALLIS: from my experience of these planning procedures 17 18 committee, if we actually had something from the subcommittee chair indicating how much time 19 Otherwise it just seems that we go with the 20 old formula and give everybody an hour and a half or 21 22 something. It's quite clear that some issues take 23 longer than others when you're bringing the whole 24 committee up to speed or if there's much more material 25

1	or something. So maybe you could help guide the
2	planning
3	CHAIRMAN POWERS: Well, let me remind you
4	that this will be the third time that the full
5	committee has been exposed to this material. I mean,
6	they're not virgins on this subject, and in fact, even
7	asking to go through the general purpose of the
8	facility is a little bit repetitious to the committee.
9	They've seen it before.
10	DR. BONACA: Well, I propose it only
11	because this has taken so long.
12	CHAIRMAN POWERS: Yeah, I mean, it's just
13	a reminder and things like that, and it's unusual. It
14	is an experiment, and it's a heroic amount of effort
15	on the part of the staff.
16	MR. ROSEN: And some important things have
17	changed.
18	CHAIRMAN POWERS: And some important
19	things have changed.
20	MS. WESTON: I have already requested
21	additional time.
22	MR. SIEBER: You need to use the
23	microphone.
24	MS. WESTON: Oh, I'm sorry.
25	CHAIRMAN POWERS: And identify yourself.
	MEAL D. CDOSS

1	DR. RANSOM: Speak with sufficient clarity
2	and volume.
3	MS. WESTON: I said I've already requested
4	additional time. We'll see whether or not we get it.
5	John understands that we need more time than the
6	usual.
7	DR. WALLIS: It also depends on how much
8	the ACRS can influence the course of events or add
9	value to this whole process. From what I've seen
10	here, I'm not sure that we have
11	CHAIRMAN POWERS: I can assure you that
12	we'll have a substantial influence on the commission's
13	vote.
14	DR. WALLIS: No, but I think that we're
15	likely to give them a blessing to go ahead and we're
16	going to say we're going to look at things later on
17	when we've got more detail. It isn't as if there are
18	some issues we want to weigh in on at the moment.
19	CHAIRMAN POWERS: No, I think I have three
20	of them, yeah.
21	DR. WALLIS: Well, if the committee has
22	got to weigh in on issues, then we need time to get
23	enough information.
24	CHAIRMAN POWERS: I think there are three
25	of them that we will certainly be exploring further.

Okay. I'd like to try to keep to the schedule and move on to the DPO process. I again can't say enough about the quality of the presentations and the delivery today from those specific topics you brought up, and I will comment on reviewing the SER.

There are, of course, a number of things I think you need to correct in there. It does bear the nature of a draft. I will compliment you on it. Much of the SER reverts to the familiar staff jargon that says, "Gee, maybe we looked at this and it sounds okay," and it didn't tell us how you looked at it, but there are occasions in which you have done a good job in explaining why you came to the conclusion, and I thank you for every one of those, and don't take it too hard for the numerous times you revert back to the familiar jargon of "it looks okay to us."

And we'll be in communication as we try to put this thing together, but I alert you that as the members of the subcommittee get through more and more of this material, it is entirely possible we may have to get together again to chat about specific issues when we don't understand them, and we do have two or three here that we're going to go through, and we'll talk about those a little bit tomorrow.

1	Otherwise I'd like to move on to the next
2	topic.
3	MR. BROWN: Thank you. Thank you for your
4	time.
5	CHAIRMAN POWERS: Thanks, Dave.
6	MR. MURRAY: If I could just have a minute
7	just to see if the copies have been finished, please.
8	(Whereupon, the foregoing matter went off
9	the record at 4:36 p.m. and went back on
10	the record at 4:38 p.m.)
11	CHAIRMAN POWERS: Okay. We're back with
12	Alex Murray.
13	MR. ROSEN: This will be interesting.
14	DR. WALLIS: Are you wearing a different
15	hat now, Alex, or is it the same hat?
16	MR. MURRAY: Yes.
17	MR. ROSEN: Is that crutch loaded?
18	MR. MURRAY: No. I only have one bit of
19	bad news. My pain medicine is wearing off.
20	(Laughter.)
21	MR. MURRAY: Thoughts of me going to a
22	higher quantum state. I apologize.
23	Well, let me begin. My name is Alex
24	Murray. I am the lead chemical safety reviewer for
25	the MOX construction authorization request. As I'm

sure everyone is aware of, I have expressed concerns about potential safety issues at this facility numerous times.

In November of 2003, I actually had, if you will, a dissenting view which I presented before the subcommittee, I believe it was, and now that we've gone a little over another year and a review of some new, additional information has been provided and so forth, I wanted to give you an update on what my thoughts are about where some of these safety issues stand, and I want to emphasize that it is possible that I may decide to pursue some of these safety issues through basically the differing professional opinion process, but I have not finalized any decisions yet.

Now, I want to give you feedback in three general areas. One is some comments on the safety review process, some observations which I think you'll find have been similar to some of the comments and statements that the subcommittee members have mentioned earlier today. I want to just comment on some of the previously open items which were presented today and then give a quick overview about DPVs and DPOs.

Now, this is a two-step licensing process.

1 We've heard that numerous times. Step one 2 construction permit. Step 2 is a license application. I do have a concern about the balance 3 4 between the two. How much can we defer to the license application? How much should we look at and have now? 5 6 In some places I think we really need some 7 more information now, particularly when we're dealing with commitments. All right. In a number of places 8 for the construction permit we, the staff, 9 10 review the application supposed to for the 11 appropriateness of PSSCs and design bases. 12 In some places the commitments are that, oh, well, we'll determine these, which seems to be 13 putting the cart before the horse, and I elaborate 14 15 upon that a little more in a moment. I went through the regulations as regards 16 17 to commitments, and there was no clear statement which even mentions commitments. 18 19 If I look at the safety guidance which is 20 primarily in the standard review plan, I note that there's a comment that commitments may be acceptable. 21 22 A concern which I have with MOX is that in general, 23 you know, we have accepted PSSCs and design basis that the SRP primary source of guidance would say we would 24 25 need more information on, and I have heard that

1 sentiment about the need for more information on PSSCs 2 and design basis mentioned by members of 3 subcommittee here. 4 We also have accepted a number of items 5 which are not what we called RAGAGEP or good practice, 6 reasonably and generally accepted good engineering 7 practices, and I'm concerned that with some of those we do not have an adequate basis for accepting them. 8 9 In particular, I note here about 10 relying on future efforts and experiments to define, 11 if you will, current PSSCs and design bases or better 12 define these PSSCs and design bases. In particular, for red oil and HAN we have a commitment to future 13 experiments to basically fill in the blanks, and that 14 15 concerns me, concerns me greatly. Now, I just want to mention very quickly 16 17 a couple of comments about diverse viewpoints. 18 member --19 DR. WALLIS: Are you going to tell us what some of the blanks are? 20 MR. MURRAY: Yes, in about five minutes. 21 22 Okay? 23 I just wanted to mention a little bit 24 about diverse viewpoints. This is what the staff haws available as, if you will, processes for expressing 25

diverse viewpoints, and I just want to give, you know, some observations.

For the most part I have found in raising safety issues, safety concerns, trying to get some resolution of safety issues and safety concerns, I find that I either deal with it locally or it has to go all the way to DPV/DPO. There's nothing in between, and that's a concern.

Okay. Now, on the positive side, I do want to mention that there are going to be a number of internal staff workshops to try and address a number of these concerns, particularly on the consensus process. So all may not be lost, but again, you know, these are some observations I have.

Now, we at the NRC, we are basically stewards for the public, and I remember from one of the public meetings that this statement was set, and it struck a cord with me, and a couple of other reviewers have picked up on it as well, namely, that the NRC needs to act as a regulator and conduct thorough safety reviews of the proposed MOX facilities.

Now, I'm going to go in and just give some feedback and comments on the previous open items. We discussed these earlier on today, and also just to

remind you, these were items that I had a dissenting viewpoint on at the November 2003 subcommittee meeting, and you can, of course, read the titles of all the issues there.

Now, red oil. Okay. We have discussed this at length. As you know -- I'll show a picture in a second -- there's a potential for significant damage and release of radiochemical materials. This event has happened.

Now, when we look at open systems, okay, we have limited information provided by the applicant. The staff went out, did a lot of digging, looked through the literature, talked to people, did a lot of reviews, and we came to the conclusion that this was clearly acceptable because it is based on test data, empirical data, but data nonetheless, and there was a nice safety margin.

However, for closed system, we really had no additional information from the applicant on the docket. We found that this clearly contradicts some of the Department of Energy and Defense Nuclear Facilities Safety Board reasonably and generally accepted good engineering practices.

And another concern is it is clearly in a range which the department of energy has identified as

1	potentially unsafe.
2	I just want to point out why are we
3	concerned. This is in the public literature. This is
4	a picture of the Tomsk facility in Russia which
5	underwent a red oil event that involved potentially
6	less than 100 gallons of red oil, okay, organic
7	material. What is even more amazing is that the event
8	occurred in a shielded canyon below grade.
9	MR. ROSEN: And that wall blew out
10	obviously with what was it made of?
11	MR. MURRAY: This wall above grade is
12	simply a thin masonry with some reinforced concrete to
13	it. The canyon below it had a four foot thick shield
14	plug blown out.
15	MR. ROSEN: And it pressurized the space
16	behind that wall which blew out
17	MR. MURRAY: Yes.
18	MR. ROSEN: towards the plane
19	MR. MURRAY: That is correct.
20	MR. ROSEN: which was masonry and maybe
21	some reinforced concrete.
22	MR. MURRAY: Some four inch reinforced
23	concrete wall, but you get some idea. This was,
24	again, comparable quantities of organic materials
25	participated in this reaction, and comparable

1	quantities to what would be available at the proposed
2	MOX facility.
3	DR. WALLIS: This was since their runaway
4	reaction?
5	MR. MURRAY: Yes.
6	DR. WEINER: Is it thoroughly documented
7	with access to the documentation, whatever they could
8	figure out? Was it thoroughly documented, whatever
9	they could figure out of the parameters of the runaway
10	reactor?
11	MR. MURRAY: There are several reports and
12	documents on this. There is some interpretation.
13	MR. ROSEN: Can you make a guess about
14	what year it was?
15	MR. MURRAY: I think it was 1994, I
16	believe. It may be '93.
17	MR. SIEBER: Yeah, it wasn't too long ago.
18	CHAIRMAN POWERS: The Department of Energy
19	sent a relatively large review team out. They had
20	access to everything you have. It's like all events
21	of this type. You've got a bunch of junk. It was a
22	less than well instrumented test.
23	MR. MURRAY: Yes. Now, I just wanted to
24	point out you've seen this slide on the pressure vent
25	relationship before. Okay? I'll just point out the

1 open system is here: clear safety margin based on capacity to the empirical test. 2 For the closed system, it's over here. 3 have concerns about that. Okay? It concerns me that 4 5 the approach for closed systems I have to conclude does not provide adequate assurances of safety at this 6 7 I have listed some of my concerns here. it's a control of a single parameter, 8 9 temperature. The potential for common mode failure effects, particularly with heat transfer and the vent. 10 I've heard a couple of the ACRS subcommittee members 11 mention something to that effect. 12 I'm very concerned about 13 14 adequate margin. We have in a closed system a situation, a chemical reaction situation where there 15 is less capability for venting and yet we, the NRC, 16 are willing to accept a higher temperature for the 17 18 reactions. It seems as if we're going the wrong way. And I've also noted what's been discussed 19 here several times about uncertainties. 20 There's very little information on uncertainties. 21 22 have little -- well, we have no calculational basis. DR. WALLIS: How can we tell who's right? 23 MR. MURRAY: That is a good question. 24

DR. WALLIS: Because we have assurances

25

Okay?

margin

1	from one side and you've got questions from the other,
2	but without some technical data, we have no basis for
3	a decision.
4	MR. MURRAY: That is correct. As I state
5	here, I have no assurance that the quench system and
6	the 125 degree Centigrade limit has the ability to
7	prevent red oil reactions.
8	MR. ROSEN: Well, I think, Alex, you stole
9	my point. I think
10	MR. MURRAY: Oh, I'm sorry. I'll give it
11	back to you.
12	MR. ROSEN: I pointed out on the slide
13	that there were no uncertainties. Uncertainties
14	weren't addressed on this 32 kilograms per square
15	centimeter number. Now, the way you deal with
16	uncertainties traditionally is margin.
17	MR. MURRAY: Yes.
18	MR. ROSEN: We establish lots of margin.
19	MR. MURRAY: Yes.
20	MR. ROSEN: So it's not like you can't
21	deal with it. It's just a question of
22	MR. SIEBER: You have to define both the
23	uncertainty and
24	DR. RANSOM: He's just pointing out the
25	vent area where the vent is not sufficient to bring it
l	

1	back to the
2	MR. ROSEN: But that's why I wanted to ask
3	you about your red dot way over there in the corner.
4	MR. MURRAY: Yes.
5	MR. ROSEN: Now, that's your view of how
6	much margin we need?
7	PARTICIPANTS: No, no, no.
8	MR. MURRAY: That is where the applicant's
9	proposed closed system resides on the vent diagram.
10	DR. WALLIS: It's a very small vent.
11	MR. MURRAY: It has a relatively small
12	vent. It is not capable of venting the reaction.
13	MR. ROSEN: But the number goes out to the
14	hundreds perhaps.
15	MR. MURRAY: I think it's around 200.
16	DR. BONACA: Could you explain to me the
17	difference of this approach to the DOE? Well, they're
18	talking about what you recommend. This seems to be an
19	approach which you suggest.
20	MR. MURRAY: Well, my suggested approach,
21	my recommendation is the Department of Energy runs
22	evaporators right now which has controls for
23	addressing red oil concerns. Their controls basically
24	focus on four parameters. So they have control of
25	multiple parameters. They generally have a good

1	branched control strategy on controlling temperature,
2	on controlling organic carryover, on controlling
3	concentration of the nitric acid, and I am controlling
4	the concentration of the organic material.
5	All right. So there are multiple
6	approaches to it.
7	DR. BONACA: So it is not that the
8	approach with DOE is to have larger vent. It's
9	MR. MURRAY: One other control is the
10	Department of Energy uses that vent relationship just
11	to
12	DR. BONACA: Does it move? Doe she move
13	it?
14	MR. MURRAY: On the same slide, the
15	Department of Energy uses vent relationships
16	approximately in this range.
17	DR. BONACA: Also for closed systems.
18	MR. MURRAY: They do not try and make a
19	they do not try to distinguish between open and closed
20	systems.
21	DR. BONACA: But you are not aware of
22	closed systems used by DOE that have must vent area
23	beyond that point?
24	MR. MURRAY: No, I'm not aware of any such
25	situations, and that is the concern I have. I think

1	it's very appropriate that the applicant would put
2	forth what is, in essence, a new safety approach.
3	However, my recommendation, since we have no details
4	on this approach, we have no follow-up test data which
5	has been provided on this approach or calculations, my
6	approach would be, gee, you know, why don't we have a
7	permit condition which imposes the DOE/DNFSV good
8	practices, if you will, which are summarized in a
9	report which they put out last summer, and then at the
10	license application stage, the applicant can come
11	forth and prove their case for something different
12	when they have data.
13	DR. BONACA: Moving to this kind of
14	recommendation, would it have significant implication
15	to the physical construction of the equipment?
16	Because you refer to a number of process issues. I'm
17	asking now regarding physical characteristic of a
18	system.
19	MR. MURRAY: I would think, yes, event
20	size would be larger. There would have to be more
21	safety controls identified, yes.
22	DR. RANSOM: Is the differentiation
23	between an open system and a closed system just the
24	size of the vent?
25	MR. MURRAY: The differentiation between

1	the two systems is basically identified by the size of
2	the event, yes, okay, and an open system as defined by
3	the applicant is in accord with that venting
4	relationship. Okay. It can vent the full red oil
5	reaction if it were to occur.
6	DR. WALLIS: It would still be
7	pressurized. It's just that when it needs to vent, it
8	has a big hole open
9	MR. MURRAY: But basically
10	DR. WALLIS: open to the sky.
11	MR. MURRAY: Right. Basically it has a
12	big enough hole through the venting system, I guess in
13	this case an evaporator be the off-gas treatment
14	system, yes.
15	DR. RANSOM: Well, is it run at one
16	atmosphere then pressure?
17	MR. MURRAY: From the construction
18	application, the revised construction application, I
19	believe two of the evaporators are nominally
20	atmospheric pressure, and one is slightly under
21	vacuum. Oh, I just should say vacuum evaporator.
22	MR. SIEBER: But the venting occurs to the
23	environment, to the atmosphere?
24	MR. MURRAY: Through an off-gas treatment
25	system, ultimately through fans, and then ultimately

1	to the environment, yes.
2	MR. SIEBER: Right, not into a tank.
3	MR. MURRAY: No.
4	DR. BONACA: Why do you feel that this
5	approach of DOE would prevent the Tomsk red oil
6	explosion? I mean you present it as the picture of
7	the explosion right after the design presented here.
8	You just did it to indicate concerns with red oil
9	explosion, not necessarily because you think well,
10	also because you think that system is vulnerable to
11	that kind of
12	MR. MURRAY: I think the Department of
13	Energy has gone through all of the information it has
14	from both its own tests, plus analyses of events like
15	Tomsk, and has come to a conclusion that if you
16	introduce these four types of controls and, if you
17	will, their design basis values, that the event is
18	rendered to be, using DOE terms, incredible, less than
19	ten to the minus six.
20	DR. BONACA: Okay.
21	DR. RANSOM: Why is that? Was the Tomsk
22	situation, for example, a closed system or
23	inadequately vented?
24	MR. MURRAY: Just very quickly, in the
25	case of Tomsk there were two vents. Okay? They both

	323
1	were nominally one inch diameter. What happens, and
2	this happens at any vessel, because of the degree of
3	gas evolution, you essentially experience choked flow
4	as the gases try to get through the vent.
5	DR. RANSOM: So that basically it would
6	not be called an open system, I guess, then.
7	MR. MURRAY: That's correct.
8	DR. RANSOM: Okay.
9	MR. MURRAY: Okay. It could not relieve
10	the full red oil reaction, the gas evolution from the
11	full red oil reaction.
12	CHAIRMAN POWERS: But, Alex
13	MR. MURRAY: Yes.
14	CHAIRMAN POWERS: the contention that
15	DOE makes that it has rendered the red oil phenomena
16	incredible is not the product of detailed kinetic
17	analysis and whatnot. I mean, it's mostly what you
18	would characterize perhaps as a plausibility argument?
19	MR. MURRAY: I would say it's an argument
20	based upon empirical data.
21	CHAIRMAN POWERS: Experiential data.
22	MR. MURRAY: Experiential data, exactly,
23	and thank you for using the word "experiential."
24	Yes?
25	DR. WALLIS: So it wasn't an incredible
	NEAL R. GROSS

1 response. CHAIRMAN POWERS: Well, I understand Tomsk 2 involved a variety of situations that 3 are 4 typically encountered. There are a number of 5 MR. MURRAY: controls which basically weren't followed at Tomsk. 6 7 They had them there. Some were influenced by administrative procedures. There was a shift turnover 8 9 at the time, things like that. Okay. Let me move on and --10 But I guess the sense you DR. BONACA: 11 have is that, in fact, controls and procedures which 12 also the applicant is proposing can, in fact, fail, 13 and you need a mitigating feature, such as a large 14 Is it your fundamental point? 15 event. MR. MURRAY: These are my concerns. 16 17 DR. BONACA: Because, you know, when you 18 look at -- okay. No, you go ahead. MR. MURRAY: These are my concerns, and 19 they include a concern about the adequacy of the vent. 20 In particular, this common mode failure and what 21 happens in the real world when you have vessels and 22 evaporators like this, you essentially hit a limit of 23 about 200 feet per minute with the vapors flowing out 24 where you have choked flow. It's a practical choke 25

1	flow limit, and you cannot get more material, more
2	gases through that vent until your pressure rises.
3	As your pressure rises, the normal boiling
4	point increases. As the normal boiling point
5	increases, the reaction rate increases. You get more
6	gas involved, and it starts running away.
7	DR. WALLIS: In feet per second or
8	MR. MURRAY: I'm sorry?
9	DR. WALLIS: From 200 feet per minute is
10	not very rapid.
11	MR. MURRAY: But that's been if you're
12	going to look at evaporator design, for example
13	DR. WALLIS: That would be in a two-phase
14	mixture that you can get that, but in a gas it's very
15	unlikely.
16	MR. MURRAY: Two-phased mixture is another
17	concern, yes.
18	Let me move on very quickly to
19	HAN/hydrazine, and as we discussed earlier today,
20	there are two cases, and one of the cases has been
21	modeled as a system of partial differential equations.
22	I just wanted to quickly show pictures of how powerful
23	this type of event can be.
24	This is from the Hanford event in 1997.
25	This was before the accident. This was afterwards.

Okay? About 25, 30 gallons of HAN were involved in this event. Fortunately the people, personnel who were in the area has left for lunch. Otherwise there could have been serious injuries and/or deaths.

Now, I just want to quickly go over my conclusions on these. I think the system of partial differential equations' mathematical model is fantastic. I love models; I love math. It's an engineer problem I have. My family thinks I'm nuts.

Having said that, all we, the staff, have done is we have checked the mathematics. That concerns me. You know, we have relatively little comparisons to actual data, and you know, if you start looking at some of these software guidance that we, the agency, have, we haven't followed it, and that bothers me. How do we know we're getting two reasonably good predictions from the system of equations for, if you will, making a safety decision.

I also want to add that there is a contradictory design basis with hydrazoic acid. Now, you know, I think it's something that can be worked out. I have a recommendation coming up in a moment, but I'm concerned there.

Now, Case 2 actually concerns me more than Case 1. Case 1 is where you're trying to prevent

1	decomposition. Case 2 is where you're trying to make
2	it happen. So you are going to have gas evolution in
3	I guess it was the October 2002 revision of the
4	application, the applicant had proposed a flow
5	control, active engineer control for the situation.
6	DR. WALLIS: What flow was being
7	controlled here?
8	MR. MURRAY: Basically the flow of the
9	reagents, the nitric acid, hydrazine.
10	DR. WALLIS: So it's flow control of every
11	reagent.
12	MR. MURRAY: Yes, or it can be a general
13	control on the total flow, essentially controlling how
14	much energy goes into that system.
15	Subsequently, in the revised safety
16	strategy which they submitted last October, I believe
17	it was I'm not sure of the exact date right now
18	the applicant decided to remove that flow control or
19	that active engineered control, and they instead cited
20	standards which accommodate flow design, but not
21	active flow control.
22	And I'm concerned that, you know, we
23	essentially have a situation where we're missing a
24	control link.
25	And here I list my recommendations for

controlling HAN/hydrazine, and for Case 1 it needs to be addressed soon. I think it could be addressed before significant construction gets underway, perhaps deliver the schedule.

On Case 2, I think the applicant and/or the staff should consider putting that active engineered flow control back in.

Let me move on. Electrolyzer. Now, this is a good one. I had a lot of concerns about this area, and I presented a dissenting viewpoint at the November 2003 meeting, and I'll just mention here that the applicant has proposed now what I would call a much more robust safety strategy, and it incorporates both active and passive engineered controls.

Also, the active controls turn off the power. If you don't have electricity, you can't have the initiator for the event, and my conclusion is they've done a smart job there, and that has the ability to meet the Part 70 requirements for construction.

I just want to just very quickly mention this just shows rough calculations by the staff and the various scenarios, and you can see there's potential for very rapid increases in the temperature of the titanium given short in currents. That cannot

	329
1	happen now with their proposed safety strategy.
2	Yes?
3	DR. WALLIS: Because it switches off
4	quickly enough?
5	MR. MURRAY: Yes, yes, exactly.
6	Just a quick comment about uranium
7	dioxide. Burnback, this is one of those strange
8	phenomena. It happens when you lease expect it and
9	when you don't want it to happen, and as you can see
10	here, the concern I have is if you use some of the
11	values that the applicant has stated can be involved,
12	you come I would say very close to the threshold for
13	damaging the filters, the HEPA filters, with the
14	material that has potentially passed through the
15	stainless steel pre-filters.
16	I think this is an easy one to fix.
17	DR. WALLIS: I was a bit curious about how
18	you filter such small particles using stainless steel
19	filters.
20	MR. MURRAY: Yes.
21	DR. WALLIS: What kind of a filter is it
22	that's stainless steel that can filter such small
23	particles?
24	MR. MURRAY: At one of the public
25	meetings, I believe it was the January 2003 one, the

applicant graciously brought in a sample of what they were proposing, and I will say, you know, stainless steel mesh type filters are quite difficult to make in this range, but you know, there are some very capable filter manufacturers out there. So, again, using the criteria, I would say, yes, there's ability to fabricate such filters.

And I think to adequately address this concern, the applicant has stated there would be intermediate HEPA filters. Right now none of those are identified as safety controls. Elevating one of those intermediate filters would address the concern.

Chemical limits, as I said, there are four issues here. One I'll discuss in a moment as a DPV/DPO; also, one related to dispersion modeling, which I'll discuss as a DPV/DPO; and also phenomenological modeling, and that is discussed and addressed in the final safety evaluation report.

This discussion I'm just going to quickly comment about the limits. I have three basic concerns or areas of concerns. One is the staff's previous findings have not been addressed. I've listed them here.

Also, I have some concerns about procedural issues. Okay? Unqualified staff made this

1	decision. You know, what are appropriate chemical
2	levels that do not involve people who have a
3	background in toxicology or in chemistry or biological
4	effects on chemicals? I have a concern about that.
5	You know, what credibility do we have as an agency?
6	And third
7	DR. WALLIS: Were these management type
8	decisions or were they some something delegated to
9	unqualified staff members? How did it happen?
10	MR. MURRAY: A friend of mine, who is a
11	very good health physicist, was asked by management to
12	do a review and to make a recommendation. And as I
13	stated here, these values and we discussed these
14	earlier in the day they do tend to fluctuate a lot.
15	DR. WALLIS: I hope you don't examine all
16	of the qualifications of the ACRS.
17	(Laughter.)
18	MR. MURRAY: You guys have perfect
19	qualifications. Don't you know that?
20	Anyway, since time is short, let me keep
21	moving along.
22	CHAIRMAN POWERS: Could you go back to the
23	variations in TEELs? You have a line there that says
24	certain TEEL values have increased substantially.
25	MR. MURRAY: Yeah, yes.

1	CHAIRMAN POWERS: Would you tell me what
2	you mean?
3	MR. MURRAY: Over the four-year course of
4	the staff's review of the application, several of the
5	TEEL values for chemicals of concern have increased by
6	factors ranging from about five to about 20, if my
7	memory is correct.
8	CHAIRMAN POWERS: And could you maybe have
9	on the top of your head a couple of those that have
10	gone up?
11	MR. MURRAY: One that comes to mind is the
12	one for nitric acid. It approximately tripled from
13	about 25 parts per million up to about 68. These are
14	what I would call Level III values.
15	The values for hydrazine have also
16	changed. I think they have changed by more like a
17	factor of ten. It's detailed in the revised draft
18	safety evaluation report.
19	CHAIRMAN POWERS: My recollection, I could
20	be wrong, but I thought the TEEL for nitric acid was
21	originally based on the one for hydrochloric acid.
22	MR. MURRAY: I don't think so. I think it
23	was based on some actual animal data.
24	CHAIRMAN POWERS: Data.
25	MR. MURRAY: Okay? Okay. Just a quick

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

I should add that two of the DPVs have

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

a dissenting opinion last November, and I will just say that I think the proposed permit condition addresses those concerns that I have.

comment about habitability, and that was where I had

Flammability issues. Okay. In this case you heard a very good discussion that we have had, and the staff had some concerns that the PSSCs, which the applicant has proposed, might not function as intended as interlocks. And we had a brief discussion on that this afternoon, and the staff, we have basically accepted the NFPA-69 as, if you will, the design basis commitment, and if the applicant wants to pursue interlocks, they need to provide the details in the license application as to how they can perform the safety functions. And I think that's a reasonable approach.

Let me just quickly summarize Okav. differing professional viewpoints and professional opinions. Five DPVs have been filed so far on this. There was a change in the DPV/DPO If you have any questions, Rene Pedersen process. from the Office of Enforcement is here, and after I'm done, you may address any concerns on that process to her.

1 through the full process, and two panels appointed by management essentially agreed with the 2 Okay. That's like hitting six 3 DPVs 100 percent. 4 grand slam home runs in a baseball game, to use a 5 sports metaphor. The concern I have was that the actions 6 and responses did not address these safety issues. So 7 8 I pursued both as DPOs. This is just an observation on some of the 9 10 changes in the DPV/DPO process. Now, this is the DPV/DPO on chemical consequences, and in it, 11 expressed concerns about chemical releases which are 12 regulated by the Nuclear Regulatory Commission. 13 that the The applicant has stated 14 15 likelihood of this event is not unlikely. The applicant has also stated that radiation doses are 16 received. However, the applicant has also stated that 17 these releases are not regulated by the NRC because 18 19 they are below 7061 performance requirements. Now, I want to point out that these types 20 of events, or at least one of them, has the potential 21 for multiple fatalities for operators outside the 22 23 emergency control rooms. Now, I am not alone. I work on a team, 24 25 and I try and help people out as much as I can and so

3

4 5

6

7

9

8

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

forth. I want to point out that other members of the staff have done assessments and have found that in the case of one of the chemicals, nitrogen tetraoxide, you can have very high concentrations at 100 meters. At 1,500 milligrams per cubic meter, that is almost like a red fog, all right, no visibility.

Other members of the staff have concluded that that would be immediately incapacitating and fatal. All right? My assessment is, yeah, I tend to agree with that. The estimated concentration could be higher because we have a nuclear facility with a lot of shielding, controlled access, security requirements. That facility design will exacerbates the hazard, and even though there are safe havens at the proposed facility, they are not identified as PSSCs to protect people, and given the magnitude of this event, it is unlikely that they could reach those safe havens or exits. They're trapped. As they're trying to get out, the release would be sucked in.

Now, I show this as an example of a chemical release of nitrogen tetraoxide. Okay. This is from one of the Titan II silos. I believe it was in the early 1970s.

The key point about this: the evaporating surface area in this silo is about comparable to the

1 evaporating surface area from a spill, a potential 2 spill of N_2O_4 at the proposed facility. 3 Also, this is being released 126 feet 4 below ground. Also, the fluid was chilled. It also required evacuation of a town two and a half miles 5 Two people were killed in this event from the 6 7 chemical release even though they had full suits. 8 At the proposed facility at the present 9 time, there is no safety requirement for protection 10 for any members of the facility against this type of 11 hazard. MR. ROSEN: The two people who were killed 12 were members of the crew of that silo? 13 14 MR. MURRAY: That is correct. They had 15 what they called rocket handling protection suit. 16 DR. RANSOM: Were the amount of N₂O₄ 17 comparable? 18 MR. MURRAY: The amounts of N₂O₄ present 19 that facility were greater. The evaporating 20 surface area was about the same. The evaporating surface area is key part to the release, if you will, 21 22 the source term, I should say. CHAIRMAN POWERS: You mentioned the N,O4 23 was chilled, and I'm wondering does that -- I mean, 24 25 the fact that it's chilled, does that enhance its off-

1	site consequences or reduce them?
2	MR. MURRAY: It would depress them, okay,
3	lower vapor pressure, less of a release.
4	CHAIRMAN POWERS: Well, what I'm thinking
5	is the dispersal is less as well. Okay? I mean, if
6	it's hot, you get a buoyancy effect.
7	MR. MURRAY: Un-huh. I know what you're
8	talking about.
9	CHAIRMAN POWERS: And whereas if it's
10	chilled, it tends to hug the ground. I mean, the
11	molecular weight is higher than that of air.
12	MR. MURRAY: Right, right.
13	CHAIRMAN POWERS: It ends to remain
14	concentrated. You just don't have the buoyancy
15	effect.
16	MR. MURRAY: Right, right. It can travel,
17	be dispersed like a heavy fog.
18	DR. WALLIS: Why does it seem to be a
19	plume in this picture if it was chilled? This picture
20	of yours
21	MR. MURRAY: I'm sorry?
22	DR. WALLIS: it seems to be a plume
23	going up, isn't it?
24	MR. MURRAY: Ultimately it is starting to
25	go up, yes. Now, this was taken at a distance from
ľ	NEAL R. GROSS

1	the facility.
2	DR. WALLIS: Some source of heat there or
3	something?
4	MR. MURRAY: What tends to happen with
5	$ m N_2O_4$ is it undergoes a dissociation reaction as it
6	heats up, and that gives some more dispersion to it.
7	So it can both hop the ground. It can move over
8	things as it disburses, go back to the ground.
9	DR. WEINER: We had a very similar
10	incident in Colorado in the very early 1970s. There
11	is an explosives factory near Colorado. It's sort of
12	between Colorado Springs and Denver, and they had a
13	chilled $\mathrm{N}_2\mathrm{O}_4$ release that most of it just simply went
14	up the stack and kind of rolled down the side of the
15	stack, but what got up to the top got picked up by the
16	wind. There are down mountain winds there, and you
17	saw a very similar kind of pattern.
18	CHAIRMAN POWERS: Mike and I think that a
19	lot of the disbursal here may be coming because you're
20	interacting with moisture and water and turning into
21	acid, and that should be an exothermic reaction that's
22	giving you the heat.
23	MR. MURRAY: Let me just continue here.
24	I just restated what the DPV panel found, and I'm a
25	little bit concerned that some of the actions by the

1 office and division didn't really address the concern, ultimately pursue 2 and this as a differing 3 professional opinion. 4 Now, there has been a draft report generated on that, and this report I understand it's 5 6 supposed to be revised and put out late December, 7 early January. This report stated that no further 8 action is needed. DR. WALLIS: What's this chilling effect 9 10 you're referring to on page 34? 11 MR. MURRAY: I asked staff if they'd be 12 willing to sit on various DPV or DPO panels, if they wanted to be involved in discussing some of the 13 issues, and privately other members of the staff, 14 15 senior members of the staff, they agreed with me, but they would not want to be involved with, if you will, 16 17 raising safety issues or being on DPV panels because 18 of concerns about their career. And it was based upon 19 what they saw happen in response to the DPV panel 20 report. Okay. Now, just to finish off, taking a 21 22 little more time -- I apologize. I'll be quick --23 this report was very interesting in that it did say

the safety issue was addressed and no further action

was needed, and it stated it that way because the

24

25

1 panel concluded the applicant has made blanket 2 commitments without exception to multiple codes and 3 standards which have habitability requirements for occupied structures. 4 5 In addition, they looked at the baseline 6 design criteria for chemical safety and that 7 habitability is implied as part of that BDC, and the 8 applicant has stated in their revised application that 9 they intend to follow that baseline design criteria. 10 So what I would conclude from that is, therefore, the applicant is required to maintain 11 12 habitability in all structures at the 13 facility. In other words, they have to address the chemical release event. 14 15 And I'll just quickly summarize about the DPV/DPO on chemical modeling, and you can read this 16 17 slide. This is just a quick summary of the situation. 18 Oh, interesting. These computers never 19 cease to amaze me. My concern is that, you know, we all love 20 21 chemical, we all love mathematical and computer models, but no V&V has been done for the use of this 22 23 model for the specific site of the proposed facility. 24 In other words, the model output has not been compared 25 to, if you will, tracer studies at Savannah River,

	simple terms.
2	CHAIRMAN POWERS: I wonder. It seems to
3	me that one of the I think the most recent ANS
4	meeting, in fact, there was a comparison of dispersion
5	models applied to the Savannah River site, and for the
6	life of me I cannot remember whether ARCON was part of
7	that comparison, but it might be worthwhile to go look
8	at it.
9	MR. MURRAY: Would that be in some of the
10	ACRS
11	CHAIRMAN POWERS: ANS. If I said ACRS, I
12	misspoke myself.
13	MR. MURRAY: ANS. I'm sorry.
14	CHAIRMAN POWERS: The recent meeting at
15	ANS, I'm almost certain there was a paper on comparing
16	several dispersion codes for the Savannah River site,
17	but I can't attest to you whether ARCON was one of
18	them, but my recollection is the paper was quite
19	interesting because the author was very frank in
20	assessing the ease and applicability of the codes.
21	Okay. If I can find that paper, I'll
22	certainly pass it back to you.
23	MR. MURRAY: We will be very interested.
24	CHAIRMAN POWERS: I may be able to find
25	the author easier than the paper.

1	MR. MURRAY: Okay. That would be fine.
2	My E-mail is axm2@nrc.gov. Call me.
3	CHAIRMAN POWERS: Yeah, I will look at
4	that, and like I said, he may not have looked at ARC,
5	but he looked at several of them and found and he
6	goes through which ones are useful and not.
7	MR. MURRAY: Yes.
8	CHAIRMAN POWERS: He was definitely not
9	looking for this facility. He was looking at a
10	tritium release as his base case.
11	MR. MURRAY: Okay, okay.
12	MS. WESTON: I might also suggest that you
13	could, depending on the model you use, you can get
14	variations over a factor of ten, and I might also
15	suggest that you try to or have somebody try to solve
16	the equation, apply the Gaussian equation analytically
17	to see what kind of answers you get, look at an
18	elevated release, look at a stat kite (phonetic), and
19	so on, under various conditions.
20	If you'll give me a call or send me an E-
21	mail, I can give you some guidance on that.
22	MR. MURRAY: Okay, okay. That would be
23	very good.
24	And as I said, I did pursue this as a DPO
25	because there are some safety significant impacts from

1 this, and let me just show you some of my concerns here graphically. 2 3 At the proposed facility, the applicant is using a wind speed 95 percent meteorology of 2.2 4 5 meters per second. So about where these two red hours 6 are. 7 This is a model data comparison, and as you can see, there's quite a bit of spread there. 8 9 Which number do you pick? Right now the applicant's value, if my 10 memory is correct, is approximately around here. 11 MR. ROSEN: Isn't the most conservative 12 value a lower value? 13 MR. MURRAY: That is correct. 14 The most conservative value would be somewhere down here. That 15 What is reasonably conservative -- I 16 17 don't know -- somewhere around here. 18 CHAIRMAN POWERS: Well, I mean, I don't 19 know of anybody that really uses Murphy-Campe anymore for chi over O. 20 MR. MURRAY: Yeah, that correct. 21 22 CHAIRMAN POWERS: I mean, Murphy-Campe is 23 a way of correcting the chi over Q to account for building wake effects, and I don't know of anybody 24 25 that's using Murphy-Campe anymore.

1	MS. WESTON: Also, if you do a joint
2	frequency distribution for wind speed, you usually get
3	a speed around four or 4.5 meters per second, which
4	puts you out a little further.
5	MR. MURRAY: Right, right. And again, you
6	know, we would expect as you get below about four
7	meters per second wind speed that you would have some
8	more variability because of eddies from the phenomena,
9	but I think the question is very valid. Which value
10	do you use for licensing?
11	And this is another comparison with data.
12	Again you see a fair spread there. Again, which value
13	should we pick as providing adequate assurances of
14	safety?
15	DR. WALLIS: You've got data here. You
16	didn't show us any data on red oil or how much it
17	scatters.
18	CHAIRMAN POWERS: No, this is a model-
19	model.
20	DR. WALLIS: No, I know, but I was going
21	back to another issue there and if there was any data
22	talked about.
23	MR. MURRAY: Well, when we were discussing
24	red oil, that's my concern.
25	Okay. Let me continue on here. The DPV

1 panel, as I stated essentially agreed with it, agreed with the DPV. What I found out was that several of 2 the responses, the actions which were taken to address 3 the DPV panel findings did not seem to be in alignment 4 5 with the report itself. Now, let me just mention I did appeal this 6 7 as a DPO, and again, I have three main points there. The information has not been verified and validated as 8 9 per, you know, the NRC normal operating approach with No adequate quality assurances, and I 10 software. believe the safety issues still remain. 11 Now, I did just this week receive a copy 12 of the DPO report, and basically the DPO appeal has 13 been denied, and this implies verification 14 validation for site specific application of the model 15 is not needed, but I'm still reviewing that report. 16 DR. RANSOM: Well, this is all an internal 17 18 NRC procedure; is that right? 19 MR. MURRAY: For these models, yes. And the panel RANSOM: is 20 DR. put They're all from within the NRC? 21 together. 22 MR. MURRAY: All from within the NRC, yes. DR. RANSOM: And who makes the final 23 decision when you said it was denied? 24 In the case of the PPO MR. MURRAY: 25

1 appeal, it's by the EDO. In this case there was no additional panel formed. 2 Let me continue on since time is 3 Okay. 4 marching onwards. There has been a DPV, which I 5 submitted on waste management concerns. Now, I've 6 heard several people here express concerns in the area 7 of waste management. I share some of those concerns, 8 and I want to emphasize that my concerns relate to the 9 NRC regulated entity at the facility, and I've listed 10 the concerns here. 11 Now, I will say this is the DPV that no 12 one seems to want to touch. I don't know why. know, I know waste is a four-letter word, but still 13 14 you know, I really don't understand what has happened 15 here. In the end, after over 12, 13 months, I 16 was told that the DPV was denied because waste is 17 18 under DOE jurisdiction, even though I am just focusing 19 on the open issues which the staff had in the original 20 draft safety evaluation reports. CHAIRMAN POWERS: The issue that's been 21 22 raised here is one that it's waste, to be sure, but it's waste actually on the MOX site. 23 MR. MURRAY: That is correct. 24 CHAIRMAN POWERS: I mean it's before it's 25

1	going to cross the boundary.
2	MR. MURRAY: That is correct, before it's
3	going to cross the boundary. That is correct, yes.
4	CHAIRMAN POWERS: That's not under DOE
5	control.
6	MR. MURRAY: On the other side of the
7	boundary well, the waste, before it goes over the
8	boundary, is under NRC jurisdiction. Again, before we
9	can send it over the boundary, it has got to meet
10	something, some requirement for the Savannah River
11	site. Otherwise it doesn't go. It stays in the NRC
12	regulated entity, and that's the concern I have.
13	DR. WALLIS: And eventually shuts down the
14	plant.
15	MR. MURRAY: Right. Again, you know, what
16	do you do? Shutdown requirement; well, you know, is
17	that something that we specify now or is that
18	something that is specified later?
19	I am of the opinion that it's something
20	that we need to have some closure on now.
	chat we need to have some crosure on how.
21	MR. ROSEN: Well, don't you know the tank
21 22	
	MR. ROSEN: Well, don't you know the tank
22	MR. ROSEN: Well, don't you know the tank sizes for the waste?
22	MR. ROSEN: Well, don't you know the tank sizes for the waste? MR. MURRAY: Yes.

1	overfill the tanks, are they, until the rooms fill up?
2	CHAIRMAN POWERS: I mean, I think Alex is
3	coming from a different point of view here, is that
4	the NRC has a societal obligation not to let a
5	facility run to fill up some tanks with waste.
6	MR. MURRAY: Right.
7	CHAIRMAN POWERS: I mean, that's pretty
8	clear from the Atomic Energy Act that thou shall not
9	do that, but
10	MR. ROSEN: Perhaps, but there's a clear
11	limit established. Things will fill up, and that will
12	be the end of it.
13	CHAIRMAN POWERS: Sometimes establishing
14	these waste acceptance criteria has been
15	extraordinarily slow. Does SRS have a WAC?
16	MR. MURRAY: At the present time, as I
17	understand it, for the proposed DOE facility which
18	would accept this waste, no WACs have been defined.
19	CHAIRMAN POWERS: Yeah. I would not be at
20	all surprised.
21	MR. MURRAY: Yeah. Not even some general
22	type WAC.
23	CHAIRMAN POWERS: Yeah. Those things are
24	I mean it doesn't obviate your point at all, but I
25	was just establishing the ground rules because it
Į	NEAL P. ODOOG

1	takes forever to get these WACs set up.
2	MR. MURRAY: That is correct. That is
3	correct, and I just want to mention that I have
4	forwarded my concerns to the ACRS/ACNW and asked do
5	you guys want to review this area, and I have not
6	heard anything back.
7	MR. ROSEN: Just this one, the waste.
8	MR. MURRAY: That's correct.
9	CHAIRMAN POWERS: You forwarded it to
10	someone besides me. I know that.
11	MR. MURRAY: Yes.
12	CHAIRMAN POWERS: Because I've not seen
13	it.
14	MR. MURRAY: It's all right. It's all
15	right.
16	CHAIRMAN POWERS: So I can't respond to
17	you.
18	MR. MURRAY: Yes, yes. I'm just
19	mentioning that.
20	CHAIRMAN POWERS: Did that come to you?
21	DR. BONACA: Came to you later on.
22	CHAIRMAN POWERS: No, I have not. Nothing
23	has been forwarded to me.
24	DR. WALLIS: It went into the waste
25	stream.

	350
1	DR. RYAN: I did see it.
2	MR. MURRAY: Oh, you have seen it?
3	DR. RYAN: I did, yes.
4	DR. RANSOM: All right. That's what it
5	was.
6	CHAIRMAN POWERS: It's Mike that's slow.
7	You're the bad guy.
8	MR. MURRAY: You got it. You got it.
9	Okay. Very good. Thank you. So it will not be
10	orphaned forever.
11	Let's see. DPVs and chemical limits and
12	flammability. I just want to mention these have been
13	delayed for something like ten months, and they're
14	still rattling around in the system, so to speak, and
15	again, one of my union friends went ahead and filed a
16	grievance on this to say this is nuts.
17	MR. ROSEN: What does this "asked for
18	resubmission" mean?
19	MR. MURRAY: For one of the DPVs I was
20	asked to resubmit it. I said, well, it's in the
21	system. Why isn't it being reviewed, you see?
22	Anyway, let me just give a very quick summary.
23	I see that they're both a process, safety
24	review process, as well as specific safety concerns
25	that I have. I'm not quite sure how strongly I feel

about some of these. There is a potential for more 1 I haven't decided yet, but I say to everybody 2 involved, both members of the staff at the NRC and 3 members of the applicant, some of my colleagues and 4 5 friends from the Department of Energy, we need to do our job, a good job, and address these safety issues 6 7 and put a nice, little, holiday Christmas bow on top of it so that it's all addressed, and in that way 8 9 we'll have discharged our public duty. 10 Thank you very much. If you have any questions, please let me know. 11 CHAIRMAN POWERS: Any questions posed? 12 Oh, my question. 13 DR. WEINER: 14 wanted to commend you for a very thorough discussion of this, and it seemed to me that, first of all, the 15 point made about modeling is one that is near and dear 16 17 Models need to be, when possible, validate to me. 18 against data, not just against another model, and that 19 is used sometimes. I think that I get he impression that he 20 applicant would need to amplify the open system 21 22 description and to thoroughly defend with some detail any use of a closed system. It seems to me you can do 23 that defensibly. Other than that, I made the point 24 25 about the Gaussian dispersion codes.

Gaussian 1 might also point out Ι 2 dispersion codes do not handle the near field well. 3 They blow up close to the source. We're confronting that problem now in a number of instances, and that's 4 5 one reason I suggested trying an analytical solution, 6 because you can play around with what happens in the 7 near field. 8 CHAIRMAN POWERS: There's a very nice 9 model, very nice; there's a useful model that LANL has 10 come up with for the near field area. DR. WEINER: I've seen it. 11 CHAIRMAN POWERS: Yeah, they developed it 12 actually for the Hanford tanks, and it seems to work 13 14 reasonably well. I mean, again, the problem with 15 these field dispersions is that you don't have a great 16 deal of data to compare against, but I mean, they did 17 an adequate job with that. 18 And the nice thing is that it's useful for heavier than air dispersance. 19 20 DR. WEINER: We had one called HAZCON that 21 was floating around Sandia a while ago. It's a very complicated model to use, but it does handle heavier 22 23 than air gases. We used it for chlorine emissions, which is a nice example of heavier than air. 24 25 think the LANL model But may

1	available. You may be able to get it through the Web.
2	MR. MURRAY: Okay.
3	CHAIRMAN POWERS: Any other questions?
4	DR. RANSOM: Are we going to hear anything
5	more on these issues from the NRC?
6	CHAIRMAN POWERS: That really is part of
7	the DPV process, and we're kind of out of that loop
8	until a disposition is made and whatnot.
9	DR. RANSOM: I get the impression
10	that's
11	DR. BONACA: The question that I have is
12	that we are asked to make a determination regarding
13	this SER, and for example, the red oil, I am not
14	two sides of a story, and I don't have the judgment on
15	that issue.
16	CHAIRMAN POWERS: Rene, you wanted to say
17	a word to us?
18	MS. PEDERSEN: Well, I want to let you
19	know that I'm available if you have specific
20	questions, and I, again, commend Alex for coming forth
21	and letting his safety concerns be heard.
22	I've just been assigned as the acting
23	differing professional opinions program what a
24	mouthful program manager since August. Back in
25	June the program was transferred to the Office of
	II

5

6

Enforcement. so this is somewhat of a new program to us, and we're trying all that we can do to address some of Alex's specific issues, but more importantly, we're trying to address the issues that individuals have expressed with this program in general.

7 8

One of the concerns that we've heard from multiple review panels that have reviewed this program since, you know, many, many years is that people are afraid of using the program for fear of retaliation, and clearly that's not acceptable in this agency.

11

10

9

12

14

13

15

16

17

18

19

20

21

23

24

25

In our office, we're trying to get the message out that raising safety concerns, raising concerns is not just a right, but it's responsibility. We want employees to come forward. That doesn't mean that management is going to agree with all of the concerns that you raise, but clearly management has a better ability to make an informed decision when all of the information is brought forward.

What I would like to do is not to go into all of the specifics that Alex has raised on his issues. I just want to clarify a couple of points, if I may. Alex has identified that he's raised five DPVs, and indeed, Alex has raised five DPVs. DPV is not formally accepted into the system until after it

1 has been reviewed by the staff, given a DPV or DPO 2 tracking number, and put into the system. 3 Of the five issues that Alex has raised, 4 two of the issues have been accepted into the system. 5 Two of the issues have been returned, and in a memorandum to Alex that I had issued back 6 7 September, I had encouraged Alex that if he still had concerns with two of these issues, they were returned 8 9 because they were viewed as premature. 10 words, the staff had not established a position at 11 that time.

> Coming into the position new, I Alex's pain in the delays. There's no doubt that this has not been a timely process thus far, but I encouraged Alex that if he had remaining concerns, to please file a DPO under the new program. We no longer have informal have DPVs. We have DPOs. We discussions, formal submittal of a DPO, and then a DPO appeal process.

> So at that point in time I encouraged and I would encourage everybody if they have a safety concern to please file it under the new DPO program, which is on line, and the issue is on Informs. know, we love our forms in the agency.

> > The final issue that Alex has raised is he

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1	had expressed a concern on waste, and this issue was
2	raised all the way to the level of the EDO. This
3	issue was rejected and basically not included, not
4	adopted as a DPV because it was outside our
5	jurisdiction.
6	So while Alex has raised these concerns,
7	I want to make sure that it's clear that these issues
8	are not rattling around in the system because they
9	haven't been adopted. Three of the issues have not
10	been adopted into the system.
11	Who of them very well could be and, again,
12	I would encourage Alex if he has these ongoing
13	concerns to please file them in the new program.
14	MR. MURRAY: I'll just make a comment on
15	that if I could, please.
16	I obviously disagree and so does the NTEU,
17	and that's why the three grievances.
18	Thank you.
19	CHAIRMAN POWERS: I'll bet they get to
20	revisit the waste issue. Just guessing.
21	Well, thank you very much, and unless
22	members have any questions.
23	(No response.)
24	CHAIRMAN POWERS: Okay. Well, what we're
25	going to do tomorrow is we're going to go into this

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

criticality business, and the only reason it's tomorrow is the speaker is available tomorrow and he was not available today.

And, gain, we will get a report from Dr. Diamond up at BNL on his examination of the criticality materials. I think he has specialized expertise in these areas, and he can help us better understand that.

will probably include in that discussion of the criticality this interface between fire protection and criticality at least so we can understand how it was handled a little bit because that's one that's been rattling around here a little bit on this, and we need to understand the role of these fire suppressant systems a little better because we have multiple experiences in the reactor community with the Halon and whatnot being great at suppressing fires, but they don't extract heat, and so you just get back into the fire situation every time air becomes available again.

Once those discussions are over, what I really want to do is to spend some time discussing an outline of the letter. I think we are stuck with producing a fairly lengthy letter here, and so I think it's worth our while to spend some time thinking about

1 | the outline.

Staff has done a very comprehensive assessment of a complex facility in a new exercise, and it's going to be new to the Commission, and so we've got to, I think, produce an equally extensive letter in order to address this.

Now, that's just my thought. We can debate that issue, and I'll remind you that the committee used to in the early days accept entire reactor systems with a glib phrase, something like, "This facility can be operated without undue risk to the public health and safety," for entire reactor systems.

So it would not be without precedence writing a short letter, but I think we're stuck here, and so I think we need to go through it and identify what points we want to make or we think should be made, and what points we need to at least put on the outline until we've had a chance to review things more thoroughly.

DR. WALLIS: Can't we write a letter that says the staff has done thus-and-so and clearly we're not convinced?

CHAIRMAN POWERS: Sure, absolutely, absolutely.

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

1 DR. DENNING: Can we write one that says 2 we're not convinced, but it's -- I'm concerned we haven't heard from the applicant. I mean, you know, 3 it seems to me there are clearly unresolved issues as 4 far as we're concerned. The question is I think that 5 to a large extent the risk here is one of the 6 7 applicant. 8 The applicant has to recognize that they could build a facility that might require major 9 10 renovations, and I could see where the DOE might be under tremendous stress to move forward with this 11 12 because of international agreements and stuff like They may very much want to move forward. 13 14 I'm saying too much because I don't know what words they would tell us if they came, but 15 16 shouldn't we hear from them as to whether they're willing to accept some risk that they may have to 17 modify the facility after it's constructed? 18 Is that really our job? 19 MR. ROSEN: Well, see, here's 20 DENNING: problem that I have, is just how far do we have to go. 21 22 We're definitely not going to hear enough to say this facility is going to be a safe facility. 23 that. So the question is: how far do we have to go? 24

And we could even have some serious

25

reservations and still say if the applicant wants to
proceed, you know, we're going to examine this thing
later and have our comments later.

CHAIRMAN POWERS: Well, right now we
really had not -- I mean, the applicant has come in

really had not -- I mean, the applicant has come in and described its facility, submitted his CAR. We've gone through that. Right now I had not planned to go through more of that material on it. It is not -- I mean, our job is to advise the Commission on what we think about this work and where we have reservations about what has been done and whatnot. I mean, we'll give them our best judgment.

So I don't know that having DOE come in and say what risk they're willing to accept would be anything to change our judgment on it. I mean, we're trying to send some advice to the Commission on this, and it is a technical judgment that we're supposed to offer, and if we have reservations, we need to lay those out in spades and quite clearly.

Yeah, I mean, and this is multi-faceted, and they quite likely will say, "Okay. This part is good and this part we were a little bit concerned about and this is parts that we have great big concerns about." We've got to say that, too.

I certainly have four issues here that I

NEAL R. GROSS

1 think will show up that will involve technical discussion to establish positions on. I think there's 2 3 no control. I mean, I don't think there are any 4 surprised people. It's this control and emergency 5 response and planning, fire protection criticality, hand-off 6 safety, waste interruption issue, 7 habitability, and the chemical control limits. 8 MR. ROSEN: What was the last one, Dana? 9 CHAIRMAN POWERS: Habitability issues, 10 what issues we send. It seems to me that we spent 11 what seemed like altogether too much of my life looking at the Reg. Guide 1.78 on control room 12 habitability, and the focus of that was precisely on 13 these limits, and I think the committee should have a 14 15 consistent position on that unless it makes a conscious decision to deviate from that consistent 16 17 position. 18 MR. ROSEN: The issue is exactly the same. 19 CHAIRMAN POWERS: Oh, yeah. MR. ROSEN: It's protection of human life. 20 CHAIRMAN POWERS: That's exactly the same 21 22 position. I mean, there's just no difference here. And it sounds to me like the demands on the operator 23 are almost consistent here. 24 25 I mean, it just seems to me we ought to

have a consistent position.

Well, at any rate, so I'll invite you tonight to think seriously about what items. I don't want to write text tomorrow, and the outline is exactly that. It is simply an outline. Things can be added to it; things can be deleted from it. It's just an outline, and you can put things on it that says, "I want to put this point on here, but I want to go back and reread the material and think about it in light of what I have -- and I may adjust what I want to say."

I mean, that's perfectly fair. I would rather have something on the outline than to get surprised later during the debate. It's far easier to delete than it is to add within the committee.

That's not to say that the ACRS doesn't have the right to add things to our outline, but I want to come in with a fairly complete outline, and we will go, for the members that are interested, we will go until about noon, and you're guaranteed it's over by one o'clock because I have a separate meeting at one o'clock on the research program. So we'll definitely come to an end prior to one o'clock.

Any other comments people would like to make?

(No response.)

NEAL R. GROSS COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

CHAIRMAN POWERS: Well, in that case, I suggest that we recess for the night and we'll resume I thank all speakers and all tomorrow at 8:30. participants. It was thoroughly enjoyable. (Whereupon, at 5:54 p.m., the subcommittee meeting was concluded.)

CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission in the matter of:

Name of Proceeding: Advisory Committee on

Reactor Safeguards

Reactor Fuels Subcommittee

Docket Number:

n/a

Location:

Rockville, MD

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and, thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Rebecca Davis

Official Reporter

Neal R. Gross & Co., Inc.



NRC Review of the Construction Authorization Request for the Mixed Oxide Fuel Fabrication Facility

David Brown, Project Manager Mixed Oxide Facility Licensing Section Division of Fuel Cycle Safety & Safeguards Office of Nuclear Material Safety & Safeguards

ACRS Subsemmittee on Reactor Fuel



Outline of Introduction

- Purpose of this presentation
- Brief overview of the MOX project
- Regulatory framework for construction authorization
- Overview of project milestones
- Future project schedule

Desember 15-10, 200

ACRS Substantibles on Receive Published



Purpose of this Meeting

Purpose of this meeting is to seek ACRS endorsement of the staff's evaluation of the Construction Authorization Request for the Mixed Oxide Fuel Fabrication Facility

15-14, 304

ACRE Substruction on Frankrick



MOX Project Overview

- September 2000 U.S. and Russia agreed to each disposition 34 metric tons of surplus weapon grade plutonium
- The Department of Energy 's National Nuclear Security Administration, Office of Fissile Materials Disposition, is responsible for all activities relating to managing, storing, and disposing of surplus fissile materials.

Danisher 15-16, 200

ACRE SAMERAN OF STREET



MOX Project Overview

- The National Nuclear Security Administration (NNSA) selected Duke Cogema Stone & Webster to design, build and operate the U.S. Mixed Oxide Fuel Fabrication Facility.
- In April 2002, the NNSA decided to disposition all 34 metric tons of U.S. surplus plutonium by irradiation of mixed oxide fuel in commercial nuclear power reactors.

Describer 15-16, 300

ACRE Subsemmittee on Feature Funts





MOX Project Overview

- NNSA will construct two adjacent facilities at the Savannah River Site near Aiken, SC, to support the Surplus Plutonium Disposition Program
 - Pit Disassembly and Conversion Facility
 Includes the Waste Solidification Building
 - Mixed Oxide Fuel Fabrication Facility

December 15-16, 200-

ICRI Salamanina da Rando Ra







MOX Regulatory Framework

- Two approvals needed for plutonium facilities: .
 - Construction Permit
 - License to possess and use licensed material
- Construction Permit 10 CFR 70.23(b)
 - A safety assessment of the <u>design bases</u> of principal structures, systems, and components (PSSCs)
 - Description of the quality assurance program
 - Environmental impact statement 10 CFR 70.23(a)(7)

Domester 16-16, 200

A786 Administra in America



MOX Regulatory Framework

- 10 CFR 50.2 Definition of Design Bases:
 - "Design Bases means that information which identifies the specific functions to be performed by a structure, system, or component of a facility and the specific values or ranges of values chosen for controlling parameters as reference bounds for design..."

December 15-16, 200

ACRE Subsembles on Reader Rust



MOX Regulatory Framework: 10 CFR 70 Risk-Informed Regulations

	Highly Unlikely	Unilikely	Not unlikely
High Consequence Publ Dose > 25 rem Worker Dose > 100 rem	Acceptable		
Medium Consequence Publ Dose 5 - 25 rem Worker Dose 25 -100 rem Env releases > 5000 Tbl 2	Acceptable	Acceptable	
Low Consequence Publ Dose < 5 rem Worker Dose < 25 rem	Acceptable	Acceptable	Acceptable

Domester 15-10, 2004

ACRS Subsementario on Resour Push



MOX Project Milestones Construction Authorization


- Construction Authorization Request (CAR), Environmental Report and Quality Assurance Program Plan submitted to NRC by February 2001.
- First draft Safety Evaluation Report (SER) in April 2002 with 56 open items.
- Revised CAR in October 2002, after NNSA decision to cancel Plutonium immobilization Project.
- Draft EIS issued by NRC in February 2003 no significant impacts
- Second draft SER in April 2003 with 19 remaining open Items
- November 2003 ACRS meeting with 11 remaining open Items; NNSA announcement of new Controlled Area Boundary

December 16-10, 200

ACRS Submandon on Francis Fusio

**

A





New Controlled Area

MOX facility is located adjacent to the proposed Pit Disassembly and Conversion Facility



December 15-10, 200

ACRS Subsemelton, on Research Publi



MOX Project Milestones

- CAR change pages received by NRC in June 2004
- Applicant made few MOX Facility changes resulting from Controlled Area Boundary change
- Safety assessment change attributed to change in CAB
 - Process Cell Exhaust System is included in the set of facility principal structures, systems, and components (PSSCs).

Domester 18-10, \$00

ACRE Substitution on Parenty Posts

15



MOX Project Milestones

- Other changes in the June 2004 CAR include:
 - Removed uranium oxide dissolution system replaced with uranyl nitrate system
 - Added Waste Organic Solvent unit
 - Updated chemical inventory list
 - Revised waste stream volume estimates
 - Other PSSCs added as a result of open item closure
 Red oil, use of TEELs, and uranium bumback
 - Other editorial changes and corrections.



MOX Project Future

- If the SER is approved and the CAR is granted in February 2005;
 - NRC will start construction inspections and exercise enforcement authority
 - DCS will file a License Application and Integrated Safety Analysis Summary
 - Other license application documents will be filed
 Facility Security Plan
 - Fundamental Nuclear Materials Control Plan
 - ·■ Emergency Plan, if required

Documber 16-16, 300

ACRS Subsemilian on Resulter Push



Open Item Status

■ Presenters:

Alex Murray, Senior Chemical Process Engineer

Bill Troskoski, Senior Chemical Engineer

Rex Wescott, Senior Fire Protection Engineer

Chris Tripp, Senior Nuclear Process Engineer

Describer 16-10, 200

ACRS Substantian on Passier Pasi



FSER Open Item Resolution Since November 2003: Chemical Safety Review Area

Alex Murray Lead Chemical Safety Reviewer NMSS/FCSS/SPB/MOFLS



Overview



- Discuss closure of open items from staff's RDSER (April 2003) and November 2003 ACRS Meeting
- CS-01: Red Oil
- CS-02: HAN/Hydrazine
- AP-03: Electrolyzer /Titanium
- MP-01: Uranium Bumback
- CS-05b: Chemical Limits/TEELs
- CS-10: Control Room Habitability
- CS-09, AP-02, AP-08, and AP-09: Flammability
- * Provide summary

11.17 7 2 10 1 2 10 1

CS-01: Red Oil Introduction



- Aqueous Polishing uses an optimized PUREX solvent extraction process
- Generally two phases: -
 - Aqueous: concentrated nitric acid (10-13.6 N)
 - Organic: Tributyl phosphate and branched dodecane mixture
- Nitrated TBP/organic compounds form
- Collectively termed "red oil" for the mixture

Demander 16-10, 2004

ACRS Substituting on Resetter Re

CS-01: Red Oil Spectrum of "Red Oil"






The solution on the far left is the normal organic phase containing U and TBP.


The far right is the material recovered following an overpressurization event.

Color is dependent mainly on amount of heating and the type of hydrocarbon objects employed.

Desember 15-16, 2004

ACRS Submission on Success State





CS-01: Red Oil Safety Issue



- Red oil species can undergo exothermic reactions, involving small quantities (< 100 gal)
- Reactions can "runaway" and overpressurize vessels
- Several incidents (e.g., "knocking")
- Several accidents with significant equipment damage and release of radionuclides

ACRI Sannantina en Rauter Ras

CS-01: Red Oil Applicant's Safety Approach



- Applicant has identified this as a high consequence event
- Selected a preventative strategy to render the event highly unlikely
- Safety controls:
 - Original application: 1 PSSC with 1 safety function
 - RCAR June 2004:
 - 3 PSSCs with 5 safety functions
 - · commitment to further research and experiments

ACRE Saturantino en Russia Ru

CS-01: Red Oil Applicant Definitions



Two red oil cases:

- Open Systems:
 - Vent provided pressure relief
 - No overpressurization from full runaway reaction
 - Can contain 100% organic compounds
- · Closed Systems: .
 - Vent provided pathway for evaporative cooling
 - Cannot prevent overpressurization from full runaway reaction
 - Can contain substantial but not 100% organic compounds

ACRE Subsemilion on Receive Per

CS-01: Red Oil Applicant's Safety Controls (I)



PSSC*1: Offgas Treatment System

- Provide venting/avoid pressurization
- · Allow path for evaporative cooling
- Open system: avoid pressurization
 -0.008 mm²/g organic (12.5 kg/cm²)
- · Closed System: evaporative cooling
 - -1.2 times [energy input from steam

+ reaction enthalpy]

December 15-16, 2004

CRS Subsection on Receive Real

CS-01: Red Oil
Applicant's Safety Controls (II)



PSSC*2: Process Safety Control Subsystem

- Control reaction enthalpy by limiting steam temperature (to 133 C)
- Limit organic compound residence time (exposure) to oxidizers and radiation
- For closed systems, use aqueous phase addition to:
 - Limit solution temperature to 125 C
 - Limit maximum heatup rate of 2 C/min

December 15-14, 200

ACRS Subsementars on Resetter Fund

,

CS-01: Red Oil
Applicant's Safety Controls (III)



PSSC43: Chemical Safety Controls:

Ensure no cyclical organic compounds in diluent

	The same
	50
BU	

December 16-10, 200

ACRE Subsembles on Resour Res

CS-01: Red Oil **Applicant Commitment**



Further research and experiments to:

- Define reaction kinetics
- Determine effects of impurities
- Establish operational limits and setpoints



CS-01: Red Oil FSER Evaluation/Conclusions




Open Systems:

- Preventative strategy acceptable
- · Multiple PSSCs and safety functions
- Offgas (vent) PSSC design basis well within DOE experimental safety range (12.5 versus limit of approx. 32 kg/cm2)

 System cannot pressurize

 Physicochemically limited to not exceed NBP of azeotrope (120.4 C)
- · Below red oil runaway conditions
- · Accepted by staff



	٠				
٠					

CS-01: Red Oil FSER Evaluation/Conclusions



Closed systems:

- Solution temperature not to exceed 125 C
 - 5 C margin below DOE safe initiation limit
 - 9-12 C below recent SRS test runaway initiation temperatures
- · Organic exposure and diluent selection controls
 - prevent participation of other species (butyl)
 - avoid initiation temperatures below 130 C
- · Temperature ramp control limits runaway enthalpy effects
- Aqueous phase addition and vent provide for evaporative cooling (20% margin) that limits temperature
- Applicant commitment to further research and experiments
- Accepted by staff

December 16-16, 2004

ACRS Subsection on Passier Res

CS-02: Hydroxylamine Nitrate (HAN)/Hydrazine - Introduction



- Aqueous Polishing uses an optimized PUREX solvent extraction process
- A dilute nitric acid solution containing Hydroxylamine Nitrate (HAN) and hydrazine is used to reduce the extracted Pu(IV) to Pu(III) in the pulsed stripping column.
- This transfers (strips) Pu(III) into the aqueous phase
- A similar nitric acid/HAN/hydrazine solution recovers unstripped Pu in the last stage of the plutonium barrier.
- (Plutonium Barrier is to remove the last traces of Pu in the solvent prior to solvent regeneration).
- Hydrazine both stabilizes the HAN and reduces some Pu(IV).

December 15-10, 200

ACRE Subsementario en Receitor Pari

CS-02: HAN/Hydrazine Potential Locations in AP

CS-02: HAN/Hydrazine Safety Issue



- · HAN a reactive chemical
 - can undergo rapid autocatalytic decomposition
 - Nitrous acid/nitric acid reactions
 - Large quantities of gas evolved, pressure excursions
- · Multiple events and accidents in industry
 - Hanford
 - SRS
- Involved quantities comparable to proposed MOX facility

December 18-10, 200

......

CS-02: HAN/Hydrazine Applicant's Safety Approach



- Applicant has identified this as a high consequence event
- Selected a preventative strategy to render the event highly unlikely
- Safety controls:
 - Original Application: partial application of DOE recommendations
 - Revised approach involves multiple parameters and controls

December 16-10, 200-

ACRE Subsemention on Property Pur

CS-02: HAN/Hydrazine Applicant Definitions



Safety strategy focuses on prevention for two areas:

- <u>Case 1:</u> Vessels with HAN/hydrazine, no NO_X addition
 - Avoid decomposition reactions
- <u>Case 2:</u> Vessels containing HAN/hydrazine, with NO_x addition
 - Induce decomposition to avoid recycle and accumulation

December 15-16, 2004

ACRE Submanitre en Resulte Per

CS-02: HAN/Hydrazine Applicant - Case 1 Analyses



- Developed kinetic model based upon multiple reaction mechanisms (5 PDEs)
- Used kinetic parameters from the literature
- Solved model using commercial software
- Predicted regions of stability and safety design basis limits
- Applicant committed to confirmatory testing to substantiate the model

December 18-16, 200

PDE = Partial Differential Equation

CS-02: HAN/Hydrazine Applicant Controls for Case 1

PSSC	Safety Function	Controlled Parameter	Design Basis
	Management of the Control of the Con		
	And more		
	(3) E		

CS-02: HAN/Hydrazine Staff Analysis



- Reviewed literature equations
- •. Developed and exercised similar model
- Found:
 - Regions of stability
 - Regions of instability
 - Margin in proposed design bases

Describer 16-10, 200

ACRE Submandone on Receive Real

CS-02: HAN/Hydrazine Staff Analysis of Case 1 DBs



Controlled Parameter	Design Basis	Stable Value	Margin (%)
Temperature	SSICLIFE	₹83 C. 3 4 H 2	13°C(25%)
HNO:	eou ;	and the	THE THE STATE OF
Hydrazine er	0.1M 2.0	SOOTEM THE	0082 M (97) (550%) ()
	2511	Al stable	NA COL
m r	OM .	YARAN	NA Y
Demonsor 16-10, 2004	ACRS Secure	no in Accepter Frants	

CS-02: HAN/Hydrazine Applicant Controls for Case 2



PSSC	Safety Function	Controlled Parameter	Design Basis
		1-7-5-5-7	

CS-02: HAN/Hydrazine Staff Conclusions



Case 1: No NOx

- \Model and literature predict stability
- · Commitment to confirmatory testing
- Acceptable for construction

Case 2: With NOx

- Codes/standards consistent with industry, RAGAGEP
- Code methodology leads to DB values/ranges
- Acceptable for construction

RAGAGEP = Reasonably And Generally Accepted Good Engineering Practices

Department 15-14, 2004 ACRS Subsembles on Register Fusion

27


C

AP-03: Electrolyzer/

- Titanium Fire Introduction
- Purification requires dissolution of PuO₂
 Dissolution can be difficult for some oxides
- Applicant selected electrolytic process based upon DOE/PNL program and Cogema use
- Electrolysis generates Ag[II], which dissolves PuO₂, circa 30 C, 6 N HNO₃
- Titanium used for corrosion resistance to Ag[II]

Documbur 15-10, 200

ACRS Substantibus on Resulter Puts



AP-03: Electrolyzer/Titanium Fire Safety Issue



- Titanium is a reactive metal
- Normal conditions: large currents and presence of oxygen (in HNO₃, oxides)
- Electrical fault could initiate titanium reactions (conditions exceed welding)
 - Planned fire protection may be ineffective, exacerbate situation due to Ti reactivity
 - Ti event would be difficult to predict and mitigate


CRE Salamantina da Rassar Ras

AP-03: ELectrolyzer/Titanium Fire Applicant's Safety Approach



- Applicant has identified this as a high consequence event
- Selected a preventative strategy to render the event highly unlikely
- Safety controls:
 - Original application: no controls
 - Revised approach involves passive and active engineered controls (PECs/AECs)

ACRS Subsementare on Resear Publi



AP-03: Electrolyzer/Titanium Fire Applicant's Safety Controls



Controls identified for:

- Maintenance/shutdown
- Seismic Event during operation
- Electrical fault during operation

Dansmitter 15-14, 390

AP-03: Electrolyzer/Titanium Fire Controls During Maintenance



- Administrative controls
 - Isolate (terminate) power
 - Other requirements in procedures in License Application (LA)
- Staff Evaluation/conclusion:
 - -- Administrative controls RAGAGEP (Reasonably And Generally Accepted Good Engineering Practice, e.g., DOE, NFPA)
 - Other details in LA OK
- Acceptable for construction



ACRE SAMESTER OF SAME

AP-03: Electrolyzer/Titanium Fire Controls during Seismic Event



- PSSC*1 is electrolyzer structure
- Resist seismic events
- Withstand turbulent flow
- Not induce vibrations
- Maintain geometry for criticality purposes
- PSSC*2: seismic trip system (part of PSCS)
 - Isolates power to electrolyzer during seismic event

Documber 16-10, 200

ACRE Subsecutions on Process Funds

AP-03: Electrolyzer/Titanium Fire
Staff Review of Seismic Event



Staff notes:

- Two independent controls
- Low frequency of seismic events
- Termination of power prevents Ti event
- Combination should have the ability to render event highly unlikely
- Acceptable for construction

Dammbur 18-10, 200

ACCES Debugger on Design Burk

AP-03: Electrolyzer/Titanium Fire Controls for Electrical Fault



Passive Engineered Controls (PECs):

- PSSC*1: Sintered frit/barrier (Si₃N₄) –
 separates the anode from cathode in nitric
 acid
- PSSC*2: PTFE separate anode from cathode and anode from ground
- PSSC*3: Guide sleeves separate anode from titanium shell

December 15-14, 304

ACRE Schoolster on Secure School

AP-03: Electrolyzer/Titanium Fire Controls for Electrical Fault (cont)



Active Engineered Controls (AECs):

- Current leakage detection system shut down if > 10 mA
- Rectifier Trip Circuit: shut down if > 420 A
- Both part of PSCS (control system)
- No other related information (experience, references, codes etc.) provided

Danuarius 18-16, \$70

CPS Substitution on Francis: Fusio

AP-03: Electrolyzer/Titanium Fire FSER Conclusions



- Analyzed as top-level fault tree
- Used generic information from SRS, INEEL, codes
- Found combination of PECs and AECs capable of achieving highly unlikely
- AECs also RAGAGEP
- Conclude it is acceptable for the construction authorization




and the St. Mark. ACRE Substitution on Security

MP-01: Uranium Burnback Introduction

- Depleted UO₂ used as the matrix in MOX
- MOX requires blending of fine PuO₂ and (Depleted) DUO₂ powders
- UO₂ thermodynamically unstable under normal conditions
- "Burnback" refers to unexpected oxidation of uranium dioxide powders, e.g., on HEPA filters

December 15-16, 2004

ACRS Subsummers on Reader



MP-01: Uranium Burnback Safety Issue



- Bumback reactions can achieve high temperatures quickly
- Bumback can initiate other reactions/fires, disperse radioactivity, breach confinement, and damage HEPA filters
- Main concern is ball-milled DUO₂ powder ready for blending with PuO₂
- Such fine (< 10 micron) powders can bumback in exothermic reactions starting at room temperature



(HEPA = High Efficiency Particulate Air filter)



ACRS Subsuspenitus en Bosen Posts

MP-01: Uranium Burnback Applicant's Safety Approach



- Applicant has identified final HEPA filters as PSSCs for other safety strategies
- Selected a preventative strategy to remove fine particles and allow HEPA filters to perform their safety functions
- Safety controls:
 - Original application: no controls
 - RCAR strategy (June 2004): 2 high strength metal prefilters identified as PSSCs; also additional protective features (APFs) included

December 15-14, 2004

ACRS Sub-recognition on Reads

MP-01: Uranium Burnback Applicant's Safety Controls



- High strength stainless steel mesh prefilters (spark arrestors)
- Protected two-stage final HEPA filters with structural integrity of >10 inches of water
- Multi redundant ventilation fan systems
- Ventilation system design ensures adequate air flow dilution
- Ventilation system design ensures a pressure drop of <10 inches of water across the HEPA filter elements
- Fire areas protected by two-hour minimum rated fire barriers
- Administrative control for inspection/maintenance of HEPAs/filters

Documber 15-16, 2004

ACRS Sobosamaites en Rendo Peals

MP-01: Uranium Burnback Prefilters (Spark Arrestors)



- Prefilter 1: stainless steel wire mesh in .
 stainless steel frame
- Prefilter 2: stainless steel and fiberglass mesh
- Safety Function: protect final HEPAs by removing particles from the airstream
- Design Basis: > 90% removal for particles > 1 micron size

Note: applicant states particle size is circs 100 micron upon receipt and circa 2 micron after bell milling

December 15-16, 2004

ACRS Substantian on Rose

45

MP-01: Uranium Burnback Applicant's APFs

- UO₂ delivered to the facility site and stored in sealed, 30 gallon drums.
- UO₂ is double-bagged within the drums, under nitrogen atmosphere.
- UO₂ is maintained in a nitrogen atmosphere throughout the process.
- Fire detection and suppression systems provided for gloveboxes (CO₂ injection) and process rooms (clean agent).
- Use noncombustible or nonflammable materials for process equipment construction and finishing.
- Control of combustible materials

APFs = Additional Protective Features - not PSSCs
December 15-16, 2004 ACRS Subsequently on Reader

MP-01: Uranium Burnback Staff Evaluation/Conclusions



- Staff postulated a glovebox spill or fire could disperse fine UO₂ into ventilation system (C4)
- Staff analysis:
 - Ball milled material
 - Amount deposited on HEPAs 10-25% of that needed to cause temperature damage
- Staff concluded adequate safety strategy
 - HEPAs would survive burnback
 - HEPAs would continue to perform safety function

Doomber 15-16, 2006

ACRS Sub-regarding on Read Parks 47

CS-05b: Chemical Limits - TEELs Introduction



- Limits required for assessing consequences from NRC-regulated chemical events
 - 70.61: protect from high and intermediate consequence events involving acute chemical exposures
 - -70.65(b)(7): "description ... quantitative standards ... from acute chemical exposure

December 15-16, 300

ACRS Subservation on Research Part

CS-05b: Chemical Limits: TEELs Safety Issue



- Chemical limits used to determine PSSCs and design bases
- SRP NUREG-1718 examples:
 - AEGLs Acute Exposure Guideline Levels
 - ERPGs Emergency Response Planning Guidelines
 - Other cited values, such as OSHA and NIOSH [PELs, STs, Cs etc.]
- · Applicant may use an alternative
- · Significant variations between different limits
- · Variations affect presence or absence of PSSCs

CS-05b: Chemical Limits: TEELs Applicant's Safety Approach



Chemical Limits:

- Initial Application: none
- Revised Application:
 - Use AEGLs or ERPGs, where available
 - Use TEELs otherwise
 - Several significant variations in values
- Revised Application (June 2004): Table 8-5 values - TEELs and ERPGs

CS-05b: Chemical Limits: TEELs



Consequence Category	(Facility and Site)	IOC/Public
	Dela S	>.1.1 <u>.2</u>
	\$ 27.1 & > 176.5	<.TT 2 >.371%;
	16.50 8	≤.171

Boundary = 160 m receptor

Consequence Category (Facility and Site) Consequence Category (Facility and Site)

CS-05b: Chemical Limits: TEELs FSER Evaluation/Conclusion



- Multiple limits available
- . Level 3 values trend towards high range of all the limits:
- · Level 2 values:
- Much lower
 - All below IDLHs
- More consistency with other limits
- Applicant commitment to < Level 2 (worker) and < Level 1 (IOC/public) addresses concern
- · Level 1 approximates habitability limits
- FSER finds Tables 8.5-8.7 approach acceptable for construction

December 15-14, 200

ACRS Subsementars on Resetter Publi

CS-10: Control Room Habitability - Introduction



- The proposed facility has multiple control rooms and control areas
- The applicant has identified two Emergency Control Rooms (ECRs)
- ECRs have two main functions:
 - maintain a habitable environment for operators
 - provide cooling to emergency electrical rooms

15-14, 200

CS-10: Control Room Habitability ECR Ventilation Systems (HVAC)



- System consists of two, 100% capacity air filter trains (1 for each ECR)
- Each ECR train has one intake
- Each ECR train consists of a filtration unit and booster fan for each intake
- Each filter consists of:
 - · hazardous gas removal cartridge and/or organic vapor cartridge
 - · HEPA filter cartridges

CS-10: Control Room Habitability Safety Issue



- Several chemicals onsite could affect habitability
 - Liquids: HNO₃, N₂H₄, solvent
 - Liquid/gas: N₂O₄, chlorine
- Releases of these chemicals could prevent ECR operators from performing safety functions

CS-10: Control Room Habitability Applicant's Safety Approach



- Applicant has identified chemical release events as affecting the ability of ECR operators to perform safety functions
- Initial application: PSSC but no DB
- FSER: permit condition requires~ habitable DB

CS-10: Control Room Habitability Applicant's Safety Controls



- ECR ventilation (HVAC) identified as **PSSC**
- Safety function is to maintain habitability for operators to perform safety functions
- Design bases use (FSER Table 8-12):
 - IDLHs from R.G. 1.78/OSHA
 - Level 2 values (Table 8.5) if no IDLH
 - Level 3 values if < IDLH

CS-10; Control Room Habitability Other Aspects of Approach (I)



- Each ECR intake is continuously monitored for hazardous chemicals.
- Upon detection of a hazardous chemical above allowable limits, the intake is automatically isolated and switched to the recirculation mode using a filtration unit with HEPA filtration and hazardous gas removal elements.
- An alarm sounds if hazardous chemical levels are detected at both intakes.
- The alarm alerts operators to don emergency self-contained breathing apparatuses (SCBAs).

CS-10: Control Room Habitability Other Aspects of Approach (II)



- Applicant stated that monitoring would be performed for those chemicals whose unmitigated release could result in control room concentrations exceeding the limits (RCAR Table 8-5a)
 - The emergency actions would be initiated when the chemical concentrations are at or below the TEEL-3 limit
 - Specific setpoints would be determined during the final design

CS-10: Control Room Habitability Asphyxiation

- Design Approach (LA):
 - During detailed design, individual rooms and areas will be addressed on a case by case basis to establish if air monitors with alarms are required.
 - · To avoid asphyxiating atmospheres, high ventilation rates are specified to preclude the creation of an asphyxiating atmosphere.
 - Publication P-14 of the Compressed Gas Association (CGA), "Accident Prevention in Oxygen Rich and Oxygen-Deficient Atmospheres"

CS-10: Control Room Habitability Staff Evaluation



- Applicant has:
 - Identified a safety function for ECR operators
 - Identified a safety function to maintain habitability in ECRs for operators
 - Identified a PSSC of ECR HVAC
- Staff found:
 - Table 8-5a values correspond to short exposures (2 minutes per R.G. 1.78)
 - These are inconsistent with habitable conditions

CS-10: Control Room Habitability Staff Conclusions



- Habitable conditions approximated by Level 1 values in Table 8-5.
- Proposed Permit Condition:
 - additional safety function of ECR HVAC shall maintain chemical concentrations below Level 1 values for duration of the event
- Staff concludes approach and permit condition provide for adequate assurances of safety

CS-09, AP-02,08,09: Flammability - Introduction



- The proposed facility uses flammable gases and combustible liquids
- Flammability control approach needed:
 - CS-09: Solvent Temperature DB
 - AP-02: Electrolyzer Flammable Gas Generation
 - AP-08: Offgas Unit Flammable Gases
 - AP-09: Offgas Solvent Flammability

CS-09, AP-02,08,09: Flammability Safety Issue



- Flammable and combustible materials can initiate fires and explosions
- Fires and explosions can breach confinement and release radiochemical materials

CS-09, AP-02,08,09: Flammability Applicant's Safety Approach



- Proposed a preventative strategy .
- Adopted NFPA 69 as DB
- Identified 6 Areas of Applicability (AOAs) and associated PSSCs:
- 1: SX, Recovery, Wastes
- 4: Low T in Acid Recovery
- 2: Oxalic Precip/Mother Liquor 5: Hydrogen from radiolysis
- 3: Higher T in Acid Recovery 6: Hydrogen from electrolysis

(Proposed PSSCs and DB (25% of LFL) around Sintering Furnace and LFL methodology already accepted)

CS-09, AP-02,08,09: Flammability Staff Review



- Reviewed NFPA 69
- Reviewed other guidance
- Reviewed electrolysis

December 15-16, 200

ACRE SAMERINE OF REAL PROPERTY.

CS-09, AP-02,08,09: Flammability NFPA 69 (I)



- Standard on Explosion Prevention Systems
- Provides guidance on oxidant/combustible concentration reduction, suppression, containment, and spark extinguishing
- Combustible concentration
 - At or below 25% of LFL
 - Exception: at or below 60% of LFL provided automatic instrumentation with interlocks

ACRE Subsembles on Practice Park

CS-09, AP-02,08,09: Flammability NFPA 69 (II)



Basic Design Considerations (Section 3-2):

- Required concentration reduction
- Variations in process, temperature, pressure, and materials
- Operating controls
- · Maintenance, inspection, and testing

ICRS Substitution on Faculty Facili

CS-09, AP-02,08,09: Flammability NRC SRP Guidance (I)



MOX Standard Review Plan - NUREG-1718

- Chapter 7 Fire
 - use and interpretation of codes and standards
 - some specific recommendations
- · Chapter 8 Chemical Safety
 - specific interactions (e.g., radiolysis, degradation)
 - analyze potential accidents

ACRS Sameonics on Record Rate

CS-09, AP-02,08,09: Flammability NRC SRP Guidance (II)



Recommendations on Hydrogen Supply

- Designed to withstand seismic events or no internal leaks or shutoff so that 2% not exceeded
- · Bulk storage outside
- Master shutoff valves on hydrogen tanks
- Inerting mentioned around reducing furnace doors and purging during automatic shutdown

December 16-16, 200

ACRS Subsummittee on Resour Rus

71

CS-09, AP-02,08,09: Flammability NRC SRP Guidance (III)



Other Recommendations Involving Hydrogen

- Inert gas use: oxygen content not to exceed 25% of the level needed for combustion
- Inert gas purge and vent on SNM bearing solution tanks
- If inerting not used, other recommendations, such as ventilation so that hydrogen concentrations maintained below 25% of LFL in tanks, pipes, etc. under all expected process conditions

December 15-14, 2004

ACRE Substitution on Project Publisher

72

CS-09, AP-02,08,09: Flammability Related NRC Guidance & Activities



- Report on Hanford Tank Wastes:
 - NFPA 69 applied inside vessels
 - Hydrogen not to exceed 25% of LFL
 - Based on interpretation of NFPA69, as applied to the situation

December 15-16, 200

ACCO D. Accomplished on December Burn

CS-09, AP-02,08,09: Flammability
Electrolytic Hydrogen

* Shows acid
Concentration can
Control hydrogen

**The Basic Concentration Control hydrogen

**The Basic Control hydroge

CS-09, AP-02,08,09: Flammability FSER Conclusions



- · Staff accepts preventative strategy
- Staff accepts general use of NFPA 69 as DB
- Staff will review implementation to check that any proposed interlocks can perform safety functions
 - Applicant has different strategies to pursue
 - Clear calculational and experiential basis needed, with setpoint analysis
 - Deferred until ISA in LA
- Acceptable for construction

Dussenberr 18-10, 200

ACRE Subsementos en Res

Summary





- Previously identified open items from:
 - -DSER
 - Revised DSER

have been satisfactorily addressed by additional controls and safety strategies

• Staff concludes, pursuant to 70.23(b), that DBs of PSSCs proposed by the applicant will provide reasonable assurance of protection against NPH and accidents



Summary

70.64: Baseline Design Criteria (BDC)



- BDC 3 for fires/explosions and 5 for chemical safety
- · Applicant:
 - Proposed many strategies, PSSCs, and DBs
 - Used many specific codes and standards
 - Adopted RAGAGEP in many areas
 - Provided information to resolve open items
 - -Stated BDCs are incorporated (RCAR 5.5.5.4)
- Staff concludes applicant has met BDC

Overall Summary



- · Unique licensing
- First significant application of revised Part 70
- Plutonium facility
- Two-part licensing
- Many NRC/applicant interactions and working together have resulted in:
 - Improved safety controls
 - Significant Improvements in applicant's safety
 - Greater assurances of safety
- The licensing process has added value



FSER Open Item Resolution Since November 2003: NCS Review Area

Christopher S. Tripp Criticality Safety Reviewer NMSS/FCSS/TSG

NCS-04: MOX Validation



- Prior to last ACRS meeting:
- Previously closed for areas of applicability:
 - AOA(1): Pu-nitrate solutions
 - -AOA(2):

MOX pellets, rods, assemblies

- AOA(5):

Miscellaneous Pu-compounds

- Still open:
 - AOA(3):

PuO₂ powders

- AOA(4):

MOX powders

ACPE Submerritus on Possier Push

NCS-04: MOX Validation



- **■** Current Status: Closed
 - -AOA(3): Approved
 - AOA(4): Approved with permit condition:
 - Additional 1% margin in k
 - ■Reduced parametric range
 - Narrowed range in H/X
 - Narrowed range in EALF
 - Limited to <60cm DU reflector
 - Permit condition required due to reduced number of benchmarks for MOX powders

Demander 15-10, 200

ACPS Subsempting on Repair Peri

K_{eff} Margin



- Benchmarks for AOA(4) non-normal
- **■** Committed to follow NUREG/CR-6698
- Nonparametric Method:
 - Uses lowest calculated k_{eff} & nonparametric margin (NPM)
 - NPM depends only on total number of benchmarks
- Method applied to AOA(3) & AOA(4)

December 15-16, 200

ACRE \$4000000 or \$10000 \$100

Application of NPM



■ AOA(3):

- -.25 PuO₂ & 24 Pu-metal benchmarks
- PuO₂ benchmarks found acceptable based on:

 Similar materials, geometry, energy spectra
- Pu-metal benchmarks found acceptable based on:
 - Differ from coide only by density & chemical form
 - Staff calculations showed k_{eff} insensitive to density
 - Æ Effect of oxygen on k_m negligible
 - Confirmed by ORNL S/U code (TSUNAMI)
- 49 applicable benchmarks → 0% NPM

Documbur 15-16, 200-

ACPE Baltermantino en Resette Resis

Application of NPM




■ AOA(4):


- 42 MOX & 17 PuO₂ benchmarks
- 38 MOX benchmarks found acceptable
- 4 MOX benchmarks too high H/X
- 17 PuO₂ benchmarks not shown applicable
 - Low correlation to 6-22wt% Pu-content MOX

 - Increasing importance of 234U capture at low Pu/(DU+Pu)
- 38 applicable benchmarks → 1% NPM

December 15-14, 200

ACRE Belonsealine on Resider And





Low-Moderated MOX



- Recognized shortage of low-H/X MOX benchmarks
- OECD/NEA workshop held April 2004 in **Paris**
 - Share experience with MOX licensing issues
 - Assess need for additional benchmarks
 - Decide among 6 competing proposals
 - Most for reactor-grade (RG)-MOX
 - Most using close-packed fuel rods

Low-Moderated MOX



■ NRC position:

- Weapons-grade (WG)-MOX benchmarks useful to support future flexibility (given restrictions to AOA)
- Not needed to license MFFF (given additional margin acceptable)
- MOX powder benchmarks with WG isotopics preferable

Daniel 15.16 200

ACRI SAMONDO DE BANCO SAM

Follow-on Actions



- TSUNAMI results part of basis for FSER
- Not available to DCS; not approved code (QAP)
- Part of supporting analysis for design basis not incorporated into DCS documentation
 - 13 follow-on areas for additional demonstration identified
 - FSER states basis will be reviewed by staff in license
 - DCS has informed us they'll provide substantiation in separate submittal

Dunamber 15-14, 300

ACRE Substantino to Franty Pub





Additional Slides


■ Safety Evaluation Report on the Construction Authorization Request for the Mixed Oxide Fuel Fabrication Facility


A-----

ACRE Salarantes on Resear Resear











Alex Murray Lead Chemical Safety Reviewer NMSS/FCSS/SPB/MOFLS





Overview

Provide feedback on:

- Safety Review Process
- Previously Open Items
- DPVs/DPOs

Note:

I am impartial – neither for nor against the proposed facility.

I am concerned some safety issues remain and need to be addressed now and not at the License Application stage.

December 2004

Presentation to ACRS Subcommitte







Safety Review Process



Two Step Licensing:

- Step 1:
 - Construction Permit
 - Present
- <u>Step 2:</u>
 - Licensing possession and use
 - Future (next year)
- Concern is the balance between the two and how much can be deferred and revisited later in the licensing stage, particularly for commitments

December 2004

Presentation to ACRS Subcommitte

3



Safety Regulations



- Part 70.23(b): NRC approved when it has determined the DBs of the PSSCs, and QA plan, provide reasonable assurance of protection
- Part 70.61: Compliance with Performance requirements
- 70.64(a): Address the Baseline Design Criteria

Commitments are not mentioned

December 2004

Presentation to ACRS Subcommitte



Safety Guidance





SRP:

- Chapter 8 for chemical safety
- Arranged for two-part licensing review
- Commitments may be acceptable



On MOX, accepted PSSCs and DBs that: In general, have less information than SRP mentions





RAGAGEP = Reasonable And Generally Accepted Good Engineering Practice

December 2004

Presentation to ACRS Subcommitte

5



Diverse Viewpoints



Part of NRC strategic plan – safety and effectiveness goals

- Staff/management discussions
- Nonconcurrences
- Differing Professional Views and Opinions (DPVs and DPOs)

December 2004

Presentation to ACRS Subcommitte

j



Some Observations



- A voting not a consensus process
- Nonconcurrences written but not accessible by the public
- DPV/DPO only practical route to upper management and public
- Prevailing staff/management and MOX management often involved in DPV/DPO process – objectivity and independence unclear
- Unclear if staff have adequately followed QA and documentation needs
- A number of workshops are being conducted to address some of these issues

December 2004

Presentation to ACRS Subcommitte

7



Public Comment



"The NRC needs to act as a regulator and conduct thorough safety reviews [of the MOX facility]"

(public comment during August 2002 public meeting on MOX, North Augusta, South Carolina)



December 2004

Presentation to ACRS Subcommitte

ō



Comments on Previous Open Items



FSER Issues discussed earlier today and at November 2003 ACRS meeting

- CS-01: Red Oil
- CS-02: HAN/Hydrazine
- MP-01: Uranium Burnback
- CS-05b: Chemical Limits/TEELs
- **CS-10: Control Room Habitability**
- AP-03: Electrolyzer / Titanium Fire CS-09, AP-02, AP-08, and AP-09: **Flammability**



December 2004

Presentation to ACRS Subcommitte







- Nitrated TBP/organic compound mixtures
- · Potential for significant damage and release of materials
- Open Systems:
 - Limited information provided by applicant
 - Acceptable because clearly based on test data
- · Closed Systems:
 - Limited information provided by applicant
 - Clearly contradicts DOE/DNFSB RAGAGER
 - In range identified as "unsafe"



December 2004

Presentation to ACRS Subcommitte





My Conclusions:



- Approach for closed systems does not provide adequate assurances of safety:
 - Corresponds to 1 control parameter (T)
 - Common mode failure heat transfer and vent
 - Inadequate margin
 - Uncertainties not adequately considered
 - High aspect ratio design will likely result in higher pressures and temperatures, and phase separation
 - No assurance quench system and 125 C limit will prevent red oil reactions
- No assurance approach can meet Part 70 requirements for a Construction Permit



December 2004

Presentation to ACRS Subcommitte 13

My Recommendation



- Impose DOE/DNFSB RAGAGEP as permit condition
- Give applicant the opportunity to provide assurances about their strategy in the license application

December 2004

Presentation to ACRS
Subcommitte

CS-02: HAN/Hydrazine



- Potential for rapid pressurization
- Two cases:
 - Case 1 without NO_X
 - Case 2 with NO_X addition
- Case 1 modeled as a system of PDEs to identify regions of stability and margin.



16

December 2004

December 2004

Presentation to ACRS Subcommitte



Presentation to ACRS Subcommitte

Why I am concerned - PRF Accident Scene









December 2004

Presentation to ACRS Subcommitte

17

My Conclusions



- Case 1: no NO_X
 - Have only checked the mathematics
 - NRC model/software guidance for making a safety decision not followed
 - Contradictory design bases with hydrazoic acid
- Case 2: with NO_X
 - Applicant removed flow control
 - Cited standards accommodate flow design not flow control
- No assurance of meeting Part 70 criteria for construction permit

December 2004

Presentation to ACRS Subcommitte

Recommendation



- Case 1: no NO_X
 - Have applicant commit to schedule to resolve
 DB conflict early after CAR/permit
- Case 2: with NO_X
 - Propose applicant's original flow control as permit condition
 - Give applicant the opportunity to provide assurances about their strategy in the license application

December 2004

Presentation to ACRS Subcommitte 19


AP-03: Electrolyzer/ Titanium Issues



- Potential for titanium interactions and fires
- Applicant's strategy using RAGAGEPs
- Active and passive engineered controls (AECs and PECs)
- Active control terminates power, which removes the initiator for the event
- Find the approach of AECs and PECs meets Part 70 requirements

December 2004

Presentation to ACRS
Subcommitte



MP-01: UO₂ Burnback



- UO₂ Burnback reactions can damage HEPA filters directly or indirectly (igniting fibers/dust on the filters)
- Strong function of particle size
- Use of applicant UO₂ values produces higher loadings than staff calculations
 - Exceed threshold for one HEPA unit
 - 50-80% of threshold if distributed over C4 HEPAs
 - Contribution from other material on HEPAs not included

December 2004

Presentation to ACRS Subcommitte

Burnback



- One or more features need to be identified as PSSCs and credited for safety
- Recommendation:
 - Propose permit condition that elevates intermediate HEPA filters to PSSCs for this event

December 2004

Presentation to ACRS Subcommitte

23

CS-05b: Chemical Limits



Four Issues:

- Chemical releases discussed as DPV/DPO later
- Modeling:
 - Dispersion Modeling discussed as DPV/DPO
 - Phenomenological Modeling addressed in FSER
- Chemical Limits this discussion

December 2004

Presentation to ACRS Subcommitte

Chemical Limit Concerns



- Findings from RDSER not addressed:
 - TEELs not independent, peer/public reviewed
 - TEELs not endorsed by a regulator
 - Certain TEEL values have increased substantially during review of the CAR
- Procedural Issues:
 - Policy decision qualified staff not involved
 - Prior staff evaluations of limits not considered
 - Public not involved
 - Other regulators not consulted

December 2004

Presentation to ACRS Subcommitte 25

Chemical Limit Concerns (cont.)



- Safety Issues not addressed:
 - Why are significantly higher values acceptable?
 - Why are values that frequently change acceptable?
 - What is appropriate for determining PSSCs and DBs?
- Recommendation: NRC needs a task force of qualified staff to address chemical limits

December 2004

Presentation to ACRS Subcommitte

CS-10: Habitability



- Safety function of ECR HVAC is to maintain habitability
- Applicant's limits do not correspond to habitability
- Proposed permit condition applies habitability limits

December 2004

Presentation to ACRS Subcommitte

27

Flammability Issues



- Applicant proposed NFPA 69 as design basis
- Applicant identified PSSCs for various areas
- Some PSSCs may not function as interlocks for NFPA 69 exception
- Staff has accepted NFPA 69 and expressed need for clear calculational basis for any exception with interlocks, for the license application

December 2004

Presentation to ACRS
Subcommitte





- 5 DPVs filed
- MD 10.159 DPV/DPO process changed in May 2004
- 2 DPVs went through full process
- 2 Management appointed panels agreed essentially 100% with the DPVs
- Actions and response did not address safety issues
- Both pursued as DPOs

December 2004

Presentation to ACRS Subcommitte

29



DPV/DPO Process Changed



- Process has DPO and DPO Appeal, no DPV
- Authority delegated to NMSS for DPOs on MOX
- NMSS has signature authority for MOX
- Consolidation of MOX issues mentioned

December 2004

Presentation to ACRS Subcommitte

DPV/DPO_on_Chemical Consequences



- DPV expressed concerns about chemical releases regulated by NRC
- · Applicant has stated:
 - Not unlikely event
 - Radiation dose received (10s of mrem to 5-10 rem)
 - Not regulated because below 70.61
- Event has the potential for multiple fatalities, perhaps all operators outside the ECRs

December 2004

Presentation to ACRS Subcommitte 31


NRC Assessment



- Management/staff
 - 1,500 mg/m 3 at 100 meters for N $_2$ O $_4$ (in EIS)
 - "Immediately lethal"
- My assessment:
 - Estimated concentrations could be higher
 - Facility design exacerbates hazard
 - Safe havens not PSSCs
 - Unlikely operators could reach safe havens or exits

December 2004

Presentation to ACRS
Subcommitte



DPV Panel Findings



- DPV Panel agreed essentially 100%
 - Recommended the issue be re-opened or a new open issue established
 - Also recommended more guidance and review of safety evaluation process
- NRC Office/Division not in alignment with Panel report and decided:
 - Enough information on the docket, no need for the open item
 - Some guidance provided
- Review of safety evaluation process resulted in a chilling effect

December 2004

Presentation to ACRS Subcommitte

Draft DPO Report



- No further action needed as safety issue is addressed
- Applicant has made blanket commitments without exception to:
 - Codes and standards with habitability requirements
 - 70.64 BDC for chemical safety habitability implied as part of BDC
- Therefore, applicant is required to maintain habitability in all structures at the proposed facility

December 2004

Presentation to ACRS Subcommitte 35

Summary of DPV/DPO on Chemical Modeling (I)



- Multiple codes available for dispersion and consequence estimation
- Applicant initially selected ARCON96, MACCS2, and ALOHA codes
- Applicant subsequently used only ARCON96



ARCON96 (coincidentally) produces lowest consequence results

December 2004

Presentation to ACRS Subcommitte

Summary of DPV/DPO on Chemical Modeling (II)



- Applicant provided input meteorology info
- No verification and validation info provided
- No QA/qualification info provided



Fundamentally, no data On docket to support Site specific safety code Use at SRS MOX site

December 2004

Presentation to ACRS Subcommitte

27

Summary of DPV/DPO on Chemical Modeling (III)





Authored DPV/DPO because:

- Matter closed no reconsideration by local mgmt
- Safety significant:
 - potentially underestimate consequences by 1-2 orders of magnitude
 - Safety controls may be unidentified
- Submitted December 2002

December 2004

Presentation to ACRS Subcommitte





DPV Panel Findings



Essentially agreed with DPV:

- Panel noted generic use of ARCON96 OK
 - <u>but</u> site specific application for MOX not verified/validated against site test data
- NRC guidance on software not followed
- Staff guidance on code selection and user needs

December 2004

Presentation to ACRS Subcommitte

41

Office/Division Responses



On DPV/DPO Appeal, not in alignment with DPV Panel Report:

- Docketed information available
- MDs and NUREG/BR-0167 (Software QA Guidance) not useful
- Sufficient staff guidance available
- RES user-need memo for development/application of scientific codes

December 2004

Presentation to ACRS Subcommitte

DPO Appeal



Three Main Points:

- Information cited is not V&V
- No adequate QA on applicant's code
- Safety issues remain

Received DPO Report Monday (12/13), from a quick review:

- DPO appeal denied
- Implies V&V for site-specific application not needed

December 2004

Presentation to ACRS Subcommitted

43

DPV on Waste Management Concerns



- Safety issues refer to premature closure of Open Items AP-05 and AP-06. Applicant should:
 - Confirm MFFF wastes are treated to meet SRS WACs and will be accepted
 - Identify PSSCs and DBs for the waste unit, such as an inventory limit DB and shutdown requirement
- Clearly within NRC regulatory authority

December 2004 Presentation of SRS Subcommitte

Waste DPV



NRC:

- Delayed the DPV for about a year
- Denied the DPV waste is under DOE jurisdiction

Subsequently:

- NTEU filed a grievance on the process
- I requested the ACRS/ACNW review the DPV and the safety issues



45

DPVs on Chemical Limits and Flammability



NRC:

- Delayed the DPV for about 10 months
- Asked for resubmission

Subsequently:

• NTEU filed a grievance on the process



Summary



- Process and specific safety concerns
- Potential for more DPOs
- We NRC, applicant, and DOE need to do a good job and address these issues

