

MANUAL HARD COPY DISTRIBUTION  
DOCUMENT TRANSMITTAL 2005-444

---

USER INFORMATION:

Name: GERLACH ROSE M EMPL#: 028401 CA#: 0363  
Address: NUCSA2  
Phone#: 54-319

TRANSMITTAL INFORMATION:

TO: GERLACH ROSE M 01/04/2005  
LOCATION: USNRC  
FROM: NUCLEAR RECORDS DOCUMENT CONTROL CENTER (NUCSA-2)  
THE FOLLOWING CHANGES HAVE OCCURRED TO THE HARDCOPY OR ELECTRONIC MANUAL ASSIGNED  
TO YOU:

TSB1 - TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

REMOVE MANUAL TABLE OF CONTENTS DATE: 12/23/2004

ADD MANUAL TABLE OF CONTENTS DATE: 01/03/2005

CATEGORY: DOCUMENTS TYPE: TSB1

ID: TEXT 3.6.4.1

REMOVE: REV:0

ADD: REV: 1

CATEGORY: DOCUMENTS TYPE: TSB1

ID: TEXT 3.6.4.2

REMOVE: REV:1

ADD: REV: 2

CATEGORY: DOCUMENTS TYPE: TSB1

ID: TEXT LOES

REMOVE: REV:53

ADD: REV: 54

UPDATES FOR HARD COPY MANUALS WILL BE DISTRIBUTED WITHIN 5 DAYS IN ACCORDANCE WITH  
DEPARTMENT PROCEDURES. PLEASE MAKE ALL CHANGES AND ACKNOWLEDGE COMPLETE IN YOUR  
NIMS INBOX UPON RECEIPT OF HARD COPY. FOR ELECTRONIC MANUAL USERS, ELECTRONICALLY  
REVIEW THE APPROPRIATE DOCUMENTS AND ACKNOWLEDGE COMPLETE IN YOUR NIMS INBOX.

ADD1

# SSSES MANUAL

Manual Name: TSB1

Manual Title: TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

## Table Of Contents

Issue Date: 01/03/2005

<u>Procedure Name</u>	<u>Rev</u>	<u>Issue Date</u>	<u>Change ID</u>	<u>Change Number</u>
TEXT LOES	54	01/03/2005		
Title: LIST OF EFFECTIVE SECTIONS				
TEXT TOC	5	11/22/2004		
Title: TABLE OF CONTENTS				
TEXT 2.1.1	1	04/27/2004		
Title: SAFETY LIMITS (SLS) REACTOR CORE SLS				
TEXT 2.1.2	0	11/15/2002		
Title: SAFETY LIMITS (SLS) REACTOR COOLANT SYSTEM (RCS) PRESSURE SL				
TEXT 3.0	0	11/15/2002		
Title: LIMITING CONDITION FOR OPERATION (LCO) APPLICABILITY				
TEXT 3.1.1	0	11/15/2002		
Title: REACTIVITY CONTROL SYSTEMS SHUTDOWN MARGIN (SDM)				
TEXT 3.1.2	0	11/15/2002		
Title: REACTIVITY CONTROL SYSTEMS REACTIVITY ANOMALIES				
TEXT 3.1.3	0	11/15/2002		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD OPERABILITY				
TEXT 3.1.4	0	11/15/2002		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM TIMES				
TEXT 3.1.5	0	11/15/2002		
Title: REACTIVITY CONTROL SYSTEMS CONTROL ROD SCRAM ACCUMULATORS				
TEXT 3.1.6	0	11/15/2002		
Title: REACTIVITY CONTROL SYSTEMS ROD PATTERN CONTROL				

# SSSES MANUAL

Manual Name: TSB1

Manual Title: TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.1.7	0	11/15/2002	
Title: REACTIVITY CONTROL SYSTEMS STANDBY LIQUID CONTROL (SLC) SYSTEM			
TEXT 3.1.8	0	11/15/2002	
Title: REACTIVITY CONTROL SYSTEMS SCRAM DISCHARGE VOLUME (SDV) VENT AND DRAIN VALVES			
TEXT 3.2.1	0	11/15/2002	
Title: POWER DISTRIBUTION LIMITS AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)			
TEXT 3.2.2	0	11/15/2002	
Title: POWER DISTRIBUTION LIMITS MINIMUM CRITICAL POWER RATIO (MCPR)			
TEXT 3.2.3	0	11/15/2002	
Title: POWER DISTRIBUTION LIMITS LINEAR HEAT GENERATION RATE (LHGR)			
TEXT 3.2.4	0	11/15/2002	
Title: POWER DISTRIBUTION LIMITS AVERAGE POWER RANGE MONITOR (APRM) GAIN AND SETPOINTS			
TEXT 3.3.1.1	0	11/15/2002	
Title: INSTRUMENTATION REACTOR PROTECTION SYSTEM (RPS) INSTRUMENTATION			
TEXT 3.3.1.2	0	11/15/2002	
Title: INSTRUMENTATION SOURCE RANGE MONITOR (SRM) INSTRUMENTATION			
TEXT 3.3.2.1	0	11/15/2002	
Title: INSTRUMENTATION CONTROL ROD BLOCK INSTRUMENTATION			
TEXT 3.3.2.2	0	11/15/2002	
Title: INSTRUMENTATION FEEDWATER - MAIN TURBINE HIGH WATER LEVEL TRIP INSTRUMENTATION			
TEXT 3.3.3.1	0	11/15/2002	
Title: INSTRUMENTATION POST ACCIDENT MONITORING (PAM) INSTRUMENTATION			
		LDCN	3702
TEXT 3.3.3.2	0	11/15/2002	
Title: INSTRUMENTATION REMOTE SHUTDOWN SYSTEM			

# SSES MANUAL

Manual Name: TSB1

Manual Title: TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.3.4.1                      0      11/15/2002  
Title: INSTRUMENTATION END OF CYCLE RECIRCULATION PUMP TRIP (EOC-RPT) INSTRUMENTATION

TEXT 3.3.4.2                      0      11/15/2002  
Title: INSTRUMENTATION ANTICIPATED TRANSIENT WITHOUT SCRAM RECIRCULATION PUMP TRIP  
(ATWS-RPT) INSTRUMENTATION

TEXT 3.3.5.1                      0      11/15/2002  
Title: INSTRUMENTATION EMERGENCY CORE COOLING SYSTEM (ECCS) INSTRUMENTATION

TEXT 3.3.5.2                      0      11/15/2002  
Title: INSTRUMENTATION REACTOR CORE ISOLATION COOLING (RCIC) SYSTEM INSTRUMENTATION

TEXT 3.3.6.1                      1      11/09/2004  
Title: INSTRUMENTATION PRIMARY CONTAINMENT ISOLATION INSTRUMENTATION

TEXT 3.3.6.2                      1      11/09/2004  
Title: INSTRUMENTATION SECONDARY CONTAINMENT ISOLATION INSTRUMENTATION

TEXT 3.3.7.1                      0      11/15/2002  
Title: INSTRUMENTATION CONTROL ROOM EMERGENCY OUTSIDE AIR SUPPLY (CREOAS) SYSTEM  
INSTRUMENTATION

TEXT 3.3.8.1                      1      09/02/2004  
Title: INSTRUMENTATION LOSS OF POWER (LOP) INSTRUMENTATION

TEXT 3.3.8.2                      0      11/15/2002  
Title: INSTRUMENTATION REACTOR PROTECTION SYSTEM (RPS) ELECTRIC POWER MONITORING

TEXT 3.4.1                        2      11/22/2004  
Title: REACTOR COOLANT SYSTEM (RCS) RECIRCULATION LOOPS OPERATING

TEXT 3.4.2                        0      11/15/2002  
Title: REACTOR COOLANT SYSTEM (RCS) JET PUMPS

TEXT 3.4.3                        0      11/15/2002  
Title: REACTOR COOLANT SYSTEM (RCS) SAFETY/RELIEF VALVES (S/RVS)

---

3

# SSS MANUAL

Manual Name: TSB1

Manual Title: TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.6.1.2	0	11/15/2002	
Title: CONTAINMENT SYSTEMS PRIMARY CONTAINMENT AIR LOCK			
TEXT 3.6.1.3	0	11/15/2002	
Title: CONTAINMENT SYSTEMS PRIMARY CONTAINMENT ISOLATION VALVES (PCIVS)			
		LDCN	3092
TEXT 3.6.1.4	0	11/15/2002	
Title: CONTAINMENT SYSTEMS CONTAINMENT PRESSURE			
TEXT 3.6.1.5	0	11/15/2002	
Title: CONTAINMENT SYSTEMS DRYWELL AIR TEMPERATURE			
TEXT 3.6.1.6	0	11/15/2002	
Title: CONTAINMENT SYSTEMS SUPPRESSION CHAMBER-TO-DRYWELL VACUUM BREAKERS			
TEXT 3.6.2.1	0	11/15/2002	
Title: CONTAINMENT SYSTEMS SUPPRESSION POOL AVERAGE TEMPERATURE			
TEXT 3.6.2.2	0	11/15/2002	
Title: CONTAINMENT SYSTEMS SUPPRESSION POOL WATER LEVEL			
TEXT 3.6.2.3	0	11/15/2002	
Title: CONTAINMENT SYSTEMS RESIDUAL HEAT REMOVAL (RHR) SUPPRESSION POOL COOLING			
TEXT 3.6.2.4	0	11/15/2002	
Title: CONTAINMENT SYSTEMS RESIDUAL HEAT REMOVAL (RHR) SUPPRESSION POOL SPRAY			
TEXT 3.6.3.1	0	11/15/2002	
Title: CONTAINMENT SYSTEMS PRIMARY CONTAINMENT HYDROGEN RECOMBINERS			
TEXT 3.6.3.2	0	11/15/2002	
Title: CONTAINMENT SYSTEMS DRYWELL AIR FLOW SYSTEM			
TEXT 3.6.3.3	0	11/15/2002	
Title: CONTAINMENT SYSTEMS PRIMARY CONTAINMENT OXYGEN CONCENTRATION			

**11**

1



..

01/03/2005. . .

### ISOLATION VALVES (SCIVS)

11/09/2004.

SGT) SYSTEM

11/15/2002.

WATER (RHRSW) SYSTEM AND THE

11/09/2004

SYSTEM

11/15/2002

### AIR SUPPLY (CREOAS) SYSTEM

11/15/2002

STEM. 3

11/15/2002

10

11/15/2002

• •

11/15/2002

**LEVEL**

10/17/2003

TING.

11/15/2002

DOWN

# SSES MANUAL

Manual Name: TSB1

Manual Title: TECHNICAL SPECIFICATION BASES UNIT 1 MANUAL

TEXT 3.8.3 0 11/15/2002

Title: ELECTRICAL POWER SYSTEMS DIESEL FUEL OIL, LUBE OIL, AND STARTING AIR

TEXT 3.8.4 0 11/15/2002

Title: ELECTRICAL POWER SYSTEMS DC SOURCES - OPERATING

TEXT 3.8.5 0 11/15/2002

Title: ELECTRICAL POWER SYSTEMS DC SOURCES - SHUTDOWN

TEXT 3.8.6 0 11/15/2002

Title: ELECTRICAL POWER SYSTEMS BATTERY CELL PARAMETERS

TEXT 3.8.7 0 11/15/2002

Title: ELECTRICAL POWER SYSTEMS DISTRIBUTION SYSTEMS - OPERATING

TEXT 3.8.8 0 11/15/2002

Title: ELECTRICAL POWER SYSTEMS DISTRIBUTION SYSTEMS - SHUTDOWN

TEXT 3.9.1 0 11/15/2002

Title: REFUELING OPERATIONS REFUELING EQUIPMENT INTERLOCKS

TEXT 3.9.2 0 11/15/2002

Title: REFUELING OPERATIONS REFUEL POSITION ONE-ROD-OUT INTERLOCK

TEXT 3.9.3 0 11/15/2002

Title: REFUELING OPERATIONS CONTROL ROD POSITION

TEXT 3.9.4 0 11/15/2002

Title: REFUELING OPERATIONS CONTROL ROD POSITION INDICATION

TEXT 3.9.5 0 11/15/2002

Title: REFUELING OPERATIONS CONTROL ROD OPERABILITY - REFUELING

TEXT 3.9.6 0 11/15/2002

Title: REFUELING OPERATIONS REACTOR PRESSURE VESSEL (RPV) WATER LEVEL



---

;

**SUSQUEHANNA STEAM ELECTRIC STATION**  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
TOC	Table of Contents	5
B 2.0	SAFETY LIMITS BASES	
	Page B 2.0-1	0
	Page TS / B 2.0-2	2
	Page TS / B 2.0-3	3
	Pages TS / B 2.0-4 and TS / B 2.0-5	2
	Page TS / B 2.0-6	1
	Pages B 2.0-7 through B 2.0-9	0
B 3.0	LCO AND SR APPLICABILITY BASES	
	Pages B 3.0-1 through B 3.0-7	0
	Pages TS / B 3.0-8 and TS / B 3.0-9	1
	Pages B 3.0-10 through B 3.0-12	0
	Pages TS / B 3.0-13 through TS / B 3.0-15	1
B 3.1	REACTIVITY CONTROL BASES	
	Pages B 3.1-1 through B 3.1-5	0
	Pages TS / B 3.1-6 and TS / B 3.1-7	1
	Pages B 3.1-8 through B 3.1-27	0
	Pages TS / B 3.1-28	1
	Pages B 3.1-29 through B 3.1-36	0
	Pages TS / B 3.1-37	1
	Pages B 3.1-38 through B 3.1-51	1
B 3.2	POWER DISTRIBUTION LIMITS BASES	
	Page TS / B 3.2-1	1
	Page TS / B 3.2-2	2
	Page TS / B 3.2-3	1
	Page TS / B 3.2-4	2
	Pages TS / B 3.2-5 and TS / B 3.2-6	1
	Page B 3.2-7	0
	Pages TS / B 3.2-8 through TS / B 3.2-10	1
	Page TS / B 3.2-11	2
	Page B 3.2-12	0
	Page TS / B 3.2-13	2
	Pages B 3.2-14 and B 3.2-15	0
	Page TS / B 3.2-16	2
	Pages B 3.2-17 and B 3.2-18	0
	Page TS / B 3.2-19	2
B 3.3	INSTRUMENTATION	
	Pages TS / B 3.3-1 through TS / B 3.3-10	1
	Page TS / B 3.3-11	2
	Pages TS / B 3.3-12 through TS / B 3.3-27	1
	Pages TS / B 3.3-28 through TS / B 3.3-31	2
	Pages TS / B 3.3-32 and TS / B 3.3-33	3

**SUSQUEHANNA STEAM ELECTRIC STATION**  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Pages TS / B 3.3-34 through TS / B 3.3-43	1
	Pages TS / B 3.3-43a through TS / B 3.3-43i	0
	Pages TS / B 3.3-44 through TS / B 3.3-54	1
	Pages B 3.3-55 through B 3.3-63	0
	Pages TS / B 3.3-64 and TS / B 3.3-65	2
	Page TS / B 3.3-66	4
	Page TS / B 3.3-67	3
	Page TS / B 3.3-68	4
	Pages TS / B 3.3-69 and TS / B 3.3-70	3
	Pages TS / B 3.3-71 through TS / B 3.3-75	2
	Page TS / B 3.3-75a	4
	Pages TS / B 3.3-75b through TS / B 3.3-75c	3
	Pages B 3.3-76 through B 3.3-89	0
	Page TS / B 3.3-90	1
	Page B 3.3-91	0
	Page TS / B 3.3-92 through TS / B 3.3-100	1
	Pages B 3.3-101 through B 3.3-103	0
	Page TS / B 3.3-104	1
	Pages B 3.3-105 and B 3.3-106	0
	Page TS / B 3.3-107	1
	Page B 3.3-108	0
	Page TS / B 3.3-109	1
	Pages B 3.3-110 and B 3.3-111	0
	Pages TS / B 3.3-112 and TS / B 3.3-112a	1
	Pages B 3.3-113 and B 3.3-114	0
	Page TS / B 3.3-115	1
	Page TS / B 3.3-116	2
	Page TS / B 3.3-117	1
	Pages B 3.3-118 through B 3.3-122	0
	Pages TS / B 3.3-123 through TS / B 3.3-124	1
	Page TS / B 3.3-124a	0
	Pages B 3.3-125 and B 3.3-126	0
	Page TS / B 3.3-127	1
	Pages B 3.3-128 through B 3.3-130	0
	Page TS / B 3.3-131	1
	Pages B 3.3-132 through B 3.3-137	0
	Page TS / B 3.3-138	1
	Pages B 3.3-139 through B 3.3-149	0
	Page TS / B 3.3-150 through TS / B 3.3-162	1
	Page TS / B 3.3-163	2
	Pages TS / B 3.3-164 through TS / B 3.3-177	1
	Pages TS / B 3.3-178 and TS / B 3.3-179	2
	Page TS / B 3.3-179a	2
	Page TS / B 3.3-179b	0
	Page TS / B 3.3-179c	0
	Page TS / B 3.3-180	1
	Page TS / B 3.3-181	2

**SUSQUEHANNA STEAM ELECTRIC STATION**  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Pages TS / B 3.3-182 through TS / B 3.3-186	1
	Pages TS B 3.3-187 and TS / B 3.3-188	2
	Pages TS / B 3.3-189 through TS / B 3.3-191	1
	Pages B 3.3-192 through B 3.3-204	0
	Page TS / B 3.3-205	1
	Pages B 3.3-206 through B 3.3-219	0
<b>B 3.4</b>	<b>REACTOR COOLANT SYSTEM BASES</b>	
	Pages B 3.4-1 and B 3.4-2	0
	Page TS / B 3.4-3 and Page TS / B 3.4-4	3
	Pages TS / B 3.4-5 through TS / B 3.4-9	2
	Pages B 3.4-10 through B 3.4-14	0
	Page TS / B 3.4-15	1
	Pages TS / B 3.4-16 and TS / B 3.4-17	2
	Page TS / B 3.4-18	1
	Pages B 3.4-19 through B 3.4-28	0
	Page TS / B 3.4-29	1
	Pages B 3.4-30 through B 3.4-48	0
	Page TS / B 3.4-49	2
	Page TS / B 3.4-50	1
	Page TS / B 3.4-51	2
	Pages TS / B 3.4-52 and TS / B 3.4-53	1
	Page TS / B 3.4-54	2
	Page TS / B 3.4-55	2
	Page TS / B 3.4-56	1
	Page TS / B 3.4-57	2
	Pages TS / B 3.4-58 through TS / B 3.4-60	1
<b>B 3.5</b>	<b>ECCS AND RCIC BASES</b>	
	Pages B 3.5-1 and B 3.5-2	0
	Page TS / B 3.5-3	2
	Pages TS / B 3.5-4 and TS / B 3.5-5	1
	Pages B 3.5-6 through B 3.5-10	0
	Page TS / B 3.5-11	1
	Pages B 3.5-12 through B 3.5-15	0
	Pages TS / B 3.5-16 through TS / B 3.5-18	1
	Pages B 3.5-19 through B 3.5-24	0
	Page TS / B 3.5-25	1
	Pages B 3.5-26 through B 3.5-31	0
<b>B 3.6</b>	<b>CONTAINMENT SYSTEMS BASES</b>	
	Page TS / B 3.6-1	2
	Page TS / B 3.6-1a	3
	Pages TS / B 3.6-2 through TS / B 3.6-5	2
	Page TS / B 3.6-6	3
	Pages TS / B 3.6-6a and TS / B 3.6-6b	2
	Page TS / B 3.6-6c	0

**SUSQUEHANNA STEAM ELECTRIC STATION**  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
	Pages B 3.6-7 through B 3.6-14	0
	Page TS / B 3.6-15	2
	Pages TS / B 3.6-15a and TS / B 3.6-15b	0
	Page B 3.6-16	0
	Page TS / B 3.6-17	1
	Page TS / B 3.6-17a	0
	Pages TS / B 3.6-18 and TS / B 3.6-19	0
	Page TS / B 3.6-20	1
	Page TS / B 3.6-21	2
	Page TS / B 3.6-22	1
	Page TS / B 3.6-22a	0
	Page TS / B 3.6-23	1
	Pages TS / B 3.6-24 through TS / B 3.6-25	0
	Page TS / B 3.6-26	0
		Corrected
	Page TS / B 3.6-27	2
	Page TS / B 3.6-28	5
	Page TS / B 3.6-29	1
	Page TS/B 3.6-30	1
	Page TS / B 3.6-31	3
	Pages B 3.6-32 through B 3.6-35	0
	Page TS / B 3.6-36	1
	Page B 3.6-37	0
	Page TS/B 3.6-38	1
	Page B 3.6-39	0
	Page TS / B 3.6-40	3
	Pages B 3.6-41 through B 3.6-43	0
	Pages TS / B 3.6-44 through TS / B 3.6-51	1
	Page TS / B 3.6-52	2
	Pages B 3.6-53 through B 3.6-63	0
	Page TS / B 3.6-64	1
	Pages B 3.6-65 through B 3.6-83	0
	Page TS / B 3.6-84	3
	Pages TS / B 3.6-85 and TS / B 3.6-86	2
	Pages TS / B 3.6-87 through TS / B 3.6-88a	1
	Page TS / B 3.6-89	2
	Page TS / B 3.6-90	1
	Page TS / B 3.6-91	3
	Pages TS / B 3.6-92 through TS / B 3.6-96	1
	Page TS / B 3.6-97	2
	Pages TS / B 3.6-98 and TS / B 3.6-99	1
	Page TS / B 3.6-100	2
	Pages TS / B 3.6-101 and TS / B 3.6-102	1
	Pages TS / B 3.6-103 through TS / B 3.6-105	2
	Pages TS / B 3.6-106 and TS / B 3.6-107	1

**SUSQUEHANNA STEAM ELECTRIC STATION**  
**LIST OF EFFECTIVE SECTIONS (TECHNICAL SPECIFICATIONS BASES)**

<u>Section</u>	<u>Title</u>	<u>Revision</u>
B 3.7	PLANT SYSTEMS BASES	
	Pages TS / B 3.7-1 through TS / B 3.7-6	2
	Page TS / B 3.7-6a	2
	Pages TS / B 3.7-6b and TS / B 3.7-6c	0
	Page TS / B 3.7-7	2
	Pages TS / B 3.7-8 through TS / B 3.7-11	1
	Pages TS / B 3.7-12 and TS / B 3.7-13	1
	Pages TS / B 3.7-14 through TS / B 3.7-18	2
	Page TS / B 3.7-18a	0
	Pages TS / B 3.7-19 through TS / B 3.7-23	1
	Pages B 3.7-24 through B 3.7-26	0
	Pages TS / B 3.7-27 through TS / B 3.7-29	3
	Page TS / B 3.7-30	1
	Pages B 3.7-31 through B 3.7-33	0
B 3.8	ELECTRICAL POWER SYSTEMS BASES	
	Pages TS / B 3.8-1 through TS / B 3.8-4	2
	Page TS / B 3.8-5	3
	Pages TS / B 3.8-6 through TS/B 3.8-8	2
	Pages TS / B 3.8-9 and TS / B 3.8-10	3
	Pages TS / B 3.8-11 and TS / B 3.8-17	2
	Page TS / B 3.8-18	3
	Pages TS / B 3.8-19 through TS / B 3.8-21	2
	Pages TS / B 3.8-22 and TS / B 3.8-23	3
	Pages TS / B 3.8-24 through TS / B 3.8-37	2
	Pages B 3.8-38 through B 3.8-53	0
	Pages TS / B 3.8-54 through TS / B 3.8-61	1
	Page TS / B 3.8-62	2
	Page TS / B 3.8-63	2
	Page TS / B 3.8-64	1
	Page TS / B 3.8-65	2
	Pages TS/B 3.8-66 through B 3.8-90	0
B 3.9	REFUELING OPERATIONS BASES	
	Pages TS / B 3.9-1 and TS / B 3.9-1a	1
	Pages TS / B 3.9-2 through TS / B 3.9-4	1
	Pages B 3.9-5 through B 3.9-30	0
B 3.10	SPECIAL OPERATIONS BASES	
	Page TS / B 3.10-1	1
	Pages B 3.10-2 through B 3.10-31	0
	Page TS / B 3.10-32	1
	Pages B 3.10-33 through B 3.10-37	0
	Page TS / B 3.10 - 38	1

TSB1 text LOES  
12/15/04

## B 3.6 CONTAINMENT SYSTEMS

### B 3.6.4.1 Secondary Containment

#### BASES

##### BACKGROUND

The secondary containment structure completely encloses the primary containment structure such that a dual-containment design is utilized to limit the spread of radioactivity to the environment to within limits. The function of the secondary containment is to contain, dilute, and hold up fission products that may leak from primary containment into secondary containment following a Design Basis Accident (DBA). In conjunction with operation of the Standby Gas Treatment (SGT) System and closure of certain valves whose lines penetrate the secondary containment, the secondary containment is designed to reduce the activity level of the fission products prior to release to the environment and to isolate and contain fission products that are released during certain operations that take place inside primary containment, when primary containment is not required to be OPERABLE, or that take place outside primary containment (Ref. 1).

The secondary containment is a structure that completely encloses the primary containment and reactor coolant pressure boundary components. This structure forms a control volume that serves to hold up and dilute the fission products. It is possible for the pressure in the control volume to rise relative to the environmental pressure (e.g., due to pump and motor heat load additions).

The secondary containment boundary consists of the reactor building structure and associated removable walls and panels, hatches, doors, dampers, sealed penetrations and valves. The secondary containment is divided into Zone I, Zone II and Zone III, each of which must be OPERABLE depending on plant status and the alignment of the secondary containment boundary. Specifically, the Unit 1 secondary containment boundary can be modified to exclude Zone II. Similarly, the Unit 2 secondary containment boundary can be modified to exclude Zone I. Secondary containment may consist of only Zone III when in MODE 4 or 5 during CORE ALTERATIONS, or during handling of irradiated fuel within the Zone III secondary containment boundary.

(continued)

---

**BASES**

---

**BACKGROUND  
(continued)**

To prevent ground level exfiltration while allowing the secondary containment to be designed as a conventional structure, the secondary containment requires support systems to maintain the control volume pressure at less than the external pressure. Requirements for the safety related systems are specified separately in LCO 3.6.4.2, "Secondary Containment Isolation Valves (SCIVs)," and LCO 3.6.4.3, "Standby Gas Treatment (SGT) System." When one or more zones are excluded from secondary containment, the specific requirements for support systems will also change (e.g., required secondary containment isolation valves).

---

**APPLICABLE  
SAFETY  
ANALYSES**

There are two principal accidents for which credit is taken for secondary containment OPERABILITY. These are a loss of coolant accident (LOCA) (Ref. 2) and a fuel handling accident inside secondary containment (Ref. 3). The secondary containment performs no active function in response to either of these limiting events; however, its leak tightness is required to ensure that the release of radioactive materials from the primary containment is restricted to those leakage paths and associated leakage rates assumed in the accident analysis and that fission products entrapped within the secondary containment structure will be treated by the SGT System prior to discharge to the environment.

Secondary containment satisfies Criterion 3 of the NRC Policy Statement (Ref. 4).

---

**LCO**

An OPERABLE secondary containment provides a control volume into which fission products that bypass or leak from primary containment, or are released from the reactor coolant pressure boundary components located in secondary containment, can be diluted and processed prior to release to the environment. For the secondary containment to be considered OPERABLE, it must have adequate leak tightness to ensure that the required vacuum can be established and maintained. The leak tightness of secondary containment must also ensure that the release of radioactive materials to the environment is restricted to those leakage paths and associated leakage rates assumed in the accident analysis. For example, secondary containment bypass leakage must be restricted to the leakage rate required by LCO 3.6.1.3. The secondary containment boundary required to be OPERABLE is dependent on the operating status of both units, as well as the configuration of walls, doors, hatches, SCIVs, and available flow paths to the SGT System.

(continued)



---

**BASES**

---

**APPLICABILITY** In MODES 1, 2, and 3, a LOCA could lead to a fission product release to primary containment that leaks to secondary containment. Therefore, secondary containment OPERABILITY is required during the same operating conditions that require primary containment OPERABILITY.

In MODES 4 and 5, the probability and consequences of the LOCA are reduced due to the pressure and temperature limitations in these MODES. Therefore, maintaining secondary containment OPERABLE is not required in MODE 4 or 5 to ensure a control volume, except for other situations for which significant releases of radioactive material can be postulated, such as during operations with a potential for draining the reactor vessel (OPDRVs), during CORE ALTERATIONS, or during movement of irradiated fuel assemblies in the secondary containment.

---

**ACTIONS**

**A.1**

If secondary containment is inoperable, it must be restored to OPERABLE status within 4 hours. The 4 hour Completion Time provides a period of time to correct the problem that is commensurate with the importance of maintaining secondary containment during MODES 1, 2, and 3. This time period also ensures that the probability of an accident (requiring secondary containment OPERABILITY) occurring during periods where secondary containment is inoperable is minimal.

---

(continued)

---

**BASES**

---

**ACTIONS**  
(continued)

B.1 and B.2

If secondary containment cannot be restored to OPERABLE status within the required Completion Time, the plant must be brought to a MODE in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and to MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

C.1, C.2, and C.3

Movement of irradiated fuel assemblies in the secondary containment, CORE ALTERATIONS, and OPDRVs can be postulated to cause fission product release to the secondary containment. In such cases, the secondary containment is the only barrier to release of fission products to the environment. CORE ALTERATIONS and movement of irradiated fuel assemblies must be immediately suspended if the secondary containment is inoperable.

Suspension of these activities shall not preclude completing an action that involves moving a component to a safe position. Also, action must be immediately initiated to suspend OPDRVs to minimize the probability of a vessel draindown and subsequent potential for fission product release. Actions must continue until OPDRVs are suspended.

Required Action C.1 has been modified by a Note stating that LCO 3.0.3 is not applicable. If moving irradiated fuel assemblies while in MODE 4 or 5, LCO 3.0.3 would not specify any action. If moving irradiated fuel assemblies while in MODE 1, 2, or 3, the fuel movement is independent of reactor operations. Therefore, in either case, inability to suspend movement of irradiated fuel assemblies would not be a sufficient reason to require a reactor shutdown.

---

**SURVEILLANCE**  
**REQUIREMENTS**

SR 3.6.4.1.1

This SR ensures that the secondary containment boundary is sufficiently leak tight to preclude exfiltration.

---

(continued)

**BASES**

---

**SURVEILLANCE  
REQUIREMENTS**     SR 3.6.4.1.1 (continued)

The 24 hour Frequency of this SR was developed based on operating experience related to secondary containment vacuum variations during the applicable MODES and the low probability of a DBA occurring between surveillances.

Furthermore, the 24 hour Frequency is considered adequate in view of other indications available in the control room, including alarms, to alert the operator to an abnormal secondary containment vacuum condition.

SR 3.6.4.1.2 and SR 3.6.4.1.3

Verifying that secondary containment equipment hatches, removable walls and access doors in each access opening required to be closed are closed ensures that the infiltration of outside air of such a magnitude as to prevent maintaining the desired negative pressure does not occur.

When the railroad bay door (No. 101) is closed; all Zone I and III hatches, removable walls, dampers, and doors connected to the railroad access bay are closed; or, only Zone I removable walls and/or doors are open to the railroad access shaft; or, only Zone III hatches and/or dampers are open to the railroad access shaft. When the railroad bay door (No. 101) is open; all Zone I and III hatches, removable walls, dampers, and doors connected to the railroad access bay are closed. The truck bay hatch is closed and the truck bay door (No. 102) is closed unless Zone II is isolated from Zones I and III.

Verifying that all such openings are closed provides adequate assurance that exfiltration from the secondary containment will not occur. In this application, the term "sealed" has no connotation of leak tightness. Maintaining secondary containment OPERABILITY requires verifying each door in each access opening to the secondary containment zones and each access opening between the secondary containment zones is closed.

When an access opening to secondary containment is being used for exit and entry, then at least one door must remain closed.

---

(continued)

## **BASES**

---

### **SURVEILLANCE REQUIREMENTS**    SR 3.6.4.1.2 and SR 3.6.4.1.3 (continued)

When an access opening between secondary containment zones is being used for exit and entry, then at least one door (where two doors are provided) must remain closed. The access openings between secondary containment zones which are not provided with two doors are administratively controlled to maintain secondary containment integrity during exit and entry.

The 31 day Frequency for these SRs has been shown to be adequate, based on operating experience, and is considered adequate in view of the other indications of door and hatch status that are available to the operator.

---

(continued)

**BASES**

**SURVEILLANCE  
REQUIREMENTS  
(continued)**

**SR 3.6.4.1.4 and SR 3.6.4.1.5**

The SGT System exhausts the secondary containment atmosphere to the environment through appropriate treatment equipment. To ensure that all fission products are treated, SR 3.6.4.1.4 verifies that the SGT System will rapidly establish and maintain a pressure in the secondary containment that is less than the pressure external to the secondary containment boundary. This is confirmed by demonstrating that one SGT subsystem will draw down the secondary containment to  $\geq 0.25$  inches of vacuum water gauge in less than or equal to the maximum time allowed. This cannot be accomplished if the secondary containment boundary is not intact. SR 3.6.4.1.5 demonstrates that one SGT subsystem can maintain  $\geq 0.25$  inches of vacuum water gauge for at least 1 hour at less than or equal to the maximum flow rate permitted for the secondary containment configuration that is operable. The 1 hour test period allows secondary containment to be in thermal equilibrium at steady state conditions. As noted, both SR 3.6.4.1.4 and SR 3.6.4.1.5 acceptance limits are dependent upon the secondary containment configuration when testing is being performed. The acceptance criteria for the SRs based on secondary containment configuration is defined as follows:

SECONDARY CONTAINMENT CONFIGURATION	MAXIMUM DRAWDOWN TIME(SEC) (SR 3.6.4.1.4 ACCEPTANCE CRITERIA)	MAXIMUM FLOW RATE (CFM) (SR 3.6.4.1.5 ACCEPTANCE CRITERIA)
Three Zone Operation with Zone II OPERABLE.	$\leq 15$ Seconds (Zones I and III)	$\leq 2885$ CFM From Zones I and III (Verify by calculation that one SGT subsystem will maintain $\geq .25$ inches of vacuum water gauge in secondary containment at a flow rate of $\leq 4000$ CFM (From Zones I, II, and III)).
Three Zone Operation with Zones I, II and III.	$\leq 125$ Seconds (Zones I, II, and III)	$\leq 4000$ CFM (From Zones I, II, and III)
Two Zone Operation with Unit 2 Shutdown and Zone II isolated.	$\leq 117$ Seconds (Zones I and III)	$\leq 2885$ CFM (From Zones I and III)

(continued)

---

**BASES**

---

**SURVEILLANCE REQUIREMENTS**    SR 3.6.4.1.4 and SR 3.6.4.1.5

Only one of the above listed configurations needs to be tested to confirm secondary containment OPERABILITY.

A Note also modifies the Frequency for each SR. This Note identifies that each SR must be performed in the most limiting Secondary Containment Configuration every 60 months. The 60 month Frequency is acceptable because operating experience has shown that these components usually pass the Surveillance and all active components are tested more frequently. Therefore, these tests are used to ensure secondary containment boundary integrity.

Since these SRs are secondary containment tests, they need not be performed with each SGT subsystem. The SGT subsystems are tested on a STAGGERED TEST BASIS, however, to ensure that in addition to the requirements of LCO 3.6.4.3, either SGT subsystem will perform SR 3.6.4.1.4 and SR 3.6.4.1.5. Operating experience has shown these components usually pass the Surveillance when performed at the 24 month Frequency. Therefore, the Frequency was concluded to be acceptable from a reliability standpoint.

- 
- REFERENCES**
1. FSAR, Section 6.2.3.
  2. FSAR, Section 15.6.
  3. FSAR, Section 15.7.4.
  4. Final Policy Statement on Technical Specifications Improvements, July 22, 1993 (58 FR 39132).
-

## B 3.6 CONTAINMENT SYSTEMS

### B 3.6.4.2 Secondary Containment Isolation Valves (SCIVs)

#### BASES

**BACKGROUND** The function of the SCIVs, in combination with other accident mitigation systems, is to limit fission product release during and following postulated Design Basis Accidents (DBAs) (Ref. 1). Secondary containment isolation within the time limits specified for those isolation valves designed to close automatically ensures that fission products that leak from primary containment into secondary containment following a DBA, or that are released during certain operations when primary containment is not required to be OPERABLE or take place outside primary containment, are maintained within the secondary containment boundary.

The OPERABILITY requirements for SCIVs help ensure that an adequate secondary containment boundary is maintained during and after an accident by minimizing potential paths to the environment. These isolation devices consist of either passive devices or active (automatic) devices. Manual valves or dampers, de-activated automatic valves or dampers secured in their closed position (including check valves with flow through the valve secured), and blind flanges are considered passive devices.

Automatic SCIVs close on a secondary containment isolation signal to establish a boundary for untreated radioactive material within secondary containment following a DBA or other accidents.

Other non-sealed penetrations which cross a secondary containment boundary are isolated by the use of valves in the closed position or blind flanges.

---

**APPLICABLE  
SAFETY  
ANALYSES** The SCIVs must be OPERABLE to ensure the secondary containment barrier to fission product releases is established. The principal accidents for which the secondary containment boundary is required are a loss of coolant accident (Ref. 1) and a fuel handling accident inside secondary containment (Ref. 2). The secondary containment performs no active function in response to either of these limiting events, but the boundary

---

(continued)

---

**BASES**

---

**APPLICABLE  
SAFETY  
ANALYSES  
(continued)**

established by SCIVs is required to ensure that leakage from the primary containment is processed by the Standby Gas Treatment (SGT) System before being released to the environment.

Maintaining SCIVs OPERABLE with isolation times within limits ensures that fission products will remain trapped inside secondary containment so that they can be treated by the SGT System prior to discharge to the environment.

SCIVs satisfy Criterion 3 of the NRC Policy Statement (Ref. 3).

---

**LCO**

SCIVs that form a part of the secondary containment boundary are required to be OPERABLE. Depending on the configuration of the secondary containment only specific SCIVs are required. The SCIV safety function is related to control of offsite radiation releases resulting from DBAs.

The automatic isolation valves are considered OPERABLE when their isolation times are within limits and the valves actuate on an automatic isolation signal. The valves covered by this LCO, along with their associated stroke times, are listed in Table B 3.6.4.2-1.

The normally closed isolation valves or blind flanges are considered OPERABLE when manual valves are closed or open in accordance with appropriate administrative controls, automatic SCIVs are deactivated and secured in their closed position, or blind flanges are in place. These passive isolation valves or devices are listed in Table B3.6.4.2-2. Penetrations closed with sealants are considered part of the secondary containment boundary and are not considered penetration flow paths.

---

**APPLICABILITY** In MODES 1, 2, and 3, a DBA could lead to a fission product release to the primary containment that leaks to the secondary containment. Therefore, the OPERABILITY of SCIVs is required.

In MODES 4 and 5, the probability and consequences of these events are reduced due to pressure and temperature

---

(continued)



## **BASES**

---

**APPLICABILITY**  
(continued)      limitations in these MODES. Therefore, maintaining SCIVs OPERABLE is not required in MODE 4 or 5, except for other situations under which significant radioactive releases can be postulated, such as during operations with a potential for draining the reactor vessel (OPDRVs), during CORE ALTERATIONS, or during movement of irradiated fuel assemblies in the secondary containment. Moving irradiated fuel assemblies in the secondary containment may also occur in MODES 1, 2, and 3.

---

**ACTIONS**      The ACTIONS are modified by three Notes. The first Note allows penetration flow paths to be unisolated intermittently under administrative controls. These controls consist of stationing a dedicated operator, who is in continuous communication with the control room, at the controls of the isolation device. In this way, the penetration can be rapidly isolated when a need for secondary containment isolation is indicated.

The second Note provides clarification that for the purpose of this LCO separate Condition entry is allowed for each penetration flow path. This is acceptable, since the Required Actions for each Condition provide appropriate compensatory actions for each inoperable SCIV. Complying with the Required Actions may allow for continued operation, and subsequent inoperable SCIVs are governed by subsequent Condition entry and application of associated Required Actions.

The third Note ensures appropriate remedial actions are taken, if necessary, if the affected system(s) are rendered inoperable by an inoperable SCIV.

### A.1 and A.2

In the event that there are one or more required penetration flow paths with one required SCIV inoperable, the affected penetration flow path(s) must be isolated. The method of isolation must include the use of at least one isolation barrier that cannot be adversely affected by a single active failure. Isolation barriers that meet this criterion are a closed and de-activated automatic SCIV, a closed manual valve, and a blind flange. For penetrations isolated in

---

(continued)

## **BASES**

---

### **ACTIONS**

#### **A.1 and A.2 (continued)**

accordance with Required Action A.1, the device used to isolate the penetration should be the closest available device to secondary containment. The Required Action must be completed within the 8 hour Completion Time. The specified time period is reasonable considering the time required to isolate the penetration, and the probability of a DBA, which requires the SCIVs to close, occurring during this short time is very low.

For affected penetrations that have been isolated in accordance with Required Action A.1, the affected penetration must be verified to be isolated on a periodic basis. This is necessary to ensure that secondary containment penetrations required to be isolated following an accident, but no longer capable of being automatically isolated, will be in the isolation position should an event occur. The Completion Time of once per 31 days is appropriate because the valves are operated under administrative controls and the probability of their misalignment is low. This Required Action does not require any testing or device manipulation. Rather, it involves verification that the affected penetration remains isolated.

Condition A is modified by a Note indicating that this Condition is only applicable to those penetration flow paths with two SCIVs. For penetration flow paths with one SCIV, Condition C provides the appropriate Required Actions.

Required Action A.2 is modified by a Note that applies to devices located in high radiation areas and allows them to be verified closed by use of administrative controls. Allowing verification by administrative controls is considered acceptable, since access to these areas is typically restricted. Therefore, the probability of misalignment, once they have been verified to be in the proper position, is low.

#### **B.1**

With two SCIVs in one or more penetration flow paths inoperable, the affected penetration flow path must be isolated within 4 hours. The method of isolation must

---

(continued)

## **BASES**

---

### **ACTIONS**

#### **B.1 (continued)**

include the use of at least one isolation barrier that cannot be adversely affected by a single active failure. Isolation barriers that meet this criterion are a closed and de-activated automatic valve, a closed manual valve, and a blind flange. The 4 hour Completion Time is reasonable considering the time required to isolate the penetration and the probability of a DBA, which requires the SCIVs to close, occurring during this short time, is very low.

The Condition has been modified by a Note stating that Condition B is only applicable to penetration flow paths with two isolation valves. For penetration flow paths with one SCIV, Condition C provides the appropriate Required Actions.

#### **C.1 and C.2**

With one or more required penetration flow paths with one required SCIV inoperable, the inoperable valve must be restored to OPERABLE status or the affected penetration flow path must be isolated. The method of isolation must include the use of at least one isolation barrier that cannot be adversely affected by a single active failure. Isolation barriers that meet this criterion are a closed and de-activated automatic valve, a closed manual valve, and a blind flange. A check valve may not be used to isolate the affected penetration. Required Action C.1 must be completed within the 4 hour Completion Time. The Completion Time of 4 hours is reasonable considering the relative stability of the system (hence, reliability) to act as a penetration isolation boundary and the relative importance of supporting secondary containment OPERABILITY during MODES 1, 2, and 3.

In the event the affected penetration flow path is isolated in accordance with Required Action C.1, the affected penetration must be verified to be isolated on a periodic basis. This is necessary to ensure that secondary containment penetrations required to be isolated following an accident are isolated.

The Completion Time of once per 31 days for verifying each affected penetration is isolated is appropriate because the

---

(continued)

## **BASES**

---

### **ACTIONS**

#### **C.1 and C.2 (continued)**

valves are operated under administrative controls and the probability of their misalignment is low.

Condition C is modified by a Note indicating that this Condition is only applicable to penetration flow paths with only one SCIV. For penetration flow paths with two SCIVs, Conditions A and B provide the appropriate Required Actions.

Required Action C.2 is modified by a Note that applies to valves and blind flanges located in high radiation areas and allows them to be verified by use of administrative means. Allowing verification by administrative means is considered acceptable, since access to these areas is typically restricted. Therefore, the probability of misalignment of these valves, once they have been verified to be in the proper position, is low.

#### **D.1 and D.2**

If any Required Action and associated Completion Time cannot be met, the plant must be brought to a MODE in which the LCO does not apply. To achieve this status, the plant must be brought to at least MODE 3 within 12 hours and to MODE 4 within 36 hours. The allowed Completion Times are reasonable, based on operating experience, to reach the required plant conditions from full power conditions in an orderly manner and without challenging plant systems.

#### **E.1, E.2, and E.3**

If any Required Action and associated Completion Time are not met, the plant must be placed in a condition in which the LCO does not apply. If applicable, CORE ALTERATIONS and the movement of irradiated fuel assemblies in the secondary containment must be immediately suspended. Suspension of these activities shall not preclude completion of movement of a component to a safe position. Also, if applicable, actions must be immediately initiated to suspend OPDRVs in order to minimize the probability of a vessel draindown and the subsequent potential for fission product release. Actions must continue until OPDRVs are suspended.

---

(continued)

---

**BASES**

---

**ACTIONS**

**E.1, E.2, and E.3 (continued)**

Required Action E.1 has been modified by a Note stating that LCO 3.0.3 is not applicable. If moving irradiated fuel assemblies while in MODE 4 or 5, LCO 3.0.3 would not specify any action. If moving fuel while in MODE 1, 2, or 3, the fuel movement is independent of reactor operations. Therefore, in either case, inability to suspend movement of irradiated fuel assemblies would not be a sufficient reason to require a reactor shutdown.

---

**SURVEILLANCE  
REQUIREMENTS**

**SR 3.6.4.2.1**

This SR verifies that each secondary containment manual isolation valve and blind flange that is required to be closed during accident conditions is closed. The SR helps to ensure that post accident leakage of radioactive fluids or gases outside of the secondary containment boundary is within design limits. This SR does not require any testing or valve manipulation. Rather, it involves verification (typically visual) that those required SCIVs in secondary containment that are capable of being mispositioned are in the correct position.

Since these SCIVs are readily accessible to personnel during normal operation and verification of their position is relatively easy, the 31 day Frequency was chosen to provide added assurance that the SCIVs are in the correct positions.

Two Notes have been added to this SR. The first Note applies to valves and blind flanges located in high radiation areas and allows them to be verified by use of administrative controls. Allowing verification by administrative controls is considered acceptable, since access to these areas is typically restricted during MODES 1, 2, and 3 for ALARA reasons. Therefore, the probability of misalignment of these SCIVs, once they have been verified to be in the proper position, is low.

A second Note has been included to clarify that SCIVs that are open under administrative controls are not required to meet the SR during the time the SCIVs are open.

---

(continued)

---

**BASES**

---

**SURVEILLANCE  
REQUIREMENTS**  
(continued)

**SR 3.6.4.2.2**

SCIVs with maximum isolation times specified in Table B 3.6.2.4-1 are tested every 92 days to verify that the isolation time is within limits to demonstrate OPERABILITY. Automatic SCIVs without maximum isolation times specified in Table B 3.6.4.2-1 are tested under the requirements of SR 3.6.4.2.3. The isolation time test ensures that the SCIV will isolate in a time period less than or equal to that assumed in the safety analyses.

**SR 3.6.4.2.3**

Verifying that each automatic required SCIV closes on a secondary containment isolation signal is required to prevent leakage of radioactive material from secondary containment following a DBA or other accidents. This SR ensures that each automatic SCIV will actuate to the isolation position on a secondary containment isolation signal. The LOGIC SYSTEM FUNCTIONAL TEST in SR 3.3.6.2.5 overlaps this SR to provide complete testing of the safety function. The 24 month Frequency is based on the need to perform this Surveillance under the conditions that apply during a plant outage and the potential for an unplanned transient if the Surveillance were performed with the reactor at power. Operating experience has shown these components usually pass the Surveillance when performed at the 24 month Frequency. Therefore, the Frequency was concluded to be acceptable from a reliability standpoint.

---

**REFERENCES**

1. FSAR, Section 6.2.
  2. FSAR, Section 15.
  3. Final Policy Statement on Technical Specifications Improvements, July 22, 1993 (58 FR 39132).
-

Table B 3.6.4.2-1  
Secondary Containment Ventilation System  
Automatic Isolation Dampers  
(Page 1 of 1)

Reactor Building Zone	Valve Number	Valve Description	Type of Valve	Maximum Isolation Time (Seconds)
I	HD-17586 A&B	Supply System Dampers	Automatic Isolation Damper	10.0
I	HD-17524 A&B	Filtered Exhaust System Dampers	Automatic Isolation Damper	10.0
I	HD-17576A&B	Unfiltered Exhaust System Dampers	Automatic Isolation Damper	10.0
II	HD-27586 A&B	Supply System Dampers	Automatic Isolation Damper	10.0
II	HD-27524 A&B	Filtered Exhaust System Dampers	Automatic Isolation Damper	10.0
II	HD-27576 A&B	Unfiltered Exhaust System Dampers	Automatic Isolation Damper	10.0
III	HD-17564 A&B	Supply System Dampers	Automatic Isolation Damper	14.0
III	HD-17514 A&B	Filtered Exhaust System Dampers	Automatic Isolation Damper	6.5
III	HD-17502 A&B	Unfiltered Exhaust System Dampers	Automatic Isolation Damper	6.0
III	HD-27564 A&B	Supply System Dampers	Automatic Isolation Damper	14.0
III	HD-27514 A&B	Filtered Exhaust System Dampers	Automatic Isolation Damper	6.5
III	HD-27502 A&B	Unfiltered Exhaust System Dampers	Automatic Isolation Damper	6.0
N/A	HD-17534A	Zone 3 Airlock I-606	Automatic Isolation Damper	N/A
N/A	HD-17534B	Zone 3 Airlock I-611	Automatic Isolation Damper	N/A
N/A	HD-17534C	Zone 3 Airlock I-707	Automatic Isolation Damper	N/A
N/A	HD-17534D	Zone 3 Airlock I-803	Automatic Isolation Damper	N/A
N/A	HD-17534E	Zone 3 Airlock I-805	Automatic Isolation Damper	N/A
N/A	HD-17534F	Zone 3 Airlock I-617	Automatic Isolation Damper	N/A
N/A	HD-17534H	Zone 3 Airlock I-618	Automatic Isolation Damper	N/A
N/A	HD-27534A	Zone 3 Airlock II-606	Automatic Isolation Damper	N/A
N/A	HD-27534C	Zone 3 Airlock II-707	Automatic Isolation Damper	N/A
N/A	HD-27534D	Zone 3 Airlock II-803	Automatic Isolation Damper	N/A
N/A	HD-27534E	Zone 3 Airlock II-805	Automatic Isolation Damper	N/A
N/A	HD-27534G	Zone 3 Airlock C-806	Automatic Isolation Damper	N/A
N/A	HD-27534H	Zone 3 Airlock II-618	Automatic Isolation Damper	N/A
N/A	HD-27534I	Zone 3 Airlock II-609	Automatic Isolation Damper	N/A

Table B 3.6.4.2-2  
Secondary Containment Ventilation System  
Passive Isolation Valves or Devices  
(Page 1 of 1)

Device Number	Device Description	Area/Elev	Required Position
X-28-2-3000	Utility Penetration to Unit 1 East Stairwell	Yard/670	Blind Flanged
X-29-2-44	SDHR System to Fuel Pool Cooling	Yard/670	Blind Flanged
X-29-2-45	SDHR System to Fuel Pool Cooling	Yard/670	Blind Flanged
X-29-2-46	Temporary Chiller to RBCW	Yard/670	Blind Flanged
X-29-2-47	Temporary Chiller to RBCW	Yard/670	Blind Flanged
X-29-2-48	Utility Penetration to Unit 1 RR Bay	Yard/670	Capped
X-33-2-3000	Utility Penetration to Unit 2 East Stairwell	Yard/670	Blind Flanged
X-28-2-3000	Utility Penetration to Unit 1 East Stairwell	28/670	Blind Flanged
X-29-2-48	Utility Penetration to Unit 1 RR Bay	29/670	Capped
X-33-2-3000	Utility Penetration to Unit 2 East Stairwell	33/670	Blind Flanged
X-29-3-54	Utility Penetration to Unit 1 RBCCW Hx Area	27/683	Blind Flanged
X-29-3-55	Utility Penetration to Unit 1 RBCCW Hx Area	27/683	Blind Flanged
X-29-5-95	Temporary Chiller to Unit 1 RBCW	29/749	Blind Flanged
X-29-5-96	Temporary Chiller to Unit 1 RBCW	29/749	Blind Flanged
X-29-5-91	Temporary Chiller to Unit 2 RBCW	33/749	Blind Flanged
X-29-5-92	Temporary Chiller to Unit 2 RBCW	33/749	Blind Flanged
X-29-5-97	Utility Penetration from Unit 1 RR Bay to Unit 2 Elev. 749	33/749	Capped
X-27-6-42	Diamond Plate Cover over Floor Penetration	27/779'	Installed
X-27-6-92	Instrument Tubing Stubs	27/779'	Capped
X-29-7-4	1" Spare Conduit Threaded Plug	29/818'	Installed
X-30-6-72	Instrument Tubing Stubs	30/779'	Capped
X-30-6-1002	Stairwell #214 Rupture Disc	30/779'	Installed Intact
X-30-6-1003	Airlock II-609 Rupture Disc	30/779'	Installed Intact
X-25-6-1008	Airlock I-606 Rupture Disc	25/779'	Installed Intact
X-29-4-102	Penetration at Door 433	29/719'	Blind Flange Installed
X-29-4-103	Penetration at Door 433	29/719'	Blind Flange Installed
X-29-4-102	Penetration at Door 433	33/719'	Blind Flange Installed
X-29-4-103	Penetration at Door 433	33/719'	Blind Flange Installed
1S2104	N <sub>2</sub> Purge Line to U1 Containment Spectacle Flange	29/683'	Blind Side Installed
2S2104	N <sub>2</sub> Purge Line to U2 Containment Spectacle Flange	34/672'	Blind Side Installed
XD-17513	Isolation damper for Railroad Bay Zone III HVAC Supply	29/799'	Position is dependent on Railroad Bay alignment
XD-17514	Isolation damper for Railroad Bay Zone III HVAC Exhaust	29/719'	Position is dependent on Railroad Bay alignment
187388	RBCW Temp Chiller Discharge Iso Vlv	29/670	Closed Manual Isolation Valve
187389	RBCW Temp Chiller Supply Iso Vlv	29/670	Closed Manual Isolation Valve
187390	RBCW Temp Chiller Supply Drain Vlv	29/670	Closed Manual Isolation Valve
187391	RBCW Temp Chiller Discharge Drain Vlv	29/670	Closed Manual Isolation Valve
110176	SDHR Supply Drain Vlv	29/670	Closed Manual Isolation Valve
110186	SDHR Discharge Drain Vlv	29/670	Closed Manual Isolation Valve
110180	SDHR Supply Vent Vlv	29/749	Closed Manual Isolation Valve
110181	SDHR Discharge Fill Vlv	27/749	Closed Manual Isolation Valve
110182	SDHR Discharge Vent Vlv	27/749	Closed Manual Isolation Valve
110187	SDHR Supply Fill Vlv	29/749	Closed Manual Isolation Valve
210186	SDHR Supply Drain Vlv	33/749	Closed Manual Isolation Valve
210187	SDHR Supply Vent Vlv	33/749	Closed Manual Isolation Valve
210191	SDHR Discharge Vent Vlv	30/749	Closed Manual Isolation Valve
210192	SDHR Discharge Drain Vlv	30/749	Closed Manual Isolation Valve
210193	SDHR Discharge Vent Vlv	33/749	Closed Manual Isolation Valve