

INDEX

ADMINISTRATIVE CONTROLS

<u>SECTION</u>	<u>PAGE</u>
<u>6.1 Responsibility</u>	6-1
<u>6.2 Organization</u>	
<u>6.2.1 Offsite And Onsite Organizations</u>	6-2
<u>6.2.2 Unit Staff</u>	6-2
TABLE 6.2-1 (Deleted)	
<u>6.2.3 (Not Used)</u>	
<u>6.2.4 (Not Used)</u>	
<u>6.3 Unit Staff Qualifications</u>	6-4
<u>6.4 (Not Used)</u>	
<u>6.5 (Not Used)</u>	
<u>6.6 (Not Used)</u>	
<u>6.7 (Not Used)</u>	
<u>6.8 Procedures, Programs, and Manuals</u>	6-6
<u>6.9 Reporting Requirements</u>	
<u>6.9.1 Annual Radiological Environmental Report</u>	6-13
Radioactive Effluent Release Report	6-14
Core Operating Limits Report	6-14
Steam Generator Tube Inspection Report	6-17
<u>6.9.2 (Not Used)</u>	
<u>6.10 (Not Used)</u>	

6.0 ADMINISTRATIVE CONTROLS
6.9 Reporting Requirements

6.9.1 The following reports shall be submitted in accordance with 10 CFR 50.4.

6.9.1.1 Not Used

6.9.1.2 Not Used

6.9.1.3 Annual Radiological Environmental Operating Report

NOTE

A single submittal may be made for the South Texas Project. The submittal should combine sections that are common to both units.

The Annual Radiological Environmental Operating Report covering the operation of the unit during the previous calendar year shall be submitted prior to May 15 of each year. The report shall include summaries, interpretations, and analysis of trends of the results of the radiological environmental monitoring program for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual (ODCM) and 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and 1V.C.

(continued)

6.0 ADMINISTRATIVE CONTROLS
6.9 Reporting Requirements

6.9.1.4 Radioactive Effluent Release Report

NOTE

A single submittal may be made for the South Texas Project, which shall specify the releases of radioactive material from each unit.

The Radioactive Effluent Release Report covering the operation of the unit in the previous year shall be submitted by May 1 of each year. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents, and solid waste released from the unit. The material provided shall be consistent with the objectives outlined in the ODCM and Process Control Program, and be in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.I.

6.9.1.5 Not Used

6.9.1.6 Core Operating Limits Report (COLR)

- a. Core operating limits shall be established prior to each reload cycle or prior to any remaining portion of a reload cycle. The core operating limits shall be documented in the COLR for the following:
1. Safety limits for thermal power, pressurizer pressure, and the highest operating loop coolant temperature (T_{avg}) for Specification 2.1,
 2. Limiting Safety System Settings for Reactor Coolant Flow-Low Loop design flow, Overtemperature ΔT , and Overpower ΔT setpoint parameter values for Specification 2.2,
 3. SHUTDOWN MARGIN limits for Specification 3/4.1.1.1,
 4. Moderator Temperature Coefficient BOL and EOL limits, and 300 ppm surveillance limit for Specification 3/4.1.1.3,
 5. Shutdown Bank Insertion Limit for Specification 3/4.1.3.5,
 6. Control Bank Insertion Limits for Specification 3/4.1.3.6,
 7. Axial Flux Difference limits and target band for Specification 3/4.2.1,

(continued)