

January 31, 2005

Mr. Thomas J. Palmisano
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT — SECOND REQUEST FOR
ADDITIONAL INFORMATION RELATED TO TECHNICAL SPECIFICATIONS
CHANGE REQUEST TO IMPLEMENT A 24-MONTH FUEL CYCLE
(TAC NO. MC3692)

Dear Mr. Palmisano:

The Nuclear Management Company's, LLC's, letter of June 30, as supplemented November 5, 2004, submitted a license amendment request implement a 24-month fuel cycle at Monticello Nuclear Generating Plant. The Nuclear Regulatory Commission staff is reviewing your request and finds that additional information is needed as shown in the enclosed request for additional information (RAI).

I discussed the enclosed RAI with Mr. John Fields of your organization on January 28, 2005, and he agreed to respond within 30 days of receipt of the RAI. Please contact me at (301) 415-1423 if you have questions.

Sincerely,

/RA/

L. Mark Padovan, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure: Request for Additional Information

cc w/encl: See next page

January 31, 2005

Mr. Thomas J. Palmisano
Site Vice President
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

SUBJECT: MONTICELLO NUCLEAR GENERATING PLANT — SECOND REQUEST FOR
ADDITIONAL INFORMATION RELATED TO TECHNICAL SPECIFICATIONS
CHANGE REQUEST TO IMPLEMENT A 24-MONTH FUEL CYCLE
(TAC NO. MC3692)

Dear Mr. Palmisano:

The Nuclear Management Company's, LLC's, letter of June 30, as supplemented November 5, 2004, submitted a license amendment request implement a 24-month fuel cycle at Monticello Nuclear Generating Plant. The Nuclear Regulatory Commission staff is reviewing your request and finds that additional information is needed as shown in the enclosed request for additional information (RAI).

I discussed the enclosed RAI with Mr. John Fields of your organization on January 28, 2005, and he agreed to respond within 30 days of receipt of the RAI. Please contact me at (301) 415-1423 if you have questions.

Sincerely,

/RA/

L. Mark Padovan, Project Manager, Section 1
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-263

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION

PUBLIC
PDIII-1 Reading
MKotzalas
MPadovan

OGC
ACRS
BBurgess
THarris

HLi
VKlein
HWalker
DLPM DPR

ADAMS Accession No.: ML050180738

NRR-088

OFFICE	PDIII-1/PM	PDIII-1/LA	PDIII-1/(A)SC
NAME	MPadovan:mp	THarris	MKotzalas
DATE	01/28/05	01/28/05	01/31/05

OFFICIAL RECORD COPY

Monticello Nuclear Generating Plant

License Amendment Request to Support 24-Month Operating Cycles

Second Request for Additional Information

Docket No. 50-263

1. Enclosure 1 to Nuclear Management Company's (NMC's) November 5, 2004, submittal contains sample calculation CA-97-241 where the allowable value is derived from the analytical limit (AL). This is similar to Instrumentation, Systems, and Automation (ISA) Society ANSI/ISA-S67.04-2000, "Setpoints for Nuclear Safety-Related Instrumentation," Method 2, but the uncertainty components are not defined in the calculation. Please confirm that the setpoint methodology used at Monticello is equivalent to ISA Method 2.
2. In sample calculation CA-97-241, Section 6.5 indicates that many analyses assume a trip value of 200 EF, and then NMC uses an AL of 212 EF. If the analyses simply indicate that the value will only reach 200 EF, but corrective action is based upon something else, then this is stated unclearly. If the analyses presume corrective action at 200 EF, then the AL must be 200 EF. Is NMC claiming that the temperature will always rise to 212 EF in a "negligible" amount of time whenever it hits 200 EF, or does this not matter because the device in question is only a "backup" device? Please more explicitly justify these points. In particular, it seems that the analyses either presume action based upon this switch or they do not. It is not clear in this context what it means to say that this is a "backup" device or function.
3. NMC's June 30, 2004, submittal proposes allowing a significant increase in the amount of drift for each component, and extends the time available for random failures to occur. Since the amount of setpoint drift could increase, it would be appropriate to make most setpoints and AVs more conservative. NMC has proposed changing very few setpoints and AVs. Is NMC maintaining that experience shows that drift is far less than assumed in the existing technical specifications (TS), and that the existing TS are overconservative and bound the increased drift? If so, then demonstrate that existing data show that present TS surveillance requirements are usually met. Explain how NMC has extrapolated the 18-month data to justify a 24-month interval considering both random failures and calibration drift. Please provide additional documentation to demonstrate the results of your evaluation that the projected 30-month drift value for these instruments does not exceed the drift allowance provided in the setpoint calculation for these instruments. Please show that the change in channel availability (in regard to equipment failures) is acceptable.
4. Pages 102 and 105 in Enclosure 6 of NMC's June 30, 2004, submittal contain marked-up changes from "Low" reactor water level to "Low-Low" reactor water level. Justify these changes and also provide references to related Updated Safety Analysis Report sections.
5. In the first paragraph on page 9 of 17 in Enclosure 1 of NMC's June 30, 2004, submittal, NMC states "NTSPs [nominal trip setpoints] were changed where it was not possible to accommodate the projected drift by adjusting plant settings" What plant settings other than setpoint change is NMC referring to?

ENCLOSURE

Monticello Nuclear Generating Plant

cc:

Jonathan Rogoff, Esquire
Vice President, Counsel & Secretary
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
2807 W. County Road 75
Monticello, MN 55362

Manager, Regulatory Affairs
Monticello Nuclear Generating Plant
Nuclear Management Company, LLC
2807 West County Road 75
Monticello, MN 55362-9637

Robert Nelson, President
Minnesota Environmental Control
Citizens Association (MECCA)
1051 South McKnight Road
St. Paul, MN 55119

Commissioner
Minnesota Pollution Control Agency
520 Lafayette Road
St. Paul, MN 55155-4194

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Commissioner
Minnesota Department of Health
717 Delaware Street, S. E.
Minneapolis, MN 55440

Douglas M. Gruber, Auditor/Treasurer
Wright County Government Center
10 NW Second Street
Buffalo, MN 55313

Commissioner
Minnesota Department of Commerce
85 7th Place East, Suite 500
St. Paul, MN 55101-2198

Manager - Environmental Protection Division
Minnesota Attorney General's Office
445 Minnesota St., Suite 900
St. Paul, MN 55101-2127

John Paul Cowan
Executive Vice President & Chief Nuclear
Officer
Nuclear Management Company, LLC
700 First Street
Hudson, WI 54016

Nuclear Asset Manager
Xcel Energy, Inc.
414 Nicollet Mall, R.S. 8
Minneapolis, MN 55401