

**From:** Ngoc Le  
**To:** Peter.Mazzaferro@Constellation.com  
**Date:** 1/11/05 5:30PM  
**Subject:** Followup questions - **01-11-05**

Pete:

**Reference:** Your Responses to NRC RAIs, NMPIL 1900 dated 12/17/04

The staff has followup questions regarding your responses to the steam separator (RAI-4) and feedwater spargers (RAI-5) of the referenced document. The concern is whether these components can fail and cause nearby, safety-related components to fail. If so, then they should be in scope.

Please check the availability of your tech staff and we can set up a conference call to address the concern with the NRC reviewer.

**Proposed time:** Wednesday PM, Thursday, and Friday and this week.  
Please let me know.

tommy le

**CC:** Samuel Miranda