

GARY R. PETERSON Vice President McGuire Nuclear Station

Duke Power MG01VP / 12700 Hagers Ferry Road Huntersville. NC 28078-9340

704 875 5333 704 875 4809 fax grpeters@duke-energy.com

January 18, 2005

U.S. Nuclear Regulatory Commission Washington, D.C. 20555-0001

ATTENTION: Document Control Desk

Subject: Duke Energy Corporation

McGuire Nuclear Station, Units 1 and 2 Docket Numbers 50-369 and 50-370

License Amendment Request for Technical Specification 3.7.11, PLANT SYSTEMS, Auxiliary Building Filtered Ventilation Exhaust System (ABFVES) - Response to Request for Additional Information

In a previous letter¹ to the NRC, Duke Energy Corporation (Duke) submitted a license amendment request (LAR) for the McGuire Nuclear Station Facility Operating Licenses and Technical Specifications (TS). This LAR proposed a change to TS 3.7.11 which added a note to allow the intermittent opening of the Auxiliary Building pressure boundary under administrative control. The NRC has requested that Duke provide a response to the requested action stated below.

Requested Action

The cited revision to Catawba TS 3.7.12 closely conforms to TSTF-287. The licensee is requested to revise its application to adopt TSTF-287 in corresponding McGuire TS 3.7.11 so that McGuire's requirements are more consistent with the provisions approved for Catawba, and to make the commitment described in the reviewer's note.

A001

¹ Letter, D. M. Jamil, Duke Energy Corporation, to the U. S. Nuclear Regulatory Commission, ATTENTION: Document Control Desk, SUBJECT: McGuire Nuclear Station, Units 1 and 2. License Amendment Request for McGuire Technical Specification 3.7.11, Auxiliary Building Filtered Ventilation Exhaust System, Dated June 3, 2003.

U.S. Nuclear Regulatory Commission January 18, 2004 Page 2

Duke Response

TSTF-287 provided two provisions which were applicable to several ventilation systems contained in the Standard Technical Specifications. These were 1) the addition of the note allowing the intermittent opening of the affecting pressure boundary, and 2) the addition of a new Condition (with a 24-hour Completion Time) which addressed the inoperability of two trains of a ventilation system due to a degraded pressure boundary. In a previous LAR submittal, Duke implemented TSTF-287 fully on McGuire TS 3.7.9, Control Room Area Ventilation System. In regard to the current LAR, McGuire TS 3.7.11 already has a Condition that covers the inoperability of two ABFVES with a 24-hour Completion Time (see Condition B). Thus, this provision of TSTF-287 was deemed unneeded and not requested for McGuire TS 3.7.11.

The NRC referenced a commitment contained in the Catawba LAR submittal³ which implemented TSTF-287. Duke hereby makes a corresponding commitment for McGuire, as stated below.

At the time of implementation of the applicable change contained in this LAR, McGuire will have approved, written administrative controls in place that describe the compensatory measures to be taken when the affected pressure boundary is opened.

As mentioned in the September 13, 1999 Duke letter (see Footnote 2), the TS Bases provide these administrative controls.

²Letter, H. B. Barron, Duke Energy Corporation, to the U. S. Nuclear Regulatory Commission, ATTENTION: Document Control Desk, SUBJECT: McGuire Nuclear Station, Unit 1 and Unit 2. License Amendment Request for Technical Specification 3.7.9 - Control Room Area Ventilation System, Dated September 13, 1999.

³ Letter, M. S. Tuckman, Duke Energy Corporation, to the U. S. Nuclear Regulatory Commission, ATTENTION: Document Control Desk, SUBJECT: Catawba Nuclear Station, Units 1 and 2. License Amendment Request for Technical Specification 3.7.10, Control Room Area Ventilation System; and Technical Specification 3.7.12, Auxiliary Building Filtered Ventilation Exhaust System, Dated April 18, 2000.

U.S. Nuclear Regulatory Commission January 18, 2004 Page 3

Inquiries on this matter should be directed to J. S. Warren at (704) 875-5171.

Very truly yours,

وسني س

G. R. Peterson

xc w/Attachments:

W. D. Travers, Regional Administrator
U. S. Nuclear Regulatory Commission, Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, GA 30303

J. J. Shea (Addressee Only)
NRC Project Manager (MNS)
U. S. Nuclear Regulatory Commission
Mail Stop O-8 H12
Washington, DC 20555-0001

J. B. Brady
Senior Resident Inspector (MNS)
U. S. Nuclear Regulatory Commission
McGuire Nuclear Site

Beverly O. Hall, Section Chief Radiation Protection Section 1645 Mail Service Center Raleigh, NC 27699-1645 U.S. Nuclear Regulatory Commission January 18, 2004 Page 4

G. R. Peterson, affirms that he is the person who subscribed his name to the foregoing statement, and that all the matters and facts set forth herein are true and correct to the best of his knowledge.

G. R. Peterson, Site Vice President

Subscribed and sworn to me: 1/18/05

Streda K. Crump, Notary Public

My commission expires: 8/17/06

