From: Mahesh Chawla To: Dale Vincent 1/19/05 1:27PM

Subject: Prairie Island - LAR - MC3043/MC3044 - Unresolved Items related to Methods

of Evaluation of CL

For the above referenced LAR, request for additional information was sent to you via e-mail on 12/8/04. A follow-up telephone conference was held between Prairie Island representatives and the NRC staff, during which this amendment request was discussed in more detail. As a result of this discussion, it was decided that the licensee will provide response to the following NRC staff questions. Please provide your response to the following by February 11, 2005.

Request for Additional Information

- 1) You indicated that the evaluation applies acceptance criteria from American Society of Mechanical Engineers (ASME) Section III, Subsection ND, Service Level D when performing stress analyses of the cooling water (CL) system non-Class I piping with design basis seismic loads. The proposed methodology and acceptance criteria provide a conservative approach for demonstrating that the CL system will perform its safety function following a design basis seismic event. Provide a description of analysis including the methodology, loss of coolant accident (LOCA) loads for the faulted condition, load combinations, input response spectra to the seismic analysis, modeling and computer code used, assumptions and resulting stresses in comparison against the code allowable limits.
- 2) Though NRC is reviewing the criteria for analyzing cooling water system non-seismic piping, confirm that the piping will continue to be protected from the failure of non-seismic structures, systems and components (SSCs) in accordance with the existing plant licensing basis. Please explain any exceptions.
- 3) The licensee proposes to credit automatic isolation valves for excluding cooling water system non-seismic piping from consideration. Confirm that these valves are seismic Category I, safety-related valves, which will automatically actuate to close during a seismic event, and that the single-failure criterion will be satisfied.
- 4) Explain in detail specific operator actions that are being relied upon for postulated pipe break conditions for NRC assessment of human factors considerations.

CC: Cheng-lh Wu; David Muller; James Tatum; Ron Young

Mail Envelope Properties (41EEA679.E4D: 15:21352)

Subject: Prairie Island - LAR - MC3043/MC3044 - Unresolved Items related to

Methods of Evaluation of CL

Creation Date: 1/19/05 1:27PM **From:** Mahesh Chawla

Created By: MLC@nrc.gov

Recipients TWGWPO01.HQGWDO01 DSM3 CC (David Muller)	Action Delivered	Date & Time 01/19/05 01:27PM
owf2_po.OWFN_DO	Delivered	01/19/05 01:27PM
CIW1 CC (Cheng-Ih Wu)	Opened	01/19/05 02:17PM
JET1 CC (James Tatum)	Opened	01/19/05 01:44PM

RMY CC (Ron Young)

nmcco.com Transferred 01/19/05 01:27PM

dale.vincent (Dale Vincent)

Post Office Delivered Route

TWGWPO01.HQGWDO01 01/19/05 01:27PM owf2 po.OWFN DO 01/19/05 01:27PM

nmcco.com

 Files
 Size
 Date & Time

 MESSAGE
 3039
 01/19/05 01:27PM

Options

Auto Delete:
Expiration Date:
None
Notify Recipients:
Priority:
Standard
Reply Requested:
No
Return Notification:
No

Concealed Subject: No Security: No Standard

To Be Delivered: Immediate

Status Tracking: Delivered & Opened

ADAMS Accession No.: ML050250435