Exel@n...

Exelon Generation Company, LLC Braidwood Station 35100 South Rt 53, Suite 84 Braceville, IL 60407-9619 Tel. 815-417-2000 www.exeloncorp.com

January 24, 2005 BW050010

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, DC 20555-0001

> Braidwood Station, Units 1 and 2 Facility Operating License Nos. NPF-72 and NPF-77 NRC Docket Nos. STN 50-456 and 50-457

Subject: Pressure and Temperature Limits Reports (PTLRs), Revision 3, Braidwood Station, Units 1 and 2

- References: (1) Letter from Kenneth A. Ainger (Exelon Generation Company, LLC) to NRC, "Request for a License Amendment to Incorporate Approved Pressure and Temperature Limits Report (PTLR) Methodology into Technical Specifications," dated May 21, 2004
 - (2) Letter from U.S. NRC to Christopher M. Crane, "Issuance of Amendments: Revised Pressure-Temperature Limits Methodology; Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2 (TAC Nos. MC3285, MC3286, MC3283, MC3284), dated October 4, 2004

The purpose of this letter is to transmit the Pressure and Temperature Limits Reports (PTLRs) for Braidwood Station, Unit 1 and Unit 2 in accordance with Technical Specification (TS) 5.6.6, "Reactor Coolant System (RCS) Pressure and Temperature Limits Report (PTLR)." This revision of the PTLRs was recently implemented and extended the current pressure-temperature (P-T) limits curves by an additional 2 effective full power years (EFPY) as described in Reference 1. The Braidwood Station, Units 1 and 2 PTLRs are being submitted in accordance with TS 5.6.6 and as requested in Reference 2. U.S. Nuclear Regulatory Commission Page 2 January 24, 2005

Please direct any questions you may have regarding this matter to Mr. Dale Ambler, Regulatory Assurance Manager, at (815) 417-2800.

Sincerely,

Keith J. Polson Site Vice President Braidwood Station

KP/LD/vk

- Attachments: 1. Braidwood Unit 1 Pressure and Temperature Limits Report, Revision 3 2. Braidwood Unit 2 Pressure and Temperature Limits Report, Revision 3
- cc: Regional Administrator NRC Region III NRC Senior Resident Inspector – Braidwood Station

BRAIDWOOD UNIT 1

PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)

Revision 3

...

Table of Contents

Section			Page
1.0	Introduc	tion	1
2.0	Operatir	ng Limits	1
	2.1 R	CS Pressure and Temperature (P/T) Limits	1
	2.2 L	ow Temperature Overpressure Protection (LTOP) System Setpoints	2
	2.3 L	TOP Enable Temperature	2
	2.4 R	eactor Vessel Boltup Temperature	3
	2.5 R	eactor Vessel Minimum Pressurization Temperature	3
3.0	Reactor	Vessel Material Surveillance Program	11
4.0	Supplen	iental Data Tables	13
5.0	Referen	ces	20

i

. ••

List of Figures

S.		
Figure		Page
2.1	Braidwood Unit 1 Reactor Coolant System Heatup Limitations (Heatup Rates up to 100° F/hr) Applicable for the First 16 EFPY (Without Margins for Instrumentation Errors)	4
2.2	Braidwood Unit 1 Reactor Coolant System Cooldown Limitations (Cooldown Rates of 0, 25, 50, and 100 °F/hr) Applicable for the First 16 EFPY (Without Margins for Instrumentation Errors)	5
2.3	Braidwood Unit 1 Nominal PORV Setpoints for the Low Temperature Overpressure Protection (LTOP) System Applicable for the First 16 EFPY	9

ii

List of Tables

Table		Page
2.1a	Braidwood Unit 1 Heatup Data Points at 16 EFPY (Without Margins for Instrumentation Errors)	6
2.1b	Braidwood Unit 1 Cooldown Data Points at 16 EFPY (Without Margins for Instrumentation Errors)	8
2.2	Data Points for Braidwood Unit 1 Nominal PORV Setpoints for the LTOP System Applicable for the First 16 EFPY	10
3.1	Braidwood Unit 1 Capsule Withdrawal Schedule	12
4.1	Braidwood Unit 1 Calculation of Chemistry Factors Using Surveillance Capsule Data	14
4.2	Braidwood Unit 1 Reactor Vessel Material Properties	15
4.3	Summary of Braidwood Unit 1 Adjusted Reference Temperatures (ARTs) at the 1/4T and 3/4T Locations for 16 EFPY	16
4.4	Braidwood Unit 1 Calculation of Adjusted Reference Temperatures (ARTs) at 16 EFPY at the Limiting Reactor Vessel Material Weld Metal (Based on Surveillance Capsule Data)	17
4.5	RT _{PTS} Calculation for Braidwood Unit 1 Beltline Region Materials at EOL (32 EFPY)	18
4.6	RT _{PTS} Calculation for Braidwood Unit 1 Beltline Region Materials at Life Extension (48 EFPY)	19

I

1.0 Introduction

This Pressure and Temperature Limits Report (PTLR) for Braidwood Unit 1 has been prepared in accordance with the requirements of Braidwood Technical Specification (TS) 5.6.6, "Reactor Coolant System (RCS) Pressure and Temperature Limits Report (PTLR)". Revisions to the PTLR shall be provided to the NRC after issuance.

The Technical Specifications (TS) addressed in this report are listed below:

LCO 3.4.3 RCS Pressure and Temperature (P/T) Limits; and LCO 3.4.12 Low Temperature Overpressure Protection (LTOP) System.

2.0 **Operating Limits**

The PTLR limits for Braidwood Unit 1 were developed using a methodology specified in the Technical Specifications. The methodology listed in WCAP-14040-NP-A (Reference 1) was used with the following exceptions:

- a) Use of ENDF/B-IV neutron transport cross-section library and ENDF/B-V dosimeter reaction cross-sections,
- b) Use of ASME Code Case N-514, and
- c) Use of RELAP computer code for calculation of LTOP setpoints for Braidwood Unit 1 replacement steam generators.

These exceptions to the methodology in WCAP 14040-NP-A have been reviewed and accepted by the NRC in Reference 2.

WCAP 14243, Reference 3, provides the basis for the Braidwood Unit 1 P/T curves, along with the best estimate chemical compositions, fluence projections and adjusted reference temperatures used to determine these limits. Reference 4 evaluated the effect of higher fluence from 5% uprate on the existing P/T curves.

The applicability periods for all areas previously evaluated for 14.0 EFPY have been extended by two additional years to 16.0 EFPY. This applicability period extension was reviewed and approved by the NRC in Reference 12.

2.1 RCS Pressure and Temperature (P/T) Limits (LCO 3.4.3).

- 2.1.1 The RCS temperature rate-of-change limits defined in Reference 3 are:
 - a. A maximum heatup of 100°F in any 1-hour period,
 - b. A maximum cooldown of 100°F in any 1-hour period, and

- c. A maximum temperature change of less than or equal to 10°F in any 1-hour period during inservice hydrostatic and leak testing operations above the heatup and cooldown limit curves.
- 2.1.2 The RCS P/T limits for heatup, inservice hydrostatic and leak testing, and criticality are specified by Figure 2.1 and Table 2.1a. The RCS P/T limits for cooldown are shown in Figure 2.2 and Table 2.1b. These limits are defined in Reference 3. Consistent with the methodology described in Reference 1 and exceptions noted in Section 2.0, the RCS P/T limits for heatup and cooldown shown in Figures 2.1 and 2.2 are provided without margins for instrument error. The criticality limit curve specifies pressure-temperature limits for core operation to provide additional margin during actual power production as specified in 10 CFR 50, Appendix G.

The P/T limits for core operation (except for low power physics testing) are that the reactor vessel must be at a temperature equal to or higher than the minimum temperature required for the inservice hydrostatic test, and at least 40°F higher than the minimum permissible temperature in the corresponding P/T curve for heatup and cooldown.

2.2 Low Temperature Overpressure Protection (LTOP) System Setpoints (LCO 3.4.12).

The power operated relief valves (PORVs) shall each have maximum lift settings in accordance with Figure 2.3 and Table 2.2. These limits are based on References 5, 6, and 7. The Residual Heat Removal (RH) Suction Relief Valves are also analyzed to individually provide low temperature overpressure protection. This analysis for the RH Suction Relief Valves remains valid with the current Appendix G limits contained in this PTLR document and will be reevaluated in the future as the Appendix G limits are revised.

The LTOP setpoints are based on P/T limits which were established in accordance with 10 CFR 50, Appendix G without allowance for instrumentation error and in accordance with the methodology described in Reference 1. The LTOP PORV nominal lift settings shown in Figure 2.3 and Table 2.2 account for appropriate instrument error.

2.3 LTOP Enable Temperature

The minimum required LTOP enable temperature is 200°F (Reference 2).

Braidwood Unit 1 procedures governing the heatup and cooldown of the RCS require the arming of the LTOP System for RCS temperature of 350°F and below and disarming of LTOP for RCS temperature above 350°F.

Note that the last LTOP PORV segment in Table 2.2 extends to 450°F where the pressure setpoint is 2350 psig. This is intended to prohibit PORV lift for an inadvertent LTOP system arming at power.

2.4 Reactor Vessel Boltup Temperature (Non-Technical Specification)

The minimum boltup temperature for the Reactor Vessel Flange shall be $\geq 60^{\circ}$ F. Boltup is a condition in which the Reactor Vessel head is installed with tension applied to any stud, and with the RCS vented to atmosphere.

2.5 Reactor Vessel Minimum Pressurization Temperature (Non-Technical Specification)

3

The minimum temperature at which the Reactor Vessel may be pressurized (i.e., in an unvented condition) shall be $\geq 60^{\circ}$ F, plus an allowance for the uncertainty of the temperature instrument, determined using a technique consistent with ISA-S67.04-1994.



Figure 2.1 Braidwood Unit 1 Reactor Coolant System Heatup Limitations (heatup rate up to 100°F/hr) Applicable for the First 16 EFPY (Without Margins for Instrumentation Errors)

1



Figure 2.2

Braidwood Unit 1 Reactor Coolant System Cooldown Limitations (Cooldown Rates up to 0, 25, 50 and 100 °F/hr) Applicable for the First 16 EFPY (Without Margins for Instrumentation Errors)

Table 2.1a

(Page 1 of 2) Braidwood Unit 1 Heatup* Data Points at 16 EFPY (Without Margins for Instrumentation Errors)

Heatup Curve							
100	F Heatup 🗄	С	Criticality Leak Te				
		Limit		Limit			
T_	P	Т	P	Т	<u> </u>		
60	0	210	0	188	2000		
60	565.09	210	611.83	210	2485		
65	565.09	210	597.56		,		
70	565.09	210	585.60				
75	565.09	210	576.77				
80	565.09	210	570.35				
85	565.09	210	566.61				
90	565.09	210	565.09				
95	565.09	210	565.87				
100	565.87	210	568.69				
105	568.69	210	573.56				
110	573.56	210	580.30				
115	580.30	210	588.84				
120	588.84	210	599.36	_			
125	599.36	210	611.78				
130	611.78	210	626.07				
135	626.07	210	642.16				
140	642.16	210	660.36				
145	660.36	·210	680.59				
150	680.59	210	702.80				
155	702.80	210	727.33				
160	727.33	210	754.07				
165	754.07	210	783.17				
170	783.17	215	814.98				
175	814.98	220	849.37				
180	849.37	225	886.54				
185	886.54	230	926.73				
190	926.73	235	970.11				
195	970.11	240	1016.91				
200	1016.91	245	1067.33				
205	1067.33	250	1121.63				
210	1121.63	255	1180.01				
215	1180.01	260	1242.62				
220	1242.62	265	1309.84				
225	1309.84	270	1382.03				
230	1382.03	275	1459.45				
235	1459.45	280	1542.27				
240	1542.27	285	1630.97				
245	1630.97	290	1726.05				
250	1726.05	295	1827.80				

Table 2.1a									
Page 2 of 2									
Heatup Curve									
100 F	Heatup	Cri	iticality	Lea	k Test				
	2]]	Limit Limit						
T	Р	Т	Р	Т	Р				
255	1827.80	300	1936.51						
260	1936.51	305	2052.39						
265	2052.39	310	2176.33						
270	2176.33	315	2308.42						
275	2308.42	320	2449.09						
280	2449.09				•				

* Heatup and Cooldown data includes vessel flange requirements of 110°F and 621 psig per 10CFR50, Appendix G.

Table 2.1b Page 1 of 1

Braidwood Unit 1 Cooldown* Data Points at 16 EFPY** (Without Margins for Instrumentation Errors)

	- Cooldown Curves									
Steady State		25 °F		50 °F		100 °F				
		Cooldown		Co	oldown	Cooldown				
Т	P T P		ТР		Т	Р				
60	0	60	0	60	0	60	0			
60	620.27	60	577.45	60	534.28	60	446.98			
65	621.00	65	590.68	65	548.52	65	463.79			
.70	621.00	70	605.03	70	563.98	70	481.93			
75	621.00	75	620.51	75	580.67	75	501.49			
80	621.00	80	621.00	80	598.51	80	522.68			
85	621.00	85 -	621.00	85	617.90	85	545.50			
90	621.00	90	621.00	90	621.00	90	570.23			
95	621.00	95	621.00	95	621.00	95	596.83			
100	621.00	100	621.00	100	621.00	100	621.00			
105	621.00	105	621.00	105	621.00	105	621.00			
110	621.00	110	621.00	110	621.00	110	621.00			
110	795.92	110	766.92	110	739.27	110	690.04			
115	821.55	115	794.59	115	769.53	115	726.24			
120	849.00	120	824.45	120	801.97	120	765.12			
125	878.42	125	856.54	125	836.87	125	807.07			
130	910.25	130	890.97	130	874.41	130	852.23			
135	944.34	135	928.00	135	915.03	135	900.91			
140	980.89	140	967.79	140	958.57	140	953.33			
145	1020.15	145	1010.84	145	1005.42	145	1009.81			
150	1062.35	150	1056.88	150	1055.76		_			
155	1107.92	155	1106.38							
160	1156.42					•				
165	1208.78									
170	1265.05									
175	1325.37									
180	1390.04									
185	1459.41									
190	1533.55									
195	1613.49									
200	1699.01									
205	1790.55									
210	1888.61									
215	1993.61									
220	2105.69									
225	2225.77									
230	2353.75									

* Heatup and Cooldown data includes vessel flange requirements of 110°F and 621 psig per 10CFR50, Appendix G.

** For each cooldown rate, the steady-state pressure values shall govern the temperature where no allowable pressure values are provided.



Figure 2.3 Braidwood Unit 1 Nominal PORV Setpoints for the Low Temperature Overpressure Protection (LTOP) System Applicable for the first 16 EFPY

Table 2.2

Data Points for Braidwood Unit 1 Nominal PORV Setpoints for the LTOP System Applicable for the First 16 EFPY

PCV-455A			PCV-456	
(1TY-0413M)	·		(1TY-0413P)	
AUCTIONEERED LOW	RCS PRESSURE		AUCTIONEERED LOW	RCS PRESSURE
RCS TEMP. (DEG. F)	(PSIG)		RCS TEMP. (DEG. F)	(PSIG)
50	497	:	50	513
70	497	. • .	70	513
100	497		100	513
110	497		110	513
160	497	•	160	513
200	618		200	634
250	603		250	619
300	588	· · ·	300	604
350	588	• • •	350	604
450	2350		450	2350

Note: To determine nominal lift setpoints for RCS Pressure and RCS Temperatures greater than 350°F, linearly interpolate between the 350°F and 450°F data points shown above.

3.0 Reactor Vessel Material Surveillance Program

۲

The pressure vessel material surveillance program (Reference 8) is in compliance with Appendix H to 10 CFR 50, "Reactor Vessel Radiation Surveillance Program." The material test requirements and the acceptance standard utilize the reference nil-ductility temperature, RT_{NDT} , which is determined in accordance with ASME Section III, NB-2331. The empirical relationship between RT_{NDT} and the fracture toughness of the reactor vessel steel is developed in accordance with Appendix G, "Protection Against Non-Ductile Failure," to Section XI of the ASME Boiler and Pressure Vessel Code. The surveillance capsule removal schedule meets the requirements of ASTM E185-82.

The third and final reactor vessel material irradiation surveillance specimens (Capsule W) have been removed and analyzed to determine changes in material properties. The surveillance capsule testing has been completed for the original operating period.

Table 3.1								
Braidwood Unit 1 Capsule Withdrawal Schedule								
CapsuleVessel LocationCapsule LeadRemoval Time(b)Estimated Capsule(Degrees)Factor(a)(EFPY)Fluence (n/cm2)								
U	58.5°	4.37	1.10	$3.87 \times 10^{18(c)}$				
х	238.5°	4.23	4.234	$1.24 \ge 10^{19(c)}$				
W	121.5°	4.20	7.61	$2.09 \ge 10^{19} $ ^(c)				
Z	301.5°	4.20	12.01	(d)				
v	61°	3.92	Standby					
Y	241°	3.92	12.01	(d)				

(a) Updated in Capsule W dosimetry analysis, (Reference 9).

(b) Effective Full Power Years (EFPY) from plant startup.

(c) Plant specific evaluation.

(d) Capsule removed and is stored in the spent fuel pool. Capsule has not been analyzed and therefore capsule fluence has not been estimated.

4.0 Supplemental Data Tables

The following tables provide supplemental information on reactor vessel material properties and are provided to be consistent with Generic Letter 96-03. Some of the material property values shown were used as inputs to the P/T limits.

Table 4.1 shows the calculation of the surveillance material chemistry factors using surveillance capsule data. The values of the CF listed in Table 4.1 are those obtained from the most recent Unit 1 Capsule data, Capsule W, (Reference 9). However, these values were not used in calculating the Adjusted Reference Temperature (ART) values that were used to generate the Braidwood Unit 1 Heatup and Cooldown Curves. The ART values listed in Table 4.3, based on Capsules U and X data, continue to be the basis for the Braidwood Unit 1 curves (Reference 10)

Table 4.2 provides the reactor vessel material properties table.

Table 4.3 provides a summary of the Braidwood Unit 1 adjusted reference temperature (ARTs) at the 1/4T and 3/4T locations for 16 EFPY. The ART values listed in Table 4.3 are based on Capsules U and X data and continue to be the basis for the Braidwood Unit 1 curves (Reference 10).

Table 4.4 shows the calculation of ARTs at 16 EFPY for the limiting Braidwood Unit 1 reactor vessel material, i.e. weld WF-562 (HT # 442011, Based on Surveillance Capsules U and X Data).

Table 4.5 provides RT_{PTS} calculation for Braidwood Unit 1 Beltline Region Materials at EOL (32 EFPY), (Reference 11).

Table 4.6 provides RT_{PTS} calculation for Braidwood Unit 1 Beltline Region Materials at Life Extension (48 EFPY), (Reference 11).

FF^(b) Capsule f^(a) ∆RT_{NDT}^(c) FF² Capsule Material FF*∆RT_{NDT} Lower Shell Forging U 0.387 0.737 4.26 0.543 5.78 49D867/49C813-1 Х 1:24 1.060 38.23 40.52 1.124 (Tangential) W 2.09 1.201 24.14 28.99 1.442 Lower Shell U 0.387 0.737 0.0 0.0 0.543 Forging 49D867-1 Х 30.48 1.24[°] 1.060 28.75 1.124 49C813-1 W 2.09 1.201 37.11 44.57 1.442 (Axial) SUM: 148.82 6.218 . $CF_{Forging} = \sum (FF * \Delta RT_{NDT}) \div \sum (FF^2) = (148.82) \div (6.218) = 23.9^{\circ}F$ Braidwood Unit 1 U 0.387 0.737 17.06 12.57 0.543 Surv. Weld X 1.24 30.15 31.96 1.060 1.124 Material W 2.09 1.201 49.68 59.67 1.442 (Heat # 442011) Braidwood Unit 2 U 0.40 0.746 0.0 0.0 0.557 Surv. Weld х 1.23 1.058 26.3 27.83 1.119 Material (Heat # 442011) W 2.25 1.220 29.16 23.9 1.488 SUM: 161.19 6.273 $CF = \sum (FF * \Delta RT_{NDT}) + \sum (FF^2) = (161.19) + (6.273) = 25.7^{\circ}F$

TABLE 4.1

Braidwood Unit 1 Calculation of Chemistry Factors Using Surveillance Capsule Data

Notes:

(a) f = Calculated fluence, (x 10¹⁹ n/cm², E > 1.0 MeV)

(b) FF = fluence factor = $f^{(0.28 - 0.1 \cdot \log f)}$.

(c) ΔRT_{NDT} values are the measured 30 ft-lb shift values.

Table 4.2							
Braidwood Unit 1 Reactor Vessel Material Properties							
Material Description	Cu (%)	Ni (%)	Chemistry Factor ^(a)	Initial RT _{NDT} (°F) ^(a)			
Closure Head Flange Heat # 5P7381/3P6406	0.11	0.67		-20			
Vessel Flange Heat # 122N357V	· 	0.77		-10			
Nozzle Shell Forging * Heat # 5P-7016	0.04	0.73	26.0°F ^(b)	10			
Intermediate Shell Forging * Heat # 49D383-1/49C344-1 (also referred to as the Upper Shell forging)	0.05	0.73	. 31.0°F ^(b)	-30			
Lower Shell Forging * Heat # 49D867/49C813-1	0.05	0.74	31.0°F ^(b) 23.9°F ^(c)	-20			
Circumferential Weld * (Intermediate Shell to Lower Shell) WF-562 (HT# 442011)	0.03	0.67	41.0°F ^(b) 25.7°F ^(c)	40			
Upper Circumferential Weld * (Nozzle Shell to Intermediate Shell) WF-645 (HT# H4498)	0.04	0.46	54.0°F ^(b)	-25			

* Beltline Region Materials

- a) The Initial RT_{NDT} values for the plates and welds are based on measured data.
- b) Chemistry Factor calculated for Cu and Ni values per Regulatory Guide 1.99, Rev. 2, Position 1.1.
- c) Chemistry Factor calculated for Cu and Ni values per Regulatory Guide 1.99, Rev. 2, Position 2.1.

Table 4.3						
Summary of Braidwood Unit 1 Adjusted Reference Temperatures (ARTs) at 1/4T and 3/4T Locations for 16 EFPY ^(c)						
	16 E	FPY ^(c)				
Material Description	1/4T ART(°F)	3/4T ART(°F)				
Intermediate Shell Forging Heat # 49D383-1/49C344-1 (RG Position 1)	25.1	8.2				
Lower Shell Forging Heat # 49D867/49C813-1 (RG Position 1)	26.2 13.4	12.1 3.2				
Using Surveillance Data ^(a) (RG Position 2 ^(a))						
Circumferential Weld (Intermediate Shell to Lower Shell) WF-562 (HT# 442011) (RG Position 1)	112.9	90.5				
Using credible surveillance Data (RG Position 2 ^(a))	76.6 ^(b)	65.4 ^(b)				

(a) Calculated using a chemistry factor based on Regulatory Guide (RG) 1.99, Position 2.

(b) These ART values were used to generate the Braidwood Unit 1 Heatup and Cooldown curves, (Reference 3).

(c) The applicability date has been increased from 14 EFPY to 16 EFPY based on an evaluation approved by the NRC in Reference 12.

÷

Table 4.4 Braidwood Unit 1 Calculation of Adjusted Reference Temperatures (ARTs) at 16 EFPY ^(b) at the Limiting Reactor Vessel Material Weld Metal (Based on Surveillance Capsule Data)								
Parameter Values								
Operating Time	16 EFPY ^(b)							
Location ^(c)	1/4T ART(°F)	3/4T ART(°F)						
Chemistry Factor, CF (°F)	20.6	20.6						
Fluence(f), n/cm ² (E>1.0 Mev) ^(a)	6.73 x 10 ¹⁸	2.43 x10 ¹⁸						
Fluence Factor, FF	0.889	0.616						
ΔRT _{NDT} = CFxFF(°F)	18.31	12.70						
Initial RT _{NDT} , I(°F)	40	40						
Margin, M (°F)	18.31	12.70						
ART= I+(CF*FF)+M,°F per RG 1.99, Revision 2	76.6	65.4						

(a) Fluence f, is based upon f_{auf} (E > 1.0 Mev) = 1.120 x 10¹⁹ at 14 EFPY for uprated conditions. (b) The applicability date has been increased from 14 EFPY to 16 EFPY based on an evaluation approved by the NRC in Reference 12.(c) The Braidwood Unit 1 reactor vessel wall thickness is 8.5 inches at the beltline region.

Table 4.5 RT_{PTS} Calculation for Braidwood Unit 1 Beltline Region Materials at EOL (32 EFPY) RT_{PTS}(b) RT_{NDT(U)}(a) ∆RT_{PTS}(c) Fluence FF CF Material Margin (°F) (10¹⁹ n/cm², (°F) (°F) (°F) (°F) E>1.0 MeV) Intermediate Shell Forging 2.05 1.20 31.0 37.2 34 -30 41 Heat # 49D383-1/49C344-1 Lower Shell Forging 2.05 1.20 31.0 37.2 34 -20 51 Heat # 49D867/49C813-1 2.05 1.20 23.9 28.7 17 -20 26 Lower Shell Forging (Using S/C Data) Nozzle Shell Forging 0.608 0.86 26.0 22.4 22.4 10 55 Heat # 5P-7016 Inter, to Lower Shell Circ. Weld 1.99 1.19 41.0 48.8 48.8 40 138 WF-562 (HT# 442011) 1.99 25.7 30.6 28 40 99 1.19 Inter. to Lower Shell Circ. Weld Using S/C Data Nozzle Shell to Inter. Shell Circ. 0.608 0.86 54.0 46.5 46.5 -25 68 Weld WF-645 (HT# H4498)

(a) Initial RT_{NDT} values are measured values.

(b) $RT_{PTS} = RT_{NDT(U)} + \Delta RT_{PTS} + Margin (°F)$

(c) $\Delta RT_{PTS} = CF * FF$

.

Table 4.6								
RT _{PTS} Calculation for Braidwood Unit 1 Beltline Region Materials at Life Extension (48 EFPY)								
Material	Fluence ^(a) (10 ¹⁹ n/cm ² , E>1.0 MeV)	FF	CF (°F)	ΔRT _{PTS} ^(¢) (°F)	Margin (°F)	RT _{NDT(U)} ^(a) (°F)	RT _{PTS} ^(b) (°F)	
Intermediate Shell Forging Heat # 49D383-1/49C344-1	3.06	1.30	31.0	40.3	34	-30	44	
Lower Shell Forging Heat # 49D867/49C813-1	3.06	1.30	31.0	40.3	34	-20	54	
Lower Shell Forging Using S/C Data	3.06	1.30	23.9	31.1	31.1	-20	42	
Nozzle Shell Forging Heat # 5P-7016	0.909	0.97	26.0	25.2	25.2	10	60	
Inter. to Lower Shell Circ. Weld Metal WF-562 (HT# 442011)	2.98	1.29	41.0	52.9	52.9	40	146	
Inter. to Lower Shell Circ. Weld Using S/C Data	2.98	1.29	25.7	33.2	28	40	101	
Nozzle Shell to Inter. Shell Circ. Weld Metal WF-645 (HT# H4498)	0.909	0.97	54.0	52.4	52.4	-25	80	

(a) Initial RT_{NDT} values are measured values.

(b) $RT_{PTS} = RT_{NDT(U)} + \Delta RT_{PTS} + Margin (°F)$ (c) $\Delta RT_{PTS} = CF * FF$

5.0 References

- 1. WCAP-14040-NP-A, Revision 2, "Methodology Used to Develop Cold Overpressure Mitigating System Setpoints and RCS Heatup and Cooldown Limit Curves," Andrachek, J.D., et. al., January 1996.
- 2. NRC Letter from R. A. Capra to O.D. Kingsley, Commonwealth Edison Company, "Byron Station Units 1 and 2 and Braidwood Station Units 1 and 2, Acceptance for referring of pressure temperature limits report, (M98799, M98800, M98801, and M98802)," January 21 1998.
- 3. WCAP-14243, "Commonwealth Edison Company, Braidwood Unit 1 Heatup and Cooldown Limit Curves for Normal Operation," March 1995.
- 4. Westinghouse Calculation CN-EMT-01-8, "Braidwood Units 1 and 2, Development of New Pressure Temperature Limit Curves and Evaluation of Byron Units 1 and 2 PT Curves EFPY."
- 5. Westinghouse Letter to Commonwealth Edison Company, CCE-95-186, "Braidwood Unit 1 LTOPS Setpoints Based on 16 EFPY P/T Limits," June 5, 1995.
- 6. ComEd Calculation BRW-96-906I/BYR 96-293, "Channel Accuracy for Power Operated Reief Valve (PORV) Setpoints and Wide Range RCS Temperature Indication (Unit 1 Original Steam Generators and Replacement Steam Generators)," Revision 0.
- 7. ComEd Nuclear Fuel Services Department, NDIT No. 960194, "Maximum Allowable LTOPS PORV Setpoints for Braidwood Unit 1 with RSGs," Revision 2.
- 8. WCAP-9807, "Commonwealth Edison Company, Braidwood Station Unit 1 Reactor Vessel Radiation Surveillance Program," February 1981.
- 9. WCAP-15316, "Analysis of Capsule W from the Commonwealth Edison Company Braidwood Unit 1 Reactor Vessel Radiation Surveillance Program," December 1999.
- 10. Letter from J. D. von Suskil (Exelon Generation Company, LLC) to U.S. NRC, "Braidwood Station Response to U. S. NRC Request for Additional Information Regarding the Braidwood Station Pressure-Temperature Limits Report", dated August 30, 2002.
- 11. WCAP-15365, Revision 1, "Evaluation of Pressurized Thermal Shock for Braidwood Unit 1," September 2000.
- 12. NRC Letter from G. F. Dick, Jr., NRR, to C. Crane, Exelon Generation Company, LLC, "Issuance of Amendments: Revised Pressure-Temperature Limits Methodology; Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2," dated October 4, 2004.

BRAIDWOOD UNIT 2

PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)

Revision 3

.

Table of Contents

Section		Page
1.0	Introduction	1
2.0	Operating Limits	1
	2.1 RCS Pressure and Temperature (P/T) Limits	1
	2.2 Low Temperature Overpressure Protection (LTOP) System Setpoints	2
	2.3 LTOP Enable Temperature	2
	2.4 Reactor Vessel Boltup Temperature	2
	2.5 Reactor Vessel Minimum Pressurization Temperature	3
3.0	Reactor Vessel Material Surveillance Program	11
4.0	Supplemental Data Tables	13
5.0	References	20

i

List of Figures

Figure

4

5

9

 2.1 Braidwood Unit 2 Reactor Coolant System Heatup Limitations (Heatup Rates up to 100°F/hr) Applicable for the First 16 EFPY
 Using the 1996 Appendix G Methodology (Without Margins for Instrumentation Errors)

 Braidwood Unit 2 Reactor Coolant System Cooldown Limitations (Cooldown Rates of 0, 25, 50 and 100°F/hr) Applicable to the First 16 EFPY using 1996 Appendix G Methodology (Without Margins for Instrumentation Errors)

2.3 Braidwood Unit 2 Nominal PORV Setpoints for the Low Temperature Overpressure Protection (LTOP) System Applicable for the First 16 EFPY

ii

List of Tables

Table	· · · · · · · · · · · · · · · · · · ·	Page
2.1a	Braidwood Unit 2 Heatup Data at 16 EFPY using 1996 Appendix G Methodology (Without Margins for Instrumentation Errors)	.6
2.1b	Braidwood Unit 2 Cooldown Data Points 16 EFPY using 1996 Appendix G Methodology (Without Margins for Instrumentation Errors)	8
2.2	Data Points for Braidwood Unit 2 Nominal PORV Setpoints for the LTOP System Applicable for the First 16 EFPY	10
3.1	Braidwood Unit 2 Capsule Withdrawal Schedule	12
4.1	Braidwood Unit 2 Calculation of Chemistry Factors Using Surveillance Capsule Data	14
4.2	Braidwood Unit 2 Reactor Vessel Material Properties	15
4.3	Summary of Braidwood Unit 2 Adjusted Reference Temperatures (ARTs) at the 1/4T and 3/4T Locations for 16 EFPY	16
4.4	Braidwood Unit 2 Calculation of Adjusted Reference Temperatures (ARTs) at 16 EFPY at the Limiting Reactor Vessel Material Weld Metal (Based on Surveillance Capsule Data)	17
4.5	RT _{PTS} Calculation for Braidwood Unit 2 Beltline Region Materials at EOL (32 EFPY)	18
4.6	RT _{PTS} Calculation for Braidwood Unit 2 Beltline Region Materials at Life Extension (48 EFPY)	19

1.0 Introduction

This Pressure and Temperature Limits Report (PTLR) for Braidwood Unit 2 has been prepared in accordance with the requirements of Braidwood Technical Specification (TS) 5.6.6, "Reactor Coolant System (RCS) Pressure and Temperature Limits Report (PTLR)". Revisions to the PTLR shall be provided to the NRC after issuance.

The Technical Specifications addressed in this report are listed below:

LCO 3.4.3 RCS Pressure and Temperature (P/T) Limits; and LCO 3.4.12 Low Temperature Overpressure Protection (LTOP) System.

2.0 **Operating Limits**

The PTLR limits for Braidwood Unit 2 were developed using a methodology specified in the Technical Specifications. The methodology listed in WCAP-14040-NP-A (Reference 1) was used with the following exception:

a) Optional use of ASME Code Section XI, Appendix G, Article G-2000, 1996 Addenda,

This exception to the methodology in WCAP 14040-NP-A has been reviewed and accepted by the NRC in Reference 2.

WCAP 15626, Reference 3, provides the basis for the Braidwood Unit 2 P/T curves, along with the best estimate chemical compositions, fluence projections and adjusted reference temperatures used to determine these limits. Reference 4 evaluated the effect of higher fluence from 5% uprate on the existing P/T curves.

The applicability periods for all areas previously evaluated for 14.0 EFPY have been extended by two additional years to 16.0 EFPY. This applicability period extension was reviewed and approved by the NRC in Reference 10.

- 2.1 RCS Pressure and Temperature (P/T) Limits (LCO 3.4.3).
- 2.1.1 The RCS temperature rate-of-change limits defined in Reference 3 are:
 - a. A maximum heatup of 100°F in any 1-hour period.
 - b. A maximum cooldown of 100°F in any 1-hour period, and
 - c. A maximum temperature change of less than or equal to 10°F in any 1-hour period during inservice hydrostatic and leak testing operations above the heatup and cooldown limit curves.

2.1.2 The RCS P/T limits for heatup, inservice hydrostatic and leak testing, and criticality are specified by Figure 2.1 and Table 2.1a. The RCS P/T limits for cooldown are shown in Figure 2.2 and Table 2.1b. These limits are defined in Reference 3. Consistent with the methodology described in Reference 1, with the exception noted in Section 2.0, the RCS P/T limits for heatup and cooldown shown in Figures 2.1 and 2.2 are provided without margins for instrument error. These limits were developed using ASME Code Section XI, Appendix G, Article G2000, 1996 Addenda. The criticality limit curve specifies pressure-temperature limits for core operation to provide additional margin during actual power production as specified in 10 CFR 50, Appendix G.

The P/T limits for core operation (except for low power physics testing) are that the reactor vessel must be at a temperature equal to or higher than the minimum temperature required for the inservice hydrostatic test, and at least 40°F higher than the minimum permissible temperature in the corresponding P/T curve for heatup and cooldown.

2.2 Low Temperature Overpressure Protection (LTOP) System Setpoints (LCO 3.4.12).

The power operated relief valves (PORVs) shall each have nominal lift settings in accordance with Figure 2.3 and Table 2.2. These limits are based on Reference 5. The Residual Heat Removal (RH) Suction Relief Valves are also analyzed to individually provide low temperature overpressure protection. This analysis for the RH Suction Relief Valves remains valid with the current Appendix G limits contained in this PTLR document and will be reevaluated in the future as the Appendix G limits are revised.

The LTOP setpoints are based on P/T limits that were established in accordance with 10 CFR 50, Appendix G without allowance for instrumentation error. The LTOP setpoints were developed using the methodology described in Reference 1. The LTOP PORV nominal lift settings shown in Figure 2.3 and Table 2.2 account for appropriate instrument error.

2.3 LTOP Enable Temperature

The minimum required LTOP enable temperature is 200°F (Reference 6).

Braidwood Unit 2 procedures governing the heatup and cooldown of the RCS require the arming of the LTOP System for RCS temperature of 350°F and below and disarming of LTOP for RCS temperature above 350°F.

Note that the last LTOP PORV segment in Table 2.2 extends to 450°F where the pressure setpoint is 2335 psig. This is intended to prohibit PORV lift for an inadvertent LTOP system arming at power.

2.4 Reactor Vessel Boltup Temperature (Non-Technical Specification)

The minimum boltup temperature for the Reactor Vessel Flange shall be $\geq 60^{\circ}$ F. Boltup is a condition in which the Reactor Vessel head is installed with tension applied to any stud, and with the RCS vented to atmosphere.

2.5 Reactor Vessel Minimum Pressurization Temperature (Non-Technical Specification)

The minimum temperature at which the Reactor Vessel may be pressurized (i.e., in an unvented condition) shall be $\geq 60^{\circ}$ F, plus an allowance for the uncertainty of the temperature instrument, determined using a technique consistent with ISA-S67.04-1994.

Material Property Basis Limiting Material: Weld Metal Limiting ART Values at 16 EFPY 1/4T 82°F 3/4T 68°F





Braidwood Unit 2 Reactor Coolant System Heatup Limitations (Heatup Rates up to 100°F/hr) Applicable for the First 16 EFPY Using the 1996 Appendix G Methodoldgy (Without Margins for Instrumentation Errors)



Figure 2.2



Table 2.1a (Page 1 of 2)

Braidwood Unit 2 Heatup* Data Points at 16 EFPY Using the 1996 Appendix G Methodology (Without Margins for Instrumentation Errors)

Heatup					
Curve					
10	0 F Heatup	Criticality		Leak Test Limit	
		Lir	nit		
Т	P	Т	P	Т	Р
60	0	207	0	186	2000
60	617	207	621	207	2485
65	617	207	621		
70	617	207	621		
75	617	207	621		
80	617	207	621		
85	617	207	621		
90	617	207	621		
95	617	207	621		
100	617	207	621		
105	619	207	621		
110	621	207	621		
115	621	207	621		
120	621	207	621		
125	621	207	621		
130	621	207	621		
135	621	207	621		
140	621	207	696		
140	621	207	715		
140	696	207	736		
145	715	207	760		
150	736	207	786		
155	760	207	815		
160	786	210	846		
165	815	215	880		
170	846	220	917		
175	880	225	957		
180	917	230	1000		
185	957	235	1047		
190	1000	240	1097		
195	1047	245	1152		
200	1097	250	1210		
205	1152	255	1273		

ł

	Table 2.1aPage 2 of 2				
]	Heatup	Curve	2	
100 F	Heatup	Criti	cality	Leak Te	st Limit
т	P	l ⊥i I ∵T		т	P
210	1210	260	1341		-
215	1273	265	1415		
220	1341	270	1493		
225	1415	- 275	1578		ĺ
230	1493	280	1669		
235	1578	285	1766		
240	1669	290	1871		
245	1766	295	1984		
250	1871	300	2105		
255	1984	-305	2235		
260	2105	310	2374		
265	2235	· · · ·			
270	2374		1 1		

* Heatup and Cooldown data includes the vessel flange requirements of 140 °F and 621 psig per 10CFR50, Appendix G.,

Table 2.1b

(Page 1 of 1) Braidwood Unit 2 Cooldown* Data at 16 EFPY** Using the 1996 Appendix G Methodology (Without Margins for Instrumentation Errors)

						Cooldo	wn Cu	rves	_		
		Stea	dy Stat	te	2:	5 °F -	. 50)°F	10	0 °F	
			•		Coo	ldown	Coo	ldown	Coo	ldown	
		Т	P		T	P	T	Р	Т	Р	Ì
		60	0		60	0	60	0	60	0	
		60	62	1	60	602	60	554	60	455	
		65	62	1	65	·616	65	568	65	471	
		70	62	1	70	621	70	583	70	489	
		75	62	1	75	621	75	599	75	508	
		80	62	1	80	621	80	617	80	529	
		85	62	1	85	621	85	621	85	552	
		90	62	1	90	621	<u>9</u> 0	621	90	576	
		95	62	1	95	621	<u>95</u>	621	95	603	
		100	62	1	100	621	100	621	100	621	
		105	62	l	105	621	105	621	105	621	
		110	62	1	110	621	110	621	110	621	
		115	62	[115	621	115	621	115	621	
		120	62	<u> </u>	120	621	120	621	120	621	
		125	62		125	621	125	621	125	621	
		130	62	l	130	621	_130_	621	130	621	•
		135	62	<u> </u>	135	621	Unaccept	able	135	621	
		140	62		<u>140</u>	621	Operation	۱ <u>(</u>	140	621	
240	νŢ	<u>-140 </u>	-62	Ħ	-140-	<u>-621</u> -	140	-621-	140-	<u> </u>	
	1	140	101	¢	_140	991	140	975	140	957	
220	Ƞ	-145	-105	€	-145-	-103 #-	<u>-145</u> -	<u>-1022</u>	-145-	-1013/	
	1	150	109	2_	150	1080	150	1072	150	1074	
200	Ƞ	- 155		1	<u>-155</u> -	<u>-1129-</u>	<u>_15\$</u> _		<u>-155-</u>	<u>-1137</u> -	·
~	1	160	118	6	160	1188	160	_1185	160	Accent	able
G 180	»f	-165		2	<u>-165</u>	<u>-1230-</u>	<u>165</u>	<u> 1239 </u>	-165-	Operati	on
Е (Р	1	170	129	<u>\$</u>	170	.1295	170	1295	170	_ <u> </u>	
5 16	20 ±	_175		(-	PC	CV-456	<u>17</u> ≸	_1356_	175-		
ES:		180	142	2	18		180	_1422	180	1422	
140	20 	_185		₽_	-185-	_1492	<u>_185_</u>	1492	-185-	1492_	
QR.	1	190	156	1_	190	15670	- 190ation	1567	190	111567	
120 ب	ю]	_195		髀╡	_194_	1649	_195_		156	PCV-455.	∧ ⊦
AN A	-	200	173	<u>¢</u>	200	1736	200	_1736	200/	0011	·
§ 100	ю]	_205	-183	9	_204_	<u>1830</u>	<u></u>	1830	<u> - P04/ </u>	1830	
	·]	210	193	Ц	210	1931	210	1931	<u>P1//</u>	1.Q2plable	
80	»H	215	203	튁	_214_	2039	~218		<u></u> -₽ <i>∥</i> 5	2039 ^m	
	1	220	215	¢	220	2156	220	2 56	720	2156	
60	»1	_225	228		224	228	-22		25	<u>ct2281</u>	. <u> </u>
	1	230	241	¢.	_230_	2416	230	2416	230	2416	
A	<u>ب</u> 1			Ę							

Figure 2.3 Braidwood Unit 2 Nominal PORV Setpoints for the Low Temperature Overpressure Protection (LTOP) System Applicable for the First 16 EFPY

Table 2.2

Data Points for Braidwood Unit 2 Nominal PORV Setpoints for the LTOP System Applicable for the First 16 EFPY

PCV-455A

PCV-456

RCS TEMP. (DEG. F)	RCS Pressure (PSIG)	RCS TEMP. (DEG. F)	RCS Pressure (PSIG)
50	495.8	50	539.5
105	495.8	105	539.5
110	451.0	110	496.0
155	451.0	155	496.0
205	496.4	205	540.1
250	551.7	250	639.0
350	551.7	350	639.0
450	2335.0	450	2335.0

Note: To determine nominal lift setpoints for RCS Pressure and RCS Temperatures greater than 350°F, linearly interpolate between the 350°F and 450°F data points shown above. (Setpoints extend to 450°F to prevent PORV liftoff from an inadvertent LTOP system arming while at power).

3.0 Reactor Vessel Material Surveillance Program

.....

ł

1

The pressure vessel material surveillance program (Reference 7) is in compliance with Appendix H to 10 CFR 50, "Reactor Vessel Radiation Surveillance Program." The material test requirements and the acceptance standards utilize the reference nil-ductility temperature, RT_{NDT} , which is determined in accordance with ASME, Section III, NB-2331. The empirical relationship between RT_{NDT} and the fracture toughness of the reactor vessel steel is developed in accordance with Appendix G, "Protection Against Non-Ductile Failure," to Section XI of the ASME Boiler and Pressure Vessel Code. The surveillance capsule removal schedule meets the requirements of ASTM E185-82.

The third and final reactor vessel material irradiation surveillance specimens (Capsule W) have been removed and analyzed to determine changes in material properties. The surveillance capsule testing has been completed for the original operating period.

	Table 3.1					
Braidwood Unit 2 Capsule Withdrawal Schedule						
Capsule	Location (Degrees)	Capsule Lead Factor ^(a)	Removal Time ^(b) (EFPY)	Estimated Capsule Fluence (n/cm ²) ^(a)		
U	58.5°	4.41	1.15	4.00 x 10 ¹⁸ (c)		
X	238.5°	3.85	4.215	1.23 x 10 ¹⁹ (c)		
W	121.5°	4.17	8.53	2.25 x 10 ¹⁹ (c)		
Z	301.5°	4.17	12.78	(d)		
v	61.0°	3.92	Standby			
Y	241.0°	3.92	12.78	(d)		

Notes:

(a) Updated in Capsule W dosimetry analysis (Reference 8).
(b) Effective Full Power Years (EFPY) from plant startup.
(c) Plant specific evaluation.

(d) Capsule has been removed and stored in the spent fuel pool. Capsule has not been analyzed and therefore capsule fluence has not been estimated.

4.0 Supplemental Data Table

The following tables provide supplemental information on reactor vessel material properties and are provided to be consistent with Generic Letter 96-03. Some of the material property values shown were used as inputs to the P/T limits.

Table 4.1 shows the calculation of the surveillance material chemistry factors using surveillance capsule data (Reference 8).

Table 4.2 provides the reactor vessel material properties table.

Table 4.3 provides a summary of the Braidwood Unit 2 adjusted reference temperatures (ARTs) at the 1/4T and 3/4T locations for 16 EFPY.

Table 4.4 shows the calculation of ARTs at 16 EFPY for the limiting Braidwood Unit 2 reactor vessel material.

Table 4.5 provides RT_{PTS} Calculation for Braidwood Unit 2 Beltline Region Materials at EOL (32 EFPY), (Reference 9).

Table 4.6 provides RT_{PTS} Calculation for Braidwood Unit 2 Beltline Region Materials at Life Extension (48 EFPY), (Reference 9).

		· · · · · · · · · · · · · · · · · · ·				
·	Table 4.1					
Braidwood	Unit 2 Calo	culation of Chen	nistry Factors	Using Surveillar	nce Capsule Data	a
Material	Capsule	Capsule f ^(a)	FF ^(b)	∆RT _{NDT} ^(c)	FF*∆RT _{ndt}	(FF) ²
Lower Shell Forging	U	0.400	0.746	0.0	0.0	0.557
(50D102-1/50C97-1)	x	1.23	1.058	0.0	0.0	1.119
(Tangential)	W	2.25	1.220	4.53	5.53	1.488
Lower Shell Forging	U	0.400	0.746	0.0	0.0	0.557
(50D102-1/50C97-1)	x	1.23	1.058	33.94	35.91	1.119
(Axial)	W	2.25	1.220	33.2	40.50	1.488
	Chemi	stry Factor = Σ (F	F*∆RT _{NDD} ÷	Sum: $\Sigma(FF^2) = (81.94)$	81.94 ÷(6.328) = 12.9°	6.328 °F
Braidwood 1 Surv.Weld Material						
	U	0.387	0.737	17.06 ^(d)	12.57	0.543
	X	1.24	1.060	<u>30.15 (d)</u>	31.96	1.124
	<u> </u>	2.09	1.201	<u>49.68^(u)</u>	59.67	1.442
Braidwood 2						
Surv. Weld Material	<u> </u>	0.40	0.746	0.0	0.0	0.557
			1.058	$26.3^{(4)}$	27.83	1.119
		_2.25	1.220	23.9**	29.10	1.488
	Sum: 161.19 6.273					6.273
	Chemistry	Factor = $\Sigma(FF^*\Delta)$	$ART_{NDT} \div \Sigma(F)$	F^2) = (161.19) ÷ ((6.273) = 25.7°F	

NOTES:

(a) f = Calculated fluence, (x 10¹⁹ n/cm², E > 1.0 MeV)

(b) FF= fluence factor = $f^{(0.28 - 0.1 \circ \log f)}$

(c) ΔRT_{NDT} values are the measured 30 ft-lb shift values

(d) The surveillance weld metal ΔRT_{NDT} values have not been adjusted.

Tab	le 4	.2
-----	------	----

· · · · · · · · · · · · · · · · · · ·				
Material Description	Cu (%)	Ni (%)	Chemistry Factor ^(a)	Initial RT _{NDT} (°F) ^(a)
Closure Head Flange Heat # 3P6566/5P7547/4P6986 Serial # 2031-V-1		0.75		20
Vessel Flange Heat # 124P455	0.07	0.70		20
Nozzle Shell Forging * Heat # 5P7056	0.04	0.90	26.0°F ^(b)	30
Intermediate Shell Forging * Heat # 49D963/49C904-1-1) (also referred to as the Upper Shell forging)	0.03	0.71	20.0°F(b)	-30
Lower Shell Forging * Heat # 50D102/50C97-1-1	0.06	0.76	37.0°F(b) 12.9°F(c)	-30
Circumferential Weld * (Intermediate Shell to Lower Shell) Weld Seam WF-562 Heat # 442011	0.03	0.67	41.0 F(b) 25.7F(c)	40
Circumferential Weld * (Nozzle Shell to Intermediate Shell) Weld Seam WF-645 Heat # H4498	0.04	0.46	54.0°F(b)	-25

Braidwood Unit 2 Reactor Vessel Material Properties

* Beltline Region Materials

- (a) The initial RT_{NDT} values for the plates and welds are based on measured data.
- (b) Chemistry Factor calculated for Cu and Ni values per Regulatory Guide 1.99, Rev.2, Position 1.1
- (c) Chemistry Factor calculated for Cu and Ni values per Regulatory Guide 1.99, Rev. 2, Position 2.1

Table 4.3

Summary of Braidwood Unit 2 Adjusted Reference Temperature (ART's) at 1/4T and 3/4T Location for 16 EFPY^{(a)(b)}

Material	16 E	16 EFPY ^(b)			
· · · · · · · · · · · · · · · · · · ·	1/4T ART (°F)	3/4T ART (°F)			
Intermediate Shell Forging Heat # 49D963/49C904-1-1)	3	-8			
Lower Shell Forging Heat # 50D102/50C97-1-1	30	11			
-Using Surveillance Data	15	11			
Circumferential Weld (Intermediate Shell to Lower Shell) Weld Seam WF-562 Heat # 442011	106	85			
-Using Surveillance Data	82 ^(a)	68 ^(a)			
Circumferential Weld (Nozzle Shell to Intermediate Shell) Weld Seam WF-645 Heat # H4498	29	8			
Nozzle Shell Forging Heat # 5P7056	56	46			

(a) These ART values were used to calculate the Heatup and Cooldown curves in Figures 2.1 and 2.2 using the 1996 Appendix G Methodology.

(b) The applicability date has been increased from 14 EFPY to 16 EFPY based on an evaluation approved by the NRC in Reference 10.

Table 4.4				
Braidwood Unit 2 Calcu (ARTs) at 16 EFPY ^(d) at Metal WF562 (B	lation of Adjusted Refe the Limiting Reactor V ased on Surveillance C	erence Temperatures Vessel Material Weld apsule Data)		
Parameter	Val	lues		
Operating Time	16 EFPY ^(d)			
Location ^(b)	1/4T ART (°F)	3/4T ART(°F)		
Chemistry Factor, CF (°F)	25.7	25.7		
Fluence(f), n/cm^2 (E>1.0 Mev)) ^(a)	5.03x10 ¹⁸	1.81x10 ¹⁸		
Fluence Factor, FF	0.808	0.546		
$\Delta RT_{NDT} = CFxFF(^{\circ}F)$	20.77 ^(c)	14.04		
Initial RT _{NDT} , I(°F)	40	40		
Margin, M(°F)	20.77	14.04		
ART= I+(CF*FF)+M, °F per RG 1.99, Revision 2	82	68		

a) Fluence, f, is the calculated peak clad/base metal interface fluence (E>1.0 Mev) =8.37x10¹⁸ n/cm² at 14 EFPY (Reference 3).

b) The Braidwood Unit 2 reactor vessel wall thickness is 8.5 inches at the beltline region.

c) Using Regulatory Guide 1.99, Revision 2.

4

..,

d) The applicability date has been increased from 14 EFPY to 16 EFPY based on an evaluation approved by the NRC in Reference 10.

. Table 4.5

Material	Fluence (10 ¹⁹ n/cm ² , E>1.0 MeV)	FF	CF (°F)	ΔRT _{PTS} ^(e) (°F)	Margin (°F)	RT _{NDT(U)} (*) (°F)	RT _{PTS} ^(b) (°F)
Intermediate Shell Forging Heat # 49D963/49C904-1-1	1.96	1.18	20	23.6	23.6	-30	17
Lower Shell Forging Heat # 50D102/50C97-1-1	1.96	1.18	37	43.7	34	-30	48
Lower Shell Forging (Using S/C Data) ^(d)	1.96	1.18	12.9	15.2	34	-30	19
Nozzle Shell Forging Heat # 5P-7056	0.567	0.841	26	21.9	21.9	30	74
Circumferential Weld (Intermediate Shell to Lower Shell) Weld Seam WF-562 Heat # 442011	1.89	1.17	41.0	48.0	48.0	40	136
Circumferential Weld (Intermediate Shell to Lower Shell) (Using S/C Data)	1.89	1.17	25.7	30.1	28	40	98
Circumferential Weld (Nozzle Shell to Intermediate Shell) Weld Seam WF-645 Heat # H4498	0.567	0.841	54	45.4	45.4	-25	66

RT_{PTS} Calculation for Braidwood Unit 2 Beltline Region Materials at EOL (32 EFPY)

(a) Initial RT_{NDT} values are measured values.

(b) $RT_{PTS} = RT_{NDT(U)} + \Delta RT_{PTS} + Margin (°F)$.

(c) $\Delta RT_{PTS} = CF * FF$

(d) Surveillance data is considered not credible. In addition, the Table chemistry factor is conservative and would normally be used for calculating RT _{PTS}. However, because the chemistry factor predicted by the Regulatory Guide 1.99 Position 2.1 for the forging surveillance data was greater that the Position 1.1 chemistry factor, then the Position 2.1 chemistry factor will be used to determine the RT_{PTS} with a full σ_{Δ} margin term.

Table 4.6

	RT _{PTS} Calculation for Braidwood Unit 2 Beltline Region Materials at Life				
Extension (48 EFPY)					

Material	Fluence (10 ¹⁹ n/cm ² , E>1.0 MeV)	FF	CF (°F)	ΔRT _{PTS} ^(c) (°F)	Margin (°F)	RT _{NDT(U)} ^(a) (°F)	RT _{PTS} ^(b) (°F)
Intermediate Shell Forging Heat # 49D963/49C904-1-1	2.94	1.29	20	25.8	25.8	-30	22
Lower Shell Forging Heat # 50D102/50C97-1-1	2.94	1.29	37	47.7	34	-30	52
Lower Shell Forging (Using S/C Data) ^(d)	2.94	1.29	12.9	16.6	34	-30	21
Nozzle Shell Forging Heat # 5P-7056	0.849	0.954	26	24.8	24.8	30	80
Circumferential Weld (Intermediate Shell to Lower Shell) Weld Seam WF-562 Heat # 442011	2.83	1.28	41.0	52.9	52.9	40	145
Circumferential Weld (Intermediate Shell to Lower Shell) (Using S/C Data)	2.83	1.28	25.7	32.9	28	40	101
Circumferential Weld (Nozzle Shell to Intermediate Shell) Weld Seam WF-645 Heat # H4498	0.849	0.954	54	51.5	51.5	-25	78

(a) Initial RT_{NDT} values are measured values .

(b) $RT_{PTS} = RT_{NDT(U)} + \Delta RT_{PTS} + Margin (°F)$

(c) $\Delta RT_{PTS} = CF * FF$

(d) Surveillance data is considered not credible. In addition the Table chemistry factor is conservative and would normally be used for calculating RT_{PTS} . However, because the chemistry factor predicted by the Reg. Guide 1.99 Position 2.1 for the forging surveillance data was greater than the Position 1.1 chemistry factor then the Postion 2.1 chemistry factor will be used to determine the RT_{PTS} with a full σ_{Δ} margin term.

5.0 References

- WCAP-14040-A, Revision 2, "Methodology Used to Develop Cold Overpressure Mitigating System Setpoints and RCS Heatup and Cooldown Limit Curves", J.D. Andrachek, et. al., January 1996.
- 2. Letter from G. F. Dick, NRC, to O. D. Kingsley, Commonwealth Edison Company, "Exemption from Requirements of 10 CFR 50.60 - Byron, Units 1 and 2, and Braidwood, Units 1 and 2," dated January 16, 1998.
- 3. WCAP-15626, "Braidwood Unit 2 12 and 14 EFPY Heatup and Cooldown Limit Curves for Normal Operation using Uprated Fluences," January 2001.
- 4. Westinghouse Calculation CN-EMT-01-8, "Braidwood Units 1 and 2, Development of New Pressure Temperature Limit Curves and Evaluation of Byron Units 1 and 2 PT Curves EFPY."
- Braidwood Station Design Change Package 9900519 (Setpoint Scaling Change Request 00-106), "Revise Unit 2 Low Temperature Overpressure Protection System setpoints/Scaling for Pressurizer Power Operated relief Valves."
- 6. NRC Letter from R. A. Capra to O.D. Kingsley, Commonwealth Edison Company, "Byron Station Units 1 and 2 and Braidwood Station Units 1 and 2, Acceptance for referring of pressure temperature limits report, (M98799, M98800, M98801, and M98802)," January 21 1998.
- 7. WCAP-11188, "Commonwealth Edison Company, Braidwood Station Unit 2 Reactor Vessel Surveillance Program," December 1986.
- WCAP-15369, "Analysis of Capsule W from the Commonwealth Edison Company Braidwood Unit 2 Reactor Vessel Radiation Surveillance Program," March 2000.
- 9. WCAP-15381, "Evaluation of Pressurized Thermal Shock for Braidwood Unit 2", T.J. Laubham, September 2000.
- NRC Letter from G. F. Dick, Jr., NRR, to C. Crane, Exelon Generation Company, LLC, "Issuance of Amendments: Revised Pressure-Temperature Limits Methodology; Byron Station, Units 1 and 2, and Braidwood Station, Units 1 and 2," dated October 4, 2004.