February 3, 2005

Dr. Robert E. Gamble, Manager, ESBWR General Electric Company 175 Curtner Avenue, M/C 365 San Jose, CA 95125-1014

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 1 RELATED TO NEDE-33083P, SUPPLEMENT 1, "TRACG APPLICATION FOR ESBWR STABILITY ANALYSIS"

Dear Dr. Gamble:

By letter dated December 9, 2004, General Electric Company (GE) submitted NEDE-33083P, Supplement 1, "TRACG Application for ESBWR Stability Analysis." The Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this topical report to ensure that the information is sufficiently complete to enable the NRC staff to reach a conclusion on the acceptability of these reports.

The NRC staff has determined that additional information is necessary to continue the review. Enclosure 1 contains requests for additional information (RAIs) regarding NEDE-33083. These RAIs were sent to you via electronic mail on January 3, 2005, and were discussed during a teleconference on January 18, 2005. One RAI was deleted because GE informed the staff that the requested information, namely the eigenvalue separation, had already been provided in Table 8.1-2 of the submitted topical report. Changes of an editorial nature were made to the remaining RAIs, however, the technical content has not been changed. Please provide the requested information by February 28, 2005, so that the review can be completed in a timely manner.

If you have any questions or comments concerning this matter, you may contact me at (301) 415-2875 or <u>aec@nrc.gov</u>.

Sincerely,

/**RA**/

Amy E. Cubbage, ESBWR Project Manager New Reactors Section New, Research and Test Reactors Program Division of Regulatory Improvement Programs Office of Nuclear Reactor Regulation

Enclosure: As stated

cc: See next page

Dr. Robert E. Gamble, Manager, ESBWR General Electric Company 175 Curtner Avenue, M/C 365 San Jose, CA 95125-1014

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 1 RELATED TO NEDE-33083P, SUPPLEMENT 1, "TRACG APPLICATION FOR ESBWR STABILITY ANALYSIS"

Dear Dr. Gamble:

By letter dated December 9, 2004, General Electric Company (GE) submitted NEDE-33083P, Supplement 1, "TRACG Application for ESBWR Stability Analysis." The Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this topical report to ensure that the information is sufficiently complete to enable the NRC staff to reach a conclusion on the acceptability of these reports.

The NRC staff has determined that additional information is necessary to continue the review. Enclosure 1 contains requests for additional information (RAIs) regarding NEDE-33083. These RAIs were sent to you via electronic mail on January 3, 2005, and were discussed during a teleconference on January 18, 2005. One RAI was deleted because GE informed the staff that the requested information, namely the eigenvalue separation, had already been provided in Table 8.1-2 of the submitted topical report. Changes of an editorial nature were made to the remaining RAIs, however, the technical content has not been changed. Please provide the requested information by February 28, 2005, so that the review can be completed in a timely manner.

If you have any questions or comments concerning this matter, you may contact me at (301) 415-2875 or <u>aec@nrc.gov</u>.

Sincerely,

/**RA**/

Amy E. Cubbage, ESBWR Project Manager New Reactors Section New, Research and Test Reactors Program Division of Regulatory Improvement Programs Office of Nuclear Reactor Regulation

Project No. 717

Enclosure: As stated

cc: See next page

OFFICE	RNRP/PM	SRXB/SC	RNRP/SC
NAME	ACubbage	FAkstulewicz	LDudes
DATE	02/2/2005	02/2/2005	02/3/2005

ACCESSION NO. ML050330481

OFFICIAL RECORD COPY

Distribution for Request For Additional Information Letter No. 1 dated February 3, 2005: Hard Copy PUBLIC RNRP R/F ACubbage JWilliams <u>E-Mail</u> DMatthews JWermiel RLandry VKlein

ACRS OGC FAkstulewicz

ESBWR

CC:

Dr. Robert E. Gamble Manager, ESBWR GE Nuclear Energy 175 Curtner Avenue, MC 365 San Jose, CA 95125

Mr. George B. Stramback Manager, Regulatory Services GE Nuclear Energy 175 Curtner Avenue, MC 747 San Jose, CA 95125

Mr. J. Alan Beard GE Nuclear Energy 13113 Chestnut Oak Drive Darnestown, MD 20878-3554

Mr. David Lochbaum, Nuclear Safety Engineer Union of Concerned Scientists 1707 H Street, NW., Suite 600 Washington, DC 20006-3919

Mr. Paul Gunter Nuclear Information & Resource Service 1424 16th Street, NW, Suite 404 Washington, DC 20036

Mr. James Riccio Greenpeace 702 H Street, Suite 300 Washington, DC 20001

Mr. Adrian Heymer Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

Mr. Thomas P. Miller U.S. Dept. of Energy, NE-20, Rm. A286 Headquarters - Germantown 19901 Germantown Road Germantown, MD 20874-1290

Mr. Paul Leventhal Nuclear Control Institute 1000 Connecticut Avenue, NW Suite 410 Washington, DC 20036 Dr. Jack W. Roe Vice President Advanced Technologies & Laboratories International, Inc. 20010 Century Boulevard, Suite 500 Germantown, MD 20874

Mr. Brendan Hoffman Research Associate on Nuclear Energy and Environmental Program 215 Pennsylvania Avenue, SE Washington, DC 20003

Mr. Tom Clements 6703 Gude Avenue Takoma Park, MD 20912

Ms. Patricia Campbell Winston & Strawn 1400 L Street, NW Washington, DC 20005

Mr. Glenn H. Archinoff 5275 Westview Drive ACR Suite Frederick, MD. 21703-8306

Mr. Gary Wright, Director Division of Nuclear Facility Safety Illinois Emergency Management Agency 1035 Outer Park Drive Springfield, IL 62704

Mr. Charles Brinkman Westinghouse Electric Co. Washington Operations 12300 Twinbrook Pkwy., Suite 330 Rockville, MD 20852

Mr. Ronald P. Vijuk Manager of Passive Plant Engineering AP1000 Project Westinghouse Electric Company P. O. Box 355 Pittsburgh, PA 15230-0355

Mr. Ed Wallace, General Manager Projects PBMR Pty LTD PO Box 9396 Centurion 0046 Republic of South Africa Mr. Russell Bell Nuclear Energy Institute Suite 400 1776 I Street, NW Washington, DC 20006-3708

Mr. Ron Simard 6170 Masters Club Drive Suwanne, GA 30024

Mr. Jerald S. Holm Framatome ANP, Inc. 3315 Old Forest Road P.O. Box 10935 Lynchburg, VA 24506-0935

<u>E-Mail:</u> jerald.holm@framatome-anp.com

Requests for Additional Information (RAIs) NEDE-33083P, Supplement 1, "TRACG Application for ESBWR Stability Analysis"

Requests for Additional Calculations:

1. Startup with Neutronic Feedback

The TRACG ESBWR startup simulations provided in NEDE-33083P, Supplement 1, do not include neutronic feedback. Even though core void generation occurs late in the transients analyzed (when the pressure is significant), the calculations shown are not conclusive because the void feedback could conceivably result in large power oscillations when coupled to operator actions to maintain the reactor at power.

Please provide a TRACG simulation of ESBWR startup that includes the neutronic feedback. Use the limiting heat up rate. Describe in detail the control model used to simulate operator actions to maintain the reactor at power during the startup transient.

2. ODYSY Calculation

Provide a frequency domain ODYSY calculation for ESBWR beginning of cycle (BOC) conditions. Provide a comparison between the channel, core-wide, and out-of-phase decay ratios calculated by ODYSY and TRACG

3. TRACG Calculation of Instability Threshold

Perform a series of TRACG steady-state calculations at BOC conditions with increasing powers until unstable power oscillations develop to demonstrate the power-margin to instability. Provide calculations for the channel, core-wide, and regional instability modes. Do not exceed power levels for reasonable TRACG calculation limits; it is an acceptable response to specify that the stability power-margin is "greater then 20%".

Requests for Additional Data from Existing Calculations:

4. 3D Power Distribution

Please provide the 2D (channel powers) and 3D power distributions for BOC, middle of cycle (MOC), and end of cycle (EOC) in electronic format.

5. Subcritical Mode Power Distribution

Please provide the 2D and 3D power distributions for the calculation shown in Figure 8.1-5 of the first subcritical mode at BOC conditions in electronic format. Also, please provide a short description of the calculation tools used for this calculation.

6. Pressure Drops

Please provide the pressure drop and void fraction as function of elevation for BOC conditions. Provide it at least for a hot channel and an average channel along with their power and flow conditions.

7. TRACG Time Traces

Please provide the time trace data for Figures 8.1-8 through 11, and 8.1-19 through 20 in electronic format.

Request fo ESBWR Design Information:

8. ESBWR Design Parameters

Please provide the following ESBWR design parameters:

Parameter	Units	Value
Number of fuel rods		
Channel height		
Heat transfer area per unit axial length		
Channel flow area		
Hydraulic diameter		
Density of the fuel		
Fuel pellet diameter		
Cladding heat capacity		
Cladding thermal conductivity		
Cladding thickness		
Gap heat transfer coefficient		
Gap width (nominal)		