Limerick Generating Station						
	Job Performance Measure					
MANUALLY INITI	MANUALLY INITIATE A CONTROL ROOM CHLORINE/TOXIC CHEMICAL					
	JPM Number: 0023					
	Revision Number: 006					
	Date://					
Developed By:	Instructor	Date				
Validated By:	SME or Instructor	Date				
Review By:	Operations Representative	Date				
Approved By:	Training Department	Date				

### LLOJPM0023 Rev006

### Job Performance Measure (JPM)

#### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

 <ol> <li>Task description and number, JPM description and number are identified.</li> </ol>
 2. Knowledge and Abilities (K/A) references are included.
 <ol><li>Performance location specified. (in-plant, control room, or simulator)</li></ol>
 4. Initial setup conditions are identified.
 5. Initiating and terminating cues are properly identified.
 6. Task standards identified and verified by SME review.
 <ol><li>Critical steps meet the criteria for critical steps and are identified with an asterisk (*).</li></ol>
 <ol> <li>Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev Date</li> </ol>
 <ol> <li>Pilot test the JPM:</li> <li>a. verify cues both verbal and visual are free of conflict, and</li> <li>b. ensure performance time is accurate.</li> </ol>
 <ol> <li>If the JPM cannot be performed as written with proper responses, then revise the JPM.</li> </ol>
 <ol> <li>When JPM is revalidated, SME or Instructor sign and date JPM cover page.</li> </ol>

ı

### LLOJPM0023 Rev006

### Job Performance Measure (JPM)

#### **REVISION RECORD (Summary)**

Revision 006, Corrected Typographical Error on Step 16

#### SIMULATOR SETUP INSTRUCTIONS:

- 1. Reset the Simulator to IC-17
- 2. Ensure the B CREFAS Fan switch is in AUTO and the A CREFAS Fan switch is in STBY
- 3. Ensure the A Control Room Supply and Return fans are in RUN, and the B Control Room Supply and Return fans are in AUTO.

#### TASK STANDARD:

1

The Control Room HVAC system is operating in the Chlorine/Toxic Chemical Isolation mode with a chlorine/toxic chemical isolation signal present on B and D isolation channels and no radiation isolation signals present.

#### **INITIAL CONDITIONS:**

- 1. Control Room HVAC is in the normal operating mode.
- 2. The Control Room Emergency Fresh Air Supply system is lined up for automatic operation.

#### **INITIATING CUES:**

You are directed by Shift Supervision to manually initiate a Control Room HVAC Chlorine/Toxic Chemical Isolation for maintenance using the 'B' subsystem only per S78.8A Section 4.4

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

ſ	EXELON NUCLEAR
ļ	LLOJPM0023 Rev006
~	Job Deufermenes Messure ( IDM)
	Job Performance Weasure (JPW)
	Operator's Name:
	JPM Title: MANUALLY INITIATE A CONTROL ROOM CHLORINE/TOXIC CHEMICAL ISOLATION JPM Number:LLOJPM0023 Revision Number:006
	K/A Number and Importance: 290003 A3.01 3.3/3.5
	Suggested Testing Environment: Simulator
	Actual Testing Environment: Simulator
	Testing Method: Perform Faulted: No
	Alternate Path: No
l	Time Critical: No
_	Estimated Time to Complete: 10 minutes Actual Time Used:minutes
	References: S78.8.A, Rev.14
	<b>EVALUATION SUMMARY:</b> Were all the Critical Elements performed satisfactorily?
	The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be:
	Comments:
	Evaluator's Name:(Print)
_	Evaluator's Signature: Date
,	The timeclock starts when the candidate acknowledges the initiating cue.
	LLOJPM0023 REv006 Page 4 of 9

### LLOJPM0023 Rev006

# Job Performance Measure (JPM)

JPM Start Time: \_\_\_\_\_

ł

·····			+		
	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1. (Cue "Coi norr S78	VERIFY Control Room HVAC in normal operating mode per S78.1.A, <u>Placing the</u> <u>Control Room HVAC</u> <u>System into Normal</u> <u>Operation</u> . : If asked, respond, ntrol Room HVAC is in the mal operating mode per .1.A.")	Recognized from task conditions that Control Room HVAC is in normal operating mode per S78.1.A., <u>OR</u> consulted supervisor to obtain this information.			
2. (Cue "Co Fre for S78	VERIFY Control Room Emergency Fresh Air System lined up for automatic operation per S78.1.B, <u>Aligning the</u> <u>Control Room HVAC</u> <u>Isolation and Emergency</u> <u>Fresh Air Supply System</u> for Automatic Operation. : If asked, respond, ontrol Room Emergency esh Air System is lined up automatic operation per 8.1.B.")	Recognized from task conditions that Control Room Emergency Fresh Air System is lined up for automatic operation, <u>OR</u> consulted supervisor to obtain this information.			
3.	ENSURE keys for keylock handswitches HS-78-017B,D (RESET), are available.	Two keys for keylock handswitches HS-78-017B,D (RESET) are obtained.			
4.	IF no chemical isolation has been initiated, <u>THEN</u> ensure alignment as follows:	N/A			

### LLOJPM0023 Rev006

# Job Performance Measure (JPM)

	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
4a.	HS-78-010B, "B" CONT RM EMERG FRESH AIR FAN CONT 0BV127 in AUTO	HS-78-010B, "B" CONT RM EMERG FRESH AIR FAN CONT 0BV127 in AUTO			
4b.	HS-78-010A, "A" CONT RM EMERG FRESH AIR FAN 0AV127 in STANDBY	HS-78-010A, "A" CONT RM EMERG FRESH AIR FAN CONT 0AV127 in STANDBY			
*5.	PLACE Control Room Isolation Valve Reset Keylock switch HS-78- 017B (RESET B) to "RESET".	Reset Keylock switch HS-78-017B (RESET B) is placed in "RESET" at 00C681.			
*6.	PLACE Control Room Isolation Valve Reset Keylock switch HS-78- 017D (RESET D) to "RESET".	Reset Keylock switch HS-78-017D (RESET D) is placed in "RESET" at 00C681.			
*7.	PLACE Control Room Isolation Valve Trip Switch HSS-78-017B (TRIP B) to "CL <sub>2</sub> ".	Switch HSS-78-017B (TRIP B) arming collar is rotated to " $CL_2$ " at 00C681.			
*8.	PLACE Control Room Isolation Valve Trip Switch HSS-78-017D (TRIP D) to " CL <sub>2</sub> ".	Switch HSS-78-017D (TRIP D) arming collar is rotated to " $CL_2$ " at 00C681.			

I

### LLOJPM0023 Rev006

# Job Performance Measure (JPM)

Ĩ		<u>ELEMENT</u>	STANDARD	SAT	UNSAT	Comment Number
	*9.	<b>PLACE</b> Control Room Isolation Valve Reset Keylock switch HS-78- 017B (RESET B) to "AUTO".	Reset Keylock switch HS-78-017B (RESET B) is placed in "AUTO" at 00C681.			
	*10.	<b>PLACE</b> Control Room Isolation Valve Reset Keylock switch HS-78- 017D (RESET D) to "AUTO".	Reset Keylock switch HS-78-017D (RESET D) is placed in "AUTO" at 00C681.			
	*11.	DEPRESS <u>AND</u> RELEASE pushbutton portion of Trip Switch HSS-78-017B (TRIP B).	Switch HSS-78-017B (TRIP B) pushbutton is depressed and released at 00C681.			
	*12.	DEPRESS <u>AND</u> RELEASE pushbutton portion of Trip Switch HSS-78-017D (TRIP D).	Switch HSS-78-017D (TRIP D) pushbutton is depressed and released at 00C681.			
	13.	<b>RECORD</b> CREFAS run time in appropriate log.	CREFAS start data is recorded in CREFAS run time log.			
	14.	<b>ENSURE</b> CHLOR ISLN CHAN B, D amber lights are lit.	CHLOR ISLN CHAN B, D amber lights are lit on 00C681.			
	15.	VERIFY CONTROL ROOM CHLORINE ISOLATION INITIATED annunciator alarmed at 002 VENT A-2.	Annunciator window A-2, CONTROL ROOM CHLORINE ISOLATION INITIATED, on 002 VENT, is in.			
	16.	VERIFY CONTROL ROOM ISOLATION NOT COMPLETE annunciator is <u>not</u> alarmed at 002 VENT A- 3, after 25 seconds.	Annunciator window A-3, CONTROL ROOM ISOLATION NOT COMPLETE, on 002 VENT, is <b>not</b> alarmed 25 seconds after the isolation is initiated.			

I

### LLOJPM0023 Rev006

# Job Performance Measure (JPM)

	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
17.	<b>ENSURE</b> 0B(A)V127, EMERGENCY AIR FAN B(A), is running.	0BV127, EMERGENCY AIR FAN B, is running.			
18.	ENSURE 0A(B)V116, CONTROL ROOM AIR SUPPLY FAN A(B) running.	0AV116, SUPPLY FAN A, is running.			
19.	ENSURE 0A(B)V121, CONTROL ROOM AIR RETURN FAN A(B) running.	0AV121, RETURN FAN A, is running.			
20.	<b>VERIFY</b> PDI-78-054, CONTROL ROOM AIR INSIDE/OUTSIDE $\triangle$ PX, 0 inches of water after a time delay	PDI-78-054, CONTROL ROOM AIR INSIDE/OUTSIDE ∆PX indicates 0 inches of water after a time delay.			
(CUE	: "You have met the termination criteria for the JPM. You may stop here.")				

JPM Stop Time: \_\_\_\_\_

1

#### **INITIAL CONDITIONS:**

- 1. Control Room HVAC is in the normal operating mode.
- 2. The Control Room Emergency Fresh Air Supply systems is lined up for automatic operation.

### **INITIATING CUES:**

You are directed by Shift Supervision to manually initiate a Control Room HVAC Chlorine/Toxic Chemical Isolation for maintenance using the 'B' subsystem only per S78.8A Section 4.4

LLOJPM0111 Rev001

Limerick Generating Station							
	Job Performance Measure						
	PLACE 3 <sup>RD</sup> RFP IN SERVICE (DFV	V)					
	JPM Number: 0111						
	Revision Number: 001						
	Date: _/_/_						
Developed By:	Instructor	 Date					
Validated By:	SME or Instructor	Date					
Review By:	Operations Representative	Date					
Approved By:	Training Department	Date					

### LLOJPM0111 Rev001

### Job Performance Measure (JPM)

#### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

 <ol> <li>Task description and number, JPM description and number are identified.</li> </ol>
 2. Knowledge and Abilities (K/A) references are included.
 <ol> <li>Performance location specified. (in-plant, control room, or simulator)</li> </ol>
 4. Initial setup conditions are identified.
 5. Initiating and terminating cues are properly identified.
 6. Task standards identified and verified by SME review.
 <ol> <li>Critical steps meet the criteria for critical steps and are identified with an asterisk (*).</li> </ol>
 <ol> <li>Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev Date</li> </ol>
 <ol> <li>Pilot test the JPM:</li> <li>a. verify cues both verbal and visual are free of conflict, and</li> <li>b. ensure performance time is accurate.</li> </ol>
 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

	LLOJPM0111 REV001
Operator's Name:	O 🗖 STA 🗆 SRO Cert
JPM Title: PLACE 3 <sup>RD</sup> RFP IN SERVICE (DFW)	
JPM Number: LLOJPM0111	Revision Number: 001
K/A Number and Importance: 259002 A4.02 3.7/3.6	
Suggested Testing Environment: Simulator	
Actual Testing Environment: Simulator	
Testing Method: Perform Faulted:	No
Alternate Path: No	
Time Critical: No	
Estimated Time to Complete: 15 minutes Actual Time	Used:minutes
References:	
S06.1.C U/1 Placing A Standby Reactor Feed Pump In Se	ervice
<b>EVALUATION SUMMARY:</b> Were all the Critical Elements performed satisfactorily?	🗆 Yes 🗖 No
The operator's performance was evaluated against the standar determined to be:	ds contained in this JPM, and has been Unsatisfactory
Comments:	
	· · · · · · · · · · · · · · · · · · ·
	······
Evaluator's Name:	(Print)
Evaluator's Signature:	Date:

### **EXELON NUCLEAR**

## LLOJPM0111 REV001

#### **Revision Record (Summary)**

1. Revision 1, Format Change Only

#### SIMULATOR SETUP INSTRUCTIONS

1. Reset to IC #3

#### INITIAL CONDITIONS:

- 1. \_\_\_\_% Power
- 2. "1C" RFPT is in Standby in accordance with S06.1.A U/1
- 3. "1C" RFPT is has been in Standby at 2300 RPM for 60 minutes
- 4. Minimum Recirculation Flow established in Auto Mode per S06.0.A U/1
- 5. Lube Oil Cooler Outlet Between 110-120°F

#### **INITIATING CUES:**

You are directed by Shift Supervision place the "1C" Reactor Feed Pump in service from Standby per S06.1.C, Section 4.1.3.

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

Critical Element(s) indicated by "\*" in Performance Checklist.

# EXELON NUCLEAR

### LLOJPM0111 REV001

JPM Start Time: \_\_\_\_\_

TASK STANDARD: "1C" RFP started and injecting into the vessel.

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1.	ENSURE the following	N/A			
1a.	Oncoming RFPT has been adequately warmed	RFPT has been adequately warmed			
CUE:	"Feedpump has been in standby for 60 minutes"	(Provided as Cue in Turnover)			
1b.	HV-006-108AC, "1C RFP Disch VIv" (FEED DISCH C), is closed for oncoming RFP	HV-006-108C, "1C RFP Disch Vlv" (FEED DISCH C) is closed			
1c.	HIC-006-106C, "C RFP Min Flow Control" (FLOW), in "AUTO" for oncoming RFP	HIC-006-106C CRFP Min Flow Control" (FLOW), in "AUTO"			
2.	IF third RFP is being placed IN SERVICE, THEN PERFORM the following:	N/A			
2a.	REFER TO current P-1 edit AND verify FLLLP value is < 0.92	Current P-1 edit obtained AND FLLLP value verified < 0.92			
2b.	ACCESS screen FWLC_01, Process Overview, at FWLCS Operator Station	FWLC_01, Process Overview Accessed at FWLCS Station			
*2c.	SELECT blue bordered box next to "Reset" in FLLLP < 0.92 Dialog Box until it is outlined in white AND then release	Blue bordered box next to "Reset" in FLLLP < 0.92 Dialog Box outlined in white then clear			
*2d.	SELECT "Activate" (D4) Dialog Key (at bottom of screen)	Activate" (D4) Dialog Key Selected			
2e.	AND verify box next to "Reset" in FLLLP < 0.92 Dialog Box turns solid blue with a white circle in center	Box next to "Reset" in FLLLP < 0.92 Box turns solid blue with a white circle in center			

EXELON NUCLEAR

### LLOJPM0111 REV001

			 1 10/07/1	<u> </u>
*3.	Place FIC-M1-1R601A(B,C), "A(B,C) RFPT Speed Controller" (FEED PUMP A(B, C), S), in "AUTO" for oncoming RFP	FIC-M1-1R601C "CRFPT Speed Controller" (FEED PUMP A, in "AUTO		
4.	ACCESS screen FWLC_07, Automatic Sequences, at FWLCS Operator Station	Screen FWLC_07 Accessed		
5.	ENSURE "READY" box to left of "Start C RFP" sequence is solid green	Ensure "READY" box to left of "Start C RFP" sequence is solid green		
*6.	SELECT blue bordered box next to "Start C RFP" sequence until it is outlined in white AND then release	Blue bordered box next to "Start C RFP" sequence until it is outlined in white AND then released		
*7.	SELECT "Start" (D4) Dialog Key (at bottom of screen)	"Start" (D4) Selected		
8.	Verify the following on screen FWLC_07, Automatic Sequences, at FWLCS Operator Station	N/A		
8a.	Box next to "Start C RFP" sequence turns solid blue	Box next to "Start C RFP" sequence turns solid blue		
8b.	Step Number AND Title appears next to blue box of "Start C RFP" sequence	Step Number AND Title appears next to blue box of "Start C RFP" sequence		
9.	VERIFY the following automatic actions:	N/A		
9a.	HV-006-108C "1C RFP Disch VIv" (DISCH C), for oncoming RFP opens	HV-006-108C "1C RFP Disch VIv" (DISCH C), for oncoming RFP opened		
9b.	Oncoming RFPT speed rises until oncoming RFP discharge pressure is nominal 10 psig below RPV pressure	Oncoming RFPT speed rises, RFP discharge pressure is nominal 10 psig below RPV pressure		
9c.	WHEN oncoming RFP discharge pressure nominal 10 psig below RPV pressure, THEN oncoming RFPT speed slowly rises until oncoming RFP begins feeding RPV	Oncoming RFP begins feeding RPV		

# EXELON NUCLEAR

### LLOJPM0111 REV001

10.	VERIFY oncoming AND running RFP(s) are maintaining RPV level	Oncoming AND running RFP(s) are maintaining RPV level		
11.	ENSURE oncoming AND running RFP flows are within 0.5 Mlb/hr of each other using the Flow Equalizer in accordance with S06.0.E U/1, Feedwater Level Control And Reactor Feed Pump Control System Manipulation	N/A		
(CUE:	"You may stop here, you have met the termination criteria for this JPM.")			

JPM Stop Time: \_\_\_\_\_

### LLOJPM0111 REV001

─ INITIAL CONDITIONS:

- 1. \_\_\_\_% Power
- 2. "1C" RFPT is in Standby in accordance with S06.1.A U/1
- 3. "1C" RFPT is has been in Standby at 2300 RPM for 60 minutes
- 4. Minimum Recirculation Flow established in Auto Mode per S06.0.A U/1
- 5. Lube Oil Cooler Outlet Between 110-120°F

#### **INITIATING CUES:**

You are directed by Shift Supervision place the "1C" Reactor Feed Pump in service from Standby per S06.1.C, Section 4.1.3.

Limerick Generating Station								
Job Performance Measure								
ST-6-001-660-1, Main Turbine CIV, Stop Valve RPS & EOC-RPT Channel Functional Test								
	JPM Number: 0112							
Revision Number: 000								
	Date://							
Developed By:	Instructor	Date						
Validated By:	SME or Instructor	Date						
Review By:	Operations Representative	Date						
Approved By:	Training Department	Date						

## LLOJPM0112 Rev000

### Job Performance Measure (JPM)

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

	<ol> <li>Task description and number, JPM description and number are identified.</li> </ol>
	2. Knowledge and Abilities (K/A) references are included.
	<ol><li>Performance location specified. (in-plant, control room, or simulator)</li></ol>
	4. Initial setup conditions are identified.
	5. Initiating and terminating cues are properly identified.
	6. Task standards identified and verified by SME review.
<u></u>	<ol><li>Critical steps meet the criteria for critical steps and are identified with an asterisk (*).</li></ol>
	<ol> <li>Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev Date</li> </ol>
	<ol> <li>Pilot test the JPM:</li> <li>a. verify cues both verbal and visual are free of conflict, and</li> <li>b. ensure performance time is accurate.</li> </ol>
	<ol> <li>If the JPM cannot be performed as written with proper responses, then revise the JPM.</li> </ol>
	<ol> <li>When JPM is revalidated, SME or Instructor sign and date JPM cover page.</li> </ol>

### LLOJPM0112 Rev000

### Job Performance Measure (JPM)

#### **REVISION RECORD (Summary)**

New Revision

#### SIMULATOR SETUP INSTRUCTIONS:

- 1. The simulator can be reset to any IC with the plant at less than 94% power
- 2. DFW MSIV Test Mode activated
- 3. Inset the following Malfunctions and Overrides

Show <u>M</u> a	Hunctions - 0 Show <u>R</u> emotes - 0 h	lide Qverrides - 4 Hide Annunciators -	3				
Override S	umməry						
Tag ID	Description	Position / Target Actual Value	Override Value	Amptime	Actime	Dactime	Trig
C71-S3C	RPS Channel A2 Scram Pushbutton Arming Collar	ARM	ON		00.00.05	00.00.15	1
C71-S3C-P8	RPS Channel A2 Manual Scram Pushbutton	SCRAM	ON		00.00.05	00.00.10	1
C71-S38	RPS Channel B1 Scram Pushbutton Arming Collar	ARM	ON		00:00:05	00:00:15	2
C71-S38-P8	RPS Channel 81 Manual Scram Pushbutton	SCRAM	DN		00.00.05	00.00.15	2
☐ Timer I Annunciat	Pause pr Summary	Delete All				<b>iyan</b> F	Pending
Window D	escription	Tamana	Override Tupe		Actime	Dactime	Trio
D1 M	anual Scram System A	108 REACTOR D1	OFF		00.00.00	00.00.00	1
D2 Ma	anual Scram Switch Armed A / B	108 REACTOR D2	OFF		00:00:00	00:00:00	0
E1 Ma	anual Scram System B	108 REACTOR E1	ON		00:00:00	00.00.00	2
						<b>er sinan</b>	uunnuk

#### TASK STANDARD:

Section 4.4 of ST-6-001-660-1 is completed for performance of MSV testing.

#### **INITIAL CONDITIONS:**

- 1. All prerequisites of ST-6-001-660-1 are completed.
- 2. The Initial Conditions have been verified per section 4.3.
- 3. An Equipment Operator is standing by in the AER to support this evolution.
- 4. An additional Reactor Operator is available to operate the controls at 10C670.

#### **INITIATING CUES:**

Shift Supervision directs you to perform MSV testing per section 4.4 of ST-6-001-660-1.

### LLOJPM0112 Rev000

### Job Performance Measure (JPM)

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

### LLOJPM0112 Rev000

~											
			<u>Job</u>	Perf	orma	nce N	leasur	<u>e (JF</u>	<u>PM)</u>		
	Operator's Name: _ Job Title:		NLO		RO		SRO		STA		SRO Cert
	JPM Title: ST-6-00 FUNCTIONAL TES JPM Number:LLOJF	1-660-1 T PM0112	, MAII 2	N TUF	RBINE	CIV, S	TOP VA	LVE I Re	RPS & I	EOC-F Numbe	RPT CHANNEL er:000
	K/A Number and Im	portanc	ce: 500	0000 E	EA1.07	3.4 / 3	3.3				
	Suggested Testing	j Enviro	onmei	nt:	Simu	lator					
	Actual Testing Env	/ironme	ent:	Simu	lator						
	Testing Method:	] Perfc	orm		Fa	ulted	: 🗖 No	)			
	Alternate Path:	] No					l ·				
$\bigcirc$	Time Critical: D	lo									
	Estimated Time to	Compl	<b>ete:</b> 1	5 minı	utes /	Actual	Time L	lsed:	mi	nutes	
	References: ST-6-0	001-660	)-1, Re	ev. 40							
	EVALUATION SUM	IMARY: Elemei	: nts pe	rforme	ed satis	factori	ly?		Yes		No
	The operator's performed to	ormance be:	e was	evalua Satis	ated ag factory	ainst t	he stan □ Ur	dards satisf	contain actory	ed in t	this JPM, and has
	Comments:				<u> </u>						
							· · · · · · · · · · · ·	- <u></u>			
	······										_
	Evaluator's Name: _						(P	rint)			
	Evaluator's Signatu	re:							_ Date		
	LLOJPM0112 Rev0	00	<u> </u>				<u> </u>	<u></u>			Page 5 of 12

## LLOJPM0112 Rev000

# Job Performance Measure (JPM)

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
1. (Cu	VERIFY status light "TURB STOP VALVE B2 CLOSURE TRIP DS2D" is Lit, at panel 10C611. e: EO reports "TURB STOP VALVE B2 CLOSURE TRIP DS2D" is Lit, at panel 10C611)	EO in AER is contacted to verify light status			
2.	VERIFY status light "TURB STOP VALVE A2 CLOSURE TRIP DS3C" is Lit, at panel 10C611.	EO in AER is contacted to verify light status			
(Cu	e: EO reports "TURB STOP VALVE A2 CLOSURE TRIP DS3C" is Lit, at panel 10C611" is Lit, at panel 10C611)				
3.	IF status lights in step 4.4.1 OR 4.4.2 are <u>not</u> lit, <u>THEN</u> STOP test <u>AND</u> INVESTIGATE problem.	N/A			
*4.	<b>DEPRESS <u>AND</u> HOLD</b> MSV-1 TEST Pushbutton, at panel 10C670.	MSV-1 TEST pushbutton is depressed and held			
5.	VERIFY MSV-1 No. 1 (TURBINE VALVE POSITION, MAIN STOP, MSV-1) closes, at panel 10C670.	MSV-1 is verified to close			
6.	<b>VERIFY</b> <u>no</u> half scram has occurred, at panel 10C603.	Alarms and panel indications are reviewed to verify no half scram			

## LLOJPM0112 Rev000

ELEMENT	STANDARD	SAT	UNSAT	Comment Number						
7. <b>POSITION</b> Turbine Stop Valve Logic Test Switch C71A-S7C in "TEST 2" position, to simulate MSV-2 closure, at panel 10C609.	EO in AER is contacted to perform this step									
(Cue: EO reports Turbine Stop Valve Logic Test Switch C71A-S7C in "TEST 2" position at panel 10C609)										
	Simulator Instructor:									
   (Cuer FO report Turking Oten )/	Activate Trigger 1									
MSV-2 closure, at panel 10C60	alve Logic Test Switch C71A-S7C in "1 9)	E91 2"	position, to	simulate						
8. <b>VERIFY</b> the following: Window A-1 "TURBINE STOP VALVE CLOSURE TRIP" is alarmed, at panel 107 REACTOR	107 REACTOR window A-1 is verified alarmed									
8a. Window B-2 "AUTO SCRAM CHANNEL A2" is alarmed, at panel 108 REACTOR	108 REACTOR window B-2 is verified alarmed									
9. VERIFY the following status lights <u>not</u> Lit, at panel 10C603: Group 1 Scram System A, SCRAM SYSTEM LOGIC, "A1", "A2", "A3", "A4"	A1, A2, A3, and A4 Scram System Status lights are verified NOT lit									
10. <b>POSITION</b> Turbine Stop Valve Logic Test	EO is contacted to return C71A-S7C to "NORM"									

## LLOJPM0112 Rev000

r .	· · · · · · · · · · · · · · · · · · ·		*****	r
ELEMENT	STANDARD	SAT	UNSAT	Comment Number
Switch, C71A-S7C to "NORM," at panel 10C609.				
	Simulator Instructor			
Delete Annur	nciator for 108 D-1 Manual Scran	n Syste	em A	
(Cue: EO report Turbine Stop Va 10C609)	Ive Logic Test Switch C71A-S7C in "N	NORM"	position at <sub>l</sub>	panel
*11. <b>RESET</b> half scram by momentarily placing Scram Reset Switch, (C71A-S5) to "GRP 1/4" <u>AND</u> "GRP 2/3" positions at panel 10C603.	"A" side half scram is reset	•		
12. <b>VERIFY</b> the following: Window B-2, "AUTO SCRAM CHANNEL A2," can be cleared at panel 108 REACTOR	108 REACTOR window B-2 is verified cleared			
12a. Window A-1, "TURBINE STOP VALVE CLOSURE TRIP," can be cleared, at panel 107 REACTOR	107 REACTOR window A-1 is verified cleared			
<ul> <li>13. VERIFY the following status lights Lit, at panel 10C603: Group 1 Scram System A, SCRAM SYSTEM LOGIC, "A1", "A2", "A3", "A4"</li> </ul>	A1, A2, A3, and A4 Scram System Status lights are verified lit			

## LLOJPM0112 Rev000

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number					
14. (Cue:	POSITION Turbine Stop Valve Logic Test Switch C71A-S7B in "TEST 1," position, to simulate MSV-3 closure, at panel 10C611. EO reports Turbine Stop Valve Logic Test Switch C71A-S7B in "TEST 1" position at panel 10C611)	EO in AER is contacted to perform this step								
	Simulator Instructor:									
		Activate Trigger 2		4 m •4•						
(Cue:   simula	EO reports Turbine Stop ate MSV-3 closure, at pane	Valve Logic Test Switch C71A-S7B in el 10C611)	"IESI	1," position	, to					
15.	VERIFY the following: Window A-1, "TURBINE STOP VALVE CLOSURE TRIP", alarmed, at panel 107 REACTOR	107 REACTOR window A-1 is verified alarmed								
16.	Window C-1, "AUTO SCRAM CHANNEL B1", alarmed, at panel 108 REACTOR	108 REACTOR window C-1 is verified alarmed								
17.	VERIFY the following status lights <u>not</u> Lit, at panel 10C603: Group 1 Scram System B, SCRAM SYSTEM LOGIC, "B1", "B2", "B3", "B4"	B1, B2, B3, and B4 Scram System Status lights are verified NOT lit								

## LLOJPM0112 Rev000

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
18. (Cue:	POSITION Turbine Stop Valve Logic Test Switch, C71A-S7B to "NORM," at panel 10C611. EO reports Turbine Stop Valve Logic Test Switch C71A-S7B in "NORM" position at panel 10C611)	EO in AER is contacted to perform this step			
		Simulator Instructor:			
	Delete Annur	nciator for 108 E-1 Manual Scrar	n Syste	em B	
(Cue: 10C6	EO report Turbine Stop Va 09)	alve Logic Test Switch C71A-S7C in "N	NORM"	position at <sub>l</sub>	oanel
*19.	<b>RESET</b> half scram by momentarily placing Scram Reset Switch (C71A-S5) to "GRP 1/4" <u>AND</u> "GRP 2/3" positions, at panel 10C603.	"B" side half scram is reset			
20.	<b>VERIFY</b> the following: Window C-1, "AUTO SCRAM CHANNEL B1," can be cleared, at panel 108 REACTOR	108 REACTOR window C-1 is verified cleared			
20a.	Window A-1, "TURBINE STOP VALVE CLOSURE TRIP," can be cleared, at panel 107 REACTOR	107 REACTOR window A-1 is verified cleared			

## LLOJPM0112 Rev000

# Job Performance Measure (JPM)

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<ul> <li>21. VERIFY the following status lights Lit, at panel 10C603:</li> <li>Group 1 Scram System B, SCRAM SYSTEM LOGIC, "B1", "B2", "B3", "B4"</li> </ul>	B1, B2, B3, and B4 Scram System Status lights are verified lit			
22. <u>WHEN</u> any transients have disappeared, <u>THEN RELEASE MSV-</u> 1 TEST pushbutton, at panel 10C670.	MSV-1 TEST pushbutton is released			
23. VERIFY TURBINE VALVE POSITION, MAIN STOP, MSV-1 indicates fully open, at panel 10C670.	MSV-1 is verified fully open			
(CUE: "You can stop here you have met the termination criteria for this JPM")	N/A			

JPM Stop Time: \_\_\_\_\_

#### $\sim$ INITIAL CONDITIONS:

- 1. All prerequisites of ST-6-001-660-1 are completed.
- 2. The Initial Conditions have been verified per section 4.3.
- 3. An Equipment Operator is standing by in the AER to support this evolution.
- 4. An additional Reactor Operator is available to operate the controls at 10C670.

#### **INITIATING CUES:**

Shift Supervision directs you to perform MSV testing per section 4.4 of ST-6-001-660-1.

Limerick Generating Station							
Job Performance Measure							
ST-6-107-880-1, APRM AND LPRM NOISE LEVEL DETERMINATION							
JPM Number: 0113							
Revision Number: 000							
Date: _/_/							
Developed By:							
	Instructor	Date					
Validated By:							
vanuated by:	SME or Instructor	Date					
Review By:							
	Operations Representative	Date					
Approved By:	<u></u>						
	Training Department	Date					

## LLOJPM0113 Rev000

## Job Performance Measure (JPM)

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- 1. Task description and number, JPM description and number are identified.
- 2. Knowledge and Abilities (K/A) references are included.
- 3. Performance location specified. (in-plant, control room, or simulator)
- \_ 4. Initial setup conditions are identified.
  - 5. Initiating and terminating cues are properly identified.
  - 6. Task standards identified and verified by SME review.
  - 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
  - Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. \_\_\_\_\_ Date \_\_\_\_\_
  - 9. Pilot test the JPM:a. verify cues both verbal and visual are free of conflict, andb. ensure performance time is accurate.
  - 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
  - 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

## LLOJPM0113 Rev000

### Job Performance Measure (JPM)

#### **REVISION RECORD (Summary)**

New Revision

#### SIMULATOR SETUP INSTRUCTIONS:

1. The simulator can be reset to any at power IC.

#### TASK STANDARD:

Section 4.3 of ST-6-107-880-1 is completed APRM/LPRM noise levels calculated.

#### **INITIAL CONDITIONS:**

- 1. "1B" Reactor Recirc Pump tripped 20 minutes ago.
- 2. All prerequisites of ST-6-107-880-1 are completed.
- 3. SSV has given permission to start test.
- 4. PRO has given permission to start test.

#### ✓ INITIATING CUES:

Shift Supervision directs you to perform Section 4.3 of ST-6-107-880-1, APRM AND LPRM NOISE LEVEL DETERMINATION.

### LLOJPM0113 Rev000

### Job Performance Measure (JPM)

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

## LLOJPM0113 Rev000

Job Performance Measure (JPM)									
Operator's Name: Job Title:									
JPM Title: ST-6-107-880-1, APRM AND LPRM NOISE LEVEL DETERMINATION JPM Number:LLOJPM0113 Revision Number:000									
K/A Number and Importance: 215005 A4.06 3.6/3.8									
Suggested Testing Environment: Simulator									
Actual Testing Environment: Simulator									
Testing Method: Perform Faulted: No									
Alternate Path: No									
Time Critical: No									
Estimated Time to Complete: 15 minutes Actual Time Used:minutes									
References: ST-6-107-880-1, Rev. 06									
EVALUATION SUMMARY: Were all the Critical Elements performed satisfactorily?   Yes   No									
The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be:									
Comments:									
Evaluator's Name:(Print)									
Evaluator's Signature: Date									

## LLOJPM0113 Rev000

# Job Performance Measure (JPM)

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: \_\_\_\_\_

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1.	RECORD time of entry into Hi Power/Lo Flow region OR Recirculation Pump trip:	Time of Recirc Pump recorded on ST			
(Cue	: "1B" Recirc Pump Tripped 20 minutes ago)				
2.	PERFORM the following to determine each APRM noise level:				
*2a.	RECORD highest value for each APRM listed on Attachment 1 from XR X- M1-1R603A through D on panel 10C603	Highest value for each APRM listed on Attachment 1 from XR X-M1-1R603A through D on panel 10C603 Recorded on ST			
*2b.	RECORD lowest value for each APRM listed on Attachment 1 from XR X- M1-1R603A through D on panel 10C603	Lowers value for each APRM listed on Attachment 1 from XR X-M1-1R603A through D on panel 10C603 Recorded on ST			
*3.	CALCULATE noise level for each APRM listed on Attachment 1 as follows	Noise level for each APRM listed on Attachment 1 calculated			
NL =	HV – LV				
NL = Noise Level (%)					
HV = Highest Value (step 4.3.2.1)					
LV = Lowest Value (step 4.3.2.2)					
	(4.3.2.1) (4.3.2.2)				
NL =%					

### LLOJPM0113 Rev000

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
4.	RECORD each APRM noise level on Attachment 1	APRM noise level recorded on Attachment 1			
5.	PERFORM the following to determine each selected LPRM noise level:				
*5a.	SELECT each rod listed on Attachment 2	Any Control Rod within the 4-rod group containing the rod specified in Attachment 2 is selected			
*5b.	RECORD highest value for all LPRM levels A/C from the Rod Block Monitor ODA on Attachment 2	Highest value for all LPRM levels A/C from the Rod Block Monitor ODA on Attachment 2 Recorded			
*5c.	RECORD lowest value for all LPRM levels A/C from the Rod Block Monitor ODA on Attachment 2	Lowest value for all LPRM levels A/C from the Rod Block Monitor ODA on Attachment 2 Recorded			
*6.	CALCULATE noise level for each LRPM listed on Attachment 2 as follows	Noise level for each LRPM listed on Attachment 2 Calculated			
NL = HV - LV					
NL = Noise Level (W/CM <sup>2</sup> )					
HV = LV = NL =	Highest Value (step 4.3.3.2) Lowest Value (step. 4.3.3.3) 				
	(4.3.3.2) (4.3.3.3)				
NL =	(W/CM <sup>2</sup> )				
7.	RECORD each LPRM noise level on Attachment 2				
### LLOJPM0113 Rev000

## Job Performance Measure (JPM)

ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<ul> <li>8. SELECT each rod listed on Attachment 2</li> <li>(CUE: "You may stop here. You have met the termination criteria for this JPM")</li> </ul>	Control Rod 30-15 Selected			

JPM Stop Time: \_\_\_\_\_

INITIAL CONDITIONS:

- 1. "1B" Reactor Recirc Pump tripped 20 minutes ago.
- 2. All prerequisites of ST-6-107-880-1 are completed.
- 3. SSV has given permission to start test.
- 4. PRO has given permission to start test.

#### **INITIATING CUES:**

Shift Supervision directs you to perform Section 4.3 of ST-6-107-880-1, APRM AND LPRM NOISE LEVEL DETERMINATION.

Limerick Generating Station								
Job Performance Measure								
SHUTDOWN COOLING FLOW ADJUSTMENTS - RHRSW HI RAD (ALTERNATE PATH)								
JPM Number: 0515								
Revision Number: 009								
	Date: _ / _ /							
Developed By:	Instructor	 Date						
Validated By:	SME or Instructor	Date						
Review By:	Operations Representative	Date						
Approved By:	Training Department	 Date						

### LLOJPM0515 Rev009

### Job Performance Measure (JPM)

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

	<ol> <li>Task description and number, JPM description and number are identified.</li> </ol>
. <u> </u>	2. Knowledge and Abilities (K/A) references are included.
<u></u>	<ol><li>Performance location specified. (in-plant, control room, or simulator)</li></ol>
	4. Initial setup conditions are identified.
	5. Initiating and terminating cues are properly identified.
	6. Task standards identified and verified by SME review.
	<ol><li>Critical steps meet the criteria for critical steps and are identified with an asterisk (*).</li></ol>
	<ol> <li>Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev Date</li> </ol>
	<ol> <li>Pilot test the JPM:</li> <li>a. verify cues both verbal and visual are free of conflict, and</li> <li>b. ensure performance time is accurate.</li> </ol>
	<ol> <li>If the JPM cannot be performed as written with proper responses, then revise the JPM.</li> </ol>
	<ol> <li>When JPM is revalidated, SME or Instructor sign and date JPM cover page.</li> </ol>

### LLOJPM0515 Rev009

### Job Performance Measure (JPM)

#### **REVISION RECORD (SUMMARY)**

Rev. 009, Format change only

### SIMULATOR SETUP INSTRUCTIONS

- 1. Reset simulator to IC-15 (Flooded up into Rx Well)
- 2. Adjust HV-C-51-103A (1A RHR Heat Exchanger Outlet Bypass POS) to 100%
- 3. Ensure HV-51-1F015A (Shutdown Cooling Return Valve) is full open
- 4. Throttle HV-C-51-1F048A (Heat Exchanger Bypass) closed to obtain 9000 gpm flow
- 5. Close HV-51-1F003A (Heat Exchanger Outlet)
- 6. Apply mousetraps to the following:
  - a. HV51-1F027A and B, SUPP POOL SPRAY
  - b. HV51-1F040 and 49, LETDOWN TO RW
  - c. HV51-1F024A, SUPP POOL CLNG
  - d. HV43-1F023A and B, RECIRC SUCTION
- 7. Prepare a copy of S51.8.B marked up to and including 4.3.22.5

### **INITIAL CONDITIONS:**

- 1. "1A" RHR has been placed in service for Shutdown Cooling with Reactor Coolant temperature at 85°F as read on XI-36-101 point 1.
- 2. "0A" RHRSW pump is in service providing flow to "1A" RHR Heat Exchanger.
- 3. Reactor level is being maintained at 83" as read on LI-42-1R605.
- 4. HV-C-51-103A, RHR Heat Exchanger Outlet Bypass (POS), is full open and additional cooling is required to maintain reactor coolant temperature within the 75°F to 85°F band.
- 5. The Unit 1 Reactor Operator is performing the cooldown ST.

### **INITIATING CUES:**

The CRS has directed you to continue performing S51.8.B at step number 4.3.22.6 to provide additional cooling to reactor coolant.

### LLOJPM0515 Rev009

### Job Performance Measure (JPM)

#### TASK STANDARD:

1A RHR pump tripped and 1A RHR Heat Exchanger isolated.

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

### LLOJPM0515 Rev009

Operator's Name:		<u>Job</u>	) Pe	rforma	ince	Meas	sur	e (JP	' <u>M)</u>		
Job Title:		NLO		RO		SF	RO		STA		SRO Cert
JPM Title:	SHU				FLOV	V ADJ	US	TMEN	TS - RH	HRSW	HI RAD
JPM Number:	(AL H LLOJ	IPM051	E PA 5	(IH)				Rev	vision N	lumber	: 009
K/A Number a	and Im	portanc	ce: 2	205000	K1.1	5 3.5/	3.6				
Suggested Testing Environment: Simulator											
Actual Testing Environment: Simulator											
Testing Method: Perform Faulted: No											
Alternate Path: Ye	es										
Time Critical: No											
Estimated Time to	o Com	plete:	15 m	ninutes	Actu	ual Tin	ne l	Jsed:	mi	nutes	
References: S51.8	3.B, Re	ev. 58, A	ARC	-MCR-0	11 B-4	4, Rev	. 1				
EVALUATION SUM Were all the Critica	<b>MMAR</b> ` I Elem	Y: ents pe	rforr	ned sati	sfacto	orily?			Yes		No
The operator's perf been determined to	orman be:	ice was □	eval Sat	luated a	gains /	t the s □	tano Un	dards isatisfa	contain actory	ed in t	his JPM, and has
Comments:											_
											_
······································						·····					_
Evaluator's Name:							_(Pi	rint)			
Evaluator's Signatu	ıre:								D	ate	<u> </u>

1

### LLOJPM0515 Rev009

# Job Performance Measure (JPM)

JPM Start Time: \_\_\_\_\_

		ELEMENT	STANDARD	SAT	UNSAT	Comment Number
	1.	If additional cooling is required, then PERFORM the following:	N/A			
	(Cue:	Additional cooling is required)				
	1a.	OPEN HV-C-51- *F048A(B), HEAT EXCH BYPASS	HV-C-51-1F048A handswitch to OPEN			
	1b.	OPEN HV-51- *F003A(B), OUTLET	HV-51-1F003A handswitch to OPEN			
1	1c.	CLOSE HV-C-51- *03A(B), POS	Depress HV-C-51-103A controller "CLOSE" pushbutton to reduce meter output to 0%			
	NOTE: Insert MRM019A U1 RI		HR SW Return Hdr Rad Mon fails to 5	00 cpm	•	
	2.	Respond to alarm B-4 on 011 SERV WTR B (RHRSW HI RADIATION.)	Obtain ARC B-4 on 011 SERV WTR B			
	(Cue if needed: "You have received the RHRSW HI Rad Alarm")					
	3.	Verify the high rad condition on RR12- 0R615A,B panel C667	Observe RHRSW rad recorder RR12-0R615A and determine increasing trend			
	4.	If an actual high radiation condition is suspected, <b>THEN:</b>	Determine recorder response is due to an actual increasing radiation condition			
	(CUE:	If asked, report Chemistry has confirmed that a hi rad condition exsist)				

## LLOJPM0515 Rev009

### Job Performance Measure (JPM)

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
*4a.	Trip associated RHR pump	RHR Pump "1A" handswitch taken to STOP			
*4b.	AND Isolate the shell side of HX by closing HV-51-*F047A(B) or HV-51-*82A(B) with HS- 51-*82A(B) (309/238' U/1) (376/238' U/2)	HV-51-1F047A keylock switch taken to CLOSE, green light on, red light off			
*4c. (Cue:	AND HV-51-*F003A(B) OR HV-C-51-*03A(B) " You have reached the	HV-51-1F003A keylock switch taken to CLOSE, green light on, red light off			
termi JPM	nation point for the ')				

JPM Stop Time \_\_\_\_\_

Initial Conditions:

- 1. "1A" RHR has been placed in service for Shutdown Cooling with Reactor Coolant temperature at 85°F as read on XI-36-101 point 1.
- 2. "0A" RHRSW pump is in service providing flow to "1A" RHR Heat Exchanger.
- 3. Reactor level is being maintained at 83" as read on LI-42-1R605.
- 4. HV-C-51-103A, RHR Heat Exchanger Outlet Bypass (POS), is full open and additional cooling is required to maintain reactor coolant temperature within the 75°F to 85°F band.
- 5. The Unit 1 Reactor Operator is performing the cooldown ST.

Initiating Cues:

The CRS has directed you to continue performing S51.8.B at step number 4.3.22.6 to provide additional cooling to reactor coolant.

Limerick Generating Station								
Job Performance Measure								
SUPPLYING POWER TO A 480 VAC NON-SAFEGUARD LOAD CENTER FROM ITS ALTERNATE SOURCE (ALTERNATE PATH)								
	JPM Number: 0525							
	Revision Number: 000							
	Date://							
Developed By:	Instructor	 Date						
Validated By:	SME or Instructor	Date						
Review By:	Operations Representative	 Date						
Approved By:	Training Department	Date						

1

### LLOJPM0525 Rev000

### Job Performance Measure (JPM)

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

 <ol> <li>Task description and number, JPM description and number are identified.</li> </ol>
 2. Knowledge and Abilities (K/A) references are included.
 <ol> <li>Performance location specified. (in-plant, control room, or simulator)</li> </ol>
 4. Initial setup conditions are identified.
 5. Initiating and terminating cues are properly identified.
 6. Task standards identified and verified by SME review.
 <ol><li>Critical steps meet the criteria for critical steps and are identified with an asterisk (*).</li></ol>
 <ol> <li>Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev Date</li> </ol>
 <ol> <li>Pilot test the JPM:</li> <li>a. verify cues both verbal and visual are free of conflict, and</li> <li>b. ensure performance time is accurate.</li> </ol>
 <ol> <li>If the JPM cannot be performed as written with proper responses, then revise the JPM.</li> </ol>
 <ol> <li>When JPM is revalidated, SME or Instructor sign and date JPM cover page.</li> </ol>

### LLOJPM0525 Rev000

### Job Performance Measure (JPM)

### **REVISION RECORD (SUMMARY)**

New Revision

### SIMULATOR SETUP INSTRUCTIONS

) Interventions Sum	mary		n se sig									_10
Show Malfunction	ns - 0	Show Remotes -	0 F	lide Qverrid	les • 1	Show J	Annuncketors •	7				PRACE
Override Summary												
Tag ID Descric	xion				Position / T	aget	Actual Value	Qverride Yake	Rmptime	Actime	Dactime	Trig
A/10210 Load Cr	enter 1248 Fee	der Ammeter Indication	0			1906 ta A		54	00:00:03	00-00-00	00.00.00	1

Trigger 1 on Indicating Light 52-10322/CS (114B Breaker Green Lamp on) when 52-10322/CS taken to close.

1 <u>-</u> Z	ED <b>B322G</b>	== (equal to)	False	-
Trigger	Variable Name	Operator		Value
	[manufacture]			

#### **INITIAL CONDITIONS:**

- 1. Shift Manger's Permission has been given to close 480 VAC Tie breaker
- 2. Maintenance has been scheduled for the 114B Reactor Area Load Center
- 3. Load on the 114B Load Center has been minimized by placing alternate trains of components in service

#### **INITIATING CUES:**

Shift Supervision has directed you to supply the 114B Non-Safeguard Load Center from its alternate source 124B Load Center per step 4.6 of S93.7.A

#### TASK STANDARD:

114B load transferred to 124B Load Center then load is restored to 114B Load Center

## LLOJPM0525 Rev000

Job Performance Mea	asure (JP	<u>'M)</u>						
Operator's Name:								
Job Title: 🛛 NLO 🗆 RO 🗆 S	SRO 🗆	STA		SRO Cert				
JPM Title: Supplying Power To A 480 VAC Non-Safeguard Load Center From Its Alternate Source (ALTERNATE PATH)								
JPM Number: LLOJPM0525 Revision Number: 000								
K/A Number and Importance: 262001 A2.10 2.9/3.4								
Suggested Testing Environment: Simulator								
Actual Testing Environment: Simulator								
Testing Method: Perform Faulted: N	Testing Method: Perform Faulted: No							
Alternate Path: Yes								
Time Critical: No								
Estimated Time to Complete: 10 minutes Actual Ti	ime Used:	mii	nutes					
References: S93.7.A, Rev. 22								
<b>EVALUATION SUMMARY:</b> Were all the Critical Elements performed satisfactorily?		Yes		No				
The operator's performance was evaluated against the been determined to be:	standards ] Unsatisfa	contain actory	ed in t	his JPM, and has				
Comments:	,, <u>,,,,,,,,,</u> ,,,,,,,,,,,,,,,,,,,,,							
Evaluator's Name:	(Print)							
Evaluator's Signature:		. D	ate					

.

### LLOJPM0525 REV000

### Job Performance Measure (JPM)

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

## LLOJPM0525 Rev000

## Job Performance Measure (JPM)

JPM Start Time: \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
*1.	PLACE Tie Breaker control switch in "CLOSE" OR (DEPRESS Tie Breaker "CLOSE" pushbutton at load center for TSC load centers 144D/244D only) AND PERFORM the following:	Breaker Control Switch 52- 10342/CS taken to "CLOSE" for 114B 480 Volt Load Center			
*2.	PLACE appropriate Bus Breaker control switch to "OPEN"	Bus Breaker 252-10110/CS placed in "OPEN"			
3.	WHEN Tie Breaker indicates closed, AND Main Breaker indicates tripped, THEN RELEASE Tie Breaker Control switch	Bus Breaker 252-10110/CS released			
	NOTE:Insert Override A	V10210 124B Load Center Ammeter I	ndicatio	n to 54 Am	ps
4.	OBSERVE ammeter associated with Load Center Bus which is now feeding intertied buses	Ammeter for 124B is Checked			
5.	IF 13 KV load exceeds specified amperage values, THEN PERFORM the following:	Recognize load exceeds amperage values			
*5a.	CLOSE opened Bus Breaker	Bus Breaker 252-10110/CS placed in "CLOSE"			
	Remove Override A/1	0210 124B Load Center Ammeter Ind	lication	to 54 Amps	
(Cue:	"You may stop here you have met the termination criteria for this JPM")				

JPM Stop Time \_\_\_\_\_

### **INITIAL CONDITIONS:**

- 1. Shift Manger's Permission has been given to close 480 VAC Tie breaker
- 2. Maintenance has been scheduled for the 114B Reactor Area Load Center
- 3. Load on the 114B Load Center has been minimized by placing alternate trains of components in service

### **INITIATING CUES:**

Shift Supervision has directed you to supply the 114B Non-Safeguard Load Center from its alternate source 124B Load Center per step 4.6 of S93.7.A

Limerick Generating Station					
Job Performance Measure					
START REACTOR RECIRC MG SET (ALTERNATE PATH) JPM Number: 0526					
Revision Number: 000					
	Date://				
Developed By:	Instructor	Date			
Validated By:	SME or Instructor	 Date			
Review By:	Operations Representative	Date			
Approved By:	Training Department	 Date			

### LLOJPM0526 Rev000

### Job Performance Measure (JPM)

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**<u>NOTE:</u>** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

	<ol> <li>Task description and number, JPM description and number are identified.</li> </ol>
	2. Knowledge and Abilities (K/A) references are included.
	<ol><li>Performance location specified. (in-plant, control room, or simulator)</li></ol>
	4. Initial setup conditions are identified.
	5. Initiating and terminating cues are properly identified.
	6. Task standards identified and verified by SME review.
	<ol><li>Critical steps meet the criteria for critical steps and are identified with an asterisk (*).</li></ol>
<u> </u>	<ol> <li>Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev Date</li> </ol>
	<ol> <li>Pilot test the JPM:</li> <li>a. verify cues both verbal and visual are free of conflict, and</li> <li>b. ensure performance time is accurate.</li> </ol>
	<ol> <li>If the JPM cannot be performed as written with proper responses, then revise the JPM.</li> </ol>
<u> </u>	<ol> <li>When JPM is revalidated, SME or Instructor sign and date JPM cover page.</li> </ol>

### LLOJPM0526 REv000

### Job Performance Measure (JPM)

### **REVISION RECORD (Summary)**

New Revision

### SIMULATOR SETUP INSTRUCTIONS:

- 1. Reset Simulator to IC 15
- 2. Ensure that the "1B" RRP shutdown IAW S43.2.A
- 3. Insert the following malfunctions when the MG drivemotor breaker is taken to "START"
  - Insert Malf VIC105A6 0-18 over 1 minute
  - Insert Malf VIC106A3 0-18 over 1 minute
  - Insert Annunciator 111 D-2 RECIRC M-G PUMP MOTOR HI VIBRATION

### TASK STANDARD:

"1B" RRP started then secured due to High Reactor Recirc Pump Vibration

#### **INITIAL CONDITIONS:**

- 1. All Prerequisites of S43.1.A have been completed
- 2. Sections 4.1 of S43.1.A has been completed
- 3. Another Operator is completing ST-6-043-390-\*, Reactor Recirculation Pump Idle Loop Startup Temperature and Flow Check and ST-6-043-390-\*, temperature differential requirements

#### **INITIATING CUES:**

You are directed by shift supervision start the "1B" Reactor Recirc pump in accordance with step 4.2.6 of S43.1.A

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

## LLOJPM0526 Rev000

Job Performance Measure (JPM)	
Operator's Name:	
JPM Title: START REACTOR RECIRC MG SET (ALTERNATE PATH) JPM Number: LLOJPM0526 Revision Number: 000	I
K/A Number and Importance: 202001 A3.02 3.1/3.0	
Suggested Testing Environment: Simulator	
Actual Testing Environment: Simulator	
Testing Method: Perform Faulted: No	
Alternate Path: Yes	
Time Critical: No	
Estimated Time to Complete: 20 minutes Actual Time Used:minutes	
References: S43.1.A, Rev.53	
EVALUATION SUMMARY: Were all the Critical Elements performed satisfactorily?	
The operator's performance was evaluated against the standards contained in this JPM, and been determined to be:	1 has
Comments:	
Evaluator's Name:(Print)	
Evaluator's Signature: Date	

### LLOJPM0526 Rev000

### Job Performance Measure (JPM)

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
*1.	PLACE "Recirc Pp M-G Set Drive Motor Control" (MOTOR), to "START" at *0C602 <u>AND</u> VERIFY the following:	"Recirc Pp M-G Set Drive Motor Control" (MOTOR), taken to "START"			
1a.	XY4-M1-*R621A(B), "Recirc Pp Speed" (S), increases to approximately 100%	XY4-M1-*R621A(B), "Recirc Pp Speed" (S), increases at approximately 100%			
1b.	M-G Field breaker closes approximately 13 seconds after M-G start	M-G Field breaker closed approximately 13 seconds after M-G start			
1c.	B32-*R627A(B), "Generator Current" (AM), rise	B32-*R627A(B), "Generator Current" (AM) rises			
1d.	B32-*R623A(B), "Generator Voltage" (V), rise	B32-*R623A(B), "Generator Voltage" (V), rises			
1e.	PDI-43-*R612A(B), "Recirc Pp Differential Pressure" (DELTA PX), rise	PDI-43-*R612A(B), "Recirc Pp Differential Pressure" (DELTA PX), rose			
1f.	XY5-M1-*R621A(B), "Recirc Pp Speed Demand" (DEMAND), reduces to approximately 20%	XY5-M1-*R621A(B), "Recirc Pp Speed Demand" , at approximately 20%			
1g.	XY4-M1-*R621A(B), "Recirc Pp Speed" (S), reduces to approximately 20%	XY4-M1-*R621A(B), "Recirc Pp Speed" (S), reduces to approximately 20%			

## LLOJPM0526 Rev000

# Job Performance Measure (JPM)

	ELEMENT	ELEMENT STANDARD		UNSAT	Comment Number			
*2a.	JOG OPEN HV-43-*F031A(B), DISCHARGE, at 0C602 for 1 to 2 seconds allowing 5 to 10 seconds for power	HV-43-*F031A(B), DISCHARGE jogged open						
2b.	AND level to stabilize repeating as necessary until the following conditions are met:	N/A .						
2c.	Recirc Pp speed is stable	Recirc Pp speed is stable						
2d. FI-42-*R611A(B), "Total Jet Pump Loop Flow" (FL), is approximately 15 lbs/hr X10E6		FI-42-*R611A(B), "Total Jet Pump Loop Flow" (FL), is approximately 15 lbs/hr X10E6						
(	Insert Malf VIC105B9 0-18 over 1 minute after Discharge Valve is fully open							
	Insert Malf VIC106B1 0	0-18 over 1 minute after Discharge	Valve is	fully open	1			
l II	nsert Annunciator 112 D-2 RE	CIRC M-G PUMP MOTOR HI VIB Discharge Valve is fully open	RATION	1 30 secon	ds after			
	The follo RECIRC	wing actions are from ARC 111 D-2 C M-G PUMP MOTOR HI VIBRATION	2 1A ON					
3.       IF no speed changes on "1B" Recirc Pump were made OR Vibration Monitoring System indicates a problem during a speed change, THEN reduce speed of "1B" Recirc Pump to clear annunciator       Recirc Pump verified to be at minimum speed								
4.	IF annunciator cannot be cleared after reducing flow to the low speed setpoint, THEN secure "1B" Recirc Pump, per S43.2.A	Recognize that the vibration alarm will not clear	S					
	The following actions are from S43.2.A							

## LLOJPM0526 Rev000

## Job Performance Measure (JPM)

	<u>ELEMENT</u>	STANDARD	SA	AT	UNSAT	Cc N	omment umber
5.	ENSURE XC-M1- *R621A(B), "Recirc Pp Speed Controller" (S), set at 0%, at *0C602	XC-M1-*R621A(B), "Recirc Pp Speed Controller" (S), set at 0%,					
*6.	<b>TRIP</b> M-G Drive Motor breaker (MOTOR)	M-G Drive Motor breaker (MOTO) Tripped	२)				
7.	AND VERIFY B32- *R628A(B), "Motor current" (AM), lowers to zero	B32-*R628A(B), "Motor current" (AM), at zero					
*8.	CLOSE HV-43- 1F031A(B), "Recirc Pp Discharge" (DISCHARGE) OR HV-43-1F023A(B), "Recirc Pp Suction" (SUCTION)	HV-43-1F031A(B), "Recirc Pp Discharge" (DISCHARGE) OR HV-43-1F023A(B), "Recirc Pp Suction" (SUCTION) CLOSED					
(CUE	: "You can stop here you have met the termination criteria for this JPM")	N/A					

JPM Stop Time: \_\_\_\_\_

#### **INITIAL CONDITIONS:**

- 1. All Prerequisites of S43.1.A have been completed
- 2. Sections 4.1 of S43.1.A has been completed
- 3. Another Operator is completing ST-6-043-390-\*, Reactor Recirculation Pump Idle Loop Startup Temperature and Flow Check and ST-6-043-390-\*, temperature differential requirements

#### **INITIATING CUES:**

You are directed by shift supervision start the "1B" Reactor Recirc pump in accordance with step 4.2.6 of S43.1.A

Limerick Generating Station					
Job Performance Measure					
T-228 DRYWELL INERTING WITH NITROGEN (ALTERNATE PATH) JPM Number: 0527					
Revision Number: 000					
	Date://				
Developed By:	Instructor	 Date			
Validated By:	SME or Instructor	 Date			
Review By:	Operations Representative	Date			
Approved By:	Training Department	 Date			

### LLOJPM0527 Rev000

### Job Performance Measure (JPM)

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE: All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

1.	Task description and number, JPM description and number are
	identified.

- 2. Knowledge and Abilities (K/A) references are included.
- 3. Performance location specified. (in-plant, control room, or simulator)
- 4. Initial setup conditions are identified.
- 5. Initiating and terminating cues are properly identified.
- 6. Task standards identified and verified by SME review.
- 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- 8. Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. \_\_\_\_ Date \_\_\_\_
- 9. Pilot test the JPM:a. verify cues both verbal and visual are free of conflict, andb. ensure performance time is accurate.
- 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

### LLOJPM0527 Rev000

### Job Performance Measure (JPM)

### **REVISION RECORD (Summary)**

New Revision

### SIMULATOR SETUP INSTRUCTIONS:

- 1. The simulator can be reset to any IC 55 or IC 17 and insert MALF MRR440A and remove when Drywell Pressure is at 25 psig.
- 2. Perform a GP-4 Shutdown.
- 3. Bypass and restore H2O2 analyzer to service.
- 4. Bypass and restore Drywell Cooling.
- 5. Stabilize plant.

Hide Malfunctions -	2 Show <u>Remotes</u> - 0	Show Overrides - 0	Show Annunciators - 0					
alfunction Summary	<u> </u>							
lalf ID Mult ID	Description		Current Value	Target Value	Amptime	Actime	Dactime	Jrig
RM005C	South Stack A Gaseous Rad Monitor Fa	ðs.		4.500e+05	00:00:30	00:01:00	00:00:00	1
rm005F	South Stack B Gaseous Rad Monitor Fa	is .		4.700e+05	00:00:30	00:01:00	00:00:00	1

Activate trigger 1 (HS-57-116 Green Indicating Light Off) when HS-57-116 is opened.

		TT 1 (criva m)	TI I asc	Anna an Anna a Anna an Anna an
Trigger	Variable Name	Operator	۷	alue
	·····	_		
	Accept		<u>C</u> ancel	

#### TASK STANDARD:

Section 4.5 of T-228 is completed to initiate inerting of the drywell with nitrogen.

### **INITIAL CONDITIONS:**

- 1. Drywell inerting is required per T-102, leg DW/G-1
- 2. Drywell pressure is 29 psig and slowly rising
- 3. N<sub>2</sub> makeup is available at a supply pressure of 70 psig
- 4. Primary containment water level is 24.2 ft
- 5. All prerequisites of T-228 are completed
- 6. An Equipment Operator is standing by to support this evolution

### LLOJPM0527 Rev000

### Job Performance Measure (JPM)

#### **INITIATING CUES:**

Shift Supervision directs you to inert the drywell with low flow nitrogen per section 4.5 of T-228, Inerting/Purging Primary Containment

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

# LLOJPM0527 Rev000

~		Job Performance	<u>Measure (JPM)</u>	
	Operator's Name: Job Title:   □	I NLO 🗆 RO 🗆	SRO 🗆 STA	SRO Cert
	JPM Title: T-228 Dryw JPM Number: LI	vell Inerting With Nitrogen (A LOJPM0527	ALTERNATE PATH) Rev	ision Number: 000
	K/A Number and Impo	ortance: 500000 EA1.07 3.4	/ 3.3	
	Suggested Testing E	<b>Invironment</b> : Simulato	r	
	Actual Testing Enviro	onment: Simulator		
	Testing Method:	Perform Fault	ed: No	
	Alternate Path:	Yes		
	Time Critical: No			
_	Estimated Time to Co	omplete: 15 minutes Act	ual Time Used:min	nutes
	References: T-228 R	ev. 20		
	EVALUATION SUMM Were all the Critical El	ARY: lements performed satisfac	torily? 🛛 Yes	🗆 No
	The operator's perform been determined to be	nance was evaluated again e:	st the standards contain ☐ Unsatisfactory	ed in this JPM, and has
	Comments:			
	Evaluator's Name:		(Print)	
~	Zevaluator's Signature:	: 	Date _	

## LLOJPM0527 Rev000

## Job Performance Measure (JPM)

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: \_\_\_\_\_

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1.	<b>DIRECT</b> dose assessment personnel to monitor offsite release	Dose Assessment personnel contacted			
(Cue:	RP is performing offsite dose Assessment)				
2.	<b>ENSURE</b> N <sub>2</sub> makeup available <u>AND</u> N <sub>2</sub> supply lined up for low flow service per S57.8.A, Placing Or Removing Liquid N <sub>2</sub> Vaporizer System In (From) Service and Changing Flow Modes.	Recognize condition met from initial conditions			
3.	IF Drywell pressure is greater than Nitrogen Supply pressure, THEN RAISE setpoint of PC-X-IE-002, "Low Flow N <sub>2</sub> Supply Pressure Controller," to a value greater than Drywell Pressure but less than 75 psig.	N/A			
4.	<b>ENSURE</b> SSVN is informed that H <sub>2</sub> /O <sub>2</sub> Analyzers will be placed in STANDBY <u>AND</u> that Hydrogen readings will <u>not</u> be available	CRS is told that H <sub>2</sub> /O <sub>2</sub> analyzers will be placed in STANDBY and H <sub>2</sub> readings will not be available			
5.	<b>PLACE</b> HSS-57-196, " $H_2/O_2$ Analyzer 10S206," in "STANDBY" at 10C600 (Main Control Room)	HSS-57-196 is placed in STANDBY			

## LLOJPM0527 Rev000

# Job Performance Measure (JPM)

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
6.	<b>PLACE</b> HSS-57-126, "H <sub>2</sub> /O <sub>2</sub> Analyzer 10S205," in "STANDBY" at 10C600 (Main Control Room).	HSS-57-126 is placed in STANDBY			
7.	PLACE HS-57-153, "Drywell Isolation," to "CLOSE" at 10C601 (Main Control Room).	HS-57-153 is placed in CLOSE			
8.	PLACE HS-57-187, "Supp Pool Isolation," to "CLOSE" at 10C601 (Main Control Room).	HS-57-187 is placed in CLOSE			
9.	PLACE HS-57-183, "Supp Pool Isolation" to "CLOSE" at 10C601 (Main Control Room).	HS-57-183 is placed in CLOSE			
*10.	<b>OPEN</b> HV-57-111, DRYWELL EXH BYPASS INBD, at 10C601 (Main Control Room).	HV-57-111 is opened			
*11.	PLACE HV-57-117, TO RX ENCL FILTER OUTBD, in "AUTO" <u>AND</u> VERIFY HV-57-117 opens at 10C601 (Main Control Room).	HV-57-117 is placed in AUTO and HV-57-117 is verified to open			
*12.	<b>OPEN</b> HV-57-116, $N_2$ MAKE-UP <u>AND</u> VERIFY $N_2$ flow on XR-57-119, "Nitrogen Purge," (red pen).	HV-57-116 is opened, and nitrogen flow is verified on XR-57-119.			
13.	MONITOR PI-57-121, "Drywell Pressure" (Px (NR)), <u>AND</u> PMS 057 DRYWELL PRESSURE	PI-57-121 is monitored			

### LLOJPM0527 Rev000

# Job Performance Measure (JPM)

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
14.	THROTTLE HV-57-116, N <sub>2</sub> MAKE-UP, to maintain desired Drywell pressure	HV-57-116 is throttled as required				
In	Insert Malf MRM005C and MRM005F (or Trigger 1) for South Stack Radiation Monitor failure upscale					
15.	Recognize South Stack Radiation Monitor Hi-Hi alarm and take action to manually isolate the drywell vent path	The drywell inerting flowpath is manually isolated				
	NOTE: The following are Actions from the ARC 003 RAD F1					
15a.	Perform ST-6-104-880-1	N/A				
(Cue:	Another operator is performing ST-6-104-880- 1)					
15b.	Perform RMMS 402	N/A				
(Cue:	Another operator is performing ST-6-104-880- 1)					
*15c.	CLOSE HV-57-117, TO RX ENCL FILTER OUTBD	HV-57-117, TO RX ENCL FILTER OUTBD, in "CLOSE"				
*15d.	OPEN HV-57-111, DRYWELL EXH BYPASS INBD	HV-57-111, DRYWELL EXH BYPASS INBD, in OPEN				
(CUE:	"You can stop here. You have met the termination criteria for this JPM.")	N/A				

JPM Stop Time: \_\_\_\_\_

#### ─ INITIAL CONDITIONS:

- 1. Drywell inerting is required per T-102, leg DW/G-1
- 2. Drywell pressure is 29 psig and slowly rising
- 3. N<sub>2</sub> makeup is available at a supply pressure of 70 psig
- 4. Primary containment water level is 24.2 ft
- 5. All prerequisites of T-228 are completed
- 6. An Equipment Operator is standing by to support this evolution

#### **INITIATING CUES:**

Shift Supervision directs you to inert the drywell with low flow nitrogen per section 4.5 of T-228, Inerting/Purging Primary Containment

Limerick Generating Station				
Job Performance Measure				
BYPASSING AND REMOVING THE *A RPS AND UPS STATIC INVERTER FROM SERVICE				
JPM Number: 0203				
Revision Number: 003				
	Date://			
Developed By:	Instructor	 Date		
Validated By:	SME or Instructor	 Date		
Review By:	Operations Representative	Date		
Approved By:	Training Department	Date		

### LLOJPM0203 Rev003

### Job Performance Measure (JPM)

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

	<ol> <li>Task description and number, JPM description and number are identified.</li> </ol>
	2. Knowledge and Abilities (K/A) references are included.
	<ol><li>Performance location specified. (in-plant, control room, or simulator)</li></ol>
	4. Initial setup conditions are identified.
	5. Initiating and terminating cues are properly identified.
<u>.                                </u>	6. Task standards identified and verified by SME review.
	<ol> <li>Critical steps meet the criteria for critical steps and are identified with an asterisk (*).</li> </ol>
	<ol> <li>Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev Date</li> </ol>
	<ol> <li>Pilot test the JPM:</li> <li>a. verify cues both verbal and visual are free of conflict, and</li> <li>b. ensure performance time is accurate.</li> </ol>
	<ol> <li>If the JPM cannot be performed as written with proper responses, then revise the JPM.</li> </ol>
	<ol> <li>When JPM is revalidated, SME or Instructor sign and date JPM cover page.</li> </ol>
## LLOJPM0203 Rev003

#### Job Performance Measure (JPM)

#### **REVISION RECORD (Summary)**

Revision 003, This revision is a complete rewrite no Revision bars used

#### SIMULATOR SETUP INSTRUCTIONS:

None

#### TASK STANDARD:

\*A RPS/UPS Static Inverter Bypassed and Removed from Service

#### **INITIAL CONDITIONS:**

1. \*A RPS and UPS Static Inverter is in Service

#### **INITIATING CUES:**

You are directed by shift supervision to bypass the \*A RPS/USP static inverter and remove it from service per S94.2.A.

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

# LLOJPM0203 Rev003

Job Performance Measure (JPM)	
Operator's Name:	
JPM Title: BYPASSING AND REMOVING THE *A RPS AND UPS STATIC INVERTER FRO SERVICE JPM Number:LLOJPM0203 Revision Number:003	M
K/A Number and Importance: 262002 K6.02 2.8/3.1	
Suggested Testing Environment: Plant	
Actual Testing Environment: Plant	
Testing Method: Simulate Faulted: No	
Alternate Path: No	
Time Critical: No	
Estimated Time to Complete: 20 minutes Actual Time Used:minutes	
References: S94.2A, Rev.13	
<b>EVALUATION SUMMARY:</b> Were all the Critical Elements performed satisfactorily?	
The operator's performance was evaluated against the standards contained in this JPM, and been determined to be:	d has
Comments:	
Evaluator's Name:(Print)	
Evaluator's Signature: Date	
LLOJPM0203 Rev003 Page 4 of 1	1

## LLOJPM0203 Rev003

# Job Performance Measure (JPM)

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: \_\_\_\_\_

ſ		ELEMENT	STANDARD	SAT	UNSAT	Comment Number
	1.	VERIFY ALT. AVAIL. yellow indicating light Lit.	ALT. AVAIL. yellow indicating light Lit.			
	(CUE:	"ALT. AVAIL. yellow indicating light Lit")				
	2.	VERIFY SYNC REF. AVAIL. yellow indicating light Lit.	SYNC REF. AVAIL. yellow indicating light Lit.			
	(CUE:	"SYNC REF. AVAIL. yellow indicating light Lit.")				
1	3.	<b>VERIFY</b> SYNC FAIL SYNC MONITOR red alarm light <u>not</u> Lit.	SYNC FAIL SYNC MONITOR red alarm light <u>not</u> Lit			
	(CUE:	"SYNC FAIL SYNC MONITOR red alarm light <u>not</u> Lit.")				
	*4.	PLACE TEST TRANSFER switch to "MAN" <u>AND</u> VERIFY the following:	TEST TRANSFER switch in "MAN"			
	(CUE:	"TEST TRANSFER switch in "MAN"				
	4a. (	DN ALTERNATE red indicating light comes on	ON ALTERNATE red indicating light on			
	(CUE:	"ON ALTERNATE red indicating light on.")				
	4b.	ON INVERTER green indicating light goes off	ON INVERTER green indicating light off			
	(CUE:	"ON INVERTER green indicating light off.")				

# LLOJPM0203 REV003

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
4c.	DC AMPS ammeter decreases to approximately 5 amps	DC AMPS ammeter approximately 5 amps			
(CUE:	"DC AMPS ammeter approximately 5 amps.")				
*5a.	PLACE BYPASS SWITCH to BYPASS position at *0NAD160	BYPASS SWITCH in BYPASS			
(CUE:	"BYPASS SWITCH in BYPASS.")				
5b.	AND VERIFY ATS BYPASSED red light comes on	ATS BYPASSED red light on			
(CUE:	"ATS BYPASSED red light on.")				
*6a.	PLACE TEST TRANSFER SWITCH to "AUTO" to transfer Static Switch from Alternate Source to Inverter AND	TEST TRANSFER SWITCH in "AUTO"			
(CUE:	"TEST TRANSFER SWITCH in "AUTO".")				
6b.	<b>VERIFY</b> the following steps occur within approximately 5 seconds:	N/A			
7.	ON INVERTER green indicating light comes on	ON INVERTER green indicating light on			
(CUE:	"ON INVERTER green indicating light on.")				

## LLOJPM0203 Rev003

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
8.	ON ALTERNATE red indicating light goes off	ON ALTERNATE red indicating light off			
(CUE:	"ON ALTERNATE red indicating light off.")				
*9.	PLACE ISOLATION SWITCH to "OPEN" position at *0NAD160, <u>AND</u> VERIFY the following:	ISOLATION SWITCH in "OPEN" position			
(CUE:	"ISOLATION SWITCH in "OPEN" position.")				
9a.	ALT. AVAIL. yellow indicating light goes off	ALT. AVAIL. yellow indicating light off			
1 (CUE:	"ALT. AVAIL. yellow indicating light off.")				
9b.	ALT. LOW VOLTS red alarm light comes on	ALT. LOW VOLTS red alarm light on			
(CUE:	"ALT. LOW VOLTS red alarm light on.")				
9c.	SYNC. REF. AVAIL. yellow indicating light goes off	SYNC. REF. AVAIL. yellow indicating light off			
(CUE:	"SYNC. REF. AVAIL. yellow indicating light off.")				
9d.	SYNC FAIL SYNC MONITOR red alarm light comes on	SYNC FAIL SYNC MONITOR red alarm light on			
(CUE:	"SYNC FAIL SYNC MONITOR red alarm light on.")				

## LLOJPM0203 Rev003

	ELEMENT	<u>STANDARD</u>	SAT	UNSAT	Comment Number
9e.	ALT. VOLTS voltmeter goes to 0 volts	ALT. VOLTS voltmeter at 0 volts			
(CUE	: "ALT. VOLTS voltmeter at 0 volts.")				
*10.	DEPRESS AND RELEASE INVERTER STOP red pushbutton AND VERIFY the following:	INVERTER STOP red pushbutton Depressed <u>and</u> Released			
(CUE	: "INVERTER STOP red pushbutton Depressed <u>and</u> Released.")				
10a.	INV. VOLTS meter goes to 0 volts	INV. VOLTS meter 0 volts			
(CUE	: "INV. VOLTS meter 0 volts.")				
10b.	INV. FREQUENCY meter drops to far left	INV. FREQUENCY meter at far left			
(CUE	"INV. FREQUENCY meter at far left.")			-	
10c.	Inverter cooling fans shut off as indicated by FAN FAIL red alarm light on <u>AND</u> <u>no</u> air flow from top rear of inverter	FAN FAIL Red light on and Inverter cooling fans off			
(CUE	: "FAN FAIL red alarm light on no air flow from top rear of Inverter")				

## LLOJPM0203 Rev003

	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
10d.	SYNC FAIL SYNC MONITOR red alarm light goes off	SYNC FAIL SYNC MONITOR red alarm light off			
(CUE	: "SYNC FAIL SYNC MONITOR red alarm light off.")				
10e.	OUTPUT LOW VOLTS red alarm light comes on after approximately 10 seconds	OUTPUT LOW VOLTS red alarm light comes on			
(CUE	: "OUTPUT LOW VOLTS red alarm light comes on")				
*11.	<b>OPEN</b> Inverter DC INPUT breaker	Inverter DC INPUT breaker Open			
(CUE	: "Inverter DC INPUT breaker Open.")				
*12.	PLACE PRECHARGE/ DISCHARGE toggle switch to "DISCHARGE" position <u>AND</u> VERIFY the following:	PLACE PRECHARGE/ DISCHARGE toggle switch in "DISCHARGE"			
(CUE	: " <b>PLACE</b> PRECHARGE/ DISCHARGE toggle switch in "DISCHARGE")				
12a.	CHARGED green indicating light goes off	CHARGED green indicating light off			
(CUE	: "CHARGED green indicating light off.")				

## LLOJPM0203 Rev003

## Job Performance Measure (JPM)

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number
12b.	DC VOLTS meter decreases to 0 volts	DC VOLTS meter at 0 volts			
(CUE:	"DC VOLTS meter at 0 volts.")				
12c.	DC AMPS meter decreases to 0 amps	DC AMPS meter decreases to 0 amps			
(CUE:	"DC AMPS meter decreases to 0 amps")				
12d.	All remaining indicating lights go off.	All remaining indicating lights off.			
(CUE:	: "All remaining indicating lights off. ")				
*13.	OPEN breaker 72- 20120 (*DA-20), at 250 VDC MCC *0D201 (*DA) (304-R11-217 for Unit 1, 370-R18-217 for Unit 2), to remove voltage to Inverter DC INPUT breaker	Breaker 72-20120 (*DA-20), at 250 VDC MCC *0D201 (*DA) (304-R11- 217 for Unit 1, 370-R18-217 for Unit 2) OPEN			
(CUE:	: "Breaker 72-20120 (*DA-20), at 250 VDC MCC *0D201 (*DA) (304-R11-217 for Unit 1, 370-R18-217 for Unit 2) OPEN.")				
(CUE	: "You have met the termination criteria for the JPM. You may stop here.")	N/A			

JPM Stop Time: \_\_\_\_\_

#### **INITIAL CONDITIONS:**

1. \*A RPS and UPS Static Inverter is in Service.

#### **INITIATING CUES:**

You are directed by shift supervision to bypass the \*A RPS/USP static inverter and remove it from service per S94.2.A.

	ิลแบท			
Job Performance Mea	sure			
VERTENT OPENING OF A REI	LIEF VALVE			
JPM Number: LLOJPM020	14			
Revision Number: 006				
Date:				
Instructor	Date			
SME or Instructor	Date			
Operations Representative	Date			
Training Department	Date			
	Job Performance Measure VERTENT OPENING OF A REL JPM Number: LLOJPM020 Revision Number: 006 Date: Instructor SME or Instructor Operations Representative Training Department			

## LLOJPM0204 Rev006

#### Job Performance Measure (JPM)

#### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

- 1. Task description and number, JPM description and number are identified.
- 2. Knowledge and Abilities (K/A) references are included.
- 3. Performance location specified. (in-plant, control room, or simulator)
- 4. Initial setup conditions are identified.
- 5. Initiating and terminating cues are properly identified.
- 6. Task standards identified and verified by SME review.
- 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev. \_\_\_\_ Date \_\_\_\_\_
- Pilot test the JPM:
   a. verify cues both verbal and visual are free of conflict, and
   b. ensure performance time is accurate.
- 10. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- 11. When JPM is revalidated, SME or Instructor sign and date JPM cover page.

## LLOJPM0204 Rev006

## Job Performance Measure (JPM)

#### **Revision Record (Summary)**

1. Revision 006, Changed rev. no. of OT-114 to Rev. 24. Verified steps accurate IAW rev. 23 of OT-114. Step 1 removed (obtain a current copy of the procedure)

#### INITIAL CONDITIONS:

- 1. LGS Unit \_\_\_\_ is in OPCON 3
- 2. PSV-41-\*F013E is confirmed stuck open

#### INITIATING CUE:

You are directed by Shift Supervision to pull fuses for PSV-41-\*F013E in accordance with OT-114.

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

## LLOJPM0204 Rev006

Operator's Name: _		···						·
Job Title:		🗆 RO		SRO		STA		SRO Cert
JPM Title: JPM Number:	Inadvertent ( LLOJPM020	Opening of 4	a Relief \	/alve Re	evision	ı Numb	er: 0(	06
K/A Number and Im	portance: 23	9002A2.03	4.1/4.2					
Suggested Testing	Environme	nt: Pla	nt					
Actual Testin	ng Environm	ient: Pla	nt					
Testing Method:	Simulate		Faulted:	No	)			
Alternate Path:	No							
Time Critical: N	0							
Estimated Time to	Complete: 1	0 minutes	Actual	Time U	sed: _	mir	nutes	
References: OT-11	4, Rev. 24, lı	nadvertent	Opening	of a Rel	lief Va	lve		
EVALUATION SUM Were all the Critical	MARY: Elements pe	rformed sa	tisfactoril	y?		Yes		No
The operator's perform determined to be:	nance was eva	luated again Satisfactory	st the stand	dards co □ Un	ntained satisfac	l in this ctory	JPM, a	nd has been
Comments:								_
••••••••••••••••••••••••••••••••••••••				·····				_
······································								
							<del>_</del>	
Evaluator's Name: _				(Pr	rint)			
Evaluator's Signatur	e:		·			Date:		
LLOJPM0204 Rev006	}							Page 4 of 8

#### LLOJPM0204 Rev006

## Job Performance Measure (JPM)

TASK STANDARD: "1E" SRV fuses simulated removed per OT-114

JPM Start Time: \_\_\_\_\_

	<u>2ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1	. Obtain Fuse Pullers	Fuse pullers in hand			
N	OTE: The operator can obtain fuse puller from a variety of locations. Most likely location is the MCR PRO's desk.				
(C	CUE: Once operator demonstrates ability to obtain fuse pullers, say "You have obtained fuse pullers.")				
	OTE: Steps 2 – 5 are to be completed when ompleted when performing this JPM on Unit	performing this JPM on U 2.	Jnit 1.	Steps 6 –	9 are to be
*2	. UNIT 1 ONLY	Fuse AA-F8 B21C-F3E			
	<b>PULL</b> Fuse AA-F8 B21C-F3E at panel 10C628	at panel 10C628 removed			
(C	Cue: "Fuse is pulled")				
*3	. UNIT 1 ONLY	Fuse AA-F9 B21C-F4E			
	<b>PULL</b> Fuse AA-F9 B21C-F4E at panel 10C628	at panel 10C628 removed			
(C	Cue: "Fuse is pulled")				
*4	UNIT 1 ONLY	Fuse AA-F7 B21C-F7E			
	PULL Fuse AA-F7 B21C-F7E at panel       at panel 10C631         10C631       removed				
(C	Cue: "Fuse is pulled")				

## LLOJPM0204 Rev006

JOD Penjorm	ance measure (JPM)			
<u>2ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*5. UNIT 1 ONLY PULL Fuse AA-F8 B21C-F8E at panel 10C631	Fuse AA-F8 B21C-F8E at panel 10C631 removed			
(Cue: "Fuse is pulled") (Cue: After all four fuses have been removed, tell operator "You have met the termination criteria for this JPM. You can stop here.")				
*6. UNIT 2 ONLY PULL Fuse 20-C628/B21C-F3E at panel 20C628	Fuse 20-C628/B21C- F3E at panel 20C628 removed			
(Cue: "Fuse is pulled")				
*7. UNIT 2 ONLY PULL Fuse 20-C628/B21C-F4E at panel 20C628	Fuse 20-C628/B21C- F4E at panel 20C628 removed			
(Cue: "Fuse is pulled")				
*8. UNIT 2 ONLY PULL Fuse 20-C631/B21C-F7E at panel 20C631	Fuse 20-C631/B21C- F7E at panel 20C631 removed			
(Cue: "Fuse is pulled")				

#### nee Meesure ( IDM)

### LLOJPM0204 Rev006

<u>Job Perform</u>	<u>ance Measure (JPM)</u>			
<u>2ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
<ul> <li>*9. UNIT 2 ONLY <ul> <li>PULL Fuse 20-C631/B21C-F8E at panel 20C631</li> </ul> </li> <li>(Cue: "Fuse is pulled")</li> <li>(Cue: After all four fuses have been removed, tell operator "You have met the termination criteria for this JPM. You can</li> </ul>	Fuse 20-C631/B21C- F8E at panel 20C631 removed			
stop here.")	I			

JPM Stop Time: \_\_\_\_\_

#### **INITIAL CONDITIONS:**

- 1. LGS Unit \_\_\_\_ is in OPCON 3
- 2. PSV-41-\*F013E is confirmed stuck open

#### INITIATING CUE:

You are directed by Shift Supervision to pull fuses for PSV-41-\*F013E in accordance with OT-114.



Inside of panel 10C628 Fuses: AA-F8 B21C-F3E AA-F9 B21C-F4E





# Inside of panel 10C631 Fuses: AA-F7 B21C-F7E AA-F8 B21C-F8E



Limerick Generating Station							
	Job Performance Measure						
SCRAM DISCHARGE VOLUME DRAINING (T-217)							
JPM Number: 0211 Revision Number: 007 Date://							
Developed By:	Instructor	 Date					
Validated By:	SME or Instructor	 Date					
Review By:	Operations Representative	 Date					
Approved By:	Training Department	 Date					

## **EXELON NUCLEAR**

## LLOJPM0211 Rev007

#### JOB PERFORMANCE MEASURE (JPM)

#### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 8 through 11 below.

 <ol> <li>Task description and number, JPM description and number are identified.</li> </ol>
 2. Knowledge and Abilities (K/A) references are included.
 <ol><li>Performance location specified. (in-plant, control room, or simulator)</li></ol>
 4. Initial setup conditions are identified.
 5. Initiating and terminating cues are properly identified.
 6. Task standards identified and verified by SME review.
 <ol> <li>Critical steps meet the criteria for critical steps and are identified with an asterisk (*).</li> </ol>
 <ol> <li>Verify the procedure referenced by this JPM matches the most current revision of that procedure: Procedure Rev Date</li> </ol>
 <ol> <li>Pilot test the JPM:</li> <li>a. verify cues both verbal and visual are free of conflict, and</li> <li>b. ensure performance time is accurate.</li> </ol>
 <ol> <li>If the JPM cannot be performed as written with proper responses, then revise the JPM.</li> </ol>
 <ol> <li>When JPM is revalidated, SME or Instructor sign and date JPM cover page.</li> </ol>

## **EXELON NUCLEAR**

## LLOJPM0211 Rev007

#### JOB PERFORMANCE MEASURE (JPM)

#### **Revision Record (Summary)**

 Complete Rewrite. No rev bars used. Revision changes JPM to new format and changes were made to ensure JPM Matches Revision 19 of T-217 U/1 and Revision 18 of T-217 U/2. Initiating Cue was revised to include step number to be preformed to clearly define the task to be accomplished.

#### SIMULATOR SETUP INSTRUCTIONS:

None

#### TASK CONDITIONS:

- 1. Scram signal exists on Unit \_\_\_\_\_ and 15 Control Rods are at various withdrawn positions
- 2. T-217 has been completed up to and including step 4.1.10
- 3. T-215 and T-216 have not been performed

#### **INITIATING CUES:**

You are directed by Shift Supervision to drain the Unit \_\_\_\_\_ Scram Discharge Volume until the SDV level switches indicate less than 62% per step 4.1.11 of T-217.

#### TASK STANDARD(S):

Scram Discharge Volume Draining

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes CRITICAL steps.

Number any comments in the "Comment Number" column. Then annotate that comment in the "Comments" section. The comment section should be used to document the reason that a step is marked as unsatisfactory and to document unsatisfactory performance relating to management expectations.

## **EXELON NUCLEAR**

## LLOJPM0211 Rev007

#### JOB PERFORMANCE MEASURE (JPM)

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

# EXELON NUCLEAR

## LLOJPM0211 Rev007

#### JOB PERFORMANCE MEASURE (JPM)

TITLE: Scram Discharge Volume Draining (T-217)								
Operator's Name: Job Title:	NLO	□ RO		SRO		STA		SRO Cert
JPM Title: So JPM Number: LL	cram Disch _OJPM021	arge Volun 1	ne Draini	ng (T-2	17) Revis	ion Nu	mber:	007
K/A Number and Impo	rtance:	295015AA	.1.01 3	8/3.9				
Suggested Testing E	nvironme	nt: Pla	nt					
Actual Testing	Environm	ent: Pla	nt					
Testing Method:	Perform	I	aulted:	No	D			
Alternate Path:	No							
Time Critical: No								
Estimated Time to Co	omplete: 3	0 minutes	Actual	Time L	Jsed:	_ m	inutes	
References: Unit 1, T-:	217, Rev. 1	9. Unit 2, Re	v. 18					
EVALUATION SUMM	EVALUATION SUMMARY: Were all the Critical Elements performed satisfactorily?  Yes No							
The operator's performance was evaluated against the standards contained in this JPM, and has been determined to be:								
Comments:								
	•••••							-
Evaluator's Name:(Print)								
Evaluator's Signature: Date:								

LLOJPM0211 Rev007

## EXELON NUCLEAR

## LLOJPM0211 Rev007

#### JOB PERFORMANCE MEASURE (JPM)

Critical Element(s) indicated by "\*" in Performance Checklist.

PERFORMANCE CHECKLIST:

JPM Start Time: \_\_\_\_\_

	ELEMENT	STANDARD	SAT	UNSAT	Comment Number			
NOTE				<u></u>				
	IF this JPM is the first of multiple T-200 series JPMs being performed by a single candidate							
	THEN steps #1 and #2 apply.							
	OTHERWISE mark steps #1 and #2 as N/A							
	AND provide the following to the candidate :							
	a. INITIATING CUE(S)							
1	b. CUE: "You are now in possession of the T-217 equipment container. It contains all tools and equipment required by the procedure. You are to simulate their use during performance of the procedure."							
1.	Obtain current revision of T-217	Current revision of T-217						
Cue:	Provide a copy of T-217.	obtained.						
*2.	The following tools, equipment obtained from Unit * T-200 Hose	(2) 10' Hoses with Swagelok Fittings						
	(580-R17-283)(Attachment 1) BL-840 key required:	(1) Flashlight obtained from Unit * T-200 Hose Storage Cabinet (506-R16-283) (Attachment 1)						
	(2) 10' Hoses with Swagelok Fittings							
	(1) Flashlight							
Cue:	You have two hoses and a flashlight.	Note: only 1 flashlight is needed						

## EXELON NUCLEAR

#### LLOJPM0211 Rev007

## JOB PERFORMANCE MEASURE (JPM)

ELEMENT		STANDARD	SAT	UNSAT	Comment Number
3.	PERFORM the following for 47- *F103A, Drain Valve (402B-R16- 253) (475-R18-253),	N/A			
*3a.	UNLOCK AND ENSURE closed.	47-*F103A unlocked and closed			
Cue:	47-*F103A unlocked and closed.				
3b.	<u>AND</u> 47-*F103B, Drain Valve (402A-R15-253) (475-R17-253) (Attachment 6):				
*3.c	Unlock AND ENSURE closed.	47-*F103B unlocked and closed			
Cue:	47-*F103B unlocked and closed.				
*4.	CONNECT approx. 10 feet of drain hose to each	Approx. 10 feet of drain hose connected to 47-*F103B.			
Cue:	Hose connected at swagelock fitting.				
*5.	DIRECT other end of hose(s) to nearest clean radwaste cleanout with Swagelok fitting. (Attachment 6)	Other end of hoses connected to radwaste cleanout with Swagelock fittings.			
Cue:	Hose connected to swagelock fitting for CRW.				
6.	NOTIFY MCR AND	MCR notified that draining will			
Cue:	I understand that you are ready to commence draining.	commence.			
*8.	slowly OPEN 47-*F103A AND	47-*F103A OPENED SLOWLY			
*8a.	47-*F103B to establish drain flow.	47-*F103B OPENED SLOWLY			
Cue:	Water is draining through the hoses				

# EXELON NUCLEAR

## LLOJPM0211 Rev007

#### JOB PERFORMANCE MEASURE (JPM)

9.	WHEN LISH-47-*N601A, B, C, D <u>all</u> indicate less than 62% at *0C609/*0C611 (Aux Equip Room), <u>THEN</u> GO TO Section 4.2.	Contact the EO in the AER and request LISH-47-*N601A, B, C, and D indication.		
Cue:	When contacted, report as the EO in the AER that LISH-47- *N601A, B, C, and D indicate 50% and are decreasing.			
Cue:	You have met the termination criteria for the JPM. You may stop here.	N/A		

JPM Stop Time: \_\_\_\_\_

## LLOJPM0211 Rev007

## Job Performance Measure (JPM)

#### TASK CONDITIONS:

- 1. Scram signal exists on Unit \_\_\_\_ and 15 Control Rods are at various withdrawn positions
- 2. T-217 has been completed up to and including step 4.1.10
- 3. T-215 and T-216 have not been performed

#### **INITIATING CUES:**

You are directed by Shift Supervision to drain the Unit \_\_\_\_\_ Scram Discharge Volume until the SDV level switches indicate less than 62% per step 4.1.11 of T-217.