

From: Kathleen O'Donohue, R2
To: Charlie Payne
Date: 3/3/04 7:07AM
Subject: Re: Fwd: Your NFPA member newsletter for March

Thanks for that - listen - have you heard about the manual action criteria being recommended for forward fit only ? Apparently they (SUNIL OR RES) seem to think that inadequate manual actions will be identified within the ROP process. Which - in my opinion would be too late because with out the criteria to be measured against the only other way we will find out there was a problem is for the manual action to fail when needed (ie a real substantial fire) and then we could very well be looking at a damaged core or worse.

This seems to be the recommendation - I have not found the draft saying that yet - Eva sent me a bunch of stuff Friday

This causes me great concern, what do you think? I believe we need to be pro-active on this before it becomes real but I don't want to go off half informed . Any suggestions? I am at 423-365-7702 or at the residents office

Later

Me

4-18

(19)

Mail Envelope Properties (4045CA89.650 : 24 : 51615)

Subject: Re: Fwd: Your NFPA member newsletter for March
Creation Date: 3/3/04 7:07AM
From: Kathleen O'Donohue

Created By: KFO@nrc.gov

Recipients

nrc.gov

ATL_PO.ATL_DO

DCP (Charlie Payne)

Post Office

ATL_PO.ATL_DO

Route

nrc.gov

Files

MESSAGE

Size

1637

Date & Time

03/03/04 07:07AM

Options

Expiration Date:

None

Priority:

Standard

Reply Requested:

No

Return Notification:

None

Concealed Subject:

No

Security:

Standard