

**ACTIONS (continued)**

CONDITION	REQUIRED ACTION	COMPLETION TIME
D. Required Action and associated Completion Time of Condition C not met.	D.1 Enter the Condition referenced in Table 3.3.3.1-1 for the channel.	Immediately
E. As required by Required Action D.1 and referenced in Table 3.3.3.1-1.	E.1 Be in MODE 3.	12 hours
F. As required by Required Action D.1 and referenced in Table 3.3.3.1-1.	F.1 Initiate action in accordance with Specification 5.6.6.	Immediately

**SURVEILLANCE REQUIREMENTS**

-----NOTE-----  
These SRs apply to each Function in Table 3.3.3.1-1.  
-----

SURVEILLANCE	FREQUENCY
SR 3.3.3.1.1 Perform CHANNEL CHECK.	31 days
SR 3.3.3.1.2 (Not Used.)	

(continued)

**SURVEILLANCE REQUIREMENTS (continued)**

SURVEILLANCE		FREQUENCY
SR 3.3.3.1.3	Perform CHANNEL CALIBRATION for each required PAM Instrumentation channel.	24 months

Table 3.3.3.1-1 (page 1 of 1)  
Post Accident Monitoring Instrumentation

FUNCTION	REQUIRED CHANNELS	CONDITIONS REFERENCED FROM REQUIRED ACTION D.1
1. Reactor Vessel Pressure	2	E
2. Reactor Vessel Water Level		
a. -150 inches to +150 inches	2	E
b. 0 inches to +210 inches	2	E
c. +150 inches to +550 inches	2	E
3. Suppression Chamber Water Level	2	E
4. Suppression Chamber Water Temperature	2	E
5. Suppression Chamber Pressure	2	E
6. Drywell Pressure	2	E
7. Drywell Temperature	2	E
8. PCIV Position	2 per penetration flow path <sup>(a)(b)</sup>	E
9. (Not Used.)		
10. Drywell Area Radiation	2	F

(a) Not required for isolation valves whose associated penetration flow path is isolated by at least one closed and deactivated automatic valve, closed manual valve, blind flange, or check valve with flow through the valve secured.

(b) Only one position indication channel is required for penetration flow paths with only one installed control room indication channel.