



444 South 16th Street Mall
Omaha NE 68102-2247

February 11, 2005
LIC-05-0003

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001


Reference: Docket No. 50-285

SUBJECT: January 2005 Monthly Operating Report (MOR)

Pursuant to Fort Calhoun Station (FCS) Unit No. 1 Technical Specification 5.9.1.c, Omaha Public Power District (OPPD) submits the attached MOR for January 2005. No commitments are made to the NRC in this letter.

If you have any questions, please contact Mr. Erick Matzke at (402) 533-6855.

Sincerely,



J. B. Herman
Licensing Manager

JBH/EPM/epm

Attachment

OPERATING DATA REPORT

DOCKET NO. 50-285
UNIT NAME **Fort Calhoun Station**
DATE February 1, 2005
COMPLETED BY E. P. Matzke
TELEPHONE (402) 533-6855

REPORT PERIOD: January 2005

Design Electrical Rating (MWe-Net): 478
Maximum Dependable Capacity (MWe-Net): 478

	<u>MONTH</u>	<u>YR-TO- DATE</u>	<u>CUMULATIVE</u>
Number of Hours Reactor was Critical:	744.0	744.0	224131.5
Number of Hours Generator was On-line:	744.0	744.0	222772.3
Unit Reserve Shutdown Hours:			
Net Electrical Energy Generated (MWh):	363921.3	363921.3	96961320.7

UNIT SHUTDOWNS

No.	Date (yy/mm/dd)	Type F: Forced S: Scheduled	Duration (Hours)	Reason ¹	Method of Shutting Down Reactor ²	Cause & Corrective Action Comments

(1) Reason:

- A-Equipment Failure (Explain)
- B-Maintenance or Test
- C-Refueling
- D-Regulatory Restriction
- E-Operator Training/License Examination
- F-Administrative
- G-Operational Error (Explain)
- H-Other (Explain)

(2) Method:

- 1-Manual
- 2-Manual Trip/Scram
- 3-Automatic Trip/Scram
- 4-Continuation
- 5-Other (Explain)

OPERATIONS SUMMARY

Fort Calhoun Station operated at a nominal 100 percent power for the of the month of January.