

February 17, 2005

NOTE TO: File

FROM: Richard L. Emch, Jr., Senior Project Manager /RA/  
Environmental Section  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

SUBJECT: DOCKETING OF DRAFT REQUEST FOR ADDITIONAL INFORMATION  
REGARDING SEVERE ACCIDENT MITIGATION ALTERNATIVES ANALYSIS  
IN SUPPORT OF THE ENVIRONMENTAL REVIEW OF CAROLINA POWER &  
LIGHT COMPANY'S LICENSE RENEWAL APPLICATION FOR BRUNSWICK  
STEAM ELECTRIC PLANT, UNITS 1 AND 2

On January 24 through 27, 2005, the NRC conducted an environmental site audit at the Brunswick Steam Electric Plant, Units 1 and 2 (BSEP). During this audit, I provided representatives of Carolina Power & Light Company (CP&L) a draft request for additional information (RAI) regarding the severe accident mitigation alternatives (SAMA) analysis. The SAMA analysis was submitted by CP&L as part of environmental report for its application for license renewal for BSEP. This note to file makes that draft SAMA RAI publicly available. A letter formally providing the final version of the SAMA RAI to CP&L will be mailed in late February of 2005. The final version will be the same as the draft version except for very minor typographical corrections.

Attachment: As stated

Docket Nos.: 50-324 and 50-325

February 17, 2005

NOTE TO: File

FROM: Richard L. Emch, Jr., Senior Project Manager /RA/  
Environmental Section  
License Renewal and Environmental Impacts Program  
Division of Regulatory Improvement Programs  
Office of Nuclear Reactor Regulation

SUBJECT: DOCKETING OF DRAFT REQUEST FOR ADDITIONAL INFORMATION  
REGARDING SEVERE ACCIDENT MITIGATION ALTERNATIVES ANALYSIS  
IN SUPPORT OF THE ENVIRONMENTAL REVIEW OF CAROLINA POWER &  
LIGHT COMPANY'S LICENSE RENEWAL APPLICATION FOR BRUNSWICK  
STEAM ELECTRIC PLANT, UNITS 1 AND 2

On January 24 through 27, 2005, the NRC conducted an environmental site audit at the Brunswick Steam Electric Plant, Units 1 and 2 (BSEP). During this audit, I provided representatives of Carolina Power & Light Company (CP&L) a draft request for additional information (RAI) regarding the severe accident mitigation alternatives (SAMA) analysis. The SAMA analysis was submitted by CP&L as part of environmental report for its application for license renewal for BSEP. This note to file makes that draft SAMA RAI publicly available. A letter formally providing the final version of the SAMA RAI to CP&L will be mailed in late February of 2005. The final version will be the same as the draft version except for very minor typographical corrections.

Attachment: As stated

Docket Nos.: 50-324 and 50-325

ADAMS Accession Nos.:

1. Note to File w/RAI: **ML050490382**

Document name: E:\Filenet\ML050490382.wpd

OFFICE	LA:	DRIP:RLEP:PM
NAME	M. Jenkins	R. Emch
DATE	2/17/05	2/17/05

OFFICIAL RECORD COPY

**Request for Additional Information Regarding the Analysis of  
Severe Accident Mitigation Alternatives (SAMAs) for the  
Brunswick Steam Electric Plant, Units 1 and 2**

1. The SAMA analysis is based on the most recent version of the Brunswick Steam Electric Plant (BSEP) Probabilistic Safety Assessment (PSA), i.e., the MOR03 model. Please provide the following information regarding this PSA model:
  - a. The Unit 2 PSA is used to quantify the risk for both Units 1 and 2. Characterize the major differences in the results from the Unit 1 and Unit 2 PSAs, and any plant design or operational differences that may impact the SAMA analysis.
  - b. Provide the CDF contribution due to station blackout events and ATWS events.
  - c. Describe the evolution of the current Level 2 PSA relative to that described in the BSEP Individual Plant Examination (IPE). Include an explanation of the Level 2 metrics (last column) presented in the table in Section F.2.1 of the Environmental Report (ER).
  - d. Provide a discussion of the Level 2 PSA models or assumptions that lead to the following results indicated in Table F-4 of the ER:
    - i. the approximate 50 percent split of ATWS Class IV sequences between high/early and moderate early release categories,
    - ii. the majority of Class IIIA sequences being assigned to the low/early release category, and
    - iii. the relatively large fraction of Classes IA, IB and IIC and the relatively small fraction of Class ID sequences being assigned to the intact containment release class.
  - e. Briefly describe the approach used to determine the source terms for each release category. Clarify whether new MAAP analyses were performed as part of the development of the current model and how the MAAP cases were selected to represent each release category (i.e., based on the frequency-dominant sequence in each category or on a conservative, bounding sequence). Clarify how the MAAP calculations used to determine the source terms relate to the MAAP calculations that were used to support the improved success criteria (as mentioned in Section F.2.3 of the ER).
  - f. Provide a breakdown of the annual population dose risk (person-rem/year) by containment release mode.
  - g. Section F.2 of the ER indicates that a major upgrade and replacement of the IPE models was undertaken during 1998-2001 and that subsequent updates were made in 2001, 2002 and 2003. Provide a discussion, similar to that in Section F.2.1.1, of the major changes made in the 1998 and subsequent updates, and the resulting CDF and LERF for each update. Note that the internal events CDF cited in the August 9, 2001 extended power uprate (EPU) submittal was  $2.55 \times 10^{-5}$  per year. Include an explanation of why the CDF value of  $5.49 \times 10^{-5}$  per year based on MOR98R1 (as reported in Section F.2.1 of the ER) was not used.



- b. Briefly describe how the information in Table A-1 of the Addendum to Appendix F of the ER was used in the identification of SAMAs.
  - c. In Table F-15 of the ER, Phase I SAMA 38 is said to address the same issues as Phase I SAMA 27. However, SAMA 27 is indicated as "Not Used." Provide an evaluation for Phase I SAMA 38 (at 3 percent and 7 percent), including implementation costs.
5. Provide the following with regard to the Phase II cost-benefit evaluations:
- a. Detailed descriptions of the PSA assumptions/modifications made to estimate the risk reduction are provided for each SAMA in Section F.6 of the ER. In order to accurately reflect the assumptions in the Summary table that is typically included in the staff's evaluation (see the summary table in prior EIS supplements for examples), provide a concise high-level statement for each SAMA that captures the assumed impact of the SAMA, e.g., eliminate all ISLOCA events; reduce RHR pump failure by a factor of two.
  - b. In Table F-16, the implementation cost for Phase II SAMA 1 is stated to be for a single unit site. However, the benefit estimate is based on the risk reduction achieved at both units. Even if only one portable DC generator is provided there may be some added cost for implementing the SAMA for both units. Provide an explanation.
  - c. The discussion of Phase II SAMA 13 indicates that this SAMA would not be beneficial for the loss of control rod drive (CRD) initiator but that there would be some benefit for other loss of makeup sequences. The benefit analysis indicates a 6.4 percent reduction in CDF and a 9.3 percent reduction in person-rem doses (dose risk). These reductions appear higher than expected considering that no CRD failures appear in the importance list of Table F-13. Please explain.
  - d. Phase II SAMA 18 is modeled by setting the loss of 4 kV bus initiators to zero and is stated to reduce the CDF by 3.1 percent. Figure F-2 of the ER indicates that the total CDF due to loss of AC "E"-bus (emergency bus) is 5.7 percent. Explain the difference. Also, discuss if eliminating the failure of an "E"-bus during other initiating events also makes a contribution to the estimated benefit for this SAMA.
  - e. The cost of implementing Phase II SAMA 31 is given as \$250,000 . This seems high for changes that appear to be limited to improved training and communications equipment. Provide a further explanation for this cost.
  - f. The description of the estimated benefit of Phase II SAMA 32 in Section F.6.21 of the ER indicates that only improvements in the North Central and North West areas elevation 20' of the reactor building were considered. Table F-16 indicates that the cost of implementation for this SAMA is based on work in additional fire areas (including the South area, the control room cabinets, and the Switchgear Rooms. Please reconcile these apparent inconsistencies and justify the cost estimate.
  - g. Information in Sections F.6.11.1 and F.6.28 of the ER indicate that Phase II SAMA 16 is not cost-beneficial. However, the entry in Table F-16 for this SAMA states that the cost of implementation is less than the averted cost-risk (\$135,817), and that this SAMA has been retained for further evaluation. Clarify this apparent discrepancy.



- Provide alternate ventilation for various rooms, e.g., using portable equipment or blocking open doors for RHR pump room, HPCS pump room, RCIC pump room (Nine Mile Point, Unit 2, SAMA 23),
- Enhance procedures to provide more specific guidance for loss of service water events (Nine Mile Point, Unit 2, SAMA 213),
- Reduce unit cooler contribution to emergency diesel generator unavailability through increased testing frequency or redundant cooling (Nine Mile Point, Unit 2, SAMA 221), and
- Enhance procedures to provide more specific guidance for loss of instrument air events (Nine Mile Point, Unit 2, SAMA 222).