From:

Daniel Merzke: HG

To: Anton Vegel; Charles Marschall; Charles R. Ogle; Christine Lipa; David Graves; David Hills; Eric Duncan; Glenn Meyer; John Rogge; Kenneth Riemer; Kerry Landis; Linda Smith; Mark Lesser; Mark Ring; Mohamed Shanbaky; Paul Fredrickson; Pete Eselgroth; Rebecca Nease; Robert Haag; Robert Summers; Stephen Cahill; Tony Gody; Troy Pruett; William D. Johnson

Date:

12/17/03 1:37PM

Subject:

SDP Active Issues Matrix

Attached is the most rough update to the SDP active issues matrix. Please provide updates to me at your earliest convenience. Thanks for your support.

Dan

CC: David Loveless; Eugene Cobey; Michael Parker; Mike Runyan; Rudolph Bernhard; Russ Bywater; Sonia Burgess; Walt Rogers; Wayne Schmidt

Information in this record was deleted
in accordance with the Freedom of Information
Act, exemptions 5, MASSINGER Secretarian

- 21A 2004-27

43

Mail Envelope Properties

(3FE0A254.BDB: 13:19382)

Subject:

SDP Active Issues Matrix Wed, Dec 17, 2003 1:37 PM

Creation Date: From:

Daniel Merzke

Created By:

DXM2@nrc.gov

Recipients

nrc.gov

ARL PO.ARL DO

ATG (Tony Gody)

CSM (Charles Marschall)

DNG (David Graves)

DPL CC (David Loveless)

LJS (Linda Smith)

MFR CC (Mike Runyan)

RLB3 CC (Russ Bywater)

RLN1 (Rebecca Nease)

TWP (Troy Pruett)

WDJ (William D. Johnson)

nrc.gov

ATL_PO.ATL_DO

CRO (Charles R. Ogle)

KDL (Kerry Landis)

MSL1 (Mark Lesser)

PEF (Paul Fredrickson)

RCH (Robert Haag)

RHB CC (Rudolph Bernhard)

SJC2 (Stephen Cahill)

WGR1 CC (Walt Rogers)

nrc.gov

ch_po.CH_DO

AXV (Anton Vegel)

CAL (Christine Lipa)

DEH (David Hills)

ERD (Eric Duncan)

KXR (Kenneth Riemer)

MAR (Mark Ring)

MEP CC (Michael Parker)

SDB2 CC (Sonia Burgess)

nrc.gov kp1_po.KP_DO EWC CC (Eugene Cobey) GWM (Glenn Meyer) JFR (John Rogge) MMS1 (Mohamed Shanbaky) PWE (Pete Eselgroth) **RJS** (Robert Summers)

WLS CC (Wayne Schmidt)

Post Office ARL_PO.ARL_DO ATL_PO.ATL_DO ch_po.CH_DO

kp1_po.KP_DO

Files Size

Active SDP Findings 12-16-03.wb3 December 17, 2003 11:36 AM

MESSAGE 769

Options

Expiration Date:

Priority:

Reply Requested:

Return Notification:

Concealed Subject:

Security:

Route

nrc.gov nrc.gov nrc.gov nrc.gov

Date & Time

57344

Wednesday,

Wednesday, December 17, 2003 1:37 PM

None Standard

No

None

No

Standard

SUMMARY OF ACTIVE SDP FINDINGS 12/16/03

RGN	TRACKING NUMBER (EA# SPSB#: or s URI#)	PLANT NAME	CORNERSTONE and	IR# and a ISSUE DATE	PRELIM SERP RESULTS	RESOLUTION DUE ((R+90)	RESPONSIBLE DIV.DIR/BRANCH GHIEFIA	STATUS (next step)
	URI-03-04-03	Peach Bottom	MS Corrective Actions for High Steam Tunnel Temp	2003-004 11/04/03	TBD	02/02/04	A. Blough/ M. Shanbaky	Pending determination of safety significance.
	URI-03-04-01	Oyster Creek	MS Surveillance Test Procedure	2003-004 11/10/03	. TBD ·	02/08/04	A. Blough/ P. Eselgroth	Pending determination of safety significance.
	URI-03-07-03	Salem	MS Inadequate Corrective Actions for SW Pump Strainer	2003-007 11/10/03	TBD	02/08/04	A. Blough/ G. Meyer	Pending determination of safety significance.
	EA-03-224	Peach Bottom	MS EDG Procedures	Not Issued	WHITE		W. Lanning/ J. Rogge	SERP held 12/11/03. Region to issue choice letter.
	SPSB	Ginna	MS Main Transformer fire	Not issued	TBD			Awaiting contractor initial feedback on scope of review: SPSB received 12/10/03. Lead reviewer. R. Perch
2	URI-50-269/ 00-08-01	Oconee	MS High temp in LP injection	2000-008 4/30/01	1 TBD	07/30/01	V. McCree/R. Haag	OVERDUE by 870 days. Licensee successfully completed test of ECCS pump under post-LOCA conditions. Region to close as a GREEN finding in the 4th quarter inspection report.
2	URI-50-395/ 01-09-01	Summer	MS Evac Procedures for Main Control Room fire	2001-009 11/28/01	TBD	02/28/02	C. Casto/ C. Ogle	OVERDUE by 658 days. Action complete. Issue GREEN. Awaiting closeout in IR. OGC would not support a violation, so Region is trying to develop as a finding.
Ž.	URI-02-03-02	Осопее	MS Operator action for Safe Shutdown Analysis not included	2002-003 3/20/02	TBD	06/20/02	C. Casto/ C. Ogle	OVERDUE by 546 days. Awaiting licensee's engineering eval regarding equipment impact. Characterized as URI pending SDP review, but requires further inspection.
RGN	IRACKING NUMBER (EA# SPSB# orb SPSB# orb	PLANT NAME	CORNERSIONE and	UR#andi ISSUE DATE	PRÉMI SERP RESOLDE	IFINAE (RESOLUTION DUE (IR 240) GEVS)	RESPONSIBLE DIVORVBRANCH OTHER	STATUS (nextedep)

0

	EA-03-145 URI-02-06-01	Oconee	MS Corrective Actions related to Pressurizer	2002-006 4/19/02	WHITE	07/19/02	V. McCree/ R. Haag	OVERDUE by 516 days. SERP held 07/30/03. Choice letter issued 08/07/03. Reg Conf scheduled 11/14/03. Licensee deferred Reg Conf. No new date proposed yet.
					en e			
	URI 03-07-01, 03-07-02, 03-07-03	Surry	MS Failed to protect RCP seals during switchgear room fire	2003-007 03/31/03	TBD	06/30/03	C. Casto/ C. Ogle	OVERDUE by_169 days. Site visit conducted 10/06/03. Draft report from SNL received 11/11/03. Phase 3 completed, sent to Region on 12/02/03. SERP to be schedule 01/07/04. Received in SPSB 08/03. Lead reviewer: R. Perch.
	SPSB URI-03-08-01	Harris	MS Loss of Decay Heat Removal	2003-008 06/03/03	TBD	09/01/03	V: McCree/_ P: Fredrickson	OVERDUE by 106 days. Phase 3 analysis complete: Incorporated comments from region received 11/13/03. Awaiting results of analysis from SRXB (Len Ward). Lead SPSB reviewer: M. Pohida.
V.2	URI-03-03-03	Oconee	MS SSF Diesel Degraded Grommets	2003-003 07/28/03	TBD	10/26/03	V. McCree/ R. Haag	OVERDUE by 51 days. Phase 3 analysis in progress by SRA. Week of 12/01/03 analysis complete, indicates GREEN. Awaiting review by second SRA.
2	URI-03-06-06	Hatch	MS Inadequate Modification to SRV Logic	2003-006 09/01/03	TBD	11/30/03	C. Casto/ C. Ogle	OVERDUE by 16 days. URI pending completion of significance determination. Region to close based on information provided by licensee.
RGN	TRACKING NUMBER (EA# SPSB# or URI#)	PLANT NAME	CORNERSTONE and +TOPICAL	IR# and ISSUE DATES of	PRELIM- SERP RESULTS:	FINAL RESOLUTION DUE (IR:+90 days)	RESPONSIBLE DIV DIR/BRANCH CHIEF	STATUS (next step)
12-14 12-14 13-14	URI-03-04-01	Oconee	MS Water Contamination of SSF ASW Pump Bearing Oil	2003-004 10/24/03	TBD	01/22/04	V. McCree/ R. Haag	URI pending determination of safety significance. Phase 3 being performed by region SRA.

2	URI-03-04-04	Watt's Bar	MS Inadequate Corrective Action to Control ECCS Venting	2003-004 10/27/03	TBD	01/25/04	V. McCree/ S. Cahill	URI awaiting final risk evaluation.
3	EA-03-180 URI-03-05-01 SPSB	Palisades	MS Digging/Excavating Leads to LOOP and Loss of Shutdown Cooling	2003-005 .05/19/03	WHITE	08/17/03	S. Reynolds/ E. Duncan	OVERDUE by 121 days. SERP held 9/25/03. Choice letter issued 10/03/03. Reg Conf scheduled 11/25/03. Caucus held 12/04/03. No change in color. Region to issue final letter.
23	EA-03-172 URI-03-15-04	Davis-Besse	MS HPI Pump Safety Function	2003-015 07/30/03	Greater than GREEN	10/28/03	J. Grobe/ C. Lipa	OVERDUE by 49 days. SERP held 9/04/03. Choice letter issued 10/08/03. Licensee submitting written response with deadline of 12/05/03.
3	EA-03-194	Perry	EP Alert Declaration	2003-006 10/30/03	WHITE	01/28/04	C. Pedersen/ K. Reimer	SERP held 10/14/03. Choice letter issued. Reg Conference held 12/09/03.
	EA-03-197	Репу	MS ESW Pump Failure	2003-006 10/30/03	WHITE	01/28/04	S. Reynolds/ M. Ring	SERP held 10/23/03. Choice letter issued. Reg Conf scheduled for 12/17/03.
	EA-03-016 SPSB URI 01-06-02	ANO 1	MS APP. R - Separation	2001-006 8/20/01 TIA issued 9/01	YELLOW	11/20/01	D. Chamberlain/ C. Marschall	OVERDUE by 758 days. SERP held 01/23/03. Reg Conf held 07/10/03. Additional licensee info received 08/12/03. Region requested clarification of licensee information on 09/19/03. Response received 11/25/03. DRS to schedule SERP to make final determination.
4.	URI-50-313/ 02-05-02	ANO1	BI Nozzle cracking	2002-005 01/27/03	TBD	04/27/03	Smith	OVERDUE by 233 days. Pending Phase 3 significance determination. Awaiting SPSB analysis guidance. Analysis template expected January 2004.
RGN	TRACKING & NUMBER (EA# SPSB# or A URI#)	PEAT NAME	CORNERSTONE End. TORIC	IRH AND ISSUE DATE		RESOLUTION DUE (IR: 90 Odys)	RESPONSIBLE DIV DIR/BRANCH CHIEF	STATUS (mexicater))
	SPSB P3-2002-05	Comanche Peak	IE SG tube leak	IR Not Issued. SPSB support requested 12/10/02	TBD		D. Chamberlain/ C. Marschall	OVERDUE Region SRAs doing peer review of Phase 3. SERP to be scheduled in January 2004. Lead reviewer: S. Long