(2)

Thank you for your response dated October 1, 2003, to our Triennial Fire Protection Inspection Report 05000321/2003006 and 05000366/2003006. In your response, you requested that we withdraw Non-Cited Violation (NCV) 50-366/03-06-03, Inadequate Procedure for Local Manual Operator Action for Post-Fire SSD Equipment and NCV 50-366/03-06-04, Unapproved Manual Operator Actions for Post-Fire SSD. In addition, you requested that we close the unresolved items (URIs) contained in the report.

An additional review of the actions necessary for local-manual operation of Valve 2E11-F015A was conducted. This review found that there were no requirements for valve operation outside of those included in General Employee Training and System Operator Training. Hence, the NRC ~~reviewer~~ concluded that no special procedure or preparations were required to support local-manual operation of Valve 2E11-F015A. NCV 50-366/03-06-03 is withdrawn. We are still reviewing the additional information that you provided in response to NCV 50-366/03-06-04. When our review is complete, we will advise you of our decision ~~in response to your request that we~~ of whether it is appropriate withdraw the NCV.

We have also begun our review of your request to close the URIs. To this end, we have held some discussions with your staff and requested additional information. When our review is complete, we will advise you of our decision.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter will be available electronically for public inspection in the NRC Public Document Room or from the Publically Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NTC Web site at http://www.nrc.gov/NRC/ADAMS/index.html (the Public Reading Room).

Should you have any questions concerning this letter, please contact us.

IE11-12