

From: Caswell Smith; R2
To: Joyce Calloway; R2
Date: 11/7/03 1:47PM
Subject: Hatch TFPI Ack. Letter

Joyce, attached is the acknowledgement letter for Hatch denial of the violations and URIs. Please prepare the attached for the Division Director's approval. This is a cut and paste job, please ensure that the date is correct. I could not change it.
Thanks.

CC: Charles Ogle

KK-15



UNITED STATES
NUCLEAR REGULATORY COMMISSION

REGION II
SAM NUNN ATLANTA FEDERAL CENTER
61 FORSYTH STREET SW SUITE 23T85
ATLANTA, GEORGIA 30303-8931

May 1, 2001

Southern Nuclear Operating Company, Inc.
ATTN: Mr. J. B. Beasley, Jr., Vice President
P. O. Box 1295
Birmingham, AL 35201-1295

05006

SUBJECT: Edwin I. Hatch Nuclear Plant
Response to Inspection Report 50-321/50-366-2003006

Dear Mr. Beasley:

Thank you for your response dated October 1, 2003, to our ^{of} ~~Notice of Violations and Unresolved Items (URIs) issued on September 1, 2003, with NRC Inspection Report~~ ^{our} 50-312/03-06, and 50-366/03-06. We have examined your response and find that it meets the requirements of 10 CFR 2.201.

In your response, you denied Violations 50-366/03-06-03 and 50-366/03-06-04. You also denied URIs 50-366/03-06-01, 50-366/03-06-02 and 50-366/03-06-06. You provided several reasons as your basis for disputing the violations. Additionally, you stated that the three URIs are associated with plant modification DCR 91-134 which was implemented at Plant hatch in 1993 for both Units 1 and 2. You provided several statements in opposition to URI 50-366/03-06-06 which evaluated the technical adequacy of DCR 91-134.

An additional review of the actions necessary for local-manual operation of Valve 2E11-F015A was conducted. This review found that there were no requirements for valve operation outside of those included in General Employee Training and System Operator Training. The reviewer concluded that no special procedure or preparations were required to support local-manual operation of Valve 2E11-F015A. Non-cited violation 50-366/03-06-03 is withdrawn. We are reviewing your reasons for disputing the remaining violation and your other statements in opposition to the URIs and will respond soon.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter will be available electronically for public inspection in the NRC Public Document Room or from the Publicly Available Records (PARS) component of NRC's document system (ADAMS). ADAMS is accessible from the NRC Web site at <http://www.nrc.gov/NRC/ADAMS/index.html> (the Public Reading Room).

Should you have any questions concerning this letter, please contact us.

Sincerely,

/RA Harold Christensen for:/

Charles A. Casto, Director
Division of Reactor Safety

Docket Nos.: 50-321, 50-366
License Nos.: DPR-57, NPF-5

cc w/encl:
J. D. Woodard
Executive Vice President
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

J. T. Gasser
General Manager, Plant Vogtle
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

(cc w/encl cont'd - See page 3)

(cc w/encl cont'd)
J. A. Bailey
Manager-Licensing
Southern Nuclear Operating Company, Inc.
Electronic Mail Distribution

Director, Consumers' Utility Counsel Division
Governor's Office of Consumer Affairs
2 M. L. King, Jr. Drive
Plaza Level East; Suite 356
Atlanta, GA 30334-4600

Office of Planning and Budget
Room 615B
270 Washington Street, SW
Atlanta, GA 30334

Office of the County Commissioner
Burke County Commission
Waynesboro, GA 30830

Director, Department of Natural Resources
205 Butler Street, SE, Suite 1252
Atlanta, GA 30334

Manager, Radioactive Materials Program
Department of Natural Resources
Electronic Mail Distribution

Attorney General

Law Department
132 Judicial Building
Atlanta, GA 30334

Resident Manager
Oglethorpe Power Corporation
Alvin W. Vogtle Nuclear Plant
Electronic Mail Distribution

Charles A. Patrizia, Esq.
Paul, Hastings, Janofsky & Walker
10th Floor
1299 Pennsylvania Avenue
Washington, D. C. 20004-9500

(cc w/encl cont'd - See page 4)

(cc w/encl cont'd)
Arthur H. Dombey, Esq.
Troutman Sanders
NationsBank Plaza
600 Peachtree Street, NE, Suite 5200
Atlanta, GA 30308-2216

Senior Engineer - Power Supply
Municipal Electric Authority
of Georgia
Electronic Mail Distribution

Distribution w/encl:
D. Jaffe, NRR
J. Zeiler, RII
RIDSNRRDIPMLIPB
PUBLIC

