



*Pacific Gas and
Electric Company*

James R. Becker
Vice President - Diablo Canyon
Operations and Station Director

Diablo Canyon Power Plant
P.O. Box 56
Avila Beach, CA 93424

805.545.3462
Fax: 805.545.4234

February 11, 2005

PG&E Letter DCL-05-010


U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, DC 20555-0001

Docket No. 50-275, OL-DPR-80
Docket No. 50-323, OL-DPR-82
Diablo Canyon Units 1 and 2
Monthly Operating Report for January 2005

Dear Commissioners and Staff:

Enclosed is the Monthly Operating Report for Diablo Canyon Power Plant, Units 1 and 2, for January 2005. This report is submitted in accordance with Technical Specification 5.6.4 and NRC Generic Letter 97-02.

Sincerely,



James R. Becker

Imp/3386/R0266969

Enclosures

cc/enc: Peter A. Darbee
Paul R. Fox, American Nuclear Insurers
Bruce S. Mallett, NRC Regional Administrator, Region IV
David L. Proulx, NRC Senior Resident Inspector
Gregory M. Rueger
Girija S. Shukla, NRC Project Manager
Linda J. Wells, NEI (ljw@nei.org)
INPO Record Center

IE24

OPERATING DATA REPORT

DOCKET NO.	50-275
UNIT NAME	Diablo Canyon 1
DATE	February 07, 2005
COMPLETED BY	Larry Parker
TELEPHONE	605-545-3336

REPORTING PERIOD: January 2005

1. Design Electrical Rating	<u>1,103.00</u>		
2. Maximum Dependable Capacity (MWe-Net)	<u>1,067.00</u>		
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>
3. Number of Hours the Reactor was Critical	<u>744.00</u>	<u>744.00</u>	<u>150,732.17</u>
4. Number of Hours Generator On-line	<u>744.00</u>	<u>744.00</u>	<u>149,083.71</u>
5. Reserve Shutdown Hours	<u>0.00</u>	<u>0.00</u>	<u>0.00</u>
6. Net Electrical Energy Generated (MWHrs)	<u>800,368.00</u>	<u>800,368.00</u>	<u>154,825,989.00</u>

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments
-----	------	-----------------------------------	---------------------	----------	---------------------------------	---------------------------------------

SUMMARY: Unit 1 started January 2005 in Mode 1 (Power Operation) at approximately 100 percent power. On January 5, 2005, operators initiated a planned curtailment to approximately 50 percent, to remove biofouling from the circulating water system. On January 7, 2005, operators returned the unit to approximately 100 percent power. There were no other significant operational activities.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)

OPERATING DATA REPORT

DOCKET NO. 50-323
 UNIT NAME Diablo Canyon 2
 DATE February 07, 2005
 COMPLETED BY Larry Parker
 TELEPHONE 605-545-3386

REPORTING PERIOD: January 2005

1. Design Electrical Rating	<u>1,119.00</u>			
2. Maximum Dependable Capacity (MWe-Net)	<u>1,087.00</u>			
	<u>This Month</u>	<u>Yr-to-Date</u>	<u>Cumulative</u>	
3. Number of Hours the Reactor was Critical	<u>744.00</u>	<u>744.00</u>	<u>147,060.18</u>	
4. Number of Hours Generator On-line	<u>744.00</u>	<u>744.00</u>	<u>145,393.95</u>	
5. Reserve Shutdown Hours	<u>0.00</u>	<u>0.00</u>	<u>0.00</u>	
6. Net Electrical Energy Generated (MWHrs)	<u>812,938.00</u>	<u>812,938.00</u>	<u>153,248,089.00</u>	

UNIT SHUTDOWNS

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason 1	Method of Shutting Down 2	Cause & Corrective Action Comments
-----	------	-----------------------------------	---------------------	----------	---------------------------------	---------------------------------------

SUMMARY: Unit 2 began January 2005 in Mode 1 (Power Operation) at approximately 100 percent power. There were no significant operation activities.

1

Reason:

- A Equipment Failure (Explain)
- B Maintenance or Test
- C Refueling
- D Regulatory Restriction
- E Operator Training & License Examination
- F Administration
- G Operational Error (Explain)
- H Other (Explain)

2

Method:

- 1 Manual
- 2 Manual Trip/Scram
- 3 Automatic Trip/Scram
- 4 Continuation
- 5 Other (Explain)