



FirstEnergy Nuclear Operating Company

Perry Nuclear Power Plant
10 Center Road
Perry, Ohio 44081

Richard Anderson
Vice President-Nuclear

440-280-5579
Fax: 440-280-8029

February 17, 2005
PY-CEI/NRR-2861L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Perry Nuclear Power Plant
Docket No. 50-440
Withdrawal Of License Amendment Request Regarding Revision of the Intermediate
Range Monitoring Instrumentation Surveillance Frequency

Ladies and Gentlemen:

The FirstEnergy Nuclear Operating Company requests the withdrawal of a previously submitted license amendment request for the Perry Nuclear Power Plant, dated April 26, 2004 (Letter PY-CEI/NRR-2764L). The license amendment request involved a proposed revision to the frequency of the Mode 5 Intermediate Range Monitoring (IRM) instrumentation CHANNEL FUNCTIONAL TEST contained in Technical Specification 3.3.1.1 from 7 days to 31 days.

If you have questions or require additional information, please contact Mr. Henry L. Hegrat, FirstEnergy Nuclear Operating Company, Fleet Licensing, at (330) 315-6944.

Very truly yours,

cc: NRC Project Manager
NRC Resident Inspector
NRC Region III
State of Ohio

A001