

RON A. JONES Vice President Oconee Nuclear Site

Duke Power ONO1VP / 7800 Rochester Highway Seneca, SC 29672

864 885 3158 864 885 3564 fax

February 10, 2005

U. S. Nuclear Regulatory Commission Document Control Desk Washington, D. C. 20555

Subject: Oconee Nuclear Site Docket No. 50-269 Core Operating Limits Report (COLR)

Gentlemen:

Attached, pursuant to Oconee Technical Specifications 5.6.5, is an information copy of a revision to the Core Operating Limits Report for Oconee Unit 1, Cycle 22, Rev. 23.

Very truly yours, Vones Site, Vice President R. Oconee Nuclear Site

Attachment

NRC Document Control Desk February 10, 2005 Page 2

ĩ

۸.

xc w/att: Mr. W. D. Travers, Regional Administrator U. S. Nuclear Regulatory Commission, Region II

:

Mr. L. N. Olshan, Project Manager Office of Nuclear Reactor Regulation

Mr. Mel Shannon Senior Resident Inspector Oconee Nuclear Site

ONEI-0400-50 Rev 23 Page 1 of 33

FOR INFORMATION ONLY

# **Duke Power Company**

# Oconee 1 Cycle 22

# **Core Operating Limits Report**

**QA Condition 1** 

Prepared By: G. M. Presnell

Checked By : J. M. Sanders

CDR By: S. G. Siry sim

Approved By: R. R. St. Clair 2.

Date: 1-31-2005

- 100 Date :

Date: 2/01/05

Date: 2/1/05

#### 01/31/05 MON 15:35 FAX 864 885 3374

ONS TRAINING

Ø001

Document No. / Rev.	
Date	J
Page No.	P

DNEI-0400-50 Rev. 23
anuary 31, 2005
age 2 of 33

# INSPECTION OF ENGINEERING INSTRUCTIONS

2

Inspection Waived By:

• ••••

.

(Sponsor)

Date: 2/1/05

		CATAWBA	
	Inspection Waived		
MCE (Mechanical & Civil)		Inspected By/Date:	
RES (Electrical Only)		Inspected By/Date:	
RES (Reactor)		Inspected By/Date:	
MOD		Inspected By/Date:	
Other ()		Inspected By/Date:	

		OCONEE	
	Inspection Waived		
MCE (Mechanical & Civil)		Inspected By/Date:	·
RES (Electrical Only)	Ø	Inspected By/Date:	<u> </u>
RES (Reactor)		Inspected By/Date:	Ites Perune 1/31/05
MOD	Ľ	Inspected By/Date:	
Other ()		Inspected By/Date:	

	MCGUIRE	
Inspection Waived		
	Inspected By/Date:	
	Inspected By/Date:	
	Inspected By/Date:	
	Inspected By/Datc:	
	Inspected By/Date:	
	Inspection Waived	MCGUIRE   Inspection   Waived   Inspected By/Date:   Inspected By/Date:

# Oconee 1 Cycle 22

-

-- --

į.

# Core Operating Limits Report

### Insertion Sheet for Revision 23

	la ravialar la r	at restict runtil		nation (on O		— <b>-</b> -
in	is revision is r	lot valid until	the end of ope	ration for U	conee 1 Cycle 21.	
Remove the	se revision 22	pages		insert t	hese revision 23 pages	;
	1 - 4, 6				1 - 4, 6	
		• .				
			,			
		•	•			
			Revision Log			
•	Effective	Pages	Pages	Pages	Total Effective	
Revision	Date	Revised	Added	Deleted	Pages	
				2010104		
Dconee 1 Cy	cle 22 revision	ns below	· · · · · · · · · · · · · · · · · · ·	•		•
23	Feb 2005	1-4,6	-	•	33	
22	Dec 2004	1 - 3, 30	· ·	-	33	
21	Feb 2004	1-4,6	· • .	•	33	
20	Nov 2003	1 - 32	33	÷.	33	
			•			
Dconee 1 Cy	cle 21 revision	ns below				
19	Aug 2003	1, 2, 3	1a	-	32	
18	Apr 2002	1, 2, 4	-	-	32	
17	Mar 2002	1-31	32	-	32	
Oconee 1 Cy	cle 20 revision	ns below				
16	May 2001	1-4	-	•	31	
15	Nov 2000	1-31	-	-	31	

#### Oconee 1 Cycle 22

#### 1.0 Error Adjusted Core Operating Limits

The Core Operating Limits Report for O1C22 has been prepared in accordance with the requirements of TS 5.6.5. The core operating limits within this report have been developed using NRC approved methodology identified in references 1 through 11. The RPS protective limits and maximum allowable setpoints are documented in references 12 through 14. These limits are validated for use in O1C22 by references 15 through 17. The O1C22 analyses assume a design flow of 107.5% of 88,000 gpm per RCS pump, radial local peaking (F $\Delta$ h) of 1.714, and axial peaking factor (Fz) of 1.5, and an EOC (< 100 ppmB) Tavg reduction of up to 10 °F provided 4 RCPs are in operation and Tavg does not decrease below 569 °F.

The error adjusted core operating limits included in section 1 of the report incorporate all necessary uncertainties and margins required for operation of the O1C22 reload core.

1.1 References

- Nuclear Design Methodology Using CASMO-3 / SIMULATE-3P, DPC-NE-1004P-A, Revision 0, SER dated November 23, 1992.
- Oconee Nuclear Station Reload Design Methodology II, DPC-NE-1002A, Revision 1, SER dated October 1, 1985.
- 3. Oconee Nuclear Station Reload Design Methodology, NFS-1001A, Revision 5, SER dated December 8, 2000.
- 4. ONS Core Thermal Hydraulic Methodology Using VIPRE-01, DPC-NE-2003P-A, Revision 1, SER dated June 23, 2000.
- 5. Thermal Hydraulic Statistical Core Design Methodology, DPC-NE-2005P-A, Revision 2, SER dated June 8, 1999.
- 6. Fuel Mechanical Reload Analysis Methodology Using TACO3, DPC-NE-2008P-A, Revision 0, SER dated April 3, 1995.
- 7. UFSAR Chapter 15 Transient Analysis Methodology, DPC-NE-3005-PA, Revision 2, SER dated September 24, 2003.
- 8. DPC-NE-3000P-A, Thermal Hydraulic Transient Analysis Methodology, Rev. 3, SER dated September 24, 2003.
- 9. BAW-10192-PA, BWNT LOCA BWNT Loss of Coolant Accident Evaluation Model for Once-Through Steam Generator Plants, SER dated February 18, 1997.
- 10. BAW-10164P-A, Rev. 4, "RELAP5/MOD2-B&W An Advanced Computer Program for Light Water Reactor LOCA and Non-LOCA Transient Analysis", SER dated April 9, 2002.
- 11. BAW-10227-PA, Evaluation of Advanced Cladding and Structural Material (M5) in PWR Reactor Fuel, SER dated February 4, 2000.
- 12. RPS RCS Pressure & Temperature Trip Function Uncertainty Analyses and Variable Low Pressure Safety Limit, OSC-4048, Revision 4, January 2001.
- 13. Power Imbalance Safety Limits and Tech Spec Setpoints Using Error Adjusted Flux-Flow Ratio of 1.094, OSC-5604, Revision 2, October 2001.
- 14. ΔTc and EOC Reduced Tavg Operation, OSC-7265, Rev. 1, Duke Power Co., June 2002.
- 15. O1C22 Maneuvering Analysis, OSC-8413, Revision 5, February 2005.
- 16. O1C22 Specific DNB Analysis, OSC-8460, Revision 1, September 2003.
- 17. O1C22 Reload Safety Evaluation, OSC-8471, Revision 3, February 2005.

#### ONEI-0400-50 Rev 23 Page 6 of 33

## Oconee 1 Cycle 22

Steady State Operating Band

EFPD Rod Index		Max	Мах	
0 to 433	292 ± 5	300	30	40
433 to EOC	292 ± 5	300	. 30	40

## Quandrant Power Tilt Setpoints

Core Power Level, %FP	Steady State 30 - 100	0 - 30	Transient 30 - 100	0 - 30	Maximum 0 - 100
Full Incore	3.50	7.60	7.10	9.39	16.54
Out of Core	2.36	6.09	5.63	7.72	14.22
Backup Incore	2.26	3.87	3.63	4.81	10.07

Referred to by TS 3.2.3.

Correlation Slope (CS)

## 1.15

Referred to by TS 3.3.1 (SR 3.3.1.3).

;