

Dominion Nuclear Connecticut, Inc.
Millstone Power Station
Rope Ferry Road
Waterford, CT 06385



Dominion

FEB 16 2005

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555

Serial No. 05-052
MPS Lic/MAE R0
Docket Nos. 50-336
50-423
License Nos. DPR-65
NPF-49

DOMINION NUCLEAR CONNECTICUT, INC.
MILLSTONE POWER STATION UNITS 2 AND 3
TECHNICAL SPECIFICATIONS ANNUAL REPORT

Pursuant to the provisions of Millstone Unit 2 and Millstone Unit 3 Technical Specifications (TS), Dominion Nuclear Connecticut, Inc (DNC) is submitting the annual reports described below. These annual reports cover unit activities for the period January 1, 2004, to December 31, 2004.

Millstone Unit 2:

The Millstone Unit 2 activities provided in this report are covered by Section 6.9.1.4, "Annual Reports" as supplemented by Sections 6.9.1.5b, 5c and 5d. Details of these activities are as follows:

- There were no steam generator tube inservice inspections performed at Millstone Unit 2 in 2004. Therefore, there are no results to be reported in accordance with Millstone Unit 2 TS 6.9.1.5b.
- There were no exceedances of Technical Specification 3.4.8 at Millstone Units 2 in 2004; therefore, there is no report to be made on reactor coolant specific activity analysis in accordance with Millstone Unit 2 TS 6.9.1.5c.
- There were no challenges to pressurizer power-operated relief valves or safety valves at Units 2 in 2004, nor any failures of these valves to lift or reclose within design basis tolerances. This report is made in accordance with Millstone Unit 2 TS 6.9.1.5d.

Millstone Unit 3:

The Millstone Unit 3 activities provided in this report are covered by Section 6.9.1.2, "Annual Reports." Details of these activities are as follows:

- There were no exceedances of Technical Specification 3.4.8 at Millstone Unit 3 in 2004; therefore, there is no report to be made on reactor coolant specific activity analysis in accordance with Millstone Unit 3 TS 6.9.1.2.b.

A001

- There were no challenges to pressurizer power-operated relief valves or safety valves at Millstone Unit 3 in 2004, nor any failures of these valves to lift or reclose within design basis tolerances. This report is made in accordance with Millstone Unit 3 TS 6.9.1.2.c.

There are no regulatory commitments contained within this letter.

If you have any questions or require additional information, please contact Mr. David W. Dodson at (860) 447-1791, extension 2346.

Very truly yours,



J. Alan Price
Site Vice President - Millstone

Enclosures: (0)

Commitments made in this letter: None.

cc: U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406-1415

Mr. V. Nerses
Senior Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 8C2
Rockville, MD 20852-2738

Mr. G. F. Wunder
Project Manager
U.S. Nuclear Regulatory Commission
One White Flint North
11555 Rockville Pike
Mail Stop 08-B-1A
Rockville, MD 20852-2738

Mr. S. M. Schneider
NRC Senior Resident Inspector
Millstone Power Station

Mr. R. Prince
NRC Inspector
U.S. Nuclear Regulatory Commission
Region I
475 Allendale Road
King of Prussia, PA 19406-1415