



SOURCE REFERENCE RECORD

Source Reference for: _____ 43-2441Q-00 Risk Informed LCO End State Changes, RAIs
 Document Number/Title
 SHL 2/8/05

File No.	Subject	Remarks/Applicable Licensing Document
12-5023272-01	Risk Assessment for Alternate STS End States	

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Question #1

RG 1.177 requires that risk related Technical Specification (TS) changes address potentially high risk plant configurations that should be avoided/considered (Tier 2 constraints). BAW-2441 does not address these considerations; recommend that Tier 2 considerations be addressed.

Response To Question # 1

The risk-informed evaluation in BAW-2441 relies upon the plant-specific configuration risk management programs (CRMP) that are required by the Maintenance Rule (10CFR50.65). The B&W Owners Group (B&WOG) plant programs for configuration risk management provide reasonable assurance that risk-significant plant equipment outage configurations will not occur when equipment beyond the affected Limiting Condition for Operation (LCO) is taken out of service at the same time. The CRMP ensures that the risk impact of out-of-service equipment is appropriately evaluated prior to performing any maintenance activity.

The plant-specific implementations of CRMP involve identification of potentially high-risk configurations that could exist when equipment is taken out of service simultaneously. In the case of the subject LCOs, that equipment may include the redundant train(s) of safety equipment, and associated support or dependent systems. It also includes any equipment out of service that could increase the likelihood of a challenge to the affected safety systems. The TSs already recognize the higher risk associated with more than one train of a safety system out of service; however, it is noteworthy that some of the mitigation equipment that the Modes 4 and 5 risk assessments have credited is not required by the TSs to be available below Mode 4. In addition to the protections provided by TSs in Mode 4, the CRMP ensure that the B&WOG utilities will evaluate defense-in-depth prior to taking equipment out of service coincident with the affected LCOs. The B&WOG commitments to their plant-specific CRMP satisfy the Tier 2 and Tier 3 requirements of Regulatory Guide 1.177.

(See also related information in response to Question # 12-1.)

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Questions # 2, 3 and 7

As justification for the proposed change of the end-state from Mode 5 within 36 hours to Mode 4 within 12 hours for LCO 3.3.5 (ESFAS Instruments) Required Action B.2.3 and LCO 3.3.6 (ESFAS Manual Initiation) Required Action B.2, the "Basis for Proposed End-state" section states that when operating in Mode 4 there are more mitigation systems available to respond to initiating events that could challenge RCS inventory or decay heat removal than when operating in Mode 5.

Please provide a comparison of the availability of the mitigating systems (e.g., high pressure injection and emergency feedwater system) between Modes 4 and 5 operations.

Response To Questions # 2, 3 and 7

Note: Plant outage planners are expected to provide for contingencies when equipment/systems important to reactor coolant system (RCS) make-up and core heat removal are removed from service, i.e., make appropriate use of the configuration risk management requirements of the maintenance rule (10CFR50.65). The following discussions are based only on equipment/systems availability for the stated plant operating states in order to clarify their understanding.

Decay Heat Removal Considerations

Decay Heat Removal Considerations - Mode 4

When in Mode 4 not on shutdown cooling (SDC)¹, reactor coolant pumps (RCPs) will be in service and the steam generators (SGs) will be removing core energy; the SDC system (also known as the decay heat removal system, DHR) is available as a backup method of core cooling.

In this plant condition, there are two trains of condensate/feedwater available to provide feed to the SGs; one is in service and one is in standby. In addition, for all but Davis-Besse (DB), there is also at least one [onsite standby power source] powered motor-driven emergency feedwater (EFW) pump available. Davis-Besse has a motor-driven feed pump and startup feed pump that are powered from [onsite standby power source] via manual control room power alignment

¹ For Davis-Besse, when Mode 4 is entered, SDC is aligned in parallel with forced RCS flow SG operation to accommodate low-temperature overpressure (LTOP) concerns. A relief valve in the SDC system serves to prevent overpressure of the RCS for LTOP control versus the pilot-operated relief valve (PORV) for all other plants.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

operations. For all plants, turbine-driven EFW pumps are available given that SG steam conditions are adequate² or an auxiliary steam supply is available.

While in this plant operating condition, a loss of feedwater (FW) can be mitigated via use of standby condensate/feedwater train, motor-driven EFW pumps, and turbine-driven EFW pumps. Should all of these systems become unavailable, then the SDC system can be used.

Decay Heat Removal Considerations - Mode 5

Prior to entering Mode 5, the RCPs are shutdown; net positive suction head becomes too low for continued operation. Once the RCPs are shutdown, the SGs are no longer in use as heat sinks for the RCS; the SDC system removes all of the core heat. In this situation, if all SDC is lost, return to use of SGs can provide a means of restoring controlled core heat removal. However, as long as the RCPs are shutdown, the SGs are not immediately available for core heat removal. In addition, the further the cooldown proceeds, i.e., toward Mode 5 (< 200°F), the more time required to re-establish appropriate RCS conditions for RCP restart. Hence, the ability to immediately use SGs for core heat removal decreases as cooldown progresses. The SGs could be used in the natural circulation mode. However, this mode may not be immediately available if SGs are not operable (e.g., low SG pressure makes steam-driven feed pumps unavailable and the SGs may not be intact), or a significant reactor coolant (RC) heatup may be necessary to develop appropriate hydraulic heads for natural circulation (NC). Also, once in Mode 5, condensate/feedwater trains would not be available due to outage dependent realignments and/or maintenance requirements (systems may be disassembled).

Given these constraints, attempts to use SGs in Mode 5 would depend largely on motor-driven EFW pumps (or in Davis-Besse's case a motor-driven feed or startup pump). That is, SG(s) (if intact with RCS filled) will have very low pressure, near atmospheric, thus preventing use of turbine-driven feed pumps.

The Mode 5 probabilistic risk assessment (PRA) models used in BAW-2441 are conservative with respect to comparison of Mode 4 and Mode 5 risk, because they assume that while in Mode 5, the plant stays in the most-favorable plant operating state for availability of the SGs (i.e., SGs intact and RCS filled), even though this is not required by the Technical Specifications.

² Turbine-driven EFW Pumps

Davis-Besse: At the low end of operation of the turbine-driven auxiliary feedwater (AFW) (EFW at other plants) pumps, i.e., 43 psia steam inlet pressure, each pump will provide a flow rate ~ 200 gpm to a SG. Mode 4 is entered at $\leq 280^\circ\text{F}$ or a SG pressure of 49 psia. Because of this, on Mode 4 entry, these pumps can be used on a continuous basis as long as cooldown to Mode 5 is not initiated. However, the DB Mode 4 probabilistic risk assessment (PRA) model is conservative and assumes that the turbine-driven EFW pumps are unavailable unless the auxiliary boiler is on line.

All Other Plants: All other plants have typical low end EFW turbine-driven pump conditions of ~ 30 psia. Mode 4 entry conditions for these plants are $\leq 280^\circ\text{F}$ and $\leq 250^\circ\text{F}$ (Oconee), which corresponds to 49 psia and 30 psia respectively. Because of this, on Mode 4 entry, these pumps can be used on a continuous basis as long as cooldown to Mode 5 is not initiated. However, the PRA model used in BAW-2441 for the generic non-DB plant is conservative and assumes that the turbine-driven EFW pump is unavailable in Mode 4 (and does not credit the auxiliary boiler).

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Decay Heat Removal Considerations Summary

The following table provides the likelihood of feedwater systems being available during Mode 4 and 5 operations:

FW System	Likely To Be Available In Mode 4	Likely To Be Available In Mode 5
Condensate/Feedwater	X	
Motor-driven Feedwater Pumps	X	X
Turbine-driven Feedwater Pumps	X	

RCS Inventory Considerations

RCS Inventory Considerations – High Pressure Injection (HPI)

HPI is available in Mode 4 for all plants; this may be on a standby basis or a manual operations basis.

When entering Mode 4, HPI is in the standby mode for DB, Crystal River (CR 3), and Oconee³. For Three Mile Island (TMI), due to higher RCS temperature LTOP limits, HPI is in a deactivated mode, but remains available on a manual operations basis. Thus, when operating in Mode 4 above the RCS LTOP temperature limits, HPI is available on a standby basis for Oconee, CR 3 and Davis-Besse and on a manual operations basis for TMI. Once cooldown proceeds in Mode 4 below the LTOP temperature limits, then HPI may be available on a standby basis for Davis-Besse⁴ and is available on a manual operations basis for the other plants. Thus, when in Mode 4, HPI is available to provide RCS make-up, if necessary. The PRA models used in BAW-2441 are conservative and assume that the HPI pumps at all of the plants are deactivated in Mode 4 and require manual action to initiate.

When in Mode 5, RCPs are off and RCS conditions allow shutdown of systems that provide RCP seals. For all plants except Davis-Besse, the HPI and Makeup (MU) pumps are one in the same. Thus, when in Mode 5, the Makeup and Purification System, which includes the MU (HPI) pumps will be secured when RCP seals are no longer needed. After this point, these systems may or may not be available based on outage dependent realignments/disassembly for maintenance/surveillance purposes.

At Davis-Besse, the HPI and MU systems are independent. For this reason, Mode 5 operations at Davis-Besse may allow for use of HPI pumps further into the cooldown depending on outage requirements, e.g., the need to realign/disassemble HPI systems for maintenance/surveillance purposes. In general, it is expected that the HPI system at Davis-Besse has a greater likelihood of being available in Mode 5, than for other plants.

³ ANO-1 did not participate in this project, and is therefore not included in this discussion.

⁴ Davis-Besse uses a relief valve on the SDC system for LTOP pressure control. This valve can pass full HPI flow while preventing RCS pressure from increasing beyond LTOP limits. For this reason, HPI need not be deactivated at Davis-Besse when its LTOP RCS temperature limit is reached.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

For the PRA models used in BAW-2441, the HPI pumps are assumed to be available in Mode 5 (on a manual operations basis), because this is the most conservative assumption with respect to comparison of Mode 4 and Mode 5 risk. If the HPI pumps are not available in Mode 5, then the PRA results would indicate an even larger contrast between the Mode 4 and Mode 5 risk than shown in this risk assessment.

HPI - Summary

At all plants HPI is considered to be available when operating in Mode 4 on either a standby or manual operations basis. This is contrasted by operations in Mode 5, where HPI is unlikely to be available for all plants except Davis-Besse once RCP seals are no longer needed; at Davis-Besse, HPI may be available in Mode 5 since these pumps do not supply RCP seals and may remain in standby.

RCS Inventory Considerations – Low Pressure Injection (LPI)

When operating in Mode 4, one train of LPI⁵ will be operable (i.e., in standby or able to be realigned to ECCS mode); the other train is not required and therefore may only be available on a delayed manual operations basis. This is contrasted with operations in Mode 5, where LPI is not required and therefore may not be available other than on a delayed basis due to potential need to realign/reassemble from maintenance/surveillance conditions.

For the PRA models used in BAW-2441, LPI is assumed to be available in Mode 5 (on a manual operations basis) even though it is not required by Technical Specifications, because this is the most conservative assumption with respect to comparison of Mode 4 and Mode 5 risk.

LPI - Summary

In Mode 4, one LPI train will be available for RCS makeup, if necessary. In Mode 5, due to maintenance/surveillance considerations, LPI may not be available except on a delayed basis; depending on conditions, i.e., system may be disassembled, such delays can be lengthy.

⁵ DHR and Low Pressure Injection (LPI) are essentially the same systems. When aligned as DHR, the system provides core cooling via heat exchangers to the plant's ultimate heat sink. When aligned as LPI, the system adds inventory to the RCS. Having DHR (LPI) available means one train is operable in Mode 4, i.e., it can be manually realigned to the LPI mode.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Questions # 4, 4.a, 4.b, 8, 8a and 8b

In the "Basis for Proposed End-state" section, it provides a justification for the proposed change to allow for continued operation in MODE 4 by deleting the end-state of MODE 5 within 24 hours for LCO 3.4.6 (RCS Loops -Mode 4) Required Action A.2 when one required loop is inoperable, and if one DHR loop is operable. It states that, "When operating in MODE 4 if both RCS loops and one DHR loop [are] inoperable, the existing LCO requires cooldown to Mode 5. In this situation, SGs are available for core heat removal and transport via NC in Mode 4 without the need for significant RCS heatup."

a. Is the definition of RCS loop inoperability restricted to the situation in which a RCP is inoperable, or does it include unavailability of a SG, such as main feedwater and EFW not in operation?

b. For the situation for which the RCS loop inoperability is due to SG unavailability (with or without RCP inoperability), should the required action be the initiation of EFW to make a SG available for decay heat removal via forced circulation or NC depending on operability of RCPs? Should the proposed deletion of Required Action A.2 end-state be modified to require the verification of or initiation of action immediately to make at least one SG available?

Response To Questions # 4, 4.a, 4.b, 8, 8a and 8b

The proposed deletion of Required Action A.2 from LCO 3.4.6 RCS Loops - MODE 4 is based on the plant condition where only one of the four required RCS Loops is available and that loop is a DHR system. Thus, in this condition, core heat is being removed via the available DHR system with both SG loops and the other DHR system loop not available.

In accordance with the basis for this LCO, i.e., B 3.4.6 RCS Loops - MODE 4, the intent of the LCO is to provide forced flow from at least one RCP or one DHR pump for decay heat removal and transport. This intent inherently includes operability of SG and/or DHR systems. In order to accommodate this intent, the Improved Standard Technical Specifications provide the following LCOs that address operability of SG and DHR systems while in Mode 4:

- 3.7.4 Atmospheric Vent Valves (AVVs)
- 3.7.5 Emergency Feedwater (EFW) System
- 3.7.6 Condensate Storage Tank (CST)
- 3.7.7 Component Cooling Water (CCW) System
- 3.8.8 Service Water System (SWS)

To further address loss of SG and DHR systems while in MODE 4, Required Action A.1 of the LCO of interest, i.e., 3.4.6 RCS Loops - MODE 4 prescribes a completion time of immediate to "Initiate action to restore a second loop to OPERABLE status." Thus there is already a requirement (within Required Action A.1) to immediately take action to restore a SG system to operable status in the event action is not already underway as a result of the LCOs listed above. For this reason, there is no need to modify Required Action A.2 (of LCO 3.4.6) to provide such actions.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

With respect to the risk analysis, the calculations that were performed originally for BAW-2441 assumed that the plant was in this LCO due to loss of forced flow from the RCPs, in other words, natural circulation cooling via the SGs was still possible. Because of this request for additional information (RAI), the PRA models for this LCO have been revised, and the risk results presented in this submittal (i.e., RAI responses) now assume that when in this LCO, that no SG cooling is available, in addition to unavailability of one DHR train.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Questions # 5 and 9

The proposed change is to replace the end-state of LCO 3.5.4 (BWST) associated with the boron concentration requirement from Mode 5 within 36 hours to Mode 4 within 12 hours. However, Required Action E.2 in the table on Page 45 specifies that the plant be in Mode 5 within 36 hours for Condition E, which states that "Required Action and associated Completion Time not met." Since Required Action E.2 is for the Conditions of BWST borated water temperature and volume not within their limits, should Condition E be modified to "Required Action and associated Completion Time for Conditions other than Condition A not met"?

Response To Questions # 5 and 9

The table on page 45 is in error; it does not correctly reflect that Condition E should be modified to acknowledge that BWST water temperature and volume are not included in the requested change. The following revised ACTIONS table provides the proposed method to address this situation:

CONDITIONS	REQUIRED ACTION	COMPLETION TIME
A. BWST boron concentration not within limits.	A.1 Restore BWST to OPERABLE status.	8 hours
B. Required Action and associated Completion Time of Condition A not met.	B.1 Be in MODE 3. <u>AND</u> B.2 Be in MODE 4.	6 hours 12 hours
C. BWST water temperature not within limits.	C.1 Restore BWST to OPERABLE status.	8 hours
D. BWST inoperable for reasons other than Conditions A or C.	D.1 Restore BWST to OPERABLE status.	1 hour
E. Required Action and associated Completion Time of Condition C or D not met.	E.1 Be in MODE 3. <u>AND</u> E.2 Be in MODE 5.	6 hours 36 hours

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Questions # 6 and 10

The lower limit for the BWST boron concentration specified in SR 3.5.4.3 was established to ensure that, following a LBLOCA, the reactor will remain shutdown in the cold condition following mixing of BWST and RCS water, and the upper limit is to avoid boric acid precipitation from the core. In "Basis for Proposed End-state" section for LCO 3.5.4, it states that the boron concentration limit is very conservative with shutdown margin in excess of approximately 9%, and that deviations in boron concentration will be relatively slow and small and boric acid addition systems would normally be available. However, LCO Condition A only specifies "BWST boron concentration not within limits" without specifying the maximum deviations.

Please provide the maximum allowable deviations, including justifications and bases, from both lower and upper boron concentration limits that the stated justifications as the basis for proposed end-state of Mode 4 remain valid, and propose change to Required Action consistent with the maximum allowable deviations.

Response To Questions # 6 and 10

The requested change to LCO 3.5.4 is to allow for Mode 4 operation if boron concentration is outside the operating limits for a period greater than 8 hours and create a new action to maintain the current end state for other inoperabilities. The justification for this position lies in the reasons for the high and low boron limits.

The low BWST boron concentration limit is based on postulated Mode 1 large break LOCAs that assume that all rods remain withdrawn from the core following initiation of the event. However, upon entry into Mode 3, the reactor is shutdown (i.e., the core is subcritical - rods are inserted) and maintained shutdown by operating procedures and other administrative controls. When in Mode 4, the large break LOCA, which is the event of concern relative to the BWST low boron limit, is of very low probability. Also, decreases in BWST boron concentration, owing to the large amount of BWST water and the low capacity of associated dilution systems, will be slow, thus allowing ample time for operator recognition and restoration.

The high BWST boron concentration limit is also based on postulated Mode 1 large break LOCAs. For these LOCAs, boron is postulated to concentrate in the core with the time to implement actions that prevent coolant flow channel blockage being dependent on the initial power level; the higher the initial power level, the shorter the time available. Again, on entry into Mode 3, the reactor is shutdown and maintained shutdown with the event of concern, i.e., large break LOCA, being of very low probability once in Mode 4. Due to the low power levels associated with Mode 4, there will be ample time to establish boron dilution flow paths should the need arise.

In the event the high or low BWST boron concentration limit is exceeded when in Mode 4, operators will take the necessary actions to restore boron concentrations to within the existing limits; this is no different from the existing LCO. The only difference is that the operator is not required to enter Mode 5. In summary, this change is acceptable because the reactor will be shutdown (subcritical with rods inserted), core power level will be low and there is a very low probability of occurrence of a large break LOCA when in Mode 4. The impact from marginally

**Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed
Justification For LCO End-State Changes"**

high or low boron concentration deviations (i.e., from prescribed limits) that might occur during operator action to restore such concentrations, has a negligible risk impact, especially when considering the limited time interval of such deviations. For these reasons, no additional specific delineation of deviations from limits is considered necessary.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Question # 11

The submitted information does not provide sensitivity studies investigating the robustness of the results to uncertainties in data and modeling assumptions. Examples of potential uncertainties in data used during Modes 3, 4 and 5 are initiating event frequencies, recovery probabilities and common cause failure probabilities. This type of data are usually taken from the power operation risk models and adjusted to reflect the different shutdown conditions (e.g., LOCA) frequencies are often assumed to be one or two orders of magnitude lower in Mode 4 than in Mode 1, due to the reduced RCS pressure. Such adjustments may not always be conservative and at times may include significant uncertainties. An example of potential non-conservative modeling assumption during Mode 4 (while on SG cooling) is the modeling of RCP seal LOCAs. Please investigate the robustness of the quantitative risk assessment results and provide your findings, including supporting discussions, for the staff's review.

Response To Question # 11

The risk model for Mode 3 was created by making adjustments to the Mode 1 (at-power) PRA model as described in this RAI. However, Mode 3 is a transition mode, and the risk from that mode is the same regardless of whether going to the current end state (Mode 5) or the requested end state (Mode 4). Therefore the response to this RAI will address Modes 4 and 5. In the DB shutdown PRA, which was used as a basis for the analysis in BAW-2441, the models for Modes 4 and 5 were not created by making adjustments to the at-power PRA. Separate PRA models were created for Modes 4 and 5. Various features of these PRA models and their sensitivities are discussed in the responses to these RAIs.

Before discussing data sensitivities, it is useful to present the base case (i.e., no sensitivity) core damage frequency (CDF) results for each of the modeled LCOs, as well as the no-LCO case.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Base Case Results Using DB Shutdown PRA

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	3.37e-6	1.18e-5
3.7.7 CCW	A. One CCW train inoperable	7.60e-5	4.79e-4
3.7.8 SWS	A. One SWS train inoperable	5.64e-6	4.81e-5
3.8.1 AC sources	A. One offsite circuit inoperable	1.43e-6	1.11e-5
		[see note 1]	[see note 1]
	B. One diesel generator inoperable	9.24e-5	1.08e-4
	C. Two offsite circuits inoperable	1.14e-4	8.71e-4
		[see note 1]	[see note 1]
	D. One offsite circuit and one diesel generator inoperable	8.91e-5	9.82e-5
	E. Two diesel generators inoperable	1.08e-3	1.17e-3
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	3.59e-6	1.46e-5
	B. Batter[y][ies] on one train inoperable	4.84e-5	1.64e-4
	C. One DC subsystem inoperable - other	4.60e-5	1.42e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	8.59e-5	1.13e-3
	B. AC vital bus inoperable	4.44e-5	5.62e-5
	C. DC distribution subsystem inoperable	4.60e-5	1.42e-4
3.8.7 Inverters	A. One inverter inoperable	4.44e-5	5.62e-5
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	4.47e-3	4.83e-3

Note for Tables

Note 1: The results for the cases “one offsite circuit inoperable” and “two offsite circuits inoperable” may be optimistic because the plant requires the emergency diesel generator(s) (EDGs) associated with the affected power division to be normally running (as well as the corresponding EFW pumps) while in the LCO. That improves the risk. However, the PRA model does not completely accommodate these LCOs because it does not include failure of the EDGs as an initiating event. Since the PRA model did not anticipate failure of EDGs as an initiating event, certain cut sets involving EDG run failures are underestimated. However, failure of all of the EDGs while in these LCOs will affect both Mode 4 and Mode 5 uniformly and add equally to both CDF estimates. Hence, the relative comparisons between Mode 4 and Mode 5 for these LCOs are valid.

Sensitivity to Initiating Event Frequency for Loss of RCS Inventory

In the PRA models for Mode 4 and Mode 5 initiating event frequencies for loss of RCS inventory are broken out into events occurring inside or outside of the Reactor Building (RB). RCS leaks less than about 100 gpm are not considered significant unless at mid-loop operation (which is not applicable for this submittal because the requested Mode 4 end state does not involve mid-loop operation, and the PRA model for the current Mode 5 end state assumes the plant is in the beginning of Mode 5 before RCS drain down). The initiating event frequencies used are shown in the table below⁶. Since DB aligns the RCS to SDC in Mode 4, and the end state RCS pressures are similar, the same initiating event frequencies are used for both Modes 4 and 5. The dominant contributors to the loss of inventory initiating events are failed open relief valves on the DHR (i.e., SDC) lines. The flow rate for failure of the relief valve inside the RB is estimated at 100 to 200 gpm, and the relief valve outside the RB is estimated at 400 gpm.

⁶ The LOCA Frequency for Mode 4 and 5 for Davis-Besse loss of coolant initiating event was obtained from Wells, J., et al., “An Analysis of Loss of Decay Heat Removal Trends and Initiating Event Frequencies (1989-1998),” EPRI Report TR-113051, October 1999.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Large Loss of Inventory Initiating Event Frequencies in DB Shutdown PRA

	Mode 4	Mode 5
Large Loss of RCS Inventory Inside the Reactor Building	8.41e-3/yr	8.41e-3/yr
Large Loss of RCS Inventory Outside the Reactor Building	1.26e-2/yr	1.26e-2/yr

The loss of inventory initiating event frequencies used in the DB Mode 4 and Mode 5 PRA models are much higher than the corresponding LOCA frequencies used in Mode 1 or Mode 3. By comparison, the LOCA frequencies used in the at-power (Mode 1) PRA for DB are: large LOCA 5e-6/yr, medium LOCA 4e-5/yr, small LOCA 5e-4/yr. The DB Mode 3 PRA model uses the Mode 1 values divided by 7.5.

For DB, the loss of inventory frequency difference between Modes 4 and 5 may be small, and in the PRA model it was assumed to be the same. Therefore, a sensitivity run was made to determine the impact upon the results if the Mode 4 loss of inventory frequency is significantly worse than in Mode 5. A set of runs was made with the Mode 4 loss of inventory frequencies increased by a factor of 5 and the Mode 5 frequencies left the same. This sensitivity case (see tables below) shows the robustness of the results even if the frequency of these initiating events is significantly worse in Mode 4 than Mode 5.

**Large Loss of Inventory Initiating Event Frequencies used in DB
Loss of Inventory Sensitivity Runs**

	Mode 4	Mode5
Large Loss of RCS Inventory Inside the Reactor Building	4.21e-2/yr	8.41e-3/yr
Large Loss of RCS Inventory Outside the Reactor Building	6.30e-2/yr	1.26e-2/yr

**Initiating Event Frequency Sensitivity (DB model)
5X Increase in Mode 4 Loss RCS Inventory (Inside and Outside RB)**

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	4.31e-6	1.18e-5
3.7.7 CCW	A. One CCW train inoperable	7.74e-5	4.79e-4
3.7.8 SWS	A. One SWS train inoperable	7.30e-6	4.81e-5
3.8.1 AC sources	A. One offsite circuit inoperable	2.46e-6	1.11e-5
	B. One diesel generator inoperable	9.33e-5	1.08e-4
	C. Two offsite circuits inoperable	1.21e-4	8.71e-4
	D. One offsite circuit and one diesel generator inoperable	9.02e-5	9.82e-5
	E. Two diesel generators inoperable	1.08e-3	1.17e-3
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	4.62e-6	1.46e-5
	B. Batter[y][ies] on one train inoperable	4.95e-5	1.64e-4
	C. One DC subsystem inoperable - other	4.71e-5	1.42e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	8.69e-5	1.13e-3
	B. AC vital bus inoperable	4.53e-5	5.62e-5
	C. DC distribution subsystem inoperable	4.71e-5	1.42e-4
3.8.7 Inverters	A. One inverter inoperable	4.53e-5	5.62e-5
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	4.47e-3	4.83e-3

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Sensitivity to Initiating Event Frequency for Loss of RCS Inventory for other B&WOG Plants

An additional sensitivity case was run for the non-DB B&WOG plant because there was a potential for more sensitivity to the loss of RCS inventory event. Recall from BAW-2441 that the DB-based shutdown risk model was modified to test the sensitivity of the results to B&WOG plant features that are different than DB. Thus a hybrid "non-DB" model was created by modifying the DB Mode 4 and Mode 5 PRA models to account for different plant features that may be important to end state risk. These modifications are discussed further in the response to RAI #12-2; the base case "non-DB" results are presented in the table below. One of the differences between DB and the other B&WOG plants is the raised-loop steam generator design. This provides more water from SG inventory that is potentially available for core cooling than the lowered-loop plants. As discussed in the response to RAI #12-2, the time available for recovery action before losing DHR suction is less in the lowered-loop plant. Because of this, there was a potential for more sensitivity to loss of RCS inventory event frequency in the non-DB model than in the DB plant model. Therefore, an additional set of sensitivity analysis runs was made using the non-DB plant model as a base. Since the other B&WOG plants do not pre-align the RCS to the SDC system in Mode 4, and use the PORV for LTOP, the factor of five increase was applied only to the loss of inventory frequency inside of the RB. As in the previous case, the factor of five increase was applied only in Mode 4, to determine how the risk contrast between Modes 4 and 5 might be affected. This sensitivity case (see tables below) also shows the robustness of the results to uncertainty in loss of inventory initiating event frequency, and also demonstrates robustness in light of B&WOG plant differences.

Large Loss of Inventory Initiating Event Frequencies used in Non-DB Model

	Mode 4	Mode 5
Large Loss of RCS Inventory Inside the Reactor Building	8.41e-3/yr	8.41e-3/yr
Large Loss of RCS Inventory Outside the Reactor Building	5.4e-3/yr	1.26e-2/yr

**Large Loss of Inventory Initiating Event Frequencies used in Non-DB
Loss of Inventory Sensitivity Runs**

	Mode 4	Mode5
Large Loss of RCS Inventory Inside the Reactor Building	4.21e-2/yr	8.41e-3/yr
Large Loss of RCS Inventory Outside the Reactor Building	5.4e-3/yr	1.26e-2/yr

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Base Case Results Using Non-DB PRA Model⁷

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	1.38e-5	5.21e-5
3.7.7 CCW	A. One CCW train inoperable	1.73e-4	3.72e-3
3.7.8 SWS	A. One SWS train inoperable	3.04e-5	8.82e-5
3.8.1 AC sources	A. One offsite circuit inoperable	1.17e-5	6.35e-5
		[see note 1]	[see note 1]
	B. One diesel generator inoperable	1.04e-4	1.42e-4
	C. Two offsite circuits inoperable	4.02e-5	5.97e-4
		[see note 1]	[see note 1]
3.8.4 DC sources	D. One offsite circuit and one diesel generator inoperable	1.03e-4	1.49e-4
	E. Two diesel generators inoperable	1.12e-3	1.15e-3
	A. Battery charger[s] on one train inoperable	1.43e-5	6.32e-5
	B. Batter[y][ies] on one train inoperable	1.25e-4	2.08e-4
	C. One DC subsystem inoperable - other	1.06e-4	1.89e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	2.43e-3	2.73e-2
	B. AC vital bus inoperable	7.11e-5	9.35e-5
	C. DC distribution subsystem inoperable	1.06e-4	1.89e-4
3.8.7 Inverters	A. One inverter inoperable	7.11e-5	9.35e-5
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	3.21e-3	3.25e-3

**Initiating Event Frequency Sensitivity (non-DB Model)
5X Increase in Mode 4 Loss of RCS Inventory (Inside RB)**

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	3.48e-5	5.21e-5
3.7.7 CCW	A. One CCW train inoperable	2.18e-4	3.72e-3
3.7.8 SWS	A. One SWS train inoperable	5.27e-5	8.82e-5
3.8.1 AC sources	A. One offsite circuit inoperable	3.28e-5	6.35e-5
	B. One diesel generator inoperable	1.25e-4	1.42e-4
	C. Two offsite circuits inoperable	6.24e-5	5.97e-4
	D. One offsite circuit and one diesel generator inoperable	1.24e-4	1.49e-4
	E. Two diesel generators inoperable	1.14e-3	1.15e-3
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	3.52e-5	6.32e-5
	B. Batter[y][ies] on one train inoperable	1.60e-4	2.08e-4
	C. One DC subsystem inoperable - other	1.30e-4	1.89e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	2.45e-3	2.73e-2
	B. AC vital bus inoperable	9.20e-5	9.35e-5
	C. DC distribution subsystem inoperable	1.30e-4	1.89e-4
3.8.7 Inverters	A. One inverter inoperable	9.20e-5	9.35e-5
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	3.23e-3	3.25e-3

⁷The DB PRA model for Modes 4 and 5 was modified to reflect differences that exist in other B&WOG plants. See BAW-2441 and the response to RAI #12-2 for a description of the changes that were made to the DB PRA model so that it would be representative for plant configurations such as may exist in the other B&WOG plants.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Sensitivity to Initiating Event Frequency for RCP Seal LOCA

The representative Mode 4 PRA model (DB) does not include RCP Seal LOCAs. The justification for not including RCP seal LOCAs in Mode 4 is:

- The likelihood of a seal LOCA is less than at power because the RCS pressure in Mode 4 is less than in Mode 1. The pressure dissipated by the entire three-stage seal package in Mode 4 (where RCS pressure is less than 700 psi) is same or less than the pressure dissipated by a single seal stage (i.e., approximately 700 psi) during normal non-faulted operation.
- The reduced temperature in Mode 4 decreases the rate of seal thermal degradation relative to an event in Mode 1, which significantly extends the time until seal failure.
- The resulting flow rate from a seal LOCA is much less in Mode 4 due to lower RCS pressure and fewer RCPs running, and is expected to be within the capacity of a single makeup pump.

Nonetheless, a sensitivity case was performed where seal LOCA sequences (extracted from the Mode 3 PRA model) were put into the Mode 4 model. For the purpose of screening, the operator action associated with failure to trip RCPs was given a probability of 1.0. The Mode 4 model was insensitive to the seal LOCA contribution, generating no new cut sets for either the base case (no LCO) or any of the LCOs. Core damage from loss of RCP seals requires a transient initiating event, failure of the operator to trip the RCPs (screening probability =1.0), failure of seal injection and cooling, and for core damage also failure of either safety injection or recirculation. The probability of these sequences is insignificant relative to the generic loss of RCS inventory initiating event already included in the model.

Sensitivity to Initiating Event Frequency for Transients

Initiating events for transients in Mode 4 and Mode 5 involve loss of the operating decay removal method: either SDC (i.e., the DHR system) or SG cooling, including associated support systems (e.g., power, cooling water). For this sensitivity study, the investigation focused on initiating events that have the potential to affect Mode 4 risk to a greater extent than Mode 5 risk.

The loss of feedwater initiating event has the potential to affect Mode 4 risk, since SG cooling is the main cooling method in Mode 4. However, the DB Mode 4 risk model was not sensitive to the loss of feedwater initiating event frequency. Power system failures were more dominant because they have greater potential for affecting backup mitigation systems as well. Therefore, the sensitivity analysis for loss of feedwater was run on the modified model that was created to show the sensitivity to B&WOG plant differences. The "non-DB" risk model is more sensitive to loss of feedwater frequency because that model takes no credit for the auxiliary boiler (thus defeating the turbine-driven EFW pump) and takes no credit for the non-safety related pumps (such as the startup feed pump). The sensitivity runs shown in the table below increase the loss of feedwater initiating event frequency by a factor of five (from 0.22/yr to 1.1/yr). This change applies to Mode 4 only. Mode 5 results are the same as the base model because there is no loss of feedwater initiating event in Mode 5. This sensitivity analysis (see table below) shows that the results of the Mode 4 versus Mode 5 end state comparison are robust even considering uncertainties in loss of feedwater initiating event frequency.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

**Initiating Event Frequency Sensitivity (non-DB Model)
5X Increase in (Mode 4) Loss of Feedwater**

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	1.96e-5	5.21e-5
3.7.7 CCW	A. One CCW train inoperable	2.53e-4	3.72e-3
3.7.8 SWS	A. One SWS train inoperable	3.56e-5	8.82e-5
3.8.1 AC sources	A. One offsite circuit inoperable	1.67e-5	6.35e-5
	B. One diesel generator inoperable	1.09e-4	1.42e-4
	C. Two offsite circuits inoperable	1.26e-4	5.97e-4
	D. One offsite circuit and one diesel generator inoperable	1.08e-4	1.49e-4
	E. Two diesel generators inoperable	1.12e-3	1.15e-3
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	1.91e-5	6.32e-5
	B. Batter[y][ies] on one train inoperable	2.07e-4	2.08e-4
	C. One DC subsystem inoperable - other	1.53e-4	1.89e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	9.87e-3	2.73e-2
	B. AC vital bus inoperable	7.58e-5	9.35e-5
	C. DC distribution subsystem inoperable	1.53e-4	1.89e-4
3.8.7 Inverters	A. One inverter inoperable	7.58e-5	9.35e-5
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	3.21e-3	3.25e-3

Another initiating event that is important to risk is loss of offsite power (LOOP). The LOOP initiating event is important because loss of power sequences have the potential to disable the preferred, the backup, and the emergency cooling methods, whichever the operating mode. Therefore a set of sensitivity cases was run where the loss of offsite power initiating event frequency was increased by a factor of five (to 0.5/yr). The initiating event frequency for LOOP is the same for both Mode 4 and Mode 5, the value used in the base models (0.1/yr) is higher than is typical for at-power operation and is intended for shutdown operating states where activity may be occurring in the switchyard. It was applied to Mode 4 as well as Mode 5 under the conservative assumption that the proposed end state of Mode 4, when implemented, may see the same sort of switchyard activity that otherwise might occur in Mode 5. As expected, the risk in both end states is sensitive to loss of offsite power frequency, as the table below shows. Dominant cut sets involving LOOP coincident with failure of onsite standby power sources are consistently present in most of the runs. However, the relative relationship of Mode 4 to Mode 5 risk is similar to the base case. Therefore, the uncertainty in LOOP initiating event frequency does not affect the robustness of the results.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

**Initiating Event Frequency Sensitivity
5X Increase in LOOP**

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	1.58e-5	2.65e-5
3.7.7 CCW	A. One CCW train inoperable	3.61e-4	8.68e-4
3.7.8 SWS	A. One SWS train inoperable	2.64e-5	1.55e-4
3.8.1 AC sources	A. One offsite circuit inoperable	5.16e-6	1.70e-5
	B. One diesel generator inoperable	4.61e-4	5.08e-4
	C. Two offsite circuits inoperable	1.14e-4	8.71e-4
	D. One offsite circuit and one diesel generator inoperable	4.44e-4	4.56e-4
	E. Two diesel generators inoperable	5.40e-3	5.79e-3
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	1.65e-5	2.93e-5
	B. Batter[y][ies] on one train inoperable	2.39e-4	3.78e-4
	C. One DC subsystem inoperable - other	2.23e-4	3.42e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	3.99e-4	2.20e-3
	B. AC vital bus inoperable	2.21e-4	2.48e-4
	C. DC distribution subsystem inoperable	2.25e-4	3.42e-4
3.8.7 Inverters	A. One inverter inoperable	2.21e-4	2.48e-4
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	4.49e-3	4.86e-3

Another sensitivity case for transient initiating events is failure of support systems associated with cooling. A set of cases was run varying the initiating event frequencies for loss of component cooling water (CCW) and service water (SW). The initiating event frequencies for loss of CCW and SW pumps were increased by a factor of five. The changes to CCW pump failure frequency (from 0.114/yr to 0.57/yr) and SW pump failure frequency (from 7.51e-2 to 0.376/yr). were made simultaneously. The results for Mode 5 were affected more by this change than Mode 4, therefore another set of cases were run where the same initiating event frequencies were reduced by a factor of five. The results are shown in the set of tables below. The results show that uncertainty in the initiating event frequency for loss of cooling water support systems does not affect the robustness of results.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

**Initiating Event Frequency Sensitivity
5X Increase in Loss of CCW and SW**

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	3.42e-6	1.55e-5
3.7.7 CCW	A. One CCW train inoperable	8.54e-5	1.11e-3
3.7.8 SWS	A. One SWS train inoperable	5.68e-6	8.28e-5
3.8.1 AC sources	A. One offsite circuit inoperable	1.48e-6	1.45e-5
	B. One diesel generator inoperable	9.24e-5	1.11e-4
	C. Two offsite circuits inoperable	1.25e-4	1.27e-3
	D. One offsite circuit and one diesel generator inoperable	8.92e-5	1.02e-4
	E. Two diesel generators inoperable	1.08e-3	1.17e-3
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	3.96e-6	2.27e-5
	B. Batter[y][ies] on one train inoperable	4.85e-5	2.05e-4
	C. One DC subsystem inoperable - other	4.64e-5	1.77e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	8.60e-6	1.17e-3
	B. AC vital bus inoperable	4.44e-5	5.94e-5
	C. DC distribution subsystem inoperable	4.64e-5	1.77e-4
3.8.7 Inverters	A. One inverter inoperable	4.44e-5	5.94e-5
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	5.99e-3	6.88e-3

**Initiating Event Frequency Sensitivity
5X Decrease in Loss of CCW and SW**

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	3.37e-6	1.15e-5
3.7.7 CCW	A. One CCW train inoperable	7.44e-5	3.54e-4
3.7.8 SWS	A. One SWS train inoperable	5.64e-6	4.14e-5
3.8.1 AC sources	A. One offsite circuit inoperable	1.42e-6	1.05e-5
	B. One diesel generator inoperable	9.24e-5	1.08e-4
	C. Two offsite circuits inoperable	1.13e-4	8.18e-4
	D. One offsite circuit and one diesel generator inoperable	8.91e-5	9.78e-5
	E. Two diesel generators inoperable	1.08e-4	1.17e-3
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	3.59e-6	1.31e-5
	B. Batter[y][ies] on one train inoperable	4.83e-5	1.56e-4
	C. One DC subsystem inoperable - other	4.60e-5	1.35e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	8.59e-5	1.12e-3
	B. AC vital bus inoperable	4.44e-5	5.57e-5
	C. DC distribution subsystem inoperable	4.60e-5	1.35e-4
3.8.7 Inverters	A. One inverter inoperable	4.44e-5	5.57e-5
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	4.13e-3	4.39e-3

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Sensitivity to Recovery Probabilities

The recovery model in the DB shutdown PRA was examined to determine if there is more uncertainty in the recovery probabilities in Mode 4 than the Mode 5. The recovery probabilities are based in part on the time available, e.g., until RCS level drops due to boiling and uncovers the top of the fuel. The time to boil and uncover the core is a function of the decay heat, which is dependent on time since shutdown. The decay heat in Mode 4 is highest during the first 8 to 12 hours, when the plant is normally cooling down to Mode 5. The risk accumulated during this time is the same whether the end state is Mode 4 or Mode 5. After that time the decay heat load is the same whether the plant is in Mode 5 or Mode 4.

The RCS temperature is initially higher in Mode 4, but so is the subcooled margin. Even if the time to boil were slightly shorter in Mode 4, this difference is small relative to the time available until sufficient inventory boils off to uncover the core. The initial RCS inventory is also the same for both end states (assuming the operators have not started draining the RCS once into Mode 5). Therefore, the timing for human reliability analysis for the Mode 4 and Mode 5 end states is similar. More importantly, there is no reason to assume that uncertainty differentially affects Mode 4 recovery probabilities over Mode 5. Therefore, the sensitivity adjustment was applied to both Mode 4 and Mode 5 equally. A set of sensitivity runs was made for both modes with all of the failure probabilities for recovery increased by a factor of ten (any that were greater than 0.1 were changed to 1.0). The results are in the table below. The results of the Mode 4 versus Mode 5 end state comparison are robust even considering order of magnitude uncertainties in the recovery probability model.

**Data Sensitivity
10X Increase in Failure Probabilities for Recovery**

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	9.78e-5	1.98e-4
3.7.7 CCW	A. One CCW train inoperable	1.91e-3	4.88e-3
3.7.8 SWS	A. One SWS train inoperable	2.24e-4	1.54e-3
3.8.1 AC sources	A. One offsite circuit inoperable	4.12e-5	1.49e-4
	B. One diesel generator inoperable	2.64e-3	3.23e-3
	C. Two offsite circuits inoperable	1.21e-3	7.14e-3
	D. One offsite circuit and one diesel generator inoperable	2.44e-3	2.55e-3
	E. Two diesel generators inoperable	2.66e-2	3.14e-2
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	1.04e-4	2.25e-4
	B. Batter[y][ies] on one train inoperable	1.31e-3	1.88e-3
	C. One DC subsystem inoperable - other	1.24e-3	1.78e-3
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	3.05e-3	1.15e-2
	B. AC vital bus inoperable	1.22e-3	1.53e-3
	C. DC distribution subsystem inoperable	1.24e-3	1.78e-3
3.8.7 Inverters	A. One inverter inoperable	1.22e-3	1.53e-3
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	9.99e-3	1.25e-2

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Sensitivity to Common Cause Failure Probabilities

A set of sensitivity analysis runs was made with the DB Mode 4 and Mode 5 PRA models to investigate sensitivity to common cause failure (CCF) probability. In these runs, all of the CCF probabilities were increased by a factor of three. This adjustment was applied to both Mode 4 and Mode 5, because there is no reason why CCF would favor one end state over the other. These adjustments resulted in some very high values for the CCF parameters (i.e., "beta-factors" and other "multiple Greek letters"). Typical examples of post-adjustment beta-factors are 0.15 for HPI pump fails to start, and 0.48 for check valves fail to open. Results are shown in the table below, and demonstrate that uncertainty in CCF data does not affect robustness of results.

**Data Sensitivity
3X Increase in Common Cause Failure Probabilities**

Tech Spec	Condition	CDF of End State (/Rx-yr)	
		Mode 4	Mode 5
Base Risk	No LCO	5.86e-6	2.18e-5
3.7.7 CCW	A. One CCW train inoperable	1.24e-4	9.80e-4
3.7.8 SWS	A. One SWS train inoperable	8.74e-6	6.45e-5
3.8.1 AC sources	A. One offsite circuit inoperable	2.25e-6	1.96e-5
	B. One diesel generator inoperable	1.79e-4	2.07e-4
	C. Two offsite circuits inoperable	1.87e-4	1.21e-3
	D. One offsite circuit and one diesel generator inoperable	1.74e-4	1.91e-4
	E. Two diesel generators inoperable	1.11e-3	1.20e-3
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	6.45e-6	2.56e-5
	B. Batter[y][ies] on one train inoperable	5.99e-5	3.41e-4
	C. One DC subsystem inoperable - other	5.25e-5	2.57e-4
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	9.52e-5	1.93e-3
	B. AC vital bus inoperable	4.93e-5	6.84e-5
	C. DC distribution subsystem inoperable	5.25e-5	2.57e-4
3.8.7 Inverters	A. One inverter inoperable	4.93e-5	6.84e-5
3.4.6 RCS loops-Mode 4	A. One RCS loop inoperable	5.34e-3	5.71e-3

Additional Comments Regarding Sensitivity

The sensitivity analyses shown above demonstrate that the risk of core damage in Mode 4 is favorable compared to the risk in Mode 5, even if uncertainties are considered. In addition to these uncertainties, the adjustment that was made to the DB shutdown PRA model, so that it would include features of other B&WOG plants, shows that the results are robust even considering differences in certain plant features. These differences are discussed in BAW-2441, and are elaborated on further in the response to RAI #12-2. The alternate risk model not only shows the applicability of the Topical Report findings to the other B&WOG plants, it also is a sensitivity analysis of sorts because it demonstrates that the impact of some modeling assumptions and configuration differences do not affect the conclusions of the topical report.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Question # 12-1

Please provide risk assessment results for each individual LCO and identify any potential high risk configurations which must be allowed only in conjunction with risk management actions based on approved implementation guidance. The quantitative risk assessment results, in terms of core damage frequency (CDF), are provided only as numerical averages of several LCOs. In addition, it is stated that the Mode 4 (on SG cooling) end state is associated with less risk than the Mode 4 (on shutdown cooling (SDC)) and Mode 5 end states, for all the individual LCO conditions for which end state change is proposed. However, this information does not provide any insights about potential high risk configurations that may occur when additional equipment, beyond the one associated with the non-met LCO, is inoperable. Insights about potential high risk configurations are needed, according to applicable regulatory guidance, to identify risk management actions and ensure that the proposed changes will be safely implemented.

Response To Questions # 12-1

The risk assessment results for each individual LCO have been provided in the response to RAI #11. These risk results cover all of the LCOs that could be explicitly modeled in the PRA. As explained in BAW-2441, for some of the LCOs, the equipment of interest is not explicitly modeled in the PRA for Modes 4 and 5. These systems are not modeled in the PRA because they have a negligible or intangible contribution to CDF in these modes (e.g., boron concentration, containment). For these LCO conditions, the general trend exhibited by the modeled LCOs, and the base case (i.e., no LCO condition) is relied upon. That is, since the base case and the modeled system LCOs all show reduced CDF in Mode 4 versus Mode 5, then it is logical that the differences in CDF for the unmodeled systems are in the same direction and less significant. This taken with the qualitative analysis, supports the assertion that the CDF is better in the proposed Mode 4 end state with the RCS on SG cooling than the Mode 5 end state, for all of the proposed LCO end state changes.

Examination of the cut sets for the proposed end state (Mode 4) (see also response to RAI #14) provides a general insight into the high risk contributors for the base (non-LCO) case. The table below summarizes the top contributors for the LCO cases. Dominant contributors when in the LCOs are similar to the base cases, with the most important contributions coming from failures of the redundant or functionally redundant systems or trains. Failures that affect normal cooling (feedwater) and also backup and emergency cooling methods (i.e., DHR and ECCS) are the most important contributors. The most common reasons for those failures are cut sets involving LOOP and failure of the diesel generators, because these affect SG cooling as well as back up DHR and ECCS cooling. (Similar results would be expected for the plants that have a standby onsite power source other than diesel generators, i.e., Ocone). When the reason for being in an LCO is inoperability of one train of a safety system, (such as EDG, batteries, CCW, or SWS) then CCF of the remaining train(s) is often a risk contributor. Loss of RCS inventory events are also important contributors, especially when the LCO reduces the redundancy of the ECCS. Examination of the cut sets indicates that the equipment that dominates risk while in these LCOs are generally in the systems that are already recognized as important contributors by the TSs and for which the conditions and compensatory action statements are written. One insight that is clear is that having ECCS capability is important, even if operator actions are required to reactivate the HPI pumps. Availability of ECCS in the current Mode 5 end state is not

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

guaranteed by TSs, even though it was credited in this PRA evaluation. The systems that tended to be dominant in this risk evaluation also have high priority in the plant-specific CRMP, and are not likely to be overlooked when making preparations for maintenance activities and equipment outages.

However, it must be cautioned that insights drawn from these results can only be used for general guidance. The CRMP used by the participating B&WOG plants evaluate the potential high risk configurations in real or near-real time. This has the advantage of being able to consider the specific combinations of equipment out of service for both the LCO and the balance of the plant, and the ability to evaluate the risk for the specific plant configurations (i.e., which trains normally operating, in standby, the alignments, etc.), which are too numerous to evaluate in their entirety here. Furthermore, the LCO evaluations performed for this risk evaluation may be conservative because they assume the complete unavailability of all of the equipment associated with the particular LCO condition (such as an entire division or train), whereas the CRMP can consider the specific conditions that are applicable at the plant. Consequently, it is the B&WOG plant programs for configuration risk management that ultimately provide the assurance that risk-significant plant equipment outage configurations will not occur when equipment beyond the affected LCO is also taken out of service.

Top Mode 4 Risk Contributors⁸

Tech Spec	Condition	Top Failures Contributing to CDF
3.7.7 CCW	A. One CCW train inoperable	LOOP Station blackout (SBO) diesel or associated operator actions EDG associated with operable CCW train CCF of other CCW pumps
3.7.8 SWS	A. One SWS train inoperable	LOOP SBO Diesel or associated operator actions EDG associated with operable SWS train CCF of other SWS pump Feedwater
3.8.1 AC sources	A. One offsite circuit inoperable	LOOP EDGs SBO Diesel or associated operator actions Unaffected power bus Loss of inventory event Feedwater Operator actions (feed and bleed)
	B. One diesel generator inoperable	LOOP CCF of unaffected EDG SBO Diesel or associated operator actions Diesel support systems

⁸ Top contributors are taken from both the DB and the generic "non-DB" Mode 4 PRA models, based on Fussell-Vesely importance.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Tech Spec	Condition	Top Failures Contributing to CDF
	C. Two offsite circuits inoperable	EDGs SBO Diesel or associated operator actions Batteries Diesel-backed DHR or feed pumps Loss of inventory event Operator actions (feed and bleed)
	D. One offsite circuit and one diesel generator inoperable	LOOP CCF of unaffected EDG SBO Diesel or associated operator actions Diesel support systems
	E. Two diesel generators inoperable	LOOP SBO Diesel or associated operator actions
3.8.4 DC sources	A. Battery charger[s] on one train inoperable	LOOP EDGs SBO Diesel or associated operator actions Battery Loss of inventory event Operator actions (feed and bleed)
	B. Batter[y][ies] on one train inoperable	LOOP EDG associated with operable DC train SBO Diesel or associated operator actions CCF of other battery Unaffected power bus
	C. One DC subsystem inoperable - other	LOOP EDG associated with operable DC train SBO Diesel or associated operator actions Battery associated with operable power bus Unaffected power bus
3.8.9 AC/DC Distribution	A. AC distribution subsystem inoperable	LOOP EDG associated with operable AC subsystem SBO Diesel or associated operator actions HPI pump associated with operable AC subsystem Operator actions (feed and bleed) Feedwater
	B. AC vital bus inoperable	LOOP EDG associated with operable AC train SBO Diesel or associated operator actions Battery associated with operable power bus Unaffected power bus Loss of inventory event Operator actions (feed and bleed)
	C. DC distribution subsystem inoperable	LOOP EDG associated with operable DC train SBO Diesel or associated operator actions Battery associated with operable power bus Unaffected power bus
3.8.7 Inverters	A. One inverter inoperable	LOOP EDG associated with operable power bus SBO Diesel or associated operator actions Battery associated with operable power bus Unaffected power bus Loss of inventory event Operator actions (feed and bleed)

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Tech Spec	Condition	Top Failures Contributing to CDF
3.4.6 RCS loops- Mode 4	A. One RCS loop inoperable	DHR pump Operator actions (feed and bleed) PORV CCW pumps Floods (affecting CCW pumps)

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Question # 12-2

There are differences in the RCS pressures allowed while the plant is in Mode 4 (on SG cooling). As a consequence, following a total loss of feedwater, there will be cases where a plant may need to enter SDC from relatively high pressures. Please list the means (and required actions) the various Babcock and Wilcox-designed plants have to depressurize the RCS to SDC entry conditions and discuss how these means and actions were modeled in the risk assessments.

Response To Questions # 12-2

All plants have a pressurizer spray, PORV and pressurizer vent available to reduce RCS pressure to SDC implementation pressures. CR 3, Oconee and DB have an auxiliary high pressure spray source that allows for spray at pressures above SDC when RCPs are off.

The PORV and pressurizer vent are available via operator action from the control room. Auxiliary high pressure spray sources are available via manual operator action; actions external to the control room may be necessary depending on plant-specific designs.

Risk Assessment for other B&WOG plants

In BAW-2441 a PRA sensitivity case was made to account for the pertinent differences between DB and the other B&WOG plants, and to show that the conclusions are applicable generically to B&WOG plants. Those plant differences are discussed in BAW-2441. Briefly recapping the changes that were made to the DB model to show sensitivity to other B&WOG features, the major differences are:

- Deleted separate makeup pumps because other B&WOG plants have combined makeup and HPI.
- Reduced the Mode 4 initiating event frequency for loss of RCS inventory outside of the RB because the other B&WOG plants do not align to the SDC for LTOP in Mode 4.
- Replaced one of the two turbine-driven EFW pumps in the DB PRA with a motor-driven EFW pump.
- Deleted credit for the auxiliary boiler.

As the RAI points out, an additional difference is the higher Mode 4 starting pressure at some other B&WOG plants. As described above, in order to get onto SDC from Mode 4 there might be situations where other B&WOG plants must rely upon another means to depressurize if there is a total loss of feedwater. In the DB Mode 4 PRA model, depressurization is not necessary because the RCS is already aligned to SDC for LTOP pressure control. However, in the PRA modification that is described in BAW-2441 for the non-DB plants, the means to depressurize the RCS to initiate SDC for the case of a total loss of feedwater was inadvertently omitted. Therefore, a new modification to the non-DB sensitivity model was made to include additional modeling for RCS depressurization. Although there may be multiple ways to depressurize, the method credited in the PRA is use of the PORV. Since this change affects only Mode 4, it is conservative to ignore the other depressurization methods (discussed above) that provide backup to the PORV. Adding the PORV failure modes to the model did not have a significant effect on the Mode 4 risk results because the failure modes that dominate the cut sets tend to be power

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

system failures that cut across the mitigating systems (DHR, feedwater, ECCS) and would result in PORV failure also.

In addition to the PORV modeling addition, some other new changes were made to the non-DB shutdown PRA model to better represent the generic B&WOG plant. These include:

- Deleted credit for the non-safety motor-driven feed pump and startup feed pump because these DB pumps are not generic to all of the B&WOG units.
- The difference between the raised-loop and lowered-loop SG on the human recovery model was examined and included in the model. The human recovery probabilities are based upon calculations of time available. In the lowered-loop plants, less SG inventory is available to drain back into the RCS. This affects boil-off time until the core is uncovered, and drain time in case of a drain down event. Because of the low decay heat in the Modes 4 and 5 end states, there is plenty of time available to perform recovery actions for events where the boil off of RCS inventory is the contributing factor, even without crediting the extra SG inventory. However for drain down events, the reduced inventory may affect the time available before the RCS level reaches the DHR suction. The DB PRA credits 180,000 gallons of inventory that must be drained and boiled off before the ability to use the DHR suction is lost. Even for large leaks the time available is in excess of 2 hours. For the lowered-loop plant, the time available is less than at DB. Therefore, for recovery actions involving the time until loss of DHR suction (starting from a full RCS), the human error probability for recovery was increased to an arbitrarily conservative value of 0.1 (about two orders of magnitude worse than for DB).

These latter changes to the PRA models tended to affect the risk in Modes 4 and 5 uniformly compared to the previous results reported in BAW-2441. Hence the non-DB CDF results are revised up from the values in BAW-2441, but the relative comparison favoring Mode 4 is unchanged. The revised results for the non-DB sensitivity case are shown in a table contained in the response to RAI #11. These results should still be considered a generic approximation for the B&WOG plants because there are other less-important plant differences. However, these results demonstrate the sensitivity of the results to the most important plant configuration assumptions, and hence show that the conclusions of BAW-2441 are generically applicable to the B&WOG plants.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Question # 13

At Davis-Besse (DB) the DHR suction is aligned to the RCS before shutdown cooling is initiated (due to low temperature overpressure protection (L TOP) considerations). Thus, the draining-related risk at DB is not only associated with Mode 4 (on SG cooling) operation but also appears to be higher than during transition to Mode 5 because of the longer time the plant stays at a higher pressure where a pressure spike or LTOP valve drift can cause an LTOP valve lift. Please discuss how this feature is modeled in the risk assessments supporting the proposed end state changes.

Response To Question # 13

The initiating event frequency for loss of inventory events is described in the response to RAI #11. Since DB aligns the RCS to SDC in Mode 4 as well as Mode 5, and uses a relief valve on the SDC line for LTOP, the same initiating event frequencies are used for both Modes. Furthermore, the initiating event frequency for a loss of inventory outside of the RB in Mode 4 is higher for DB than for the other B&WOG plants. The SDC relief valves are considered the dominant contributors for a loss of inventory initiating event at DB (this is also consistent with the findings of NSAC-176L).

The initiating event frequencies used in the DB Mode 4 and Mode 5 PRA model are relatively high compared to the LOCA frequencies used in the Mode 1 PRA. This reflects the increased risk of pressure spikes and LTOP valve failure, as well as plant activity that may inadvertently result in valve misalignment. The judgment was made to use the same initiating event frequencies for both Mode 4 and Mode 5 except for the case of the loss of inventory outside of the RB prior to SDC alignment (non-DB plant model). The considerations affecting this decision are, on the one hand, pressure spikes due to higher RCS pressure may be more likely in Mode 4; however, on the other hand, containment access in Mode 4 is more limited than Mode 5 due to higher containment temperature and shorter stay times. Nonetheless, it is appropriate to examine a sensitivity case where the Mode 4 loss of RCS inventory is assigned a higher frequency than Mode 5. These sensitivity cases were run, and their results are described in the response to RAI #11.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Question # 14

Please list the initiating event categories that were considered in the risk assessments for both the current and the proposed end states. Also, please provide the base case (no LCO) dominant cutsets (e.g., top 100; less than 100 cutsets will be adequate if they are contributing to at least 90% of the end state's CDF) with a brief discussion.

Response To Question # 14

Initiating Event Categories

The shutdown PRA addresses a plant shutdown condition having two safety function events: insufficient removal of decay heat and insufficient inventory. Initiating events that can initiate an accident sequence leading to these events must originate in systems that normally provide the required support for core decay heat removal control and inventory control. While other systems may be available for recovery, they are in standby when the initiating event occurs and, therefore, cannot initiate the sequence themselves. For this reason, initiating events are those associated with failure of the DHR system, primary-to-secondary heat transfer (SG cooling), or control of the RCS inventory. The initiating event categories are summarized in the table below.

The decay heat removal function is defined as the removal of decay heat from the core using systems normally designed to perform this function. This function is performed by the DHR system and by SG cooling, depending upon operating mode. In Mode 5, the decay heat is normally removed by the DHR system. In Mode 4, the decay heat is primarily being removed by the SGs. However, each system is a backup to the other in the opposite mode.

Of the initiating events challenging the DHR system, one is unique to midloop operations (i.e., loss of RCS level control leading to vortexing at the pump suction causing loss of DHRS flow) and is therefore not applicable to the end states comparison. Other initiating events challenging the DHR system encompass any failure that prevents the DHR system from successfully performing its function. These failures could be caused by failure of a DHR pump or loss of a support system function, e.g., loss of the ultimate heat sink. Loss of DHR due to isolation of the DHR process fluid flow could be caused by inadvertent closure of DHR drop line valves due to operation of overpressure protection interlocks. Failures of DHR pumps and supporting systems can also be caused by loss of electrical power, e.g., loss of offsite power.

Initiating events challenging SG cooling encompass any failure leading to loss of the operating feedwater source. These could be caused by loss of the operating feedwater or condensate pump(s), or loss of a support system such as power source, instrument air, or cooling water.

Successful RCS inventory control is defined as maintaining inventory sufficient for adequate core cooling. There are mechanisms that can potentially cause insufficient inventory control: random RCS pipe breaks, potential stuck open DHR relief valves, and inventory drain down. Large random pipe breaks are not considered to be contributors to the shutdown risk because of their low probability for occurrence, especially in Mode 4 and Mode 5 when the RCS is cooled down and depressurized. A large loss of inventory in the DB model is assumed to be around 400 gpm (e.g., at DB, a likely location for a leak is a stuck relief valve on the DHR system, this

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

would be 100 to 200 gpm for the relief valve outside containment and 400 gpm for the relief valve inside containment). Drain down challenges to inventory control could be caused by such things as misaligning or failing to close valves, DHR system relief valve leakage following operation/testing and inappropriate maintenance practices leading to improper valve control schemes/set points. (There are also other potential drain down causes such as cold leg nozzle dam and fuel transfer canal seal plate failures that are not applicable until later shutdown operating states.) The specific causes are not modeled individually in the PRA, but are rolled up into categories.

In order to characterize the drain down initiating events, the location of diverted reactor coolant was considered. If the drain down occurs with the reactor coolant directed to the RB, then this diverted RCS inventory may be recovered for cooling and/or makeup via RB emergency sump recirculation. However, if the RC is drained to a location outside the RB, then it is assumed that this RCS inventory is lost and cannot be used for recirculation cooling or makeup. Drain down is assumed to terminate, with or without operator action, when the RCS level reaches the midpoint of the hot leg (i.e., reactor vessel failure was not considered).

Initiating Event Categories for Mode 4 and Mode 5

Initiating Event Category	Example Initiating Events Included in the PRA
Insufficient decay heat removal via DHR system	Loss of running DHR pump DHR system auto suction valve closure Loss of power bus(s) Loss of offsite power Loss of cooling water (CCW, SWS) Floods in pump rooms (DHRS, CCW, SWS)
Insufficient decay heat removal via steam generators	Loss of feedwater (MDFP, MFW, condensate as applicable) Loss of offsite power Loss of power bus(s) Loss of cooling water Loss of instrument air Floods in pump rooms
Insufficient inventory	Large loss of inventory outside RB Large loss of inventory inside RB Small loss of inventory outside RB (applies to midloop operation) Small loss of inventory inside RB (applies to midloop operation)

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Dominant Cut Sets

Attachments A and B provide the top 100 cut sets for the base case (no LCO) for the proposed (Mode 4) and current (Mode 5) end states, respectively. These cut sets were generated using the DB Mode 4 and Mode 5 PRA models. Attachments C and D provide similar information for the other B&WOG plants that was generated with the "non-DB" sensitivity model⁹.

Using the DB model, the top cut set in Mode 4 (Attachment A) is a loss of RCS inventory outside of the RB. Here the operators fail to take action to stop the drain down before losing the DHR suction (their backup cooling method) and also fail to initiate ECCS before exposing the top of the fuel.¹⁰ For these recovery actions, there is significant time estimated before the RCS level decreases enough to threaten the core, and many alerts in the mean time associated with dropping RCS level and leaking inventory. However, the events that dominate the risk for this operating mode are LOOP events with subsequent failure of onsite standby power sources (i.e., diesel generators), because the loss of power sequences cut across the primary and backup core cooling options including SG Cooling, DHR system cooling, and ECCS (feed and bleed). Collectively, the LOOP sequences make up a much greater portion of the CDF than the loss of inventory or any other sequence.

In Mode 5 (Attachment B), initiating events involving loss of the operating DHR train (i.e., SDC) are important with subsequent failure of operator recovery actions to establish backup cooling with the standby DHR train, SG cooling, or ECCS. LOOP sequences are also important contributors, for the same reason as in Mode 4. There is also a significant contribution from failure of the CCW system (sometimes from internal floods), which affects the function of the DHR and other systems.

Using the non-DB model, some of the cut sets for Mode 4 (Attachment C) are similar to the DB case. LOOP continues to be a dominant contributor, due to the ability of the loss of power sequences to cut across the lines of redundancy and defense-in-depth that are present in this operating mode. Diesel generators are assumed in this model for the onsite standby power; however similar results can be expected for plants that use other standby power sources (i.e., Oconee). The cut set involving loss of RCS inventory has a larger probability than in the DB case because of diminished credit (due to less SG inventory available to drain back into the RCS in a lowered-loop plant) for the recovery action of stopping the leak before DHR suction is lost combined with the dependent action of recovery via ECCS. Loss of feedwater is more important as an initiating event than in the DB model. There are two reasons for this: first, the non-DB model deletes credit for the backup non-safety startup feedwater pump as well as the auxiliary boiler (for the turbine-driven EFW pump). Second, it is not quite as easy to initiate DHR as in the DB plant, where it is already aligned in Mode 4.

⁹The "non-DB" model is a modified version of the DB model created to show the impact of B&WOG plant features that are different from DB.

¹⁰ Operator actions are assigned a probability of 0.1 for cut set generation (screening). Then the individual operator actions are reassigned values of 1.0 in the cut set quantification. Recovery probabilities are then generated, which are calculated for each combination of human actions that appear in the top cut sets so that dependencies can be properly accounted for. Only one recovery probability is allowed per cut set. The only exception is recovery of offsite power, which is applied independently of actions that are occurring in-plant.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

In Mode 5 (Attachment D), the non-DB PRA model also includes the loss of inventory sequences, except the initiating event frequency is higher than Mode 4 because of the alignment of SDC. Loss of DHR system initiating events are important just as in the DB model, being caused by both DHR system failures as well as failures of support systems (e.g., CCW) or related internal floods. As with all of the other cases, this case also includes LOOP sequences.

All of the cases have significant contributions from operator actions related to recovery. This is to be expected in Modes 4 and 5 because much of the plant systems are in operator control at this time. There is also significant time available to perform most operator actions because of the low decay heat levels relative to the heat removal requirements at power. Nonetheless, operator action probabilities carry a relatively high level of uncertainty. The sensitivity analyses presented in response to RAI #11 should be beneficial in demonstrating the robustness of results in light of these uncertainties. In addition, examination of the cut sets should be informative in demonstrating the defense in depth that is present with respect to operator recovery options that are available in the current and proposed end states. In most cases, these include startup of the standby DHR train(s), establishing SG cooling or backup feedwater sources, and establishing ECCS cooling. The PRA takes credit for these options in Mode 4 and (conservatively) in Mode 5 as well, although from a Technical Specifications perspective, the minimum equipment requirements in Mode 4 operation do not apply (and are therefore voluntary) in Mode 5.

Response to: Request For Additional Information Regarding BAW-2441, "Risk-Informed Justification For LCO End-State Changes"

Question # 15

The quantitative risk assessments do not include external events, such as seismic, internal fires and internal floods. This implies that it is assumed that the results and conclusions would not change had external event risks been considered. Please provide arguments to justify this assumption.

Response To Question # 15

The DB PRA, which was used as the basis for this risk assessment, does include internal floods. However, it does not include fires, seismic, or other external events. While internal floods do not represent a comprehensive list of external events, they do provide some assurance that the results are robust when considering the types of failures that external events can cause, such as those that reach across systems or trains.

For fires, Appendix R evaluations address the safe shutdown requirements. Consequently, the operating procedures are designed to deal with fires. The operators will deal with fires occurring in Mode 4 and Mode 5 similarly, although the minimum complement of safety system equipment that is guaranteed by TSs in Mode 4 provides additional assurance of success for fires and all external events.

With respect to seismic events, a seismic PRA is not available for Modes 4 and 5. However, examination of the PRA in light of which equipment is seismically qualified provides some insights. For DB, the non-safety feedwater pumps that may be used in Modes 4 and 5 are non-seismic. The turbine-driven EFW pump could be used, and is more likely to be useful in Mode 4, but is not credited in this risk assessment without the auxiliary boiler. The DHR system and ECCS and their support systems are seismic and can be relied upon in both modes. Since the DHR system is already aligned to the RCS in Mode 4, it will be immediately available. Therefore the expectation for DB is that the risk profiles should be similar for the unlikely seismic event occurring in Modes 4 or 5.

For the other B&WOG plants, the addition of the motor-driven EFW pump(s) improves the likelihood of success of SG cooling during a Mode 4 or Mode 5 seismic event. Therefore, the systems that are generally relied upon in the PRA, that is EFW, the DHR system, ECCS, cooling water systems, and the onsite standby power sources, can be expected to be available in a seismic event. Hence the relative Mode 4 and Mode 5 risk for a seismic event is expected to be in similar proportion to what has been estimated for non-seismic initiating events.

In summary, although the risk is not quantified for every external event, the risk should be lower in Mode 4 because more core cooling options are likely to be available to the operators (see RAI #2), and there are minimum safety equipment requirements dictated by TS. With more options available to start with, there is less likelihood in Mode 4 than Mode 5 that all redundancy and defense-in-depth will be defeated by the external event.

Attachment A

**Top 100 Cut Sets for the Base Case (no LCO) for the
Proposed End State (Mode 4)**

Davis-Besse Model

Cutsets with Descriptions Report

MODE-4 = 3.37E-06

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
1	1.26E-07	1.26E-02				1.26E-2		IE-SVL2	Large Loss of Inventory Outside of Reactor Building
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-05						SDHADHR5AE	
2	1.12E-07	1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
3	1.08E-07	8.34E-02	3	3.630E-03	H	24	H	SDOP007R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00				1.00		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						MODE-4-FLAG	MODE 4 (FLAG)
4	8.60E-08	1.00E-01				1.00E-01		SDHASBLOR	
		3.10E-03						T3	Loss of offsite power <initiating event>
		1.55E-02				1.55E-02		SDOP001R	
		3.51E-03	1	3.510E-03		1		EDG0SBOA	SBODG FAILS TO START
		9.30E-02				.093		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
5	8.41E-08	1.00E+00				1.00		EMFDLTA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		8.41E-03				8.41E-3		IE-SVL1	Large Loss of Inventory Inside of Reactor Building
6	7.95E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-05						SDHADHR5AE	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
6	7.95E-08	4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
7	6.37E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
8	5.50E-08	5.90E-03						SDOP003R	
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
9	5.50E-08	5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
10	5.30E-08	1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
11	5.02E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
12	4.93E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.50E-02						SDOP006R	
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
13	4.87E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
14	4.08E-08	1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
15	3.87E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
16	3.87E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
17	3.77E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
18	2.96E-08	2.50E-02						SDOP006R	
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
19	2.75E-08	5.90E-03						SDOP003R	
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02					SDOP005R		

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
20	2.53E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
21	2.52E-08	1.70E-01						SDOP007R	
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
22	2.31E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
23	2.29E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.50E-02						SDOP006R	
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
24	2.12E-08	3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.40E-03						SDOP002R	
25	1.97E-08	2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
26	1.97E-08	2.20E-02						SDOP005R	
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
26	1.97E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)		
1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>		
5.90E-03						SDOP003R			

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
27	1.96E-08	4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
28	1.96E-08	9.70E-03						SDOP004R	
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
29	1.96E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
30	1.95E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
31	1.94E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
32	1.80E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
33	1.79E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
34	1.74E-08	4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
35	1.74E-08	4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
36	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMF1521A	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
37	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMF1522A	MOTOR-DRIVEN FAN C152-2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
38	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFSBOAA	SBODG MOTOR-DRIVEN FAN A FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
39	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFSBOBA	SBODG MOTOR-DRIVEN FAN B FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01					SDOP007R		

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
40	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6000N	MOTOR-OPERATED CV 6000 DAMPER FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
41	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6001N	MOTOR-OPERATED DAMPER CV 6001 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
42	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6002N	MOTOR-OPERATED CV 6002 DAMPER FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
43	1.44E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
44	1.44E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
45	1.42E-08	3.50E-03	1	3.500E-03		1		EMDZ091N	MOTOR DAMPER HV5329A FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
46	1.42E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.50E-03	1	3.500E-03		1		EMDZ097N	MOTOR DAMPER HV5329C FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
47	1.42E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.50E-03	1	3.500E-03		1		EMDZ119N	MOTOR DAMPER HV5336A FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
48	1.42E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.50E-03	1	3.500E-03		1		EMDZ121N	NO CONTROL POWER (AC & DC) TO EDG 1-
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
49	1.38E-08	4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
50	1.38E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		3.77E-05	3	1.570E-06	H	24	H	EB200D2F	BUS D2 LOCAL FAULTS
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
51	1.34E-08	1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		2.18E-01	5	5.870E-06	H	87600	H	FAV2955F	AOV CT 2955 FAILS TO OPERATE
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.50E-03	1	3.500E-03		1		EMDZ119N	MOTOR DAMPER HV5336A FAILS TO OPEN
52	1.25E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
53	1.25E-08	1.36E-02	1	1.360E-02	1	1		EDG0011A	EDG 1-1 FAILS TO START
		1.55E-02						EDG0SBOA	SBODG FAILS TO START
		3.50E-03						EMDZ121N	NO CONTROL POWER (AC & DC) TO EDG 1-
		1.00E+00						MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01						T3	Loss of offsite power <initiating event>
54	1.25E-08	1.36E-02	1	1.360E-02	1	1		SDOP007R	EDG 1-2 FAILS TO START
		1.55E-02						EDG0012A	SBODG FAILS TO START
		3.50E-03						EDG0SBOA	MOTOR DAMPER HV5329A FAILS TO OPEN
		1.00E+00						EMDZ091N	MODE 4 (FLAG)
		1.00E-01						MODE-4-FLAG	Loss of offsite power <initiating event>
55	1.25E-08	1.36E-02	1	1.360E-02	1	1		T3	EDG 1-2 FAILS TO START
		1.55E-02						EDG0012A	SBODG FAILS TO START
		3.50E-03						EDG0SBOA	MOTOR DAMPER HV5329C FAILS TO OPEN
		1.00E+00						EMDZ097N	MODE 4 (FLAG)
		1.00E-01						MODE-4-FLAG	Loss of offsite power <initiating event>
56	1.20E-08	1.36E-02	1	1.360E-02	1	1		SDOP007R	EDG 1-1 FAILS TO START
		1.36E-02						EDG0012A	EDG 1-2 FAILS TO START
		2.95E-02						EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00						MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01						T3	Loss of offsite power <initiating event>
57	1.17E-08	2.20E-02	1	3.510E-03	1	1		SDOP005R	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		3.51E-03						EMF1521A	ANY ONE EDG VENT FAN FAILS TO START
		3.51E-03						EMFCC19A	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		9.30E-02						EMFDLTAA	MODE 4 (FLAG)
		1.00E+00						MODE-4-FLAG	Loss of offsite power <initiating event>
58	1.17E-08	1.00E-01	1	3.510E-03	1	1		T3	AMBIENT TEMPERATURE IS> 40
		6.02E-01						XHOS-AMB->40F	SDOP007R
		1.70E-01						EMF1522A	MOTOR-DRIVEN FAN C152-2 FAILS TO START
		3.51E-03						EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		3.51E-03						EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
59	1.17E-08	1.00E+00	1	3.510E-03	1	1		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01						T3	Loss of offsite power <initiating event>
		6.02E-01						XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	ANY ONE EDG VENT FAN FAILS TO START
		3.51E-03						EMFCC19A	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
60	1.17E-08	3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		3.51E-03	1	3.510E-03		1		EMFSBOBA	SBODG MOTOR-DRIVEN FAN B FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
61	1.17E-08	3.50E-03	1	3.500E-03		1		EMD6000N	MOTOR-OPERATED CV 6000 DAMPER FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
62	1.17E-08	3.50E-03	1	3.500E-03		1		EMD6001N	MOTOR-OPERATED DAMPER CV 6001 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
63	1.17E-08	3.50E-03	1	3.500E-03		1		EMD6002N	MOTOR-OPERATED CV 6002 DAMPER FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
64	1.10E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.70E-01						SDOP007R	
65	1.10E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.70E-01						SDOP007R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
66	1.08E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMF1521A	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
67	1.08E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMF1522A	MOTOR-DRIVEN FAN C152-2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
68	1.08E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFSBOAA	SBODG MOTOR-DRIVEN FAN A FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
69	1.08E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFSBOBA	SBODG MOTOR-DRIVEN FAN B FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
70	1.08E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBC1E	OPERATORS FAILS TO START SBODG AND ALIGN TO BUS C1
		1.00E+00	1	1.000E+00		0.1		EHASBD1E	OPERATORS FAIL TO START SBODG AND ALIGN TO BUS D1
		1.00E+00	1	1.000E+00		0.1		EHASBDGE	OPERATORS FAIL TO LINE UP SBODG TO BUS D2
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.50E-03						SDHASBD1E	
71	1.08E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.50E-03	1	3.500E-03		1		EMD6000N	MOTOR-OPERATED CV 6000 DAMPER FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40		
1.70E-01						SDOP007R			

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
72	1.08E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.50E-03	1	3.500E-03		1		EMD6001N	MOTOR-OPERATED DAMPER CV 6001 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
73	1.08E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.50E-03	1	3.500E-03		1		EMD6002N	MOTOR-OPERATED CV 6002 DAMPER FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
74	9.96E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.50E-03	1	3.500E-03		1		EMDZ091N	MOTOR DAMPER HV5329A FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
75	9.96E-09	1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.50E-03	1	3.500E-03		1		EMDZ097N	MOTOR DAMPER HV5329C FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
76	9.96E-09	3.50E-03	1	3.500E-03		1		EMDZ119N	MOTOR DAMPER HV5336A FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.50E-03	1	3.500E-03		1		EMDZ121N	NO CONTROL POWER (AC & DC) TO EDG 1-
77	9.96E-09	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.50E-03	1	3.500E-03		1		EMDZ121N	NO CONTROL POWER (AC & DC) TO EDG 1-
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
78	9.42E-09	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		3.77E-05	3	1.570E-06	H	24	H	EB200D2F	BUS D2 LOCAL FAULTS
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		1.53E-01				.153		FCIRCTMP	CIRC WATER TEMPERATURE NOT ACCEPTABLE
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)		

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
79	8.76E-09	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
80	8.76E-09	2.20E-02						SDOP005R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
81	8.74E-09	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
82	8.74E-09	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
83	8.68E-09	3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
84	8.68E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMF1521A	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
85	8.68E-09	5.90E-03						SDOP003R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMF1522A	MOTOR-DRIVEN FAN C152-2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
85	8.68E-09	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		5.90E-03						SDOP003R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
85	8.68E-09	3.51E-03	1	3.510E-03		1		EMFSBOAA	SBODG MOTOR-DRIVEN FAN A FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		5.90E-03						SDOP003R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
86	8.68E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMFSBOBA	SBODG MOTOR-DRIVEN FAN B FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		5.90E-03						SDOP003R	
87	8.65E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.50E-03	1	3.500E-03		1		EMD6000N	MOTOR-OPERATED CV 6000 DAMPER FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		5.90E-03						SDOP003R	
88	8.65E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.50E-03	1	3.500E-03		1		EMD6001N	MOTOR-OPERATED DAMPER CV 6001 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		5.90E-03						SDOP003R	
89	8.65E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.50E-03	1	3.500E-03		1		EMD6002N	MOTOR-OPERATED CV 6002 DAMPER FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40.
		5.90E-03						SDOP003R	
90	8.32E-09	1.00E+00	1	1.000E+00		0.1		EHASBC1E	OPERATORS FAILS TO START SBODG AND ALIGN TO BUS C1
		1.00E+00	1	1.000E+00		0.1		EHASBD1E	OPERATORS FAIL TO START SBODG AND ALIGN TO BUS D1
		1.00E+00	1	1.000E+00		0.1		EHASBDGE	OPERATORS FAIL TO LINE UP SBODG TO BUS D2
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.50E-03						SDHASBD1E	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
91	8.25E-09	4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
2.50E-02						SDOP006R			

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
92	8.25E-09	4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
93	7.69E-09	2.50E-02						SDOP006R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		1.00E+00	1	1.000E+00		0.1		EHASBC1E	OPERATORS FAILS TO START SBODG AND ALIGN TO BUS C1
		1.00E+00	1	1.000E+00		0.1		EHASBD1E	OPERATORS FAIL TO START SBODG AND ALIGN TO BUS D1
		1.00E+00	1	1.000E+00		0.1		EHASBDGE	OPERATORS FAIL TO LINE UP SBODG TO BUS D2
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.50E-03						SDHASBD1E	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
94	7.10E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.51E-03	1	3.510E-03		1		EMFZ170A	VENT FAN 1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
95	7.10E-09	5.00E-01				.5		XHOS-AMB->68F	OUTSIDE AMBIENT TEMPERATURE > 68 F
		9.70E-03						SDOP004R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.51E-03	1	3.510E-03		1		EMFZ172A	VENT FAN 2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.00E-01				.5		XHOS-AMB->68F	OUTSIDE AMBIENT TEMPERATURE > 68 F
		9.70E-03						SDOP004R	
96	7.10E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.51E-03	1	3.510E-03		1		EMFZ163A	VENT FAN 3 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.00E-01				.5		XHOS-AMB->68F	OUTSIDE AMBIENT TEMPERATURE > 68 F
		9.70E-03						SDOP004R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
97	7.10E-09	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.51E-03	1	3.510E-03		1		EMFZ165A	VENT FAN 4 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.00E-01				.5		XHOS-AMB->68F	OUTSIDE AMBIENT TEMPERATURE > 68 F
98	7.04E-09	9.70E-03						SDOP004R	
		4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
99	7.04E-09	4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
100	6.70E-09	5.90E-03						SDOP003R	
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03					SDOP003R		

Report Summary:

Filename: C:\init 1\base mode4\basecase\MODE-4.CUT

Print date: 2/2/2005 2:53 PM

Not sorted

Attachment B

**Top 100 Cut Sets for the Base Case (no LCO) for the Current
End State (Mode 5)**

Davis-Besse Model

Cutsets with Descriptions Report

SPOS-A = 1.18E-05

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
1	1.45E-06	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		4.30E-06						SDHAC306E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
2	1.45E-06	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		4.30E-06						SDHAC307E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
3	3.79E-07	3.37E-01				.337		IE-LMPP42XF	DHR Pump Fails to Run
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		5.35E-02				0.0535		LMPBETAF	CC FACTOR FOR LPI PUMPS FAILING TO RUN
		2.10E-05						SDHAC209E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
4	3.79E-07	3.37E-01				.337		IE-LMPP42XF	DHR Pump Fails to Run
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		5.35E-02				0.0535		LMPBETAF	CC FACTOR FOR LPI PUMPS FAILING TO RUN
		2.10E-05						SDHAC213E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
5	3.37E-07	1.00E+00				0.1		LHADH10E	Operator Fails to Initiate Recirculation
		1.00E+00				.1		LHADHR13E	Failure to recover DHR
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR8E	Oper fails to align & start a system to refill BWST
		1.00E+00				.1		LHADHR9E	Oper fails to align altern pump to refill BWST
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		1.00E-06						SDHAC308E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
6	1.64E-07	4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		4.10E-04						SDHADHR4E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
7	1.39E-07	1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		3.51E-02				.0351		FMPBETAF	CC FACTOR FOR TPCW PUMPS FAILING TO RUN
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
8	1.31E-07	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
9	1.26E-07	4.10E-04						SDHADHR4E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.26E-02				1.26E-2		IE-SVL2	Large Loss of Inventory Outside of Reactor Building
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
10	1.25E-07	1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		1.00E-05						SDHADHR5AE	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		4.00E-04	1	3.040E-03		4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
11	1.17E-07	3.04E-03				1		FV011XN	AVV FAILS TO OPEN
		1.03E-01				.103		FVVBETAN	CC FACTOR FOR AVVs FAILING TO OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
12	1.14E-07	1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		4.10E-04						SDHADHR4E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP30F3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
13	1.14E-07	1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
13	1.14E-07	1.00E-06						SDHAC404E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.14E-01				1.14E-01	H	TMPP431F	CCW PUMP 1-1 FAILS TO RUN
		1.00E+00				5.8E-03		WHASPREE	FAILURE TO RECOVER CCW USING THE SPARE CCW TRAIN
13	1.14E-07	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E-06						SDHAC405E	
13	1.14E-07	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.14E-01				1.14E-01	H	TMPP431F	CCW PUMP 1-1 FAILS TO RUN
		1.00E+00				5.8E-03		WHASPREE	FAILURE TO RECOVER CCW USING THE SPARE CCW TRAIN

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
14	1.12E-07	1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.70E-01						SDOP007R	
15	1.11E-07	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		3.51E-02				.0351		FMPBETAF	CC FACTOR FOR TPCW PUMPS FAILING TO RUN
16	1.08E-07	9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
17	1.00E-07	1.00E+00				1.00		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		3.10E-03						SDOP001R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
18	9.90E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		3.04E-03	1	3.040E-03		1		FVV011XN	AVV FAILS TO OPEN
		1.03E-01				.103		FVVBETAN	CC FACTOR FOR AVVs FAILING TO OPEN
19	9.90E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.51E-02				.0351		FMPBETAF	CC FACTOR FOR TPCW PUMPS FAILING TO RUN
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
20	9.90E-08	2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
21	9.21E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E-06						SDHAC404E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		9.90E-02	3	1.190E-05	H	8760	H	TTC1424T	TEMP CONTROL VALVE SW1424 FAILS TO THROTTLE (1 YEAR MISSION TIME)
22	9.90E-08	1.00E+00				5.8E-03		WHASPREE	FAILURE TO RECOVER CCW USING THE SPARE CCW TRAIN
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
23	9.21E-08	1.00E-06						SDHAC405E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		9.90E-02	3	1.190E-05	H	8760	H	TTC1424T	TEMP CONTROL VALVE SW1424 FAILS TO THROTTLE (1 YEAR MISSION TIME)
		1.00E+00				5.8E-03		WHASPREE	FAILURE TO RECOVER CCW USING THE SPARE CCW TRAIN
24	9.21E-08	9.30E-06				9.3E-6		F2DM	Maximum flood in room 53 from cooling tower makeup <initiating event>
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		1.00E+00				0.1		SHAF2ISE	FAILURE TO ISOLATE FLOOD BEFORE SERVICE WATER PUMPS ARE AFFECTED
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
22	8.92E-08	3.04E-03	1	3.040E-03		1		FVV011XN	AVV FAILS TO OPEN
		1.03E-01				.103		FVVBETAN	CC FACTOR FOR AVVs FAILING TO OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01		H TMPT14BF	CCW PUMP FAILS TO RUN
23	8.60E-08	1.55E-02	1	3.510E-03		1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.51E-03				1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
24	8.41E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		8.41E-03				8.41E-3		IE-SVL1	Large Loss of Inventory Inside of Reactor Building
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		1.00E-05						SDHADHR5AE	
25	8.22E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		8.30E-06				8.3E-6		F2BM	Maximum flood in room 53 from failure of SW1395 or SW1399 <initiating event>
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
26	7.95E-08	4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
27	7.51E-08	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E-06						SDHAC406E	
		1.00E+00				0.1		SHADILPE	OPERATORS FAIL TO RECOVER SW WITH DILUTION PUMP
28	7.51E-08	1.00E+00				1.2E-3		SHASTBTE	OPERATORS FAIL TO RECOVER SW WITH SPARE SW PUMP
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		7.51E-02				7.51E-02		TMPP301F	SW PUMP 1-1 FAILS TO RUN (1 YEAR MISSION TIME)
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E-06						SDHAC407E	
		1.00E+00				0.1		SHADILPE	OPERATORS FAIL TO RECOVER SW WITH DILUTION PUMP
		1.00E+00				1.2E-3		SHASTBTE	OPERATORS FAIL TO RECOVER SW WITH SPARE SW PUMP
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		7.51E-02				7.51E-02		TMPP301F	SW PUMP 1-1 FAILS TO RUN (1 YEAR MISSION TIME)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
29	7.43E-08	2.50E-05				2.5E-5		F2CM	Maximum flood in room 53 from service water return <initiating event>
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		1.00E+00				0.1		SHAF2ISE	FAILURE TO ISOLATE FLOOD BEFORE SERVICE WATER PUMPS ARE AFFECTED
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.00E-01				0.3		ZHAF2CME	HUMAN ACTION (DURING EVENT)
30	6.91E-08	3.82E-01				.382		NOT-SWSUM-SWWIN	OUTSIDE AMBIENT TEMP BETWEEN 40-86
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		3.10E-03						SDHADILPE	
		1.00E+00				0.1		SHADILPE	OPERATORS FAIL TO RECOVER SW WITH DILUTION PUMP
		7.65E-02	3	9.090E-06	H	8760	H	SMF0T12F	SW PUMP ROOM FAN FAILS TO RUN
31	6.40E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		7.70E-02				.077		TMF4OF4F	COMMON CAUSE FACTOR FOR 4 OF 4 SW PMP ROOM VENT FANS FAILING TO RUN
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
32	6.40E-08	1.49E-02	2	3.400E-06	H	8760	H	LHXIE11P	DH COOLER 1-1 FAILS DURING OPERATION (Initiating Event)
		4.30E-06						SDHAC306E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
33	6.37E-08	1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.49E-02	2	3.400E-06	H	8760	H	LHXIE11P	DH COOLER 1-1 FAILS DURING OPERATION (Initiating Event)
		4.30E-06						SDHAC307E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
34	5.87E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		5.90E-03						SDOP003R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
35	5.87E-08	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		4.30E-06						SDHAC306E	
		1.00E+00	3	1.570E-06	H	8760	H	SPOS-A-FLAG	SPOSA (FLAG)
35	5.87E-08	1.37E-02						TB200C1F	BUS C1 LOCAL FAULTS
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		4.30E-06						SDHAC307E	
35	5.87E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.37E-02	3	1.570E-06	H	8760	H	TB200C1F	BUS C1 LOCAL FAULTS

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
36	5.74E-08	1.40E-04				1.4E-4		F2CL	Large flood in room 53 from service water return <initiating event>
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		4.10E-04						SDHADHR4E	
		1.00E+00				0.1		SHAF2ISE	FAILURE TO ISOLATE FLOOD BEFORE SERVICE WATER PUMPS ARE AFFECTED
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
37	5.50E-08	1.36E-02	1	1.360E-02				EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		9.70E-03						SDOP004R	
38	5.50E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
39	5.30E-08	5.00E-02						SDHASBLOR	
		9.70E-03						SDOP004R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
40	5.30E-08	1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		2.50E-02						SDOP006R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
41	5.02E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		5.24E-03	1	5.240E-03		1		RRZRC2AN	PORV (RC2A) FAILS TO OPEN
42	4.93E-08	3.00E-05						SDHAC210E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
42	4.93E-08	5.00E-02						SDHASBLOR	
		3.10E-03						SDOP001R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
42	4.93E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		2.95E-02				2.95E-02		EDGOSBOF	SBODG FAILS TO RUN
		2.40E-03						SDOP002R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
43	4.87E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
44	4.80E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		1.12E-02	2	2.550E-06	H	8760		LAVIE4BK	DH14B FAILS TO REMAIN OPEN (Initiating Event)
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR2E	Operators fail to Recover from Inadvertent Isolation of Decay Heat
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		4.30E-06						SDHAC306E	
45	4.80E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.12E-02	2	2.550E-06	H	8760		LAVIE4BK	DH14B FAILS TO REMAIN OPEN (Initiating Event)
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR2E	Operators fail to Recover from Inadvertent Isolation of Decay Heat
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		4.30E-06						SDHAC307E	
46	4.80E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		4.30E-06						SDHAC306E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.12E-02	2	2.550E-06	H	8760	H	WAVIE67K	AOV CC 1467 FAILS TO REMAIN OPEN (Initiating Event)
47	4.80E-08	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		4.30E-06						SDHAC307E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.12E-02	2	2.550E-06	H	8760	H	WAVIE67K	AOV CC 1467 FAILS TO REMAIN OPEN (Initiating Event)
		1.40E-04				1.4E-4		F2CL	Large flood in room 53 from service water return <initiating event>
48	4.16E-08	9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		1.00E+00				0.1		SHAF2ISE	FAILURE TO ISOLATE FLOOD BEFORE SERVICE WATER PUMPS ARE AFFECTED
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.00E-02				3E-2		ZHAF2CLE	HUMAN ACTION (DURING EVENT)
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
49	4.08E-08	5.00E-02						SDHASBLOR	
		2.50E-02						SDOP006R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
50	3.87E-08	3.37E-01				.337		IE-LMPP42XF	DHR Pump Fails to Run
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		5.35E-02				0.0535		LMPBETAF	CC FACTOR FOR LPI PUMPS FAILING TO RUN
		5.24E-03	1	5.240E-03		1		RRZRC2AN	PORV (RC2A) FAILS TO OPEN
		4.10E-04						SDHADHR4E	
51	3.87E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		2.20E-02						SDOP005R	
52	3.87E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
53	3.77E-08	2.20E-02						SDOP005R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
54	3.28E-08	1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		2.50E-02						SDOP006R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
55	3.13E-08	3.51E-02				.0351		FMPBETAF	CC FACTOR FOR TPCW PUMPS FAILING TO RUN
		3.37E-01				.337		IE-LMPP42XF	DHR Pump Fails to Run
		5.35E-02				0.0535		LMPBETAF	CC FACTOR FOR LPI PUMPS FAILING TO RUN
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		5.24E-03	1	5.240E-03		1		RRZRC2AN	PORV (RC2A) FAILS TO OPEN
56	3.07E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.02E-03				1.020E-03		F1A	MAXIMUM OR LARGE FLOOD IN ROOM 52 FROM SERVICE WATER <INITIATING EVENT>
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		3.10E-03						SDHADILPE	
		1.00E+00				0.1		SHADILPE	OPERATORS FAIL TO RECOVER SW WITH DILUTION PUMP
56	3.07E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		4.34E-03				4.34E-03		LMPP422A	FAILURE OF DECAY HEAT PUMP 1-2 TO START
2.10E-05						SDHAC209E			
1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)		

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
57	3.07E-08	1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		4.34E-03				4.34E-03		LMPP422A	FAILURE OF DECAY HEAT PUMP 1-2 TO START
		2.10E-05						SDHAC213E	
58	2.96E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		5.90E-03						SDOP003R	
59	2.96E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.04E-03	1	3.040E-03		1		FVV011XN	AVV FAILS TO OPEN
		1.03E-01				.103		FVVBETAN	CC FACTOR FOR AVVs FAILING TO OPEN
		3.37E-01				.337		IE-LMPP42XF	DHR Pump Fails to Run
60	2.93E-08	5.35E-02				0.0535		LMPBETAF	CC FACTOR FOR LPI PUMPS FAILING TO RUN
		5.24E-03	1	5.240E-03		1		RRZRC2AN	PORV (RC2A) FAILS TO OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
61	2.93E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E-06						SDHAC404E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.93E-02	3	3.400E-06	H	8760	H	THXE221P	CCW HEAT EXCHANGER PLUGS DURING OPERATION
		1.00E+00				5.8E-03		WHASPREE	FAILURE TO RECOVER CCW USING THE SPARE CCW TRAIN
62	2.88E-08	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E-06						SDHAC405E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
63	2.81E-08	2.93E-02	3	3.400E-06	H	8760	H	THXE221P	CCW HEAT EXCHANGER PLUGS DURING OPERATION
		1.00E+00				5.8E-03		WHASPREE	FAILURE TO RECOVER CCW USING THE SPARE CCW TRAIN
		3.82E-01				.382		NOT-SWSUM-SWWIN	OUTSIDE AMBIENT TEMP BETWEEN 40-86
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		7.65E-02	3	9.090E-06	H	8760	H	SMF0T12F	SW PUMP ROOM FAN FAILS TO RUN
63	2.81E-08	1.29E-03				1.29E-03		SMPP180A	DILUTION PUMP FAILS TO START
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		7.70E-02				.077		TMF4OF4F	COMMON CAUSE FACTOR FOR 4 OF 4 SW PMP ROOM VENT FANS FAILING TO RUN
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		3.51E-02				.0351		FMPBETAF	CC FACTOR FOR TPCW PUMPS FAILING TO RUN
63	2.81E-08	2.00E-03				2.0E-03		QHAMDPL	MDFP MISALIGNED AFTER TEST/MAINT
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
64	2.75E-08	2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		2.20E-02						SDOP005R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
65	2.73E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		2.10E-05						SDHAC209E	
66	2.73E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		2.10E-05						SDHAC213E	
67	2.53E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.70E-01						SDOP007R	
68	2.52E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
69	2.38E-08	1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		5.80E-05				5.8E-5		F2BL	Large flood in room 53 from failure of SW1395 or SW1399 <initiating event>
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
70	2.31E-08	4.10E-04						SDHADHR4E	
		1.00E+00				0.1		SHAF2ISE	FAILURE TO ISOLATE FLOOD BEFORE SERVICE WATER PUMPS ARE AFFECTED
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		2.50E-02						SDOP006R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
71	2.29E-08	2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24		H EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		2.40E-03						SDOP002R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
72	2.25E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		3.51E-02				.0351		FMPBETAF	CC FACTOR FOR TPCW PUMPS FAILING TO RUN
		2.00E-03				2.0E-03		QHAMDPL	MDFP MISALIGNED AFTER TEST/MAINT
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
73	2.12E-08	2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		2.20E-02						SDOP005R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
74	2.04E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		2.88E-03	2	2.550E-06	H	2256	H	LAV013AR	AOV DH 13A FAILS TO REMAIN CLOSED
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
75	2.04E-08	2.88E-03	2	2.550E-06	H	2256	H	SDHAC209E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		LAV013AR	AOV DH 13A FAILS TO REMAIN CLOSED
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		3.37E-01				.337		LHADHR6E	Operator fails to open PORV
76	2.04E-08	2.88E-03	2	2.550E-06	H	2256	H	LMPIE21F	DHR Pump 1 Fails to Run
		1.00E+00				1.00		SDHAC213E	
		1.00E+00				0.1		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		LAV014AK	AOV DH 14A FAILS TO REMAIN OPEN
		3.37E-01				.337		LHADHR4E	Operator fails to establish prim to sec heat transfer
77	2.04E-08	2.88E-03	2	2.550E-06	H	2256	H	LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				1.00		LMPIE21F	DHR Pump 1 Fails to Run
		1.00E+00				0.1		SDHAC209E	
		1.00E+00				0.1		SPOS-A-FLAG	SPOSA (FLAG)
		3.37E-01				.337		LAV014AK	AOV DH 14A FAILS TO REMAIN OPEN
78	2.00E-08	2.88E-03	2	2.550E-06	H	2256	H	LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				0.1		LMPIE21F	DHR Pump 1 Fails to Run
		3.37E-01				.337		SDHAC213E	
		2.10E-05				1.00		SPOS-A-FLAG	SPOSA (FLAG)
78	2.00E-08	3.51E-02				.0351		FMPBETAF	CC FACTOR FOR TPCW PUMPS FAILING TO RUN
		2.00E-03				2.0E-03		QHAMDPL	MDFP MISALIGNED AFTER TEST/MAINT
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
79	1.97E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		5.90E-03						SDOP003R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
80	1.97E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		5.90E-03						SDOP003R	
81	1.96E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
82	1.96E-08	5.00E-02						SDHASBLOR	
		9.70E-03						SDOP004R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
83	1.96E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		9.70E-03						SDOP004R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
84	1.95E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		2.20E-02						SDOP005R	
85	1.94E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
85	1.94E-08	1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
85	1.94E-08	9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
86	1.80E-08	3.37E-01				.337		IE-LMPP42XF	DHR Pump Fails to Run
		1.00E+00				0.1		LHADH10E	Operator Fails to Initiate Recirculation
		1.00E+00				.1		LHADHR13E	Failure to recover DHR
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR8E	Oper fails to align & start a system to refill BWST
		1.00E+00				.1		LHADHR9E	Oper fails to align altern pump to refill BWST
		5.35E-02				0.0535		LMPBETAF	CC FACTOR FOR LPI PUMPS FAILING TO RUN
		1.00E-06						SDHAC313E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
87	1.80E-08	4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
88	1.79E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
89	1.76E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		4.10E-03				4.1E-03		F4	Flood in ECCS pump room 101 (& 105) from aux bldg drainage <initiating event>
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
90	1.76E-08	4.30E-06						SDHAC306E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		4.10E-03				4.1E-03		F4	Flood in ECCS pump room 101 (& 105) from aux bldg drainage <initiating event>
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
91	1.74E-08	1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		4.30E-06						SDHAC307E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
92	1.74E-08	1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
93	1.73E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBC1E	OPERATORS FAILS TO START SBODG AND ALIGN TO BUS C1
		1.00E+00	1	1.000E+00		0.1		EHASBD1E	OPERATORS FAIL TO START SBODG AND ALIGN TO BUS D1
		1.00E+00	1	1.000E+00		0.1		EHASBDGE	OPERATORS FAIL TO LINE UP SBODG TO BUS D2
		2.40E-03						SDHASBD1E	
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
94	1.73E-08	1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBC1E	OPERATORS FAILS TO START SBODG AND ALIGN TO BUS C1
		1.00E+00	1	1.000E+00		0.1		EHASBD1E	OPERATORS FAIL TO START SBODG AND ALIGN TO BUS D1
		2.40E-03						SDHASBD1E	
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBC1E	OPERATORS FAILS TO START SBODG AND ALIGN TO BUS C1
95	1.72E-08	1.00E+00	1	1.000E+00		0.1		EHASBD1E	OPERATORS FAIL TO START SBODG AND ALIGN TO BUS D1
		2.40E-03						SDHASBD1E	
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		1.00E+00	1	1.000E+00		0.1		XHACLDNE	OPERATORS FAIL TO COOLDWN MANUALLY ON AVVS
		5.80E-05				5.8E-5		F2BL	Large flood in room 53 from failure of SW1395 or SW1399 <initiating event>
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		1.00E+00				0.1		SHAF2ISE	FAILURE TO ISOLATE FLOOD BEFORE SERVICE WATER PUMPS ARE AFFECTED
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
96	1.72E-08	3.00E-02				3e-2		ZHAF2BLE	HUMAN ACTION (DURING EVENT)
		3.82E-01				.382		NOT-SWSUM-SWWIN	OUTSIDE AMBIENT TEMP BETWEEN 40-86
		9.90E-03				9.90E-03		QMPMDFPA	MDFP FAILS TO START
		7.65E-02	3	9.090E-06	H	8760	H	SMF0T12F	SW PUMP ROOM FAN FAILS TO RUN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		7.72E-04	1	7.720E-04		1		SXV0401N	MANUAL VALVE SW-401 FAILS TO OPEN
		7.70E-02				.077		TMF40F4F	COMMON CAUSE FACTOR FOR 4 OF 4 SW PMP ROOM VENT FANS FAILING TO RUN
		8.30E-06				8.3E-6		F2BM	Maximum flood in room 53 from failure of SW1395 or SW1399 <initiating event>
		2.00E-03				2.0E-03		QHAMDPL	MDFP MISALIGNED AFTER TEST/MAINT
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
97	1.66E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMF1521A	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
98	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMF1521A	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
99	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMF1522A	MOTOR-DRIVEN FAN C152-2 FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
100	1.52E-08	6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFSBOAA	SBODG MOTOR-DRIVEN FAN A FAILS TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1	T3	Loss of offsite power <initiating event>	
		6.02E-01				.602	XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40	

Report Summary:

Filename: C:\nit 1\base Q-posa\basecase\SPOS-A.CUT
 Print date: 2/2/2005 2:52 PM
 Not sorted

Attachment C

**Top 100 Cut Sets for the Base Case (no LCO) for the
Proposed End State (Mode 4)**

Non-Davis-Besse Model

Cutsets with Descriptions Report

MODE-4 = 1.38E-05

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
1	5.21E-06	8.41E-03				8.41E-3		IE-SVL1	Large Loss of Inventory Inside of Reactor Building
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		6.20E-04						SDHADHR5E	
2	3.35E-06	5.40E-03				5.4e-3		IE-SVL2	Large Loss of Inventory Outside of Reactor Building
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		6.20E-04						SDHADHR5E	
3	2.57E-07	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		3.07E-03	1	3.070E-03		1		QMP0002A	MOTOR-DRIVEN EFW PUMP FAILS TO START
		3.80E-04						SDHADHR6E	
4	2.37E-07	2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		2.83E-03	1	2.830E-03		1		QSV6451D	SOLENOID VALVE AF6451 FAILS TO OPERATE
5	1.12E-07	3.80E-04						SDHADHR6E	
		2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
6	1.08E-07	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL		
1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)		
5.00E-02						SDHASBLOR			
1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>		
3.10E-03						SDOP001R			

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
7	9.28E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.11E-03	1	1.110E-03		1		PAVZ012N	AOV MS 5889B FAILS TO OPEN
		3.80E-04						SDHADHR6E	
8	8.60E-08	2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
9	7.95E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
10	6.56E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
11	6.56E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		7.85E-04	2	8.960E-08	H	17520	H	QMV0599K	MOV AF 599 FAILS TO REMAIN OPEN
		3.80E-04						SDHADHR6E	
		2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
12	6.37E-08	1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		7.85E-04	2	8.960E-08	H	17520	H	QMV3872K	MOV AF 3872 FAILS TO REMAIN OPEN
		3.80E-04						SDHADHR6E	
		2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
13	5.91E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		7.07E-04	2	1.840E-06	H	768	H	QLC0CH2F	SFRCS CHANNEL 2 LOGIC BOARD FAILS
							SDHADHR6E		
						.22	T2	Plant trip due to loss of main feedwater <initiating event>	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
14	5.91E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		7.07E-04	2	1.840E-06	H	768	H	QLC0CH4F	SFRCS CHANNEL 4 LOGIC BOARD FAILS
		3.80E-04						SDHADHR6E	
15	5.50E-08	2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
16	5.50E-08	5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
17	5.30E-08	1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
18	5.02E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
19	4.93E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.50E-02						SDOP006R	
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
19	4.93E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		3.10E-03						SDOP001R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
19	4.93E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.40E-03						SDOP002R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
20	4.89E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.85E-04	3	2.440E-05	H	24	h	QMP0002F	MOTOR-DRIVEN PUMP FAILS TO RUN (imaginary AFP)
		3.80E-04						SDHADHR6E	
21	4.87E-08	2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
22	4.08E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
23	3.87E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.50E-02						SDOP006R	
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
24	3.87E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
25	3.77E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.50E-02						SDOP006R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
26	3.62E-08	1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		3.13E-03				3.13E-03		HMP0011A	HPI PUMP 1-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
27	2.96E-08	1.70E-01						SDOP007R	
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
28	2.87E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		3.13E-03				3.13E-03		HMP0011A	HPI PUMP 1-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
29	2.75E-08	5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
30	2.59E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		3.77E-05	3	1.570E-06	H	24	H	EB200D1F	BUS D1 LOCAL FAULTS
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		3.13E-03				3.13E-03		HMP0011A	HPI PUMP 1-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
31	2.53E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
32	2.52E-08	1.70E-01						SDOP007R	
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>		
1.70E-01						SDOP007R			

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
33	2.31E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
34	2.29E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.50E-02						SDOP006R	
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
35	2.12E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.40E-03						SDOP002R	
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
36	2.03E-08	9.30E-02				.093		EMFDLTA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
37	1.98E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		3.07E-03	1	3.070E-03		1		QMP0002A	MOTOR-DRIVEN EFW PUMP FAILS TO START
		3.00E-05						SDHAC211E	
		2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
38	1.97E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		3.07E-03	1	3.070E-03		1		QMP0002A	MOTOR-DRIVEN EFW PUMP FAILS TO START
		3.80E-04						SDHADHR6E	
39	1.97E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
39	1.97E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
39	1.97E-08	2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
40	1.96E-08	4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
41	1.96E-08	9.70E-03						SDOP004R	
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
42	1.96E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
43	1.95E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
44	1.94E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
45	1.87E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		2.83E-03	1	2.830E-03		1		QSV6451D	SOLENOID VALVE AF6451 FAILS TO OPERATE
46	1.83E-08	3.00E-05						SDHAC211E	
		2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		2.83E-03	1	2.830E-03		1		QSV6451D	SOLENOID VALVE AF6451 FAILS TO OPERATE
46	1.83E-08	3.80E-04						SDHADHR6E	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
47	1.80E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
48	1.79E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
49	1.74E-08	4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
50	1.74E-08	4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
51	1.73E-08	1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		1.50E-03	1	1.500E-03		1		LMV007BN	MOV DH 7B FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
52	1.69E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		3.13E-03				3.13E-03		HMP0011A	HPI PUMP 1-1 FAILS TO START
52	1.69E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
53	1.65E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
		3.80E-04						SDHADHR6E	
		2.20E-01					.22	T2	Plant trip due to loss of main feedwater <initiating event>
54	1.65E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
		3.80E-04						SDHADHR6E	
		2.20E-01					.22	T2	Plant trip due to loss of main feedwater <initiating event>
55	1.65E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
		3.80E-04						SDHADHR6E	
		2.20E-01					.22	T2	Plant trip due to loss of main feedwater <initiating event>
56	1.65E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
		3.80E-04						SDHADHR6E	
		2.20E-01					.22	T2	Plant trip due to loss of main feedwater <initiating event>
57	1.61E-08	1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.93E-04	1	1.930E-04		1		QRE522AD	K21 RELAY FAILS TO OPERATE ON DEMAND
		3.80E-04						SDHADHR6E	
58	1.61E-08	2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.93E-04	1	1.930E-04		1		QRE524AD	K81 RELAY FAILS TO OPERATE ON DEMAND
3.80E-04						SDHADHR6E			
2.20E-01					.22		T2	Plant trip due to loss of main feedwater <initiating event>	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
59	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMF1521A	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
60	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMF1522A	MOTOR-DRIVEN FAN C152-2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
61	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFSBOAA	SBODG MOTOR-DRIVEN FAN A FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
62	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFSBOBA	SBODG MOTOR-DRIVEN FAN B FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
63	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD600N	MOTOR-OPERATED CV 6000 DAMPER FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
64	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6001N	MOTOR-OPERATED DAMPER CV 6001 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
65	1.52E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6002N	MOTOR-OPERATED CV 6002 DAMPER FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
66	1.52E-08	8.41E-03				8.41E-3		IE-SVL1	Large Loss of Inventory Inside of Reactor Building
		1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		1.80E-05	3	7.520E-07	H	24	H	LTK0001J	BWST RUPTURE
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
67	1.44E-08	1.00E-01						SDHASDV2E	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
68	1.44E-08	1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03						SDOP003R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
69	1.42E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		5.90E-03				0.1		SDOP003R	
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
70	1.42E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		3.07E-03	1	3.070E-03		1		QMP0002A	MOTOR-DRIVEN EFW PUMP FAILS TO START
		3.80E-04						SDHADHR6E	
		1.22E-02	3	1.400E-06	H	8760	H	TPXNNIXF	NNIX POWER SUPPLY NO OUTPUT
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
71	1.42E-08	1.00E+00				0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.50E-03	1	3.500E-03		1		EMDZ091N	MOTOR DAMPER HV5329A FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
71	1.42E-08	9.70E-03						SDOP004R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.50E-03	1	3.500E-03		1		EMDZ097N	MOTOR DAMPER HV5329C FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
71	1.42E-08	5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
72	1.42E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.50E-03	1	3.500E-03		1		EMDZ119N	MOTOR DAMPER HV5336A FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
73	1.42E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		3.50E-03	1	3.500E-03		1		EMDZ121N	NO CONTROL POWER (AC & DC) TO EDG 1-
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		9.70E-03						SDOP004R	
74	1.38E-08	4.85E-03	1	4.850E-03		1		EC2Z141N	BKR AC110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
75	1.38E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
76	1.38E-08	1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
77	1.31E-08	1.50E-03	1	1.500E-03		1		LMV007BN	MOV DH 7B FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
77	1.31E-08	1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		2.83E-03	1	2.830E-03		1		QSV6451D	SOLENOID VALVE AF6451 FAILS TO OPERATE
		3.80E-04						SDHADHR6E	
		1.22E-02	3	1.400E-06	H	8760	H	TPXNNIXF	NNIX POWER SUPPLY NO OUTPUT

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
78	1.29E-08	4.85E-03	1	4.850E-03		1		EC2Z000N	BKR AD110 FAILS TO OPEN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		3.13E-03				3.13E-03		HMP0011A	HPI PUMP 1-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		5.00E-02						SDHASBLOR	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
79	1.25E-08	1.36E-02	1	1.360E-02		1		SDOP007R	
		1.55E-02				1.55E-02		EDG0011A	EDG 1-1 FAILS TO START
		3.50E-03	1	3.500E-03		1		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1.00		EMDZ119N	MOTOR DAMPER HV5336A FAILS TO OPEN
		1.00E-01				1.00E-01		MODE-4-FLAG	MODE 4 (FLAG)
		1.70E-01						T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
80	1.25E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		3.50E-03	1	3.500E-03		1		EMDZ121N	NO CONTROL POWER (AC & DC) TO EDG 1-
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.70E-01						EDG0012A	EDG 1-2 FAILS TO START
81	1.25E-08	1.36E-02	1	1.360E-02		1		EDG0SBOA	SBODG FAILS TO START
		1.55E-02				1.55E-02		EMDZ091N	MOTOR DAMPER HV5329A FAILS TO OPEN
		3.50E-03	1	3.500E-03		1		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E+00				1.00		T3	Loss of offsite power <initiating event>
		1.00E-01				1.00E-01		SDOP007R	
		1.70E-01						EDG0012A	EDG 1-2 FAILS TO START
		1.70E-01						EDG0SBOA	SBODG FAILS TO START
82	1.25E-08	1.36E-02	1	1.360E-02		1		EMDZ097N	MOTOR DAMPER HV5329C FAILS TO OPEN
		1.55E-02				1.55E-02		MODE-4-FLAG	MODE 4 (FLAG)
		3.50E-03	1	3.500E-03		1		T3	Loss of offsite power <initiating event>
		1.00E+00				1.00		SDOP007R	
		1.00E-01				1.00E-01		EDG0012A	EDG 1-2 FAILS TO START
		1.70E-01						EDG0SBOA	SBODG FAILS TO START
		1.70E-01						EMDZ097N	MOTOR DAMPER HV5329C FAILS TO OPEN
83	1.24E-08	3.77E-05	3	1.570E-06	H	24	H	EB200D1F	BUS D1 LOCAL FAULTS
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		1.50E-03	1	1.500E-03		1		LMV007BN	MOV DH 7B FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>
84	1.20E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		2.20E-02						SDOP005R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
85	1.17E-08	3.51E-03	1	3.510E-03		1		EMF1521A	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
86	1.17E-08	3.51E-03	1	3.510E-03		1		EMF1522A	MOTOR-DRIVEN FAN C152-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
87	1.17E-08	3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		3.51E-03	1	3.510E-03		1		EMFSBOAA	SBODG MOTOR-DRIVEN FAN A FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
88	1.17E-08	3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		3.51E-03	1	3.510E-03		1		EMFSBOBA	SBODG MOTOR-DRIVEN FAN B FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
89	1.17E-08	3.50E-03	1	3.500E-03		1		EMD6000N	MOTOR-OPERATED CV 6000 DAMPER FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
90	1.17E-08	3.50E-03	1	3.500E-03		1		EMD6001N	MOTOR-OPERATED DAMPER CV 6001 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
91	1.17E-08	3.50E-03	1	3.500E-03		1		EMD6002N	MOTOR-OPERATED CV 6002 DAMPER FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
92	1.12E-08	1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		1.00E+00				1		ELOOP2	BATTERY DEPLETION FOLLOWING LOSS OF CHARGING
		3.13E-03				3.13E-03		HMP0011A	HPI PUMP 1-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
93	1.10E-08	1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		3.51E-03	1	3.510E-03		1		EMFC153A	MOTOR-DRIVEN FAN C-153 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
94	1.10E-08	1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		3.50E-03	1	3.500E-03		1		EMD6004N	MOTOR-OPERATED DAMPER CV 6004 FAILS TO OPEN
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		1.70E-01						SDOP007R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
95	1.08E-08	3.51E-03	1	3.510E-03		1		EMF1521A	MOTOR-DRIVEN FAN C152-1 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
96	1.08E-08	3.51E-03	1	3.510E-03		1		EMF1522A	MOTOR-DRIVEN FAN C152-2 FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
97	1.08E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFSBOAA	SBODG MOTOR-DRIVEN FAN A FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
98	1.08E-08	6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03	1	4.850E-03		1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		3.51E-03	1	3.510E-03		1		EMFSBOBA	SBODG MOTOR-DRIVEN FAN B FAILS TO START
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
		6.02E-01				.602		XHOS-AMB->40F	AMBIENT TEMPERATURE IS> 40
		1.70E-01						SDOP007R	
99	1.08E-08	3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBC1E	OPERATORS FAILS TO START SBODG AND ALIGN TO BUS C1
		1.00E+00	1	1.000E+00		0.1		EHASBD1E	OPERATORS FAIL TO START SBODG AND ALIGN TO BUS D1
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.50E-03						SDHASBD1E	
		1.00E-01				1.00E-01		T3	Loss of offsite power <initiating event>
100	1.08E-08	1.00E+00				0.1		SDOP007R	
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHADHR6E	Operator fails to open PORV
		1.00E+00				1.00		MODE-4-FLAG	MODE 4 (FLAG)
		1.41E-02	2	2.140E-06	H	13140	H	PLT09XXD	SG LEVEL TRANSMITTER FAILS TO RESPOND
		9.20E-03				0.0092		PLTDLTAD	COMMON CAUSE FACTOR FOR 4 OF 4 LEVEL TRANSMITTERS FAILING TO RESPOND
		3.80E-04						SDHADHR6E	
2.20E-01				.22		T2	Plant trip due to loss of main feedwater <initiating event>		

Report Summary:

Filename: C:\init 1\non-db-Mode4\basecase\MODE-4.CUT

Print date: 2/2/2005 2:54 PM

Not sorted

Attachment D

**Top 100 Cut Sets for the Base Case (no LCO) for the Current
End State (Mode 5)**

Non-Davis-Besse Model

Cutsets with Descriptions Report

SPOS-A = 5.21E-05

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
1	7.81E-06	1.26E-02				1.26e-2		IE-SVL2	Large Loss of Inventory Outside of Reactor Building
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		6.20E-04						SDHADHR5E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
2	5.21E-06	8.41E-03				8.41E-3		IE-SVL1	Large Loss of Inventory Inside of Reactor Building
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E+00				0.1		LHASDV2E	Failure to stop loss of inventory before loss of decay heat pump
		6.20E-04						SDHADHR5E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
3	3.99E-06	1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		3.07E-03	1	3.070E-03		1		QMP0002A	MOTOR-DRIVEN EFW PUMP FAILS TO START
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
4	3.68E-06	1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		2.83E-03	1	2.830E-03		1		QSV6451D	SOLENOID VALVE AF6451 FAILS TO OPERATE
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
5	1.45E-06	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		4.30E-06						SDHAC306E	
6	1.44E-06	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.11E-03	1	1.110E-03		1		PAVZ012N	AOV MS 5889B FAILS TO OPEN
7	1.23E-06	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		3.07E-03	1	3.070E-03		1		QMP0002A	MOTOR-DRIVEN EFW PUMP FAILS TO START
8	1.13E-06	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		2.83E-03	1	2.830E-03		1		QSV6451D	SOLENOID VALVE AF6451 FAILS TO OPERATE
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
9	1.02E-06	1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		7.85E-04	2	8.960E-08	H	17520	H	QMV0599K	MOV AF 599 FAILS TO REMAIN OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
10	1.02E-06	1.30E-03 7.85E-04 1.00E+00	2	8.960E-08	H	1.3E-03 17520 1.00	H	F6 QMV3872K SPOS-A-FLAG	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even MOV AF 3872 FAILS TO REMAIN OPEN SPOSA (FLAG)
11	9.82E-07	3.20E-04 3.07E-03 1.00E+00	1	3.070E-03		3.2E-4 1 1.00		F3AM QMP0002A SPOS-A-FLAG	Maximum flood in CCW pump room from service water <initiating event> MOTOR-DRIVEN EFW PUMP FAILS TO START SPOSA (FLAG)
12	9.19E-07	1.30E-03 7.07E-04 1.00E+00	2	1.840E-06	H	1.3E-03 768 1.00	H	F6 QLC0CH2F SPOS-A-FLAG	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even SFRCS CHANNEL 2 LOGIC BOARD FAILS SPOSA (FLAG)
13	9.19E-07	1.30E-03 7.07E-04 1.00E+00	2	1.840E-06	H	1.3E-03 768 1.00	H	F6 QLC0CH4F SPOS-A-FLAG	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even SFRCS CHANNEL 4 LOGIC BOARD FAILS SPOSA (FLAG)
14	9.06E-07	3.20E-04 2.83E-03 1.00E+00	1	2.830E-03		3.2E-4 1 1.00		F3AM QSV6451D SPOS-A-FLAG	Maximum flood in CCW pump room from service water <initiating event> SOLENOID VALVE AF6451 FAILS TO OPERATE SPOSA (FLAG)
15	8.75E-07	3.07E-03 1.00E+00 2.50E-03 1.14E-01	1	3.070E-03		1 1.00 .0025 1.14E-01		QMP0002A SPOS-A-FLAG TMP3OF3F TMPT14BF	MOTOR-DRIVEN EFW PUMP FAILS TO START SPOSA (FLAG) COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN CCW PUMP FAILS TO RUN
16	8.07E-07	2.83E-03 1.00E+00 2.50E-03 1.14E-01	1	2.830E-03		1 1.00 .0025 1.14E-01	H	QSV6451D SPOS-A-FLAG TMP3OF3F TMPT14BF	SOLENOID VALVE AF6451 FAILS TO OPERATE SPOSA (FLAG) COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN CCW PUMP FAILS TO RUN
17	7.61E-07	1.30E-03 5.85E-04 1.00E+00	3	2.440E-05	H	1.3E-03 24 1.00	h	F6 QMP0002F SPOS-A-FLAG	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even MOTOR-DRIVEN PUMP FAILS TO RUN SPOSA (FLAG)
18	5.33E-07	1.30E-03 1.00E+00 4.10E-04 1.00E+00				1.3E-03 0.1 1.00		F6 LHADHR4E SDHADHR4E SPOS-A-FLAG	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even Operator fails to establish prim to sec heat transfer SPOSA (FLAG)
19	5.15E-07	3.77E-05 1.00E+00 1.37E-02	3	1.570E-06	H	24 1.00 8760	H	EB200D1F SPOS-A-FLAG TB200C1F	BUS D1 LOCAL FAULTS SPOSA (FLAG) BUS C1 LOCAL FAULTS
20	4.44E-07	4.00E-04 1.11E-03 1.00E+00	1	1.110E-03		4.0E-4 1 1.00		F3AL PAVZ012N SPOS-A-FLAG	Large flood in CCW pump room from service water <initiating event> AOV MS 5889B FAILS TO OPEN SPOSA (FLAG)
21	4.07E-07	1.00E+00 1.30E-03 3.04E-03 1.03E-01 1.00E+00	1	3.040E-03		0.1 1.3E-03 1 .103 1.00		WHAF3ISE F6 FVV011XN FVBETAN SPOS-A-FLAG	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even AVV FAILS TO OPEN CC FACTOR FOR AVVs FAILING TO OPEN SPOSA (FLAG)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
22	3.79E-07	3.37E-01				.337		IE-LMPP42XF	DHR Pump Fails to Run
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		5.35E-02				0.0535		LMPBETAF	CC FACTOR FOR LPI PUMPS FAILING TO RUN
		2.10E-05						SDHAC209E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
23	3.55E-07	3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.11E-03	1	1.110E-03		1		PAVZ012N	AOV MS 5889B FAILS TO OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
24	3.37E-07	1.00E+00				0.1		LHADH10E	Operator Fails to Initiate Recirculation
		1.00E+00				.1		LHADHR13E	Failure to recover DHR
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR8E	Oper fails to align & start a system to refill BWST
		1.00E+00				.1		LHADHR9E	Oper fails to align altern pump to refill BWST
		3.37E-01				.337		LMPIE21F	DHR Pump 1 Fails to Run
		1.00E-06						SDHAC308E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
25	3.16E-07	1.11E-03	1	1.110E-03		1		PAVZ012N	AOV MS 5889B FAILS TO OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP30F3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
26	3.14E-07	4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		7.85E-04	2	8.960E-08	H	17520	H	QMV0599K	MOV AF 599 FAILS TO REMAIN OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
27	3.14E-07	1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		7.85E-04	2	8.960E-08	H	17520	H	QMV3872K	MOV AF 3872 FAILS TO REMAIN OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
28	2.83E-07	1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		7.07E-04	2	1.840E-06	H	768	H	QLC0CH2F	SFRCS CHANNEL 2 LOGIC BOARD FAILS
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
29	2.83E-07	1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		7.07E-04	2	1.840E-06	H	768	H	QLC0CH4F	SFRCS CHANNEL 4 LOGIC BOARD FAILS
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
30	2.57E-07	1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
31	2.57E-07	1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
32	2.57E-07	1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
33	2.57E-07	1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
34	2.51E-07	3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		7.85E-04	2	8.960E-08	H	17520	H	QMV0599K	MOV AF 599 FAILS TO REMAIN OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
35	2.51E-07	3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		7.85E-04	2	8.960E-08	H	17520	H	QMV3872K	MOV AF 3872 FAILS TO REMAIN OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
36	2.51E-07	1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.93E-04	1	1.930E-04		1		QRE522AD	K21 RELAY FAILS TO OPERATE ON DEMAND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
37	2.51E-07	1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.93E-04	1	1.930E-04		1		QRE524AD	K81 RELAY FAILS TO OPERATE ON DEMAND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
38	2.34E-07	4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		5.85E-04	3	2.440E-05	H	24	h	QMP0002F	MOTOR-DRIVEN PUMP FAILS TO RUN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
39	2.26E-07	3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		7.07E-04	2	1.840E-06	H	768	H	QLC0CH2F	SFRCS CHANNEL 2 LOGIC BOARD FAILS
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
40	2.26E-07	3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		7.07E-04	2	1.840E-06	H	768	H	QLC0CH4F	SFRCS CHANNEL 4 LOGIC BOARD FAILS
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
41	2.24E-07	7.85E-04	2	8.960E-08	H	17520	H	QMV0599K	MOV AF 599 FAILS TO REMAIN OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
42	2.24E-07	7.85E-04	2	8.960E-08	H	17520	H	QMV3872K	MOV AF 3872 FAILS TO REMAIN OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
43	2.01E-07	7.07E-04	2	1.840E-06	H	768	H	QLC0CH2F	SFRCS CHANNEL 2 LOGIC BOARD FAILS
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
44	2.01E-07	1.14E-01	2	1.840E-06	H	1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
		7.07E-04				768		QLC0CH4F	SFRCS CHANNEL 4 LOGIC BOARD FAILS
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
45	1.87E-07	2.50E-03	3	2.440E-05	H	.0025	h	TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01		TMPT14BF	CCW PUMP FAILS TO RUN
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
46	1.68E-07	5.85E-04	2	2.140E-06	H	24	H	QMP0002F	MOTOR-DRIVEN PUMP FAILS TO RUN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
47	1.67E-07	1.41E-02	3	2.440E-05	H	13140	h	PLT09XXD	SG LEVEL TRANSMITTER FAILS TO RESPOND
		9.20E-03				0.0092		PLTDLTAD	COMMON CAUSE FACTOR FOR 4 OF 4 LEVEL TRANSMITTERS FAILING TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
48	1.64E-07	5.85E-04	3	1.570E-06	H	24	H	QMP0002F	MOTOR-DRIVEN PUMP FAILS TO RUN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
49	1.54E-07	1.14E-01	3	1.570E-06	H	1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
50	1.43E-07	4.10E-04	1	3.040E-03		1.00		SDHADHR4E	SPOSA (FLAG)
		1.00E+00				0.1		SPOS-A-FLAG	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		1.00E+00				0.1		WHAF3ISE	BUS D1 LOCAL FAULTS
51	1.31E-07	3.77E-05	3	1.570E-06	H	24	H	EB200D1F	Flood in ECCS pump room 101 (& 105) from aux bldg drainage <initiating event>
		4.10E-03				4.1E-03		F4	SPOSA (FLAG)
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
52	1.25E-07	1.30E-03	1	3.040E-03		1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		1.10E-04				1.1E-04		QHA0002L	AFW TRAIN 2 MISALIGNED AFTER TEST/MAINT
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
53	1.17E-07	3.20E-04	1	3.040E-03		3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		4.10E-04				1.00		SDHADHR4E	SPOSA (FLAG)
53	1.17E-07	1.00E+00	1	3.040E-03		4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		3.04E-03				1		FVV011XN	AVV FAILS TO OPEN
		1.03E-01				.103		FVVBETAN	CC FACTOR FOR AVVs FAILING TO OPEN
53	1.17E-07	1.00E+00	1	3.040E-03		1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
53	1.17E-07	4.10E-04	1	3.040E-03		1.00		SDHADHR4E	SPOSA (FLAG)
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description				
54	1.16E-07	1.30E-03	1	2.830E-03		1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even				
		2.83E-03				1		QSVAFXD	AFW SOLENOID VALVE FAILS TO OPERATE				
		3.14E-02				.0314		QSVBETAD	CC FACTOR FOR AFW FLOW CONTROL VALVES FAILING TO OPERATE				
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)				
55	1.14E-07	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train				
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer				
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling				
		1.00E-06						SDHAC404E					
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)				
		1.14E-01				1.14E-01		H	TMPP431F	CCW PUMP 1-1 FAILS TO RUN			
56	1.12E-07	1.00E+00				5.8E-03		WHASPREE	FAILURE TO RECOVER CCW USING THE SPARE CCW TRAIN				
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START				
		3.12E-02				.0312		EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START				
		1.36E-02				1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START				
		1.70E-01						SDOP007R					
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)				
57	1.08E-07	1.00E-01				0.1		T3	Loss of offsite power <initiating event>				
		8.34E-02				3		3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02				3		3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.00E+00				1		1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02										SDHASBLOR	
		3.10E-03										SDOP001R	
58	1.00E-07	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)				
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>				
		3.20E-04				1		3.040E-03	1	F3AM	Maximum flood in CCW pump room from service water <initiating event>		
		3.04E-03				1		3.040E-03	1	FVV011XN	AVV FAILS TO OPEN		
		1.03E-01				.103				FVVBETAN	CC FACTOR FOR AVVs FAILING TO OPEN		
		1.00E+00				1.00				SPOS-A-FLAG	SPOSA (FLAG)		
59	9.90E-08	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train				
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer				
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling				
		1.00E-06						SDHAC404E					
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)				
		9.90E-02				3		1.190E-05	H	8760	H	TTC1424T	TEMP CONTROL VALVE SW1424 FAILS TO THROTTLE (1 YEAR MISSION TIME)
60	8.92E-08	1.00E+00				5.8E-03		WHASPREE	FAILURE TO RECOVER CCW USING THE SPARE CCW TRAIN				
		3.04E-03				1		3.040E-03	1	FVV011XN	AVV FAILS TO OPEN		
		1.03E-01				.103				FVVBETAN	CC FACTOR FOR AVVs FAILING TO OPEN		
		1.00E+00				1.00				SPOS-A-FLAG	SPOSA (FLAG)		
		2.50E-03				.0025				TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN		
		1.14E-01				1.14E-01		H	TMPT14BF	CCW PUMP FAILS TO RUN			

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
61	8.60E-08	1.55E-02	1	3.510E-03		1.55E-02		EDG0SBOA	SBDG FAILS TO START
		3.51E-03				1		EMFCC19A	ANY ONE EDG VENT FAN FAILS TO START
		9.30E-02				.093		EMFDLTAA	CC FACTOR FOR ALL EDG ROOM VENT FANS FAILING TO START
		1.70E-01						SDOP007R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
62	7.95E-08	1.00E-01	1	4.850E-03		0.1		T3	Loss of offsite power <initiating event>
		6.22E-02				0.0622		EC2BE11D	CC FACTOR FOR FAILURE OF 4160V BUS-TIE BREAKERS
		4.85E-03				1		EC2CC11N	AC110 OR AD110 FAILS TO OPEN
		1.55E-02				1.55E-02		EDG0SBOA	SBDG FAILS TO START
		1.70E-01						SDOP007R	
63	7.91E-08	1.00E+00	2	2.140E-06	H	1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.41E-02				13140		H PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02				13140		H PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
64	7.91E-08	1.00E+00	2	2.140E-06	H	1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.41E-02				13140		H PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02				13140		H PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
65	7.91E-08	1.00E+00	2	2.140E-06	H	1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.41E-02				13140		H PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02				13140		H PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
66	7.91E-08	1.00E+00	2	2.140E-06	H	1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.41E-02				13140		H PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02				13140		H PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
67	7.72E-08	1.00E+00	1	1.930E-04		1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.93E-04				1		QRE522AD	K21 RELAY FAILS TO OPERATE ON DEMAND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
68	7.72E-08	1.00E+00	1	1.930E-04		0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.93E-04				1		QRE524AD	K81 RELAY FAILS TO OPERATE ON DEMAND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
69	7.51E-08	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.00E-06						SDHAC406E	
		1.00E+00				0.1		SHADILPE	OPERATORS FAIL TO RECOVER SW WITH DILUTION PUMP
		1.00E+00				1.2E-3		SHASTBTE	OPERATORS FAIL TO RECOVER SW WITH SPARE SW PUMP
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
70	6.40E-08	7.51E-02				7.51E-02		TMPP301F	SW PUMP 1-1 FAILS TO RUN (1 YEAR MISSION TIME)
		1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		1.49E-02	2	3.400E-06	H	8760	H	LHXIE11P	DH COOLER 1-1 FAILS DURING OPERATION (Initiating Event)
		4.30E-06						SDHAC306E	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
71	6.37E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
		1.55E-02				1.55E-02		EDG0SBOA	SBODG FAILS TO START
		5.90E-03						SDOP003R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
72	6.33E-08	1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
73	6.33E-08	3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
74	6.33E-08	1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
75	6.33E-08	1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
76	6.30E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating event>
		4.85E-05	3	2.020E-06	H	24	H	PLT09A3H	SG 1-2 LEVEL TRANSMITTER LTSP9A3 FAILS HIGH
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
77	6.18E-08	3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.93E-04	1	1.930E-04		1		QRE522AD	K21 RELAY FAILS TO OPERATE ON DEMAND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
78	6.18E-08	3.20E-04				3.2E-4		F3AM	Maximum flood in CCW pump room from service water <initiating event>
		1.93E-04	1	1.930E-04		1		QRE524AD	K81 RELAY FAILS TO OPERATE ON DEMAND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
79	5.87E-08	1.00E+00				0.1		LHADHR1E	Operators Fail to Recover DHR with the Standby Train
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		1.00E+00				0.1		LHADHR5E	Operator fails to start HPI or LPI pump for Makeup Cooling
		4.30E-06						SDHAC306E	
80	5.74E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.37E-02	3	1.570E-06	H	8760	H	TB200C1F	BUS C1 LOCAL FAULTS
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		4.42E-05	3	1.840E-06	H	24	H	PLC6451F	LOGIC CARD FAILS DURING OPERATION
81	5.74E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.40E-04				1.4E-4		F2CL	Large flood in room 53 from service water return <initiating event>
		1.00E+00				0.1		LHADHR4E	Operator fails to establish prim to sec heat transfer
		4.10E-04						SDHADHR4E	
82	5.63E-08	1.00E+00				0.1		SHAF2ISE	FAILURE TO ISOLATE FLOOD BEFORE SERVICE WATER PUMPS ARE AFFECTED
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
83	5.63E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A8D	LEVEL TRANSMITTER LTSP9A8 FAILS TO RESPOND
84	5.63E-08	1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
85	5.63E-08	1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B6D	LEVEL TRANSMITTER LTSP9B6 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
86	5.53E-08	1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
		1.41E-02	2	2.140E-06	H	13140	H	PLT09A9D	LEVEL TRANSMITTER LTSP9A9 FAILS TO RESPOND
		1.41E-02	2	2.140E-06	H	13140	H	PLT09B7D	LEVEL TRANSMITTER LTSP9B7 FAILS TO RESPOND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
87	5.50E-08	2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		3.83E-02				0.0383		PAVBETAN	CC FACTOR FOR AFPT STEAM INLET VALVES FAILING TO OPEN
87	5.50E-08	1.11E-03	1	1.110E-03		1		PAVZ01XN	AFPT STEAM INLET AOV FAILS TO OPEN
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.36E-02	1	1.360E-02		1		EDG0011A	EDG 1-1 FAILS TO START
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
87	5.50E-08	1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		9.70E-03						SDOP004R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1	T3	Loss of offsite power <initiating event>	

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
88	5.50E-08	8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		1.36E-02	1	1.360E-02		1		EDG0012A	EDG 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		9.70E-03						SDOP004R	
89	5.50E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		1.93E-04	1	1.930E-04		1		QRE522AD	K21 RELAY FAILS TO OPERATE ON DEMAND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
90	5.50E-08	1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
		1.93E-04	1	1.930E-04		1		QRE524AD	K81 RELAY FAILS TO OPERATE ON DEMAND
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		2.50E-03				.0025		TMP3OF3F	COMMON CAUSE FACTOR FOR 3 OF 3 CCW PUMPS FAILING TO RUN
		1.14E-01				1.14E-01	H	TMPT14BF	CCW PUMP FAILS TO RUN
91	5.30E-08	3.12E-02				.0312	H	EDGBET2A	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO START
		1.36E-02	1	1.360E-02		1		EDGCC02A	EITHER EDG 1-1 OR 1-2 FAILS TO START
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
		2.50E-02						SDOP006R	
92	5.17E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		4.00E-04				4.0E-4		F3AL	Large flood in CCW pump room from service water <initiating event>
		1.41E-02	2	2.140E-06	H	13140	H	PLT09XXD	SG LEVEL TRANSMITTER FAILS TO RESPOND
		9.20E-03				0.0092		PLTDLTAD	COMMON CAUSE FACTOR FOR 4 OF 4 LEVEL TRANSMITTERS FAILING TO RESPOND
93	5.05E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E+00				0.1		WHAF3ISE	FAILURE TO ISOLATE FLOOD IN ROOM 328 BEFORE CCW PUMPS ARE AFFECTED
		1.30E-03				1.3E-03		F6	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even
		7.07E-04	2	1.840E-06	H	768	H	QLC0CHXF	LOGIC CARD FAILS DURING OPERATION
		5.50E-02				.055		QLC2OF4F	COMMON CAUSE FACTOR FOR > THAN 2 OF 4 LOGIC CHANNEL TO RESPOND
94	5.02E-08	1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		3.88E-02				.0388		EDGBET1F	CC FACTOR FOR 2 OF 2 DIESEL GENERATORS FAILING TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDGCC01F	EITHER EDG 1-1 OR 1-2 FAILS TO RUN
		1.00E+00	1	1.000E+00		0.1		EHASBLOE	OPERATORS FAIL TO ADD SBODG FUEL OIL
		5.00E-02						SDHASBLOR	
95	4.93E-08	3.10E-03						SDOP001R	
		1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)
		1.00E-01				0.1		T3	Loss of offsite power <initiating event>
		8.34E-02	3	3.630E-03	H	24	H	EDG0011F	EDG 1-1 FAILS TO RUN
		8.34E-02	3	3.630E-03	H	24	H	EDG0012F	EDG 1-2 FAILS TO RUN
2.95E-02				2.95E-02		EDG0SBOF	SBODG FAILS TO RUN		
2.40E-03						SDOP002R			
1.00E+00				1.00		SPOS-A-FLAG	SPOSA (FLAG)		
1.00E-01				0.1		T3	Loss of offsite power <initiating event>		

#	Cutset Prob	Event Prob	C	Rate	U	Exposure	U	Event	Description
96	4.90E-08	3.77E-05 1.30E-03 1.00E+00	3	1.570E-06	H	24 1.3E-03 1.00	H	EB200D1F F6 SPOS-A-FLAG	BUS D1 LOCAL FAULTS Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even SPOSA (FLAG)
97	4.87E-08	1.36E-02 1.36E-02 1.55E-02 1.70E-01 1.00E+00 1.00E-01	1 1 1	1.360E-02 1.360E-02		1 1 1.55E-02 1.00 0.1		EDG0011A EDG0012A EDG0SBOA SDOP007R SPOS-A-FLAG T3	EDG 1-1 FAILS TO START EDG 1-2 FAILS TO START SBODG FAILS TO START SPOSA (FLAG) Loss of offsite power <initiating event>
98	4.86E-08	1.30E-03 3.74E-05 1.00E+00	1	3.740E-05		1.3E-03 1 1.00		F6 QCV0020N SPOS-A-FLAG	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even CHECK VALVE AF 20 FAILS TO OPEN SPOSA (FLAG)
99	4.86E-08	1.30E-03 3.74E-05 1.00E+00	1	3.740E-05		1.3E-03 1 1.00		F6 QCV0043N SPOS-A-FLAG	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even CHECK VALVE AF 43 FAILS TO OPEN SPOSA (FLAG)
100	4.86E-08	1.30E-03 3.74E-05 1.00E+00	1	3.740E-05		1.3E-03 1 1.00		F6 QCV0075N SPOS-A-FLAG	Flood in ECCS rooms 101, 113, & 115 from aux building drainage <initiating even CHECK VALVE AF 75 FAILS TO OPEN SPOSA (FLAG)

Report Summary:

Filename: C:\init 1\non-db-q-posa\basecase\SPOS-A.CUT
Print date: 2/2/2005 2:55 PM
Not sorted