



**FRAMATOME ANP**



# ***Replacement Topical BAW-2374***

## **B&WOG Representatives**

***Eric Henshaw – Duke Energy***

***Gregg Swindlehurst – Duke Energy***

***Morris Byram – Entergy***

***Rich Freeman – Exelon***

***John Klingenfus – FANP Analysis Services***

***Gordon Wissinger – FANP Analysis Services***

***Darrell Costa – FANP SG Services***

***Jim Begley – FANP SG Services***

***Gayle Elliott – FANP Regulatory Affairs***

***Bob Schomaker – FANP Project Management***

# ***Replacement BAW-2374***

***> Background Material Provided***

***Topical Report Framework***

***Steam Generator Tube Sever Approach***

***Dose Consequence Approach***

***Rev 1 of BAW-2374 (provided today)***

# ***Replacement for BAW-2374***

## **> *Anticipated Conclusions***

- ◆ *Conclude that only 1 steam generator tube is likely to rupture as a result of the transient***
- ◆ *Conclude that fuel cladding does not rupture during the transient.***
- ◆ *Dose consequences do not need to include fuel gap activity***