

March 3, 2005

LICENSEE: Florida Power & Light Company

FACILITY: Turkey Point Units 3 and 4

SUBJECT: SUMMARY OF FEBRUARY 24, 2005, MEETING WITH FLORIDA POWER & LIGHT COMPANY REGARDING A PENDING FEEDWATER CONTROL AMENDMENT REQUEST

On February 24, 2005, a Category 1 public meeting was held between the U.S. Nuclear Regulatory Commission (NRC) and representatives of the Florida Power & Light Company (FPL) at NRC Headquarters, One White Flint North, 11555 Rockville Pike, Rockville, Maryland. The purpose of the meeting was to allow FPL the opportunity to present information to the NRC staff related to a pending license amendment request for a modification to the feedwater control system at Turkey Point Units 3 and 4. A list of attendees is provided as Attachment 1.

FPL requested the meeting, which was open to the public as stated in the meeting notice dated February 10, 2005 [ADAMS Accession No. ML050410515], but members of the public were not in attendance. Public Meeting Feedback forms were received from the meeting participants. Comments received were generally favorable. These have been forwarded to the Office of Nuclear Reactor Regulation Senior Communications Analyst who will forward them to the Office of the Executive Director for Operations.

FPL presented the information contained in Attachment 2. This information gave the NRC staff an overview of the pending license amendment and its technical basis. Additionally, FPL gave a brief overview of its Life Cycle Management Program, whose objective is to deal with obsolescence of components and systems at Turkey Point and St. Lucie. As part of this program overview, FPL described some modifications and replacements planned for Turkey Point. These modifications and replacements are planned by the licensee to be performed under the provision of Title 10 *Code of Federal Regulations* (10 CFR), Section 50.59.

The NRC staff queried the licensee about various details of the presentation related to the pending amendment and the modifications planned under 10 CFR 50.59. Specifically, the NRC staff expressed concerns regarding the appropriateness of the provision of 10 CFR 50.59 to the modifications and replacements planned for Turkey Point. Additionally, the NRC staff questioned the licensee regarding the relation of the pending amendment with the Instrumentation, Systems, and Automation Society of America (ISA) Standard, ISA-S67.04-1994, "Setpoints for Nuclear Safety-Related Instrumentation," ISA 67.04, Part 2 Method 3.

- 2 -

Please direct any inquiries to Eva Brown at 301-415-2315 or eab1@nrc.gov, or Jose Arroyo at 301-415-2149 or jxa1@nrc.gov.

Sincerely,

/RA/

Jose R. Arroyo, Project Engineer, Section 2
Project Directorate 2
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos.: 50-250 and 50-251

Attachments: 1. List of Attendees
2. Licensee Handouts

cc w/atts: See next page

Please direct any inquiries to Eva Brown at 301-415-2315 or eab1@nrc.gov, or Jose Arroyo at 301-415-2149 or jxa1@nrc.gov.

Sincerely,

/RA/

Jose R. Arroyo, Project Engineer, Section 2
Project Directorate 2
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos.: 50-250 and 50-251

Attachments: 1. List of Attendees
2. Licensee Handouts

cc w/atts: See next page

Distribution:

PUBLIC	LMarsh	EBrown	SSun	ASlubbs	JMunday, RII
PDII-2 Rdg	JLyons	BMoroney	EMarinos	JHernandez	UShoop, EDO
OGC	EHackett	JArroyo	HGarg	TMensah	
ACRS	MMarshall	DCoe	SJones	BClayton (Hard Copy)	

Package No.: MmL050610338

Meeting Handouts: ML050610361

Meeting Notice: ML050410515

ADAMS Accession No.: ML050610341

NRC-001

OFFICE	PE/PDII-2	PM/PDII-2	PM/PDII-2	LA/PDII-2	SC/PDII-2
NAME	JArroyo	BMoroney	EBrown	BClayton	MMarshall
DATE	03/02/2005	03/02/2005	03/02/2005	03/02/2005	03/03/2005

OFFICIAL RECORD COPY

**LIST OF ATTENDEES
FEBRUARY 24, 2005
MEETING WITH FLORIDA POWER & LIGHT**

NRC

Michael Marshall
Brendan Moroney
Jose Arroyo
Angelo Stubbs
Jorge Hernandez
Summer Sun
Hukum Garg

FPL

Ed Lozito
Warren Busch
D. J. Tomaszewski

Westinghouse

Paul Collette