

 **Duke
Power®**

Oconee Nuclear Station
McGuire Nuclear Station
Catawba Nuclear Station

**THERMAL-HYDRAULIC TRANSIENT
ANALYSIS METHODOLOGY**

DPC-NE-3000-A
Revision 3

September 2004

Nuclear Engineering Division
Nuclear Generation Department
Duke Power Company



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

September 24, 2003

Mr. Ronald A. Jones
Vice President, Oconee Site
Duke Energy Corporation
P. O. Box 1439
Seneca, SC 29679

SUBJECT: OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3 - SAFETY EVALUATION
OF REVISIONS TO TOPICAL REPORTS DPC-NE-3000, -3003, AND -3005
(TAC NOS. MB5441, MB5442, AND MB5443)

Dear Mr. Jones:

By letter dated June 13, 2002, you submitted the following revisions to three topical reports: (1) DPC-NE-3000-P, Revision 3, "Thermal-Hydraulic Transient Analysis Methodology"; (2) DPC-NE-3003-P, Revision 1, "Mass and Energy Release and Containment Response Methodology"; and (3) DPC-NE-3005-PA, Revision 2, "UFSAR Chapter 15 Transient Analysis Methodology." You asked for approval of three revisions to support the replacement of the steam generators at Oconee Nuclear Station, Units 1, 2, and 3. You provided additional information in your letters dated May 21, July 7, and July 28, 2003.

Enclosure 1 contains our Safety Evaluation (SE) of DPC-NE-3000-P, Revision 3, and DPC-NE3005-PA, Revision 2; and Enclosure 2 contains our SE of DPC-NE-3003-P, Revision 1.

Sincerely,

A handwritten signature in dark ink, appearing to read "L. N. Olshan", is written over a circular stamp or seal.

Leonard N. Olshan, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosures: As stated

cc w/encls: See next page



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR
REGULATION OF REVISION 3 TO DPC-NE-3000-P "THERMAL-HYDRAULIC
TRANSIENT ANALYSIS METHODOLOGY" AND REVISION 2 TO DPC-NE-3005-P,
"UFSAR CHAPTER 15 TRANSIENT ANALYSIS METHODOLOGY"

1.0 INTRODUCTION

The Duke Energy Corporation (the licensee) is making preparations to replace the steam generators at the Oconee Nuclear Station. The replacement once-through steam generators (ROTSGs) are essentially of the same once-through design as the original once-through steam generators (OTSGs), but there are a number of small differences that call for revisions to the previously-approved topical reports. This safety evaluation involves the revisions to two topical reports namely: DPC-NE-3000-P "Thermal-Hydraulic Transient Analysis Methodology" and DPC-NE-3005-P, "UFSAR Chapter 15 Transient Analysis Methodology." The licensee has reanalyzed several design basis transients and accidents in the Oconee Updated Final Safety Analysis Report (UFSAR). The licensee used the RETRAN-3D thermal/hydraulic computer code rather than the RETRAN-02 code that is the current approved analytical method to perform the transient reanalyses. Other revisions to the topical reports include editorial and minor technical changes. The licensee requested NRC review by letter dated June 13, 2002 (Ref. 1), and the licensee provided additional information in a letter dated May 21, 2003 (Ref. 2).

2.0 REGULATORY EVALUATION

The NRC staff approved the generic use of RETRAN-3D by licensees as discussed in Ref. 3. The licensee plans to utilize RETRAN-3D in a manner that causes the code to essentially default to be the same as RETRAN-02. In Ref. 3, the NRC staff stated that organizations with NRC-approved RETRAN-02 methodologies can use the RETRAN-3D code in the RETRAN-02 mode without additional NRC approval, provided that none of the new RETRAN-3D models are used.

The licensee has selected to use certain of the new RETRAN-3D models. In addition, the licensee requested the RETRAN code developers to make several Oconee specific changes in RETRAN-3D. These changes include options to the critical flow model, to the vertical steam/water separation model and forced convection heat transfer.

As part of its approval of RETRAN-3D, the NRC staff included 45 conditions that users of RETRAN-3D must address before using the code. The licensee provided responses to each of these conditions. Since the licensee does not utilize the majority of the new RETRAN-3D features, most of these conditions do not apply. Those instances, where the licensee has deviated from the RETRAN-02 mode either as a result of using RETRAN-3D features or as a

result of code modifications, are evaluated in the following section. The NRC staff will approve use of the Oconee-specific RETRAN-3D model if the licensee demonstrates that the options added provide conservative results, or more realistic or accurate modeling of the plant response; and the specific limitations and conditions imposed generically on the RETRAN-3D code have been satisfied.

3.0 TECHNICAL EVALUATION

A significant difference between the ROTSGs and the OTSGs is the addition of a flow restriction in the exit nozzles. Flow restrictions are common in pressurized water reactors of a more recent design than Oconee. Flow restrictions limit the rate of steam release in the event of a main steam line break and limit the rate of reactor system cooldown. In addition, the ROTSGs provide a small increase in the number of tubes and available heat transfer area compared to the OTSGs. There is slightly more water in the ROTSGs and the steam generator tube material has been modified. Because of the physical changes, the licensee believed it necessary to reevaluate certain of the transients and accidents in the plant UFSAR.

The licensee made the required reevaluations using RETRAN-3D. RETRAN-3D has the benefit of being a newer computer code than RETRAN-02 and has incorporated error corrections by the code developers based on the experience of the users. The licensee has utilized RETRAN-3D in a mode that essentially defaults to RETRAN-02 with certain exceptions:

- With RETRAN-3D the steam generators can now be modeled using separate velocities for the steam and water flowing up a tube bundle. The model was benchmarked against the steam generator design codes. The licensee requested code modifications to allow the relative velocities between the steam and water phases to be adjusted to produce the appropriate steam generator inventory. The NRC staff views this modification as an improvement in code accuracy and modeling capability. It is, therefore, acceptable.
- The licensee extended the heat transfer capability of RETRAN-3D to allow for condensation heat transfer when the surface temperature of a conductor is lower than that of steam in an adjacent channel. This modification is similar to one made in RETRAN-02 for the licensee by the code developers. The modification extends the accuracy of the code and is acceptable to the NRC staff.
- The licensee added a user option to calculate critical flow for a main steam line break assuming an inlet enthalpy corresponding to that of pure steam or two-phase conditions as predicted by the code from the level swell in the affected steam generator. Use of this model permits the licensee to conservatively perform main steam line break analyses assuming only steam exits the steam generator and is therefore acceptable to the NRC staff. The assumption of pure steam flow is used by the licensee for predicting mass and energy release to the containment. The licensee will retain the option of performing best estimate main steam line breaks in which the code calculates liquid entrainment.
- For analyses of the reactor system cooldown following a main steam line break, the licensee will utilize an enhanced steam separation velocity in the affected steam generator. Reactor system cooldown is evaluated to investigate the possibility of return to criticality in the core and departure from nucleate boiling (DNB). The use of an

enhanced steam velocity in the ROTSG will effectively eliminate liquid removal from the steam generator unless the steam generator completely fills with water from continued feedwater flow. Assumptions which cause water to remain in the steam generator and only steam to be removed are conservative for analysis of reactor system cooling. There is no steam separation equipment in the Oconee steam generators and the assumption of enhanced steam separation is made to ensure conservative results. These assumptions provide for a conservative prediction of reactor cooldown following a main steam line break and are, therefore, acceptable to the NRC staff.

- The licensee added options to the forced convection model so as not to over predict heat transfer from the steam generator structural metal to the exiting fluid during a main steam line break. This modification provides for more accurate predictions of steam generator stresses following a main steam line break and is, therefore, acceptable to the NRC staff.

The licensee provided the NRC staff with the updates to RETRAN-3D for each of these modifications. The NRC staff reviewed the source coding and confirmed that in each case the modification was performed by the code developer and independently verified. With the exception of these modifications, the licensee will use RETRAN-3D in the RETRAN-02 mode. The NRC staff reviewed the responses by the licensee to all of the generic conditions required of users of RETRAN-3D. The NRC staff agrees with the licensee's assessment that in each case the condition either does not apply because that feature of the code is not utilized by the licensee or the proposed use of the code by the licensee meets the NRC requirement.

Topical report DPC-NE-3005-P describes the details of how RETRAN-3D is utilized to analyze reactor system transients and accidents. The plant nodding description is essentially unchanged for analyses with the new steam generators. One difference in methodology is the use of MCNP Monte-Carlo transport code (Ref. 4) to evaluate neutron attenuation to the excore detectors. The neutron source for input into MCNP is evaluated using SAS2H/ORIGEN-S modules of the SCALE code system (Ref. 5). This methodology is commonly used in the nuclear industry and will provide increased accuracy over the methodology currently in use. The effect of downcomer temperature on neutron attenuation is important in evaluating the differences between measured and actual reactor power for the high power reactor trip determination. This determination is important to the analyses of control rod misalignment events and small steam line breaks.

RETRAN-3D is programmed to incorporate the ANS-5.1 decay heat standard of 1979. The RETRAN-3D code does not include the contribution from neutron capture within stable fission products that is part of the standard. The licensee accounts for this omission by inputting a decay heat correction multiplier table to the code input. The table includes the addition of two standard deviations to the decay power. This approach provides a high confidence that the actual decay heat will be bounded by the RETRAN-3D calculation and is, therefore, acceptable to the NRC staff. The NRC staff has accepted a similar approach for use with RETRAN-02. This upper bound of decay heat is applied for applications when it is conservative for decay heat to be high. For applications when it is conservative to have low values of decay heat, such as to evaluate overcooling following a main steam line break, the licensee uses conservatively low values of the decay heat multiplier.

To demonstrate the effect of using RETRAN-3D for analysis when the new steam generators are installed, the licensee performed a limited number of plant transient and accident analyses. These results will be added as a revision to the UFSAR. The specific revised analyses were for large and small main steam line breaks and turbine trip.

A turbine trip causes a sudden cessation of main steam flow. The effect is to cause primary and secondary system pressures to increase. The main steam safety valves open and the reactor trips on high primary system pressure. With the ROTSGs installed and using the RETRAN-3D computer code, the reactor system pressure was calculated to reach 2595 psig. This pressure is within 110 percent of design pressure and, therefore, meets the acceptance criteria of the NRC staff's Standard Review Plan. The maximum reactor system pressure calculated for a turbine trip using RETRAN-02 and the OTSGs was 2611.8 psig. The closeness of the results shows there is little change between the older and newer versions of RETRAN for overpressure events. The change in steam generators would not be expected to significantly affect the consequences for events of this type.

The rupture of a main steam line causes a rapid increase in reactor system heat removal and a decrease in reactor system temperature and pressure. The licensee analyzed two cases of large main steam line breaks at full power. A case for which offsite power remains available was analyzed to determine the maximum overcooling. A case for which offsite power was lost was analyzed to determine if DNB would occur on the fuel pins. At Oconee, the steam generators contain the maximum water mass at full power so that a steam line break from full power will be the most severe condition for overcooling.

The Oconee plants are equipped with an automatic feedwater isolation system to prevent continued feedwater flow into the steam generators in the event of a main steam line break. The system is not fully safety-related so the licensee does not take credit for operation of this system. For the case with offsite power available, the feedwater pumps are assumed to continue to operate filling both steam generators. The licensee analyzed the consequences of a main steam line break with continued feedwater pump operation in the previous revision to DC-NE-3005-P using RETRAN-02. These analyses were for the OTSGs.

With offsite power available, the reactor coolant pumps would remain in operation and maximize the rate of cooldown. If the reactor is sufficiently cooled, reactivity feedback from the moderator might cause the core to return to criticality with the control rods inserted. Return to criticality would be of particular concern in the event one control assembly failed to insert in the core causing power to peak at that location. In previous analyses using RETRAN-02 with the OTSGs, the reactor core was calculated to return to criticality if the most reactive control rod did not enter the core. The DNB limits for the core were shown to not be exceeded for this condition. In the analysis with the ROTSG, the core does not become critical again. This is because the flow restriction in the steam generator nozzles delays the cooldown and provides more time for boric acid to be pumped into the reactor core from the core flood tanks and the high pressure injection system. The licensee verified that the core will remain subcritical by inputting the thermal/hydraulic conditions calculated for the core into the three dimensional SIMULATE-3P neutronics code. The SIMULATE-3P results confirmed that the core will remain subcritical.

As part of the NRC staff review of the previous revision to DC-NE-3005-P (Ref. 6) the NRC staff performed audit calculations of postulated main steam breaks using RELAP5 and compared

the results of these audit calculations to the licensee's calculations using RETRAN-02. The NRC staff uses audit calculations as an aid in understanding and evaluating the sequences and phenomena in postulated reactor accidents. Conclusions on the acceptability or unacceptability of license applications are based on licensee calculations using approved methodology and not on the results of the NRC staff audit.

In previous analysis using RETRAN-02, the licensee predicted that the maximum overcooling following a main steam line break would occur if the feedwater control system continued to function. This was in conflict with the NRC staff audit using RELAP5 that indicated that maximum overcooling would occur if the feedwater control system failed. The new analysis using RETRAN-3D agrees with the NRC staff's prediction that failure of feedwater control system is the worst case. In the previous analysis using RETRAN-02, the reactor coolant pumps in the unaffected coolant loop became unstable and had to be tripped to keep the code from failing. In the RETRAN-3D analyses the pumps do not become unstable and continue to run. This result is also similar to the NRC staff's audit.

For the case of a large steam line break with loss of offsite power, the concern is loss of the required core DNB margin as a result of the reactor coolant pump coastdown and the decrease in reactor system pressure. The licensee uses maximum values of decay heat for this calculation to conservatively calculate the DNB margin. The thermal/hydraulic conditions predicted for the core by RETRAN-3D are input into the VIPRE code to calculate the minimum margin to DNB. The minimum DNB margin was found to be increased from the previous analysis primarily as a result of the action of the flow restriction in the steam generator nozzles. The licensee uses critical heat flux correlations that have been approved by the NRC staff to evaluate the DNB margin.

The licensee analyzed a spectrum of small steam line breaks to determine the effect of the ROTSGs. The limiting cases for small steam line breaks do not result in a reactor trip due to the reduction in reactor vessel downcomer temperature affecting the excore neutron detectors. The resulting margin to DNB was found to be increased over the previous analysis with the OTSGs.

The licensee has stated that the revised analyses for turbine trip and large and small steam line breaks will be incorporated into the Oconee UFSAR.

In addition to the technical revisions to topical reports DPC-NE-3000-P and DPD-NE-3005, the licensee has proposed minor editorial changes. The NRC staff has reviewed these changes and finds all of them to be acceptable.

4.0 CONCLUSIONS

On the basis of its review of Revision 3 to DPC-NE-3000-P and Revision 2 to DPC-NE-3005-P, including supplemental information provided by the licensee, the NRC staff concludes (1) that the modifications to RETRAN-3D will result in conservative results, and (2) that the licensee has demonstrated that the limitations and conclusions of the generic safety evaluation for RETRAN-3D are met. Therefore, the NRC staff concludes that RETRAN-3D as modified is acceptable for use at Oconee. In addition, the licensee has adequately applied RETRAN-3D to the safety analyses for Oconee in accordance with the requirements of the NRC staff's safety evaluation for RETRAN-3D (Ref. 3) and has made other revisions to the topical reports that are

acceptable to the NRC staff. The methodology in Revision 3 to DPC-NE-3000-P and Revision 2 to DPC-NE-3005-P is therefore approved and found acceptable for performing UFSAR Chapter 15 transient and accident analyses at Oconee. Use of this methodology for applications other than described in the topical reports will require additional NRC staff review and approval. The plant analyses contained in the topical reports are typical of those that will be incorporated into the UFSAR. For subsequent core reloads or other plant modifications, the licensee should verify that the analyses in the topical reports and UFSAR bound the results that would be obtained for the new plant condition or should perform new analyses that are conservative for that purpose.

5.0 REFERENCES

1. Letter from M. S. Tuckman, Duke Energy Corporation, to Chief, Information Management Branch, NRC, "Revisions to Topical Reports DNC-NE-3000, 3003, and 3005 in Support of Steam Generator Replacement, June 13, 2002.
2. Letter from K. S. Canady, Duke Energy Corporation, to Chief, Information Management Branch, NRC, "Revisions to Topical Reports DPC-NE-3000 and 3005 in Support of Steam Generator Replacement Response to NRC Staff Requests for Additional Information, May 21, 2003.
3. Letter from Stuart A. Richards, NRC to Gary L. Vine EPRI, Safety Evaluation Report on EPRI Topical Report NP-7450(P) Revision 4, "RETRAN-3D - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems," January 21, 2001.
4. Judith F. Briesmeister, Ed., "MCNP-A General Monte Carlo N-Particle Transport Code," Los Alamos National Laboratory Report, LA-13709-M, March 2000.
5. "SCALE Version 4.4, A Modular Code System for Performing Standardized Computer Analysis for Licensing Evaluation," Oak Ridge National Laboratory, ORNL/NUREG/CSD-2/R6, May 2000.
6. Letter from David E. LaBarge, NRC to W. R. McCollum, Jr., Duke Energy Company, Oconee Nuclear Station, Units 1, 2, and 3 RE: Safety Evaluation for Revision 1 to Topical Report DPC-NE-3005-P, "UFSAR Chapter 15 Transient and Accident Analysis Methodology," May 25, 1999.

Principal Contributor: W. Jensen, SRXB


Date: September 24, 2003



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 14, 1998

Mr. W. R. McCollum
Vice President, Oconee Site
Duke Energy Corporation
P. O. Box 1439
Seneca, SC 29679



SUBJECT: REVIEW OF TOPICAL REPORT DPC-NE-3000-PA, REVISION 2,
"THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY" -
OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3
(TAC NOS. MA1127, MA1128, AND MA1129)

Dear Mr. McCollum:

By letter dated December 23, 1997, Duke Energy Corporation (DEC/the licensee) submitted Revision 2 to Topical Report DPC-NE-3000-PA, "Thermal-Hydraulic Transient Analysis Methodology," for NRC staff review and approval. The report describes changes to thermal-hydraulic transient analysis methodology that are due to: (1) simulation model revision to reflect the new Mk-B11 fuel assembly design; (2) application of the new critical heat flux correlation (BWU-Z with the Mk-B11V multiplier); and (3) several RETRAN model improvements.

Based on our review of the submittal, and as explained in the enclosed Safety Evaluation, the staff has determined that the revisions incorporating the Mk-B11 fuel assembly design, BWUZ critical heat flux correlation with the Mk-B11V multiplier, and RETRAN model are acceptable for applications to non-loss-of-coolant accident transient and safety analysis.

Sincerely,

A handwritten signature in black ink, appearing to read "David E. LaBarge".

David E. LaBarge, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, and 50-287

Enclosure: Safety Evaluation

cc w/encl: See next page

Oconee Nuclear Station

cc:

Mr. Paul R. Newton
Legal Department (PBO5E)
Duke Energy Corporation
422 South Church Street
Charlotte, North Carolina 28201-1006

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Mr. Rick N. Edwards
Framatome Technologies
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852-1631

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory
Commission
7812B Rochester Highway
Seneca, South Carolina 29672

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
Atlanta Federal Center
61 Forsyth Street, S.W., Suite 23T85
Atlanta, Georgia 30303

Virgil R. Autry, Director
Division of Radioactive Waste Management
Bureau of Land and Waste Management
Department of Health and Environmental
Control
2600 Bull Street
Columbia, South Carolina 29201-1708

County Supervisor of Oconee County
Walhalla, South Carolina 29621

Mr. J. E. Burchfield
Compliance Manager
Duke Energy Corporation
Oconee Nuclear Site
P. O. Box 1439
Seneca, South Carolina 29679

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

L. A. Keller
Manager - Nuclear Regulatory
Licensing
Duke Energy Corporation
526 South Church Street
Charlotte, North Carolina 28201-1006

Mr. Richard M. Fry, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health, and
Natural Resources
3825 Barrett Drive
Raleigh, North Carolina 27609-7721

Mr. Steven P. Shaver
Senior Sales Engineer
Westinghouse Electric Company
5929 Carnegie Blvd.
Suite 500
Charlotte, North Carolina 28209



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

TOPICAL REPORT DPC-NE-3000-PA, REVISION 2

"THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY"

DUKE ENERGY CORPORATION

OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3

DOCKET NOS. 50-269, 50-270, AND 50-287

1.0 INTRODUCTION AND BACKGROUND

By letter dated December 23, 1997, Duke Energy Corporation (the licensee) submitted a revision to topical Report DPC-NE-3000-PA, Revision 1, "Thermal-Hydraulic Transient Analysis Methodology," dated December 1997 (Reference 1) for NRC staff review and approval. The report describes changes to the thermal-hydraulic transient analysis methodology that are due to: (1) simulation model revision to reflect the new Mk-B11 fuel assembly design; (2) application of the new critical heat flux correlation (BWU-Z with the Mk-B11V multiplier); and (3) several RETRAN model improvements.

The topical report DPC-NE-3000-PA, Revision 1, was submitted for staff review on August 8, 1995, (Reference 2), and approved by the staff on December 27, 1995, for reference for the Catawba, McGuire, and Oconee Nuclear Stations. Revision 1 included changes to the methodology due to the steam generator replacement for Catawba Unit 1, and McGuire Units 1 and 2, and correction of typographical errors.

This review is focused upon determining acceptability of the revised fuel assembly design, application of the new critical heat flux correlation, and RETRAN model improvements.

2.0 SUMMARY OF REPORT REVISIONS

The licensee incorporated in Revision 2 of DPC-NE-3000, a new Appendix A describing how the Mk-B11 fuel assembly will be simulated with the RETRAN-02 and VIPRE-01 models, text revisions which describe changes to the Oconee RETRAN models made to support the Updated Final Safety Analysis Report Chapter 15 analyses, and minor model revisions to the Catawba and McGuire RETRAN models that are identical to the Oconee revisions.

Appendix A of Revision 2 also discusses the use of the BWU-Z form of the BWU critical heat flux correlation with the Mk-B11V multiplier approved by the NRC for use in Mk-B11 fuel analysis.

3.0 EVALUATION

The Mk-B11 fuel assembly has smaller diameter fuel pins and mixing vane grids than the current fuel assembly design. Four lead test assemblies began operation in Oconee Unit 2, Cycle 16 in May 1996.

3.1 Mk-B11 Fuel Assembly

The Mk-B11 fuel assembly consists of a 15 by 15 array containing 208 fuel rods, 16 control rod guide tubes, one incore instrument guide tube, one nonmixing vane grid type grid spacer, and five mixing vane type grid spacers. The fuel pins are smaller in diameter than the current fuel design. The fuel design was previously reviewed and approved (Reference 3).

The VIPRE bulk void model has been modified to use the Zuber-Findlay model only when the void fraction is below 85 percent. When the void fraction is above 85 percent, the Armand or Smith bulk void fraction model will be used. The difference in use of these models will result in a change in minimum DNBR of 0.1 percent, an insignificant change. Four Mk-B11 lead fuel assemblies have been in operation in Oconee Unit 2 since May 1996.

The staff finds the revisions for the Mk-B11 fuel assembly acceptable.

3.2 Critical Heat Flux Correlation

The staff has reviewed and approved the BWU-Z form of the BWU critical heat flux correlation with the Mk-B11V multiplier for application to the Mk-B11 fuel assembly design (Reference 3). Duke will use the correlation within the range of applicability:

Pressure, psia	400 to 2465
Mass velocity, 10^6 lbm/hr-ft ²	0.36 to 3.55
Quality, percent	less than 74

Use of the BWU-Z form of the BWU critical heat flux correlation with the Mk-B11V multiplier is acceptable, as approved in Reference 3.

3.3 RETRAN Model Revisions

The RETRAN modeling was revised in the following areas:

Structural conductors - included metal heat sources previously excluded.

Process variable indications - correct circuit indications previously excluded, and extend indications where required.

Phase separation - apply the non-equilibrium bubble rise model for a more realistic pressure response when voiding has occurred.

Steady-state initialization - more accurately initialize steady-state conditions.

General transport model - general transport model added to an intermediate RETRAN version used to track soluble boron.

Reactor protection system functions - additional control system trip added to trip logic.

The revisions noted are applying previously approved code models and are acceptable.

4.0 CONCLUSIONS AND LIMITATIONS

The licensee's revision incorporating the Mk-B11 fuel assembly design, BWUZ critical heat flux correlation with the Mk-B11V multiplier, and RETRAN model revisions are acceptable for applications to non-loss-of-coolant accident (non-LOCA) transient and safety analysis.

Acceptability of the use of the proposed revisions in non-LOCA transients safety analysis remains subject to the limitations that were previously described in the safety evaluations for DPC-NE-3001 and DPC-NE-3002. Furthermore, acceptability does not remove limitations and restrictions previously described in the safety evaluation related to the original DPC-NE-3000 Topical Report for those issues not impacted by the subject revision.

Licensees who reference this topical report are expected to submit documentation describing how they comply with these safety evaluation conditions as part of their applications to use the topical report.

REFERENCES

1. Letter M. S. Tuckman (Duke Energy Corporation) to NRC, Attachment "DPC-NE-3000-PA, Revision 2," December 23, 1997.
2. DPC-NE-3000, "Thermal-Hydraulic Transient Analysis Methodology" original version July 1987, the approved version (DPC-NE-3000-PA dated August 1994) submitted by letter from M. S. Tuckman (Duke Energy Corporation) to NRC, August 8, 1995.
3. The BWU Critical Heat Flux Correlations Applications to the Mk-B11 and Mk-BW17 MSM Designs, Addendum 1 to BAW-10199P-A, Babcock and Wilcox, Lynchburg, Virginia, September 1996.

Principal Contributor: Ralph Landry

Date: October 14, 1998



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

December 27, 1995

Mr. M. S. Tuckman
Senior Vice President
Nuclear Generation
Duke Power Company
P. O. Box 1006
Charlotte, NC 28201-1006

SUBJECT: SAFETY EVALUATION FOR REVISION 1 TO TOPICAL REPORT DPC-NE-3000-P, "THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY" MCGUIRE NUCLEAR STATION, UNITS 1 AND 2; CATAWBA NUCLEAR STATION, UNITS 1 AND 2; AND OCONEE NUCLEAR STATION UNITS 1, 2, AND 3 (TAC NOS. M90143, M90144, AND M90145)

Dear Mr. Tuckman:

Your letter of August 9, 1994, submitted a revision to Duke Power Company (DPC) Topical Report DPC-NE-3000-P, "Thermal-Hydraulic Transient Analysis Methodology," dated June 1994, for review. The report describes changes to the DPC thermal-hydraulic transient analysis methodology that are due to: (1) the steam generator replacement for Catawba Unit 1 and McGuire Units 1 and 2, (2) changes to the methodology previously documented in DPC-NE-3000-P, and (3) corrections of typographical errors. Supplemental information was submitted in a letter dated September 12, 1995. This report, for reasons discussed in the enclosed Safety Evaluation, will be referred to hereafter, as Revision 1 to the original DPC-NE-3000-P report, which was issued in its approved form (DPC-NE-3000-PA) by DPC's letter of August 8, 1995.

Since Catawba Unit 2 continues to operate with the currently installed pre-heater steam generators, the previously reviewed and approved steam generator model will continue to be utilized. The DPC-NE-3000-PA report has been augmented in this revision to describe the models to be used for the Catawba Unit 1 and the McGuire Units 1 and 2 new feeding steam generators (FSG).

The staff finds DPC-NE-3000P, Revision 1, to be acceptable for referencing in Catawba, McGuire and Oconee licensing applications to the extent specified, and under the limitations stated, in DPC-NE-3000-P, Revision 1, and the associated NRC Safety Evaluation. The enclosed safety evaluation defines the basis for accepting this Topical Report. The staff was assisted in its review by the International Technical Services (ITS), Inc. The ITS Technical Evaluation Report (TER ITS/NRC/95-4) is also enclosed.

The staff does not intend to repeat its review of the matters described in the Topical Report and found acceptable when the report is referenced in a license application, except to ensure that the material presented is applicable to the specific plant involved. Staff acceptance applies only to the matters described in the Topical Report.

December 27, 1995

In accordance with procedures established in NUREG-0390, DPC must publish accepted proprietary and non-proprietary versions of this report. The accepted versions shall incorporate this letter and the enclosed Safety Evaluation between the title page and the abstract. The accepted versions shall include an -A (designating accepted) following the report identification symbol.

Should NRC criteria or regulations change so that staff conclusions regarding the acceptability of the report are invalidated, you will be expected to revise and resubmit your documentation, or to submit justification for continued effective applicability of the Topical Report without revision of the documentation.

This completes NRC actions for TAC Nos. M90143, M90144 and M90145.

Sincerely,



Robert E. Martin, Senior Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Docket Nos. 50-269, 50-270, 50-287
50-369, 50-370, 50-413
and 50-414

Enclosures: 1. Safety Evaluation
2. Technical Evaluation Report ITS/NRC/95-4

cc w/encls: See next page

Duke Power Company

cc:

Mr. Z. L. Taylor
Regulatory Compliance Manager
Duke Power Company
4800 Concord Road
York, South Carolina 29745

Mr. Paul R. Newton
Duke Power Company, PB05E
422 South Church Street
Charlotte, North Carolina 28242

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

North Carolina Municipal Power
Agency Number 1
1427 Meadowood Boulevard
P. O. Box 29513
Raleigh, North Carolina 27626

Mr. Peter R. Harden, IV
Account Sales Manager
Westinghouse Electric Corporation
Power Systems Field Sales
P. O. Box 7288
Charlotte, North Carolina 28241

County Manager of York County
York County Courthouse
York, South Carolina 29745

Richard P. Wilson, Esquire
Assistant Attorney General
S.C. Attorney General's Office
P. O. Box 11549
Columbia, South Carolina 29211

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Catawba Nuclear Station
McGuire Nuclear Station
Oconee Nuclear Station

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

Saluda River Electric Cooperative,
Inc.
P. O. Box 929
Laurens, South Carolina 29360

Senior Resident Inspector
4830 Concord Road
York, South Carolina 29745

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW Suite 2900
Atlanta, Georgia 30323

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-0001

Duke Power Company

cc:

Dr. John M. Barry
Mecklenburg County
Department of Environmental
Protection
700 N Tryon Street
Charlotte, North Carolina 29202

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. J. E. Snyder
Regulatory Compliance Manager
Duke Power Company
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Senior Resident Inspector
c/o U.S. Nuclear Regulatory
Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Mr. Dayne H. Brown, Director
Department of Environmental
Health and Natural Resources
Division of Radiation Protection
P. O. Box 27687
Raleigh, North Carolina 27611

County Supervisor of Oconee County
Walhalla, South Carolina 27621

Mr. J. W. Hampton
Vice President, Oconee Site
Duke Power Company
P. O. Box 1439
Seneca, South Carolina 29679

Catawba Nuclear Station
McGuire Nuclear Station
Oconee Nuclear Station

Mr. Ed Burchfield
Compliance
Duke Power Company
Oconee Nuclear Site
P. O. Box 1439
Seneca, South Carolina 29679

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Division
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Route 2, Box 610
Seneca, South Carolina 29678

Mr. W. R. McCollum
Site Vice President
Catawba Nuclear Station
Duke Power Company
4800 Concord Road
York, South Carolina 29745

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF THE NUCLEAR REACTOR REGULATION

TOPICAL REPORT DPC-NE-3000-P, REVISION 1

"THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY"

DUKE POWER COMPANY, ET AL.

MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

CATAWBA NUCLEAR STATION, UNITS 1 AND 2

OCONEE NUCLEAR STATION, UNITS 1, 2, AND 3

DOCKET NOS. 50-369, 50-370, 50-413, 50-414

50-269, 50-270, AND 50-287

1.0 INTRODUCTION AND BACKGROUND

By letter dated August 9, 1994, Duke Power Company (DPC or licensee) submitted a revision to the DPC Topical Report DPC-NE-3000-P, "Thermal-Hydraulic Transient Analysis Methodology," dated June 1994 (Reference 1) for NRC staff review and approval. The report describes changes to the DPC thermal-hydraulic transient analysis methodology that are due to: (1) the steam generator replacement for Catawba Unit 1 and McGuire Units 1 and 2, (2) changes to the methodology previously documented in DPC-NE-3000-P, and (3) corrections of typographical errors. Supplemental information was submitted in a letter dated September 12, 1995.

The subject report was submitted on August 9, 1994, and was identified by DPC as Revision 3 to the original DPC-NE-3000 report that was submitted by letter from H. B. Tucker to the NRC on September 29, 1987. The original report, following approvals for the Catawba, McGuire, and Oconee stations, was issued by DPC in its approved form by letter from M. S. Tuckman, DPC, to the NRC dated August 8, 1995, wherein it was identified as DPC-NE-3000-PA with no revision number. Accordingly, since the revisions in the August 9, 1994, report are beyond the scope of the original report, DPC's letter of September 12, 1995, renames the August 9, 1994, report as Revision 1 to DPC-NE-3000-P. Therefore, the August 9, 1994, report will be referred to, hereafter, as Revision 1 to the original DPC-NE-3000-P report.

In Revision 1 of the Topical Report DPC-NE-3000, DPC documents revisions to the currently approved thermal-hydraulic transient analysis methodology for Oconee, McGuire and Catawba stations (Reference 2). The revisions reflect changes due to the proposed replacement of the steam generators for McGuire

Units 1 and 2 and Catawba Unit 1 and methodology changes. Corrections of typographical errors are also included. Additional information was provided in Reference 3.

The currently approved methodology (Reference 2) for non-LOCA transient safety analysis is based upon the use of the RETRAN-02 and the VIPRE-01 computer codes for the McGuire, Catawba and Oconee stations. In Revision 1, only the RETRAN portion of the methodology was revised. The stated objective of the subject revision of the Topical Report is for DPC to demonstrate acceptability of changes in the analysis methodology for the Oconee, McGuire and Catawba plants.

This review is focused upon determining acceptability of the revised RETRAN plant models and their impact on previously approved analysis.

2.0 SUMMARY OF REPORT REVISIONS

The licensee incorporated, in Revision 1 of DPC-NE-3000, new sections describing Babcock and Wilcox's (B&W's) feedring steam generator (FSG), which is expected to replace the existing Westinghouse preheater steam generators (PSG) at the McGuire Units 1 and 2 and Catawba Unit 1 nuclear stations. Necessary modifications to associated components such as steamline and feedwater lines were also made.

There are minor modifications to the RETRAN methodology including the treatment of phase separation in some volumes and pressurizer modeling. Setpoint changes were incorporated into the description of the respective components and control systems. A description of the General Transport model to simulate boron transport (its use was approved in connection with the steamline break analysis in DPC-NE-3001 (Reference 4) was also added to the report for completeness. In addition, DPC corrected numerous typographical errors and made some editorial changes, which are of minimal technical significance.

3.0 EVALUATION

Revisions incorporated into the submittal can be categorized into three classes: (1) modeling upgrades and incorporation of a new steam generator model; (2) setpoint changes due to revised Technical Specifications; (3) non-technical correction to the text. Revisions to the approved RETRAN transient analysis methodology and their acceptability are discussed. Minor changes of a non-technical nature are not discussed, since these changes have no technical impact and are acceptable.

3.1 Revisions to RETRAN Models

These model revisions resulted from consolidation of modifications made due to (i) proposed steam generator replacements, (ii) better understanding gained through sensitivity studies performed since the original review, and (iii) plant Technical Specification changes.

3.1.1 Editorial Changes

The RETRAN General Transport model is used to simulate boron transport in the steamline break analysis. The model description is added to the Topical Report for completeness. The use of this model for steamline break was reviewed and approved in DPC-NE-3001.

3.1.2 Setpoint Changes

There are many setpoint changes used in the RETRAN control systems documented in this revision due to revised Technical Specifications. DPC will use setpoints which have been approved by the NRC.

3.1.3 Revised RETRAN Plant Models

Modeling upgrades were made in the (1) pressurizer model, (2) two-phase modeling, and (3) feedring steam generator (FSG) model. The addition of the FSG model and changes necessitated in associated components were also presented in this revision.

3.2 Description and Qualification of Revised Models

Pressurizer Model

The pressurizer vessel model was modified to include heat conductors using the local conditions heat transfer model. The pressurizer level is computed in the RETRAN control system whose modeling simulates the actual plant function.

Phase Separation

The bubble-rise model was used to simulate the two-phase separation in components where two-phase liquid is expected. The bubble rise velocity and gradient are specified. This option is specified instead of the homogeneous equilibrium model in the primary system volumes stated in the revision. As long as the primary system remains subcooled, the option is not activated. However, in the event that subcooling is lost, with the exception of the pressurizer, DPC should submit justification to the staff that use of this option is appropriate and will result in conservative predictions.

Steam Generator Replacement

The description of the B&W FSG is provided. Due to the design differences, the FSG nodalization is slightly different from the pre-heater SG nodalization. Although there is no transient data to qualify the adequacy of the nodalization, DPC provided a comparison of RETRAN-computed SG mass and level with the vendor-computed data and obtained good agreement. Similarly, DPC provided a comparison of RETRAN-computed RCS hot and cold leg temperatures given a specified RCS flow and steamline pressure with the vendor predictions. The comparison indicated that the heat transfer of the FSG was predicted well with the RETRAN model. Based upon these comparisons, it was concluded that the feedring SG nodalization and model are acceptable.

4.0 CONCLUSION AND LIMITATIONS

The DPC Topical Report DPC-NE-3000, Revision 1, and the DPC responses to NRC requests for additional information were reviewed.

The licensee's revised RETRAN models for the McGuire, Catawba and Oconee stations are acceptable for applications to non-LOCA transient and safety analysis.

Acceptability of the use of the proposed revisions in non-LOCA transients safety analysis remains subject to the limitations set forth in the SERs on DPC-NE-3001 and DPC-NE-3002 (References 4 and 5). Furthermore, acceptability does not remove limitations and restrictions set forth in the SER on the original DPC-NE-3000 for those issues not impacted by the subject revision.

Principal Contributor: L. Lois

Date: December 27, 1995

REFERENCES

1. Letter from H. B. Tucker (DPC) to NRC, Attachment "DPC-NE-3000 Revision 3" August 9, 1994.
2. DPC-NE-3000, "Thermal-Hydraulic Transient Analysis Methodology" original version July 1987, the approved version (DPC-NE-3000PA dated August 1994) submitted by letter from M. S. Tuckman, DPC, to NRC, dated August 8, 1995.
3. Letter from M. S. Tuckman (DPC) to NRC, "Request for Additional Information Relative to DPC-NE-3000P, Revision 1; Responses to Questions" September 12, 1995.
4. DPC-NE-3001P, "Duke Power Company Multidimensional Reactor Transients and Safety Analysis Physics Parameters Methodology," January 1990.
5. DPC-NE-3002, "FSAR Chapter 15 System Transient Analysis Methodology" Revision 1, November 1994.

TECHNICAL EVALUATION:
THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY
DPC-NE-3000 REVISION 3
FOR
DUKE POWER COMPANY

P.B. Abramson
H. Komoriya

Prepared for
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
Under NRC Contract No. NRC-03-90-027
FIN No. L1318



International Technical Services, Inc.
420 Lexington Avenue
New York, NY 10170

TECHNICAL EVALUATION
OF THE THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY
TOPICAL REPORT DPC-NE-3000 REVISION 3
FOR THE
DUKE POWER COMPANY
OCONEE, MCGUIRE AND CATAWBA NUCLEAR STATIONS

1.0 INTRODUCTION

In Revision 3 of the topical report entitled "Thermal-Hydraulic Transient Analysis Methodology," DPC-NE-3000, dated July 1994 (Ref. 1), Duke Power Company (DPC) documents revisions to the currently approved thermal-hydraulic transient analysis methodology for Oconee, McGuire and Catawba stations (Ref. 2). The revisions reflect changes due to the proposed replacement of steam generators for the McGuire and Catawba Unit 1 stations and methodology changes. Corrections of typographical errors are also included. Additional information was provided in Reference 3.

The currently approved methodology (Ref. 2) for non-LOCA transient safety analysis is based upon the use of the RETRAN-02 and VIPRE-01 computer codes for McGuire, Catawba and Oconee stations. In Revision 3, only the RETRAN portion of the methodology was revised. The stated objective of the subject revision of the topical report is for DPC to demonstrate acceptability of changes in the analysis methodology for Oconee, McGuire and Catawba plants.

This review is focused upon determining acceptability of the revised RETRAN plant models and their impact on previously approved analysis.

2.0 SUMMARY

DPC incorporated, in Revision 3 of DPC-NE-3000, new sections describing B&W's feedring steam generator (FSG), which is expected to replace the existing Westinghouse preheater steam generators (PSG) at the McGuire and Catawba Unit 1 nuclear stations. Necessary modifications to associated components such as steam line and feedwater lines were also made.

There are minor modifications to the RETRAN methodology including the treatment of phase separation in some volumes and pressurizer modeling. Setpoints changes were incorporated into the description of the respective components and control systems. A description of the General Transport model to simulate boron transport (its use was approved in connection with the steam line break analysis in DPC-NE-3001 (Ref. 4)) was also added to the report for completeness. In addition, DPC corrected numerous typographical errors and made some editorial changes which are of no technical significance.

3.0 EVALUATION

Revisions incorporated into the submittal can be categorized into three classes: (1) modeling upgrades and incorporation of a new steam generator model; (2) setpoint changes due to revised Technical Specifications; (3) non-technical correction to the text. Revisions to the approved RETRAN transient analysis methodology and their acceptability are discussed. Minor changes of a non-technical nature are not discussed, since these changes have no technical impact and are acceptable.

3.1 Revisions to RETRAN Models

These model revisions resulted from consolidation of modifications made due to (i) proposed steam generator replacements, (ii) better understanding gained through sensitivity studies performed since the original review, and (iii) plant technical specification changes.

3.1.1 Editorial Changes

The RETRAN General Transport model is used to simulate boron transport in the steam line break analysis. The model description is added to the topical report for completeness. The use of this model for steam line break was reviewed and approved in DPC-NE-3001.

3.1.2 Setpoint Changes

There are many setpoint changes used in the RETRAN control systems documented in this revision due to revised Technical Specifications. DPC will use NRC approved setpoints.

3.1.3 Revised RETRAN Plant Models

Modeling upgrades were made in the (1) pressurizer model, (2) two-phase modeling, and (3) Feedring SG model. The addition of the Feedring SG model and changes necessitated in associated components were also presented in this revision.

3.2 Description and Qualification of Revised Models

Pressurizer Model

The pressurizer vessel model was modified to include heat conductors using the local conditions heat transfer model. The pressurizer level is computed in the RETRAN control system whose modeling simulates the actual plant function.

Phase Separation

The bubble-rise model was used to simulate the two-phase separation in components where two-phase liquid is expected. The bubble rise velocity and gradient are specified. This option is specified instead of the HEM option

in the primary system volumes stated in the Revision. As long as the primary system remains subcooled, the option is not activated. However, in the event that subcooling is lost, with the exception of the pressurizer, DPC should justify that its use is appropriate and results in conservative predictions.

Steam Generator Replacement

The description of the B&W Feeding Steam Generator (FSG) is provided. Due to the design differences, the FSG nodalization is slightly different from the pre-heater SG nodalization. Although there is no transient data to qualify the adequacy of the nodalization, DPC provided comparison of RETRAN computed SG mass and level with the vendor computed data and obtained good agreement. Similarly, DPC provided comparison of RETRAN computed RCS hot and cold leg temperatures given a specified RCS flow and steam line pressure with the vendor predictions. Comparison indicated that the heat transfer of the FSG was predicted well with the RETRAN model. Based upon these comparisons, it was concluded that the feeding SG nodalization and model is acceptable.

4.0 CONCLUSIONS

DPC topical report DPC-NE-3000 Revision 3 and the DPC responses to NRC questions were reviewed.

DPC's revised RETRAN models for the McGuire/Catawba and Oconee nuclear power plants are acceptable in application to non-LOCA transient and safety analysis.

Acceptability of the use of the proposed revisions in non-LOCA transient safety licensing analysis remains subject to the limitations set forth in the SERs on DPC-NE-3001 and 3002 (Ref. 5). Furthermore, acceptability does not remove limitations and restriction set forth in the SER on the original DPC-NE-3000 for those issues not impacted by the subject revision.

5.0 REFERENCES

1. Letter from H.B. Tucker (DPC) to USNRC, Attachment "DPC-NE-3000 Revision 3," August 9, 1994.
2. "Thermal-Hydraulic Transient Analysis Methodology," DPC-NE-3000, July 1987.
3. Letter from M.S. Tuckman (DPC) to USNRC, "Request for Additional Information Relative to DPC-NE-3000P, Revision 1; Responses to Questions," September 12, 1995.
4. "Duke Power Company Multidimensional Reactor Transients and Safety Analysis Physics Parameters Methodology," DPC-NE-3001-P, January 1990.
5. "FSAR Chapter 15 System Transient Analysis Methodology," DPC-NE-3002, Revision 1, November 1994.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

August 8, 1994

Docket Nos. 50-269, 50-270
and 50-287

Mr. M. S. Tuckman
Senior Vice President
Nuclear Generation
Duke Power Company
P. O. Box 1006
Charlotte, North Carolina 28201-1006

Dear Mr. Tuckman:

SUBJECT: SAFETY EVALUATION REGARDING THE THERMAL HYDRAULIC TRANSIENT ANALYSIS
METHODOLOGY DPC-NE-3000 FOR OCONEE NUCLEAR STATION UNITS 1, 2,
AND 3 (TAC NOS. M87112, M87113, AND M87114)

By letter dated July 1987, Duke Power Company (DPC), submitted DPC-NE-3000, a topical report documenting DPC's use of the RETRAN computer code for McGuire/Catawba and Oconee. It was determined that DPC's use of the code was acceptable with respect to McGuire/Catawba; however, its use for Oconee licensing type analyses was restricted, primarily due to the difficulty in modeling the performance of the once-through steam generators. DPC submitted supplemental information, dated October 16, 1991, and October 5, 1993, to qualify the RETRAN model for use with Oconee analyses.

The NRC staff and its contractor, International Technical Services, Incorporated (ITS), have completed their review of the topical report and the supplemental submittals. The staff concludes that the DPC modifications of the steam generator model are acceptable. The staff's Safety Evaluation is included as Enclosure 1 and the ITS Technical Evaluation Report is included as Enclosure 2. This completes NRC actions for TAC Nos. M87112, M87113, and M87114. If you have questions regarding this matter, contact me at (301) 504-1495.

Sincerely,

A handwritten signature in dark ink, appearing to read "L. A. Wiens", written over the typed name.

L. A. Wiens, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. NRC Safety Evaluation
2. ITS Technical Evaluation Report

cc w/enclosures:
See next page

Mr. J. W. Hampton
Duke Power Company

Oconee Nuclear Station

cc:

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW.
Washington, DC 20005

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Division
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3rd Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 610
Seneca, South Carolina 29678

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

County Supervisor of Oconee County
Walhalla, South Carolina 29621

Mr. Steve Benesole
Compliance
Duke Power Company
Oconee Nuclear Site
P. O. Box 1439
Seneca, South Carolina 29679

Mr. Marvin Sinkule, Chief
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of
Justice
P. O. Box 629
Raleigh, North Carolina 27602

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
526 South Church Street
Charlotte, North Carolina 28242-0001

Dayne H. Brown, Director
Division of Radiation Protection
North Carolina Department of
Environment, Health and
Natural Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATING TO TOPICAL REPORT DPC-NE-3000
THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY
FOR DUKE POWER COMPANY
OCONEE NUCLEAR STATION, UNIT NOS. 1, 2, AND 3
DOCKET NO. 50-269, 50-270, AND 50-287

1.0 INTRODUCTION

By letter dated July 1987, Duke Power Company (DPC), the licensee for Oconee Nuclear Station, Units 1, 2, and 3, submitted DPC-NE-3000, a topical report documenting DPC's use of the RETRAN computer code for McGuire/Catawba and Oconee. It was determined that DPC's use of the code was acceptable with respect to McGuire/Catawba; however, its use for Oconee licensing type analysis was restricted. DPC submitted supplemental information, dated October 16, 1991, and October 5, 1993, to qualify its RETRAN Oconee model.

International Technical Services (ITS), Incorporated, reviewed the topical and supplemental submittals, and provided a final Technical Evaluation Report (TER) to the staff. The primary aspects of the review focused on the ability of the RETRAN Oconee model to predict the primary and secondary side performance of the once-through steam generator (OTSG).

2.0 STAFF EVALUATION

Duke Power Company (DPC) developed two RETRAN models to analyze plant response for transient analysis. The two models were (1) the single loop model for cases when both loops have the same transient response, and (2) the two loop model for cases when the loops respond differently to transients. The difficulty in modeling the OTSG is due to the phenomena that occur during operation. The upper portion of the OTSG is super heated and the tubes are partially uncovered. This results in the primary-to-secondary heat transfer rate being a function of a two-phase mixture height in the steam generator (S/G). RETRAN is not capable of directly modeling the two-phase mixture; and the model of the secondary side of the S/G greatly affects the predicted plant response to transients. Therefore, it was necessary for the licensee to make compensations in the S/G model. The major compensations were the location of nodes in modeling the steam generator and timing of the emergency feedwater actuation signal.

Once the modeling changes were incorporated, the licensee verified the adequacy of the modified S/G model. The licensee demonstrated the adequacy of the base plant model by comparing the RETRAN analyses to the available plant data. Duke Power demonstrated that the differences in results using different nodalizations were small, and therefore concluded that the S/G nodalization in the base model is valid.

In using the model for the Final Safety Analysis Report type analysis, certain events cause specific plant responses. To compensate for the RETRAN model consistently overpredicting the primary-to-secondary heat transfer following a reactor trip, the licensee incorporated appropriate delays in the determination of the emergency feedwater actuation time.

The method of predicting the S/G mixture level in the RETRAN base code is non-conservative for once-through steam generators. Initially, DPC was not going to rely on the original RETRAN steam generator low level trip for actuation of the emergency feedwater system. However, DPC was able to modify the RETRAN control system to adequately simulate S/G level instrumentation. The ITS verified that the method used by DPC resulted in a conservative prediction of the S/G level for the time period of interest.

3.0 CONCLUSION

The ITS reviewed DPC-NE-3000 and the supplemental documents and provided separate TERs for the McGuire/Catawba plants and the Oconee plant. It was necessary to modify the RETRAN steam generator modeling to more accurately depict the response of Oconee's once-through steam generators. Duke Power provided a detailed justification and qualification of the RETRAN modifications including an explanation of the system impact due to inaccuracies in the modeling of primary-to-secondary heat transfer.

The steamline break modeling, although not part of this review, was briefly described as a modification of the Oconee base model nodalization. The descriptive method of steamline break analysis was found acceptable, but DPC stated that the specific details of the analysis will be submitted to the staff in a separate topical report.

The contractor has found the DPC approach to RETRAN modeling of the Oconee plant with compensating modeling techniques and transient assumptions to be acceptable. The approach is reasonable subject to the condition that the models are applied only to the Oconee plant. The staff concurs with the findings presented in the TER in that DPC has adequately modified the RETRAN computer code to simulate the response of the OTSG.

Principal Contributor: S. Brewer

Date: August 8, 1994

SUPPLEMENTAL TECHNICAL EVALUATION:
THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY
DPC-NE-3000
FOR
DUKE POWER COMPANY
OCONEE NUCLEAR STATIONS

1.0 INTRODUCTION

DPC-NE-3000, dated July 1987 (Ref. 1), documented results of a series of studies performed by Duke Power Company (DPC) to support the development of thermal-hydraulic transient analysis methodology. The transient analysis methodology documented in the topical report was based on the use of the RETRAN-02 (Ref. 2) and VIPRE-01 (Ref. 3) computer codes, subject to conditions for its Oconee plants (which are B&W plants) and its McGuire and Catawba plants (which are Westinghouse plants) (Ref. 4)

The NRC review of DPC-NE-3000 resulted in acceptance of the methodology for McGuire and Catawba analysis applications. However, its licensing application to Oconee analysis was restricted until further qualification of the RETRAN Oconee models and their uses (Ref. 4). The VIPRE portion of the submittal for both types of plant analysis was found to be adequate.

The purpose of this review, which is based upon a review of the additional information (Refs. 1, 5, 6 & 7) provided by the licensee since the previous review, is to determine adequacy of the RETRAN Oconee plant model for use in licensing type calculations focusing upon the ability of the RETRAN Oconee model to predict the primary and secondary side performance of the once-through steam generator (OTSG).

Details of plant nodalization and transient benchmark calculations were presented in the original topical report and their review findings documented in Reference 4 and are unaffected by this supplement. In this report, only those changes which impact the previous review findings are presented. Review of actual licensing applications and associated conservative assumptions is beyond the scope of this review. Similarly, although a philosophical approach to the Oconee steam line break was provided, details of such transient analysis was stated by DPC to be beyond the scope of the topical report, and therefore detailed review of steam line break was not performed. DPC stated that a future topical report will detail this transient and others.

2.0 REPORT SUMMARY

The topical report was supplemented by submission of additional information

provided by DPC to specifically address conditions regarding use of RETRAN for Oconee application cited in the earlier SER on DPC-NE-3000.

Supplemental materials focused upon further qualification of the RETRAN Oconee steam generator model. Details of the steam generator model including nodalization sensitivity studies were provided. In addition, an explanation and analysis of sources of overprediction of primary-to-secondary heat transfer was provided.

A philosophical approach to Oconee steam line break analysis was also provided.

3.0 EVALUATION

Adequacy of DPC's application of the RETRAN computer code for thermal-hydraulic calculations of the transient behavior of its Oconee plants with focus upon DPC's Oconee steam generator modeling is discussed below.

3.1 Oconee Plant Model

DPC developed two Oconee RETRAN models: (1) a one-loop plant model to be used where there is little asymmetry between loop responses; and (2) a two-loop plant model to be used when asymmetric conditions are expected in the analysis. Detailed descriptions of the plant nodalizations and models selected for use in the analysis are presented in Chapter 2 of the topical report.

In the one-loop model, DPC models both steam generators and the accompanying hot and cold legs by one hot leg, one once-through steam generator (OTSG) and one cold leg. The core and steam generator nodalizations are the same as those in the two-loop plant model.

The base two-loop Oconee plant model consists of two separate loops each containing one hot leg, an OTSG and two cold legs. The OTSG is nodalized with equal height shell and tube side volumes except at the bottom of the steam generator. DPC stated that the specific degree of detail selected (i.e. the number of nodes) for the OTSG is necessary to model the void distribution in the OTSG.

The modeling of OTSGs is very difficult because in normal operation the steam in the upper portion of the SG is super heated and the SG tubes are partially uncovered (in marked contrast to U-tube type plants). Therefore the primary-to-secondary heat transfer rate is a function of the two-phase mixture height on the secondary side and the predicted transient behavior is strongly dependent upon the two-phase modeling on the secondary side of the steam generator. The mixture interface location and its transient behavior are very difficult to model with RETRAN, facts which DPC has acknowledged (Ref. 8).

DPC indicated, in Reference 5, certain potential nodalization and model changes for FSAR analyses to obtain conservative results. Each of these changes should add conservatism. However, it is recommended that DPC should

demonstrate that such implementation produces conservative results.

3.1.1 Oconee RETRAN Steam Generator Model Qualification

In DPC-NE-3000, DPC chose to demonstrate the adequacy of the base plant model for Oconee plants through comparison of RETRAN analyses to available plant data, providing reasonably thorough analyses of the transients analyzed. In the supplemental submittals, justifications of DPC's Oconee SG nodalization were documented. DPC performed SG nodalization sensitivity studies and demonstrated that the differences between the two nodalizations considered were small indicating that the SG nodalization in the base model is converged.

However, in the earlier benchmark analyses it was found that the Oconee RETRAN model consistently overpredicted primary-to-secondary heat transfer following reactor trip. In order to manage this inherent modeling difficulty with RETRAN, DPC classified the FSAR transients into four categories (Ref. 7) according to expected impact of overprediction of post-trip heat transfer.

Category 1 contains transients 15.2 through 15.7 and 15.12 for which this phenomenon has little impact. For the transients in Category 2 (15.13 and 10.4.7.1.7 (Feedwater Line Break)), overprediction of post-trip heat transfer will result in a conservatively higher initial rate of overcooling. Computation of the source term in the steam generator tube rupture event (Category 3) over a 2-hour time period is not significantly affected by the overprediction of the initial post-trip heat transfer since the secondary inventory boil-off during the 2-hour time period will remain essentially the same.

Category 4 consists of loss of main feedwater (LOMFw), LOMFW with loss of offsite AC power, LOMFW with loss of onsite and offsite AC power and loss of electric power accidents. For these transients, there is a potential for the post-trip heat transfer to have an impact on the acceptance criteria (MDNBR and peak system pressure) being met. In order to prevent a premature injection of emergency feedwater due to faster boil-off in the LOMFW event caused by overprediction of primary-to-secondary heat transfer, an additional delay in the EFW start time is used. For the loss of electric power events in which the RCP's are tripped off, in order to maintain the required SG liquid level for natural circulation in the RCS, the EFW is assumed to open immediately to increase SG levels after adequate delay times.

DPC stated that the use of compensatory conservative assumptions will assure that the overprediction of primary-to-secondary heat transfer following a reactor trip will result in overall conservative predictions. DPC further stated that the specific sizes of delay and other corresponding conservative assumptions will be addressed in a future topical report. This approach is reasonable.

3.1.2 Steam Generator Mixture Level Prediction

In the previous review, DPC stated that the steam generator level trip would not be relied upon for actuation of the emergency feedwater system (EFW).

However, during this review, DPC revised the earlier position by stating its intent to use this setpoint. Thus closer examination of the manner in which the SG level is computed was conducted.

EFW actuates on MFW pump trip or on low SG level. DPC used a RETRAN control system to simulate SG level instrument function by calculating a differential pressure between the location of the two taps used by the instrument.

Benchmark analysis presented in DPC-NE-3000 showed that at the time period of interest, the predicted SG level compared well against the plant data. Prior to reaching that low level, the prediction tended to show a lower level than the data indicated, but this underprediction had minimal impact on the transient scenario as long as the minimum SG level was maintained.

3.1.3 Steam Line Break Modeling

In order to conservatively model the licensing type analysis of the steam line break event, DPC modified the base model Oconee RETRAN nodalization. These modifications include a split core and reactor vessel incorporating cross flow junctions. Although limited descriptive details of how the steam line break analysis would be performed by DPC were provided in Reference 7 and found to be reasonable, no quantitative information related to qualification of the methodology was provided. DPC stated that the specific details regarding the analysis are beyond the scope of DPC-NE-3000 and will be submitted to the NRC in a separate topical report.

4.0 CONCLUSIONS

DPC topical reports DPC-NE-3000 and its supporting documents, including the DPC responses to NRC questions, were reviewed. These responses addressed conditions cited in the earlier SER issued on DPC-NE-3000. Of four conditions cited, modeling deficiency with respect to the steam generator was the most serious. DPC provided detailed justification and qualification of its Oconee steam generator models using RETRAN. Thorough explanation of sources of predicted bias in the primary-to-secondary heat transfer was provided and found to be reasonable.

It is DPC's intent to overcome RETRAN modeling problems with compensating modeling techniques and transient assumptions. Review of actual licensing applications and associated conservative assumptions was beyond the scope of this review, since such details are to be presented in a future topical report. Similarly, because DPC stated that the specific details regarding the analysis are beyond the scope of DPC-NE-3000 and will be submitted to the NRC in a separate topical report, detailed review of an Oconee split core model for the steam line break analysis was not performed as part of this review and should be performed as part of the review of a subsequent topical report.

This approach is reasonable subject to the following conditions:

1. Acceptability of use of the DPC RETRAN transient analysis methodology is applicable only to Oconee plants.

2. When these models are used in licensing calculations, DPC should demonstrate that the models are adequately modified, where appropriate, to incorporate sufficient conservatism so that the resulting analysis is conservative. Furthermore, DPC should demonstrate that the compensatory assumptions and delay times which it introduces to offset the over-prediction of post-trip heat transfer produce adequately conservative results.

4.0 REFERENCES

1. "Thermal-Hydraulic Transient Analysis Methodology," DPC-NE-3000, July 1987.
2. Letter, C.O. Thomas (NRC) to T.W. Schnatz (UGRA), September 4, 1984, (Transmittal of RETRAN-02 Safety Evaluation Report).
3. "Acceptance for Referencing of Licensing Topical Report VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores, EPRI NP-2511-CCM Vols. 1-4," May 1, 1986.
4. Safety Evaluation on Topical Report DPC-NE-3000 "Thermal-Hydraulic Transient Analysis Methodology," November 15, 1991.
5. Letter from H.B. Tucker (DPC) to USNRC, "Handouts Presented in the October 7 & 8, 1991 Meeting with NRC Staff and Contract Reviewers, October 16, 1991.
6. Letter from H.B. Tucker (DPC) to USNRC, "Thermal-Hydraulic Transient Analysis Methodology," March 11, 1992.
7. Letter from M. S. Tuckman (DPC) to USNRC, "Thermal-Hydraulic Transient Analysis Methodology, DPC-NE-3000" October 5, 1993.
8. Letter from H.B. Tucker (DPC) to USNRC, "Duke Power Response to NRC Questions Regarding Steam Generator Heat Transfer Modeling with the RETRAN Code," August 9, 1989.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

November 15, 1991

Docket Nos. 50-369, 50-370
50-413 and 50-414
50-269, 50-270, and 50-287

Mr. H. B. Tucker, Senior Vice President
Nuclear Generation
Duke Power Company
P. O. Box 1007
Charlotte, North Carolina 28201-1007


Dear Mr. Tucker:

SUBJECT: SAFETY EVALUATION ON TOPICAL REPORT DPC-NE-3000, "THERMAL-
HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY (TAC NOS. 73765/73766/
73767/73768)

The NRC staff with the support of its contractor has reviewed Duke Power Company Topical Report DPC-NE-3000, "Thermal-Hydraulic Transient Analysis Methodology," transmitted on September 29, 1987, as revised by letter dated May 11, 1989. Additional information supporting the review was provided by DPC letters dated June 15, June 19, August 9, and September 13, 1989, February 20, 1990, August 29, October 16, and November 5, 1991. The staff has found the topical report to be acceptable for referencing in the symmetric non-LOCA system and core thermal-hydraulic transient analyses for the McGuire and Catawba Nuclear Station subject to the conditions delineated in section 3.0 of the attached Safety Evaluation. At this time, DPC-NE-3000 is not acceptable for referencing in analyses involving the Oconee Nuclear Station. The staff is continuing its review of DPC-NE-3000 for Oconee.

This concludes our review activities in response to your submittals regarding Topical Report DPC-NE-3000 for the McGuire and Catawba Nuclear Stations.

Sincerely,


Timothy A. Reed, Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Safety Evaluation
2. Technical Evaluation Report ITS/NRC/91-2,
Parts 1 and 2

cc: See next page

Duke Power Company

cc:

Mr. R. C. Futrell
Regulatory Compliance Manager
Duke Power Company
Catawba Nuclear Site
Clover, South Carolina 29710

North Carolina Electric Membership
Corp.

P.O. Box 27306
Raleigh, North Carolina 27611

Saluda River Electric Cooperative,
Inc.

P.O. Box 929
Laurens, South Carolina 29360

North Carolina MPA-1
Suite 600
P.O. Box 29513
Raleigh, North Carolina 27626-513

Mr. Heyward G. Shealy, Chief
Bureau of Radiological Health
South Carolina Dept. of Health
and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

County Manager of York County
York County Courthouse
York, South Carolina 29745

Richard P. Wilson, Esq.
Assistant Attorney General
S.C. Attorney General's Office
P.O. Box 11549
Columbia, South Carolina 29211

Senior Resident Inspector
Route 2, Box 179N
York, South Carolina 29745

Mr. M. S. Tuckman
Vice President, Catawba Site
Duke Power Company
P. O. Box 256
Clover, South Carolina 29710

McGuire Nuclear Station
Catawba Nuclear Station
Oconee Nuclear Station

Mr. M. E. Patrick
Compliance
Duke Power Company
Oconee Nuclear Site
P. O. Box 1439
Seneca, South Carolina 29679

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Division
Suite 525
1700 Rockville Pike
Rockville, Maryland 20852

Manager, LIS
NUS Corporation
2650 McCormick Drive, 3 Floor
Clearwater, Florida 34619-1035

Senior Resident Inspector
U. S. Nuclear Regulatory Commission
Route 2, Box 610
Seneca, South Carolina 29678

Mr. J. W. Hampton
Vice President, Oconee Site
Duke Power Company
P. O. Box 1439
Seneca, South Carolina 29679

Office of Intergovernmental Relations
116 West Jones Street
Raleigh, North Carolina 27603

County Supervisor of Oconee County
Walhalla, South Carolina 29621

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Duke Power Company

cc:

Mr. A.V. Carr, Esq.
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

County Manager of Mecklenburg County
720 East Fourth Street
Charlotte, North Carolina 28202

Mr. R. O. Sharpe
Compliance
Duke Power Company
McGuire Nuclear Site
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985

J. Michael McGarry, III, Esq.
Winston and Strawn
1400 L Street, N.W.
Washington, DC 20005

Senior Resident Inspector
c/o U.S. Nuclear Regulatory Commission
12700 Hagers Ferry Road
Huntersville, North Carolina 28078

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Frank Modrak
Project Manager, Mid-South Area
ESSD Projects
Westinghouse Electric Corporation
MNC West Tower - Bay 241
P. O. Box 355
Pittsburgh, Pennsylvania 15230

McGuire Nuclear Station
Catawba Nuclear Station
Oconee Nuclear Station

Dr. John M. Barry
Department of Environmental Health
Mecklenburg County
1200 Blythe Boulevard
Charlotte, North Carolina 28203

Mr. Dayne H. Brown, Director
Department of Environmental,
Health and Natural Resources
Division of Radiation Protection
P.O. Box 27687
Raleigh, North Carolina 27611-7687

Mr. Alan R. Herdt, Chief
Project Branch #3
U.S. Nuclear Regulatory Commission
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. Karen E. Long
Assistant Attorney General
N. C. Department of Justice
P.O. Box 629
Raleigh, North Carolina 27602

Mr. R. L. Gill, Jr.
Licensing
Duke Power Company
P.O. Box 1007
Charlotte, North Carolina 28201-1007

Mr. T. C. McMeekin
Vice President, McGuire Site
Duke Power Company
12700 Hagers Ferry Road
Huntersville, North Carolina 28078-8985



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATING TO TOPICAL REPORT DPC-NE-3000

"THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY"

OCONEE NUCLEAR STATIONS, UNITS 1, 2, AND 3

MCGUIRE NUCLEAR STATIONS, UNITS 1 AND 2

CATAWBA NUCLEAR STATIONS, UNITS 1 AND 2

DOCKET NOS. 50-269, 50-270, 50-287, 50-369, 50-370, 50-413 AND 50-414

1.0 INTRODUCTION

Duke Power Company (DPC) submitted Topical Report DPC-NE-3000, "The Thermal-Hydraulic Transient Analysis Methodology, Oconee Nuclear Station, McGuire Nuclear Station, and Catawba Nuclear Station" in a letter dated September 29, 1987 (Ref. 1), as revised by a letter dated May 11, 1989 (Ref. 2). Additional information was also provided in References 3 to 10. This topical report documents the development of the thermal-hydraulic simulation models for the Oconee, McGuire, and Catawba plants using RETRAN-02 and VIPRE-01 computer codes and provide DPC's responses to Generic Letter 83-11, "Licensee Qualification for Performing Safety Analyses in Support of Licensing Actions" (Ref. 11).

RETRAN-02 is a large and sophisticated computer code developed to simulate a wide spectrum of thermal-hydraulic transients for both pressurized water reactors and boiling water reactors (Ref. 12). VIPRE-01 is an open channel code designed to evaluate DNBR and coolant state for steady state and transient core thermal-hydraulic analyses (Ref. 13). Both RETRAN-02 and VIPRE-01 have been approved for PWR licensing calculations with generic limitations (Refs. 14 to 15).

Generic Letter 83-11 requests that each licensee or vendor who intends to use large, complex computer codes to perform their own safety analyses to demonstrate their proficiency to use the codes by submitting code verification performed by themselves. To demonstrate their technical competence in using the RETRAN computer code and qualify their RETRAN models for thermal-hydraulic transient simulation, DPC provided in the RETRAN portion of this topical report: (1) detailed descriptions of the plant nodalizations, control system models, code models, and code options selected for use in the analysis, (2) analyses benchmarked against start-up test data and plant operational transient data from the Oconee, McGuire, and Catawba plants.

In the SER for VIPRE-01, the staff requests each user to document and submit a separate report which, (1) describes how they intend to use VIPRE, and (2) provides justification for specific modeling assumptions, choices of particular

models and correlations, and input values of plant specific data such as turbulent mixing coefficient and grid loss coefficient. DPC previously submitted VIPRE-01 models for use in steady-state which have been addressed in specific SERs. VIPRE-01 models for transient applications are addressed in this SER.

2.0 STAFF EVALUATION

The staff review and evaluation of the Topical Report DPC-NE-3000 addresses: (1) DPC's competence in using the RETRAN and VIPRE computer codes, (2) the degree to which the topical report and supplemental information satisfy requirements in the VIPRE-01 and RETRAN SERs; and, (3) the ability of the RETRAN simulations to match plant operational data. The review of this topical was performed with technical assistance from International Technical Services, Incorporated (ITS) and its review findings are contained in the Technical Evaluation Report (TER) which is attached. The staff has reviewed the TER and concurred with its findings.

3.0 FINDINGS AND CONCLUSIONS

The staff has reviewed the Topical Report DPC-NE-3000, which documents the development of the thermal-hydraulic simulation models for the Oconee, McGuire, and Catawba plants. Overall we conclude that the licensee has demonstrated a high degree of technical competence in using RETRAN-02 and VIPRE-01 computer codes. Specific findings and conclusions regarding the RETRAN and VIPRE models are discussed below.

RETRAN FINDINGS

We find that DPC's RETRAN-02 models to be acceptable for the simulation of the symmetric non-LOCA thermal-hydraulic transients for the McGuire, and Catawba Nuclear Units, subject to the limitations listed below. However, the RETRAN-02 models for Oconee have not been shown to be adequate for best estimate nor licensing calculations, and are therefore not approved for either of these applications.

- (1) With respect to analyzing transients which result in a reduction in steam generator secondary water inventory, use of the RETRAN-02 steam generator modeling is acceptable, only for transients in that category for which the secondary side inventory for the effective steam generator(s) relied upon for heat removal never decreases below an amount which would cover enough tube height to remove decay heat.
- (2) All generic limitations specified in the RETRAN-02 SER (Reference 14).

VIPRE FINDINGS

We find that the subject topical report, together with DPC responses, contains sufficient information to satisfy the VIPRE-01 SER requirement that each VIPRE-01 user submit a document describing proposed use, sources of input variables, and selection and justification of correlations as it relates to use by DPC for FSAR Chapter 15 analyses regarding Oconee, McGuire and

Catawba. We further find that the manner in which the code is to be used for such analyses, selection of nodalization, models, and correlations provides, except as listed below, adequate assurances of conservative results and is therefore acceptable. Furthermore, the use of the DPC developed statistical core design methodology as approved in the Staff Safety Evaluation Report on DPC-NE-2004, is approved for the transient application subject to the same conditions.

The following items are limitations regarding VIPRE-01 application presented in DPC-NE-3000 and its supplemental materials:

- (1) Determination of acceptability is based upon review of selection of models/correlations for transients involving symmetric core neutronic and thermal-hydraulic conditions only. Thus, the VIPRE-01 models are approved for use in analyzing symmetric transients only;
- (2) When using the DPC developed SCD method, the licensee must satisfy the conditions set forth in the staff's safety evaluation of DPC-NE-2004;
- (3) Whenever DPC intends to use other CHF correlations, power distribution, fuel pin conduction model or any other input parameters and default options which were not part of the original review of the VIPRE-01 code, DPC must submit its justification for NRC review and approval;
- (4) Core bypass flow should be determined on cycle-by-cycle bases;
- (5) All generic limitations specified in the VIPRE-01 SER.

4.0 REFERENCES

1. Letter from H. B. Tucker (DPC) to USNRC, "Thermal-Hydraulic Transient Analysis Methodology, DPC-NE-3000, Response to Generic Letter 83-11," September 29, 1987.
2. Letter from H. B. Tucker (DPC) to USNRC, Attachment "DPC-NE-3000 Revision 1," May 11, 1989.
3. Letter from H. B. Tucker (DPC) to USNRC, Attachment "Duke Power Responses to NRC Questions Dated April 7, 1989 Regarding DPC-NE-3000," June 15, 1989.
4. Letter from H. B. Tucker (DPC) to USNRC, "Response to Questions Regarding Differences Between Duke Topical Reports DPC-NE-2003 and DPC-NE-3000," June 19, 1989.
5. Letter from H. B. Tucker (DPC) to USNRC, "Duke Power Response to NRC Questions Regarding Steam Generator Heat Transfer Modeling with the RETRAN Code," August 9, 1989.
6. Letter from H. B. Tucker (DPC) to USNRC, Attachment 1 "Responses to NRC Questions on the McGuire/Catawba Sections of DPC-NE-3000" and Attachment 2 "Revisions to Section 4 of DPC-NE-3000," September 13, 1989.

7. Letter from H. B. Tucker (DPC) to USNRC, "Response to NRC Questions on DPC-NE-3000 Dated July 25, 1989," February 20, 1990.
8. Letter from M. S. Tuckman (DPC) to USNRC, "Supplemental Information to Assist in Review of Topical Reports DPC-NE-3000 and DPC-NE-2004," August 29, 1991.
9. Letter from H. B. Tucker (DPC) to USNRC, "Handouts Presented in the October 7 & 8, 1991 Meeting with NRC Staff and Contract Reviewers," October 16, 1991.
10. Letter from H. B. Tucker (DPC) to USNRC, "Final Response to Questions Regarding the Topical Reports Associated with the M1C8 Reload Package," November 5, 1991.
11. Licensee Qualification for Performing Safety Analyses in Support of Licensing Actions (Generic Letter No. 83-11), USNRC, February 8, 1983.
12. "RETRAN-02 - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems," EPRI NP-1850-CCM Revision 2, EPRI, November 1984.
13. "VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores," EPRI NP-2511-CCM Revision 2, EPRI, July 1985.
14. Letter, C. O. Thomas (NRC) to T. W. Schnatz (UGRA), September 4, 1984, (Transmittal of RETRAN-02 Safety Evaluation Report).
15. Letter, C. E. Rossi (NRC) to J. A. Blaisdell (UGRA), May 1, 1986, (Transmittal of VIPRE-01 Safety Evaluation Report).
16. "Oconee Nuclear Station Core Thermal-Hydraulic Methodology Using VIPRE-01," DPC-NE-2003, August 1988.

Date: November 15, 1991

TECHNICAL EVALUATION
OF THE THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY
TOPICAL REPORT DPC-NE-3000
FOR THE
DUKE POWER COMPANY
OCONEE, MCGUIRE AND CATAWBA NUCLEAR STATIONS
Part 1

1.0 INTRODUCTION

DPC-NE-3000, dated July 1987 (Ref. 1), documents results of a series of studies performed by Duke Power Company (DPC) to support the development of thermal-hydraulic transient analysis methods and provides DPC's response to Generic Letter 83-11 (Ref. 2). These methods were developed using the RETRAN-02 (Ref. 3) and VIPRE-01 (Ref. 4) computer codes, both of which have been approved, subject to conditions (Refs. 5 & 6). The stated objective of the subject report was for DPC to demonstrate DPC capability and technical competence through RETRAN analysis of its Oconee plants (which are B&W plants) and its McGuire and Catawba plants (which are Westinghouse plants).

The purpose of this review, which is based upon a review of the submitted materials (Refs. 1, 7-13), is to determine (i) the degree of DPC's technical competence demonstrated in the transient analyses, (ii) acceptability of the RETRAN plant models by review of the accuracy of the results obtained using the computer codes and submitted models and (iii) adequacy of DPC's documentation of its VIPRE-01 models to fulfill VIPRE SER requirements.

This technical evaluation report (TER) is divided into two parts: Part 1 presents our evaluation (in accordance with the RETRAN SER) of DPC's use of the RETRAN computer code and the acceptability of the DPC RETRAN models for Oconee and McGuire/Catawba plants; Part 2 contains an evaluation (in accordance with the VIPRE SER) of DPC's intended method for use of the VIPRE computer code in transient application for the same plants.

2.0 EVALUATION

Acceptability of DPC's application of the RETRAN computer code for thermal-hydraulic calculations of the transient behavior of its Oconee and McGuire/Catawba plants is discussed below.

2.1 Oconee Plant Model

DPC developed two Oconee RETRAN models: (1) a one-loop plant model to be used where there is little asymmetry between loop responses and (2) a two-loop plant model to be used when asymmetric conditions are expected in the analysis. Detailed descriptions of the plant nodalizations and models selected for use in the analysis are presented in Chapter 2 of the topical report.

In the one-loop model, DPC models both steam generators and the accompanying hot and cold legs by one hot leg, one once-through steam generator (OTSG) and one cold leg. The core and steam generator nodalizations are the same as those in the two-loop plant model.

The base two-loop Oconee plant model consists of two separate loops each containing one hot leg, an OTSG and two cold legs. The OTSG is nodalized with equal height shell and tube side volumes except at the bottom of the steam generator. DPC stated that the specific degree of detail selected (i.e. the number of nodes) for the OTSG is necessary to model the void distribution in the OTSG.

The modeling of OTSGs is very difficult because in normal operation the steam in the upper portion of the SG is super heated and the SG tubes are partially uncovered (in marked contrast to U-tube type plants). Therefore the primary-to-secondary heat transfer rate is a function of the two-phase mixture height on the secondary side and the predicted transient behavior is strongly dependent upon the two-phase modeling on the secondary side of the steam generator. The mixture interface location and its transient behavior are

very difficult to model with RETRAN, facts which DPC has acknowledged (Ref. 10).

DPC used the non-equilibrium pressurizer option to model the pressurizer (PZR) for best-estimate safety analysis. Other model options are used as necessary to obtain conservative results for Chapter 15 type analyses.

Although the DPC responses to NRC questions referred to their experience with three sets of nodalizations and to sensitivity studies performed to arrive at the base nodalization, DPC did not justify selection of built-in RETRAN thermal-hydraulic models and correlations. Furthermore, although the nodalization study indicates that the model was converged, it did not indicate accurate convergence to the mixture level on the secondary side.

In addition, DPC presented qualitative arguments supporting the selection of various nodalizations for other plant components (such as the reactor vessel) and the selection of the use of the certain models such as the bubble rise model and the non-equilibrium model.

The Oconee base model is based on the Unit 1 thermal design flow, since it is lower than Units 2 and 3 and is conservative with respect DNB. The RETRAN initial conditions for computed RCS flow as well as other key plant parameters were adjusted by DPC on a transient-by-transient basis to better match the plant data as noted later.

RETRAN control systems were developed and used extensively by DPC to specify transient boundary conditions, such as automatic plant actions and operator actions as well as control actions by modulating valves, changing fill rates or reactivity and simulation of trip actuation. The control system was also used to compute the steam generator level by emulating the plant measurement device by taking DP across SG pressure taps. In addition, uncertainty in the degree of SG tube fouling generally resulted further in large discrepancies between the predicted and measured data as discussed in the following sections.

2.1.1 Oconee RETRAN Model Qualification

DPC chose to demonstrate the adequacy of the base plant model for both Oconee and McGuire/Catawba plants through comparison of RETRAN analyses to available plant data, providing reasonably thorough analyses of the transients analyzed. However, DPC provided only limited justification for its plant nodalization, input selection, and selection of particular correlations built into the code, and did not present any description of its RETRAN control systems models in the topical report. DPC took the position that the test of the model was in its ability to reproduce plant data, notwithstanding the fact that it is widely recognized that modeling of a once-through steam generator is difficult with RETRAN (as is evident from results of DPC benchmark analysis).

Therefore, this evaluation is based upon a review of the ability of the base model (best-estimate model) to benchmark startup test data and several operational transient data over a wide range of plant conditions.

2.1.2 Benchmark Analyses

For the purpose of benchmarking the base Oconee RETRAN models, DPC analyzed 11 tests and transients, one of which was a transient which occurred at Arkansas Nuclear One - Unit 1, a sister plant.

The one-loop model was used for six analyses: (1) Loss of Main Feedwater, (2) Turbine Bypass Valve Failure Following Reactor Trip, (3) Loss of Offsite Power, (4) Steady State Natural Circulation Comparisons, (4) Control Rod Group Drop, and (6) Main Feedwater Pump Trip.

The two-loop model was used in the five remaining analyses: (1) Steam Generator Overfeed Following Reactor Trip, (2) Overcooling Following Loss of ICS Power, (3) Reactor Coolant Pump Coastdowns, (4) Turbine Bypass Valve Failure, and (5) Reactor Trip from Three Reactor Coolant Pump Operation.

2.1.2.1 Loss of Main Feedwater

DPC analyzed the loss of main feedwater event which occurred in August 1984 at Oconee Nuclear Station Unit 3 while it was operating at full power. Letdown was manually isolated in the first 10 seconds and RCS makeup flow was increased manually. Only one high pressure injection (HPI) pump operated during the transient. All three emergency feedwater (EFW) pumps started immediately following the loss of the MFW pumps, and contributed to maintaining SG levels.

The modeling of this transient was revised and resubmitted by DPC (Ref. 8) to better model the boundary conditions. In the revised analysis, RCS flow and T-ave were adjusted to match the plant data which resulted in T_{hot} and T_{cold} being initialized at slightly different values. Since the EFW flow data were unavailable, DPC inferred the EFW flowrate from the SG levels and used a RETRAN control system to simulate throttling of EFW to match the simulated SG level with the plant data.

DPC provided a thorough analysis for this transient. Following the trip, results indicated a modest over-prediction of primary-to-secondary heat transfer and, after the PZR spray setpoint was first reached at roughly 450 seconds into the transient, the predicted RCS pressure cycled at approximately double the frequency of the plant data until about 900 seconds into the transient. Thereafter until the EFW flow was reestablished, the predicted pressure cycled at only a slightly higher frequency than the data. During the period between the beginning of the transient and about 1100 seconds, DPC computed the PZR level to be lower than the data, and the predicted hot and cold leg (average since one loop represents both cold legs) temperatures were predicted to be lower than the plant data implying an overprediction of the primary-to-secondary heat transfer.

After reestablishment of the EFW, the computed average cold leg temperature matched the loop B data but was roughly 10 degrees above the loop A data, the computed hot leg temperatures agreed with the data and the predicted

pressurizer level was about 35 inches higher than the measured data, while the RCS pressure was predicted to decrease at roughly twice the measured rate.

DPC explained these modest differences between the predicted and plant data as being due to several factors:

- (1) the code tended to couple too closely between SG temperature and RCS temperature during low SG flow conditions (which were present during the EFW stages of this transient) due, in part, to overprediction of the boiling length/mixture level caused by the lack in RETRAN of an unequal phase velocity model in the SG tube region;
- (2) the overprediction of pressure decrease following reestablishment of EFW at 1310 seconds was due to pressurizer modeling which did not model the expected stratification of fluid which would accompany an insurge of cooler primary loop water, which would affect pressure response during the outsurge which accompanied the renewed EFW flow; and
- (3) the lack of accurate modeling in RETRAN of interphase heat transfer which was very important in modeling the impact of pressurizer spray.

The last two factors may also have been at responsible for the facts that the PZR spray was predicted to cycle twice as frequently as the data during the period between 450 to 900 seconds and at approximately the same rate between 900 to 1300 seconds.

2.1.2.2 Turbine Bypass Valve Failure Following Reactor Trip

The turbine bypass valve failure occurred after an anticipatory reactor trip occurred on a main turbine trip signal. The failure was due to a malfunction in the turbine bypass system. Letdown was manually isolated in the first 10 seconds and makeup flow was increased by manually opening a second makeup valve. Main feedwater remained available throughout the event. The turbine

bypass valves were manually closed.

DPC adjusted the RCS and MFW flows to obtain the measured primary and secondary temperatures.

The DPC analysis predicted the global trend for the key plant parameters. However, the fine structure of this transient was not well predicted, with the RCS temperatures and RCS pressure being consistently underpredicted. With RCS temperatures and pressure consistently underpredicted, the PZR level would be expected to also be consistently underpredicted. However, the PZR level was overpredicted at times and underpredicted at other times during this transient. DPC stated that the "RCS pressure data ... may not be ... accurate".

An offset in the SG level, developed between the predicted results and the data after the first 10 seconds of the transient, was attributed to fouling of the SGs, causing SG level data to be in error. RETRAN did not predict the repressurization of SG pressure after the TBVs closure. DPC stated that this may be due to discrepancy in SG secondary side inventory and primary-to-secondary heat transfer rate. In addition, DPC stated that changes in slope in the data may be due to lifting and reseating of the main steam relief valves.

2.1.2.3 Steam Generator Overfeed Following Reactor Trip

Following the turbine trip, due to an Integrated Control System failure, the MFW pumps did not run back properly, resulting in overfeeding the steam generators. This led to a pump trip on high level in SG "A".

For this analysis DPC matched the initial SG levels to the plant data since the fouling in the SG was deemed less significant at the time of this transient.

The computed values of the key predicted plant parameters agreed well with the plant data. Steam generator secondary side mixture levels on the other

hand, after starting at the same levels, drifted apart (RETRAN predicting lower than the data) to maintain about the same offset after 40 seconds into the transients. DPC attributed this discrepancy to overprediction of primary-to-secondary heat transfer, which was consistent with the moderate underprediction of primary temperatures.

2.1.2.4 Overcooling Following Loss of ICS Power

Due to a spurious low hotwell level signal, Oconee Unit 3 tripped the hotwell pumps at 99% full power operation. At 73 seconds the power supply to the ICS was lost for a period of 150 seconds. During the same period, the turbine bypass valves failed at an unknown partially open position. This resulted in a loss of SG pressure control and overcooling.

DPC specified as boundary conditions the reactor power runback, MFW flow data, EFW and HPI actuation, a post-trip auxiliary steam demand, and the steam relief flowrate through a turbine control system.

Since so much was unknown after the ICS was lost and due to the partially stuck opened turbine bypass valves at an unknown position, only the first 73 seconds of this analysis was reviewed.

The repressurization of the RCS beginning at about 30 seconds was overpredicted by the code by 150 psi and the PZR level was slightly overpredicted. This was attributed by DPC to be due to the code's neglect of heat transfer between the steam and liquid regions of the PZR during the compression of the steam which accompanies the insurge.

The cold leg temperature increases were similarly overpredicted by the code during this same period, indicating underprediction of primary-to-secondary heat transfer, which was consistent with the underprediction of SG levels, and was probably also related to minor imprecisions in the modeling of power runback during the first 55 seconds of the transient.

2.1.2.5 Loss of Offsite Power at Arkansas Nuclear One - Unit 1

While operating at 100% power, Arkansas Nuclear One Unit 1 experienced a loss of offsite power. Stable natural circulation was established and maintained for more than one hour before the offsite power was restored.

DPC used as boundary conditions a one second MFW flow coastdown, EFW and HPI flows, ANO-1 MSSV lift setpoints and SG pressure vs. time control.

Although primary and secondary pressures were well predicted, the hot-to-cold leg delta T was overpredicted by nearly a factor of 2 at around 100 seconds, which was the time that natural circulation flows were set up. This implies that this analysis did not predict natural circulation flows very well. However, by roughly 150 seconds, the prediction nearly matched the data, implying a much better computation of natural circulation at this stage. DPC attributed the mismatch in the RCS temperatures during the early portion of the transient to differences in the predicted RCS flow and the actual flow during the coastdown.

2.1.2.6 Reactor Coolant Pump Coastdowns

A series of RCP coastdown tests were conducted as part of the startup testing. All of these tests were performed at hot zero power conditions considering all possible numbers of pumps available.

For this analysis, DPC stripped the two-loop model to include only those components pertinent to the benchmark remained.

The predicted and test results compared favorably, except in cases where reverse flow thorough the pump(s) occurred. For these cases, discrepancies ranged from 10 to 20% of full flow. DPC stated that where the divergent results were obtained, the divergence was in part due to suspect plant data. In addition, other discrepancies were said to occur for operating regimes in quadrants in which relatively little test data had been obtained, and therefore to not be necessarily indicative of code errors.

DPC further stated that the pump coastdown cases are not limiting with respect to the plant operating limits and that DPC does not perform transient analyses to determine operating limits with pump coastdown flow rates which are non-conservative with respect to plant data.

2.1.2.7 Steady State Natural Circulation Flow Comparisons

The RETRAN predictions were compared to calculated natural circulation flow rates from various tests and events at lowered-loop 177 fuel assembly B & W units at the end of a loss of offsite power simulation. Predictions varied from data by as much as a factor of two, with RETRAN consistently overpredicted the RCS natural circulation flows, a result which is consistent with the observed results of the ANO-1 analyses discussed above.

DPC attributed these discrepancies to prediction of a higher mixture level in the secondary side of the steam generators due to the lack of an unequal phase velocity model in RETRAN.

2.1.2.8 Control Rod Group Drop

The Group 6 control rods dropped when Oconee Unit 1 was operating at 100% power.

RCS makeup flow, MFW flow and steam generator pressure control are among the boundary conditions specified for the analysis. DPC increased the PZR surge line loss coefficient by a factor of 5 over its nominal value for analysis of this transient.

The computed plant parameters exhibited the same trend as those measured during the event. DPC stated that the increase in surge line loss coefficient was necessary to accurately model strong outsurges.

2.1.2.9 Main Feedwater Pump Trip

The 1B MFW pump tripped on low hydraulic oil pressure at Oconee Unit 1.

DPC used the reactor and turbine control valve controls, Unit Load Demand signal to the reactor control and MFW flows as boundary conditions.

The computed RCS temperatures were underpredicted slightly due to the overprediction of primary-to-secondary heat transfer, otherwise the computed key parameters agreed reasonably with those measured during the event.

2.1.2.10 Turbine Bypass Valve Failure

Following an increase in the steam generator "A" pressure signal at 100% full power at Oconee Unit 1, the turbine bypass valves opened. The erroneous pressure signal increased by 128 psi in 8 seconds, with the turbine bypass valves opening ~80%, while the actual SG pressure decreased ~25 psi during this period. After 14 seconds the erroneous SG pressure signal decreased and the bypass valves closed.

The boundary conditions used by DPC were reactor and turbine control, SG pressure signal to the turbine bypass controller, MFW flow and a reduction in the turbine bypass valve setpoint.

Since the main steam pressure response was not well predicted, the balance of the plant parameters were not well predicted.

2.1.2.11 Reactor Trip from Three Reactor Coolant Pump Operation

Oconee Unit 3 was operating at 74% full power with the B2 RCP secured. A component failure within the ICS caused a reduction in FW flow to the "A" SG. After 23 seconds, the reactor tripped on high RCS pressure.

SG levels were initially matched, but the SG "A" pressure was much higher than the data. The boundary conditions specified by DPC for the code were control rod movement, kinetics parameters, RCS makeup flow, MFW flow and SG pressure control.

The predicted RCS pressure dropped more than 100 psi below the drop in the data, and was attributed to overprediction of primary-to-secondary heat transfer due to inaccurate steam generator modeling.

2.1.3 Summary

In its modeling of the Oconee plant transient results, difficulties in accurately modeling primary-to-secondary heat transfer with the RETRAN two-phase flow and heat transfer models were a consistent source of erroneous computations (discrepancies between the predicted and measured data). These secondary-side originated difficulties also caused errors in primary-side results.

In addition, the RETRAN results consistently indicated inaccurate modeling of natural circulation flow.

Furthermore, DPC has observed that the pressurizer surge line loss factor must be increased by roughly a factor of 5 during the outsurge portion of any transient containing a strong outsurge.

Finally, DPC's model indicates an inability to accurately model reverse flow through stopped RCPs during coastdown of the other RCPs.

2.2 McGuire and Catawba Plant Model

Since these are not identical Westinghouse 4-loop plants, DPC developed different RETRAN models starting from the same basic model. Modifications were made in each analysis to better model the specific plant introducing some design differences between McGuire and Catawba plants and unit-dependent differences between two units of McGuire and Catawba. However, DPC assumed that the differences between the plants were small enough that model qualification through benchmark analysis of one should be considered to support the model developed for the other.

In addition, DPC developed two different models of McGuire and Catawba Plants: (1) one-loop plant model and (2) two-loop model. The one-loop model is to be used when all four loops are expected to behave similarly so that there is no asymmetrical condition. The two-loop model is to be used when asymmetric conditions are expected in the plant during the transient, thus one affected loop was modeled separately while the other three loops are lumped together. Although no details were presented, DPC also developed a three-loop model using the same basic approach.

A detailed description of the plant nodalization and models selected for use in transient analysis was presented in Chapter 3 of the topical report. The steam generator model contained a multiple number of volumes in the secondary side. DPC selected the RETRAN internal model for all volumes after an extensive series of parametric studies (Refs. 13 and 14). The mixture level prediction is made as a function of differential pressure across the location of pressure taps rather than to attempt to compute the mixture level. DPC is aware of the inability of its model to compute a mixture level.

The pressurizer is represented by a non-equilibrium volume.

RETRAN control systems were developed and used extensively by DPC to specify transient boundary conditions, such as automatic plant actions and operator actions as well as control actions by modulating valves, changing fill rates or reactivity and simulation of trip actuation. The control system is also used to compute the steam generator level by emulating the plant measurement device by computing DP across the locations of the SG pressure taps. It is also used to convert a predicted mixture levels in the pressurizer into an indicated level and incorporating time delays into the predicted RCS loop temperatures to convert to the indicated temperatures. In all cases, DPC attempted to simulate the actual plant measuring devices.

2.2.1 McGuire/Catawba RETRAN Model Qualification

Although in general DPC chose to demonstrate the adequacy of the base plant

model for McGuire/Catawba (M/C) plants through comparison of RETRAN analyses to available plant data, in response to NRC questions, DPC provided (Refs. 13 and 14) details of sensitivity studies performed to assess adequacy of its M/C nodalization, in particular its steam generator model, and certain model and input selections. DPC provided thorough analyses of parametric sensitivity studies. The M/C plant RETRAN model was found to be acceptable not only in application for best-estimate analyses but also for licensing type analyses subject to the limitations set forth in the SERs on the topical reports DPC-NE-3001 and DPC-NE-3002.

This evaluation is based upon a review of the ability of the base model to benchmark startup test data and several operational transient data in a wide range of plant conditions.

2.2.2 Benchmark Analyses

For this objective, DPC performed benchmark analyses of 8 tests and plant transients, of which two were from the Catawba plants and the rest were from the McGuire plants.

The one-loop model was used for (1) Loss of Main Feedwater from 30% Power, (2) Steam Line PORV Failures, (3) Loss of Offsite Power and (4) Turbine Trip Test at 68 % Power.

The two-loop model was used for (1) loss of Main Feedwater to One Steam Generator and (2) Reactor Coolant Pump Trip at 89% Power.

For the reactor coolant pump flow coastdown tests, DPC simplified the base RETRAN models to only model the primary loop without any thermal modeling. The one-loop model simulated the four pump coastdown while two-, three- and four-loop models were also used to modeling consistency. The three-loop model was used for other combination of pump configuration during the tests.

The natural circulation test was simulated by use of two plant models: the one-loop as the base case and the three-loop model for the case with

sequential isolation of SGs.

2.2.2.1 Loss of Main Feedwater from 30% Full Power

In the benchmark analysis of the loss of main feedwater event from 30% full power, DPC used the one-loop McGuire Unit 2 RETRAN model.

For this analysis, DPC developed control systems: to match the pre-trip steam line pressure data, to match the post-trip steam line pressure response, and to regulate PZR spray flow. These as well as MFW and AFW flows were used as boundary conditions. Charging and letdown flows were not modeled.

The RETRAN results and plant data agreed reasonably well between 0 and 150 seconds. After roughly 150 seconds, DPC postulated two contributors to the discrepancies in pressurizer parameters between RETRAN results and plant data: (1) pressurizer backup heaters were predicted to de-energized by RETRAN but did not actually shut off, and (2) the absence of modeling of the charging and letdown system in the RETRAN model. The belief that charging and letdown actually had been activated at the plant was supported by a hand calculation by DPC.

The RETRAN control system used to compute the steam generator NR level was based upon the DP measurements between two pressure taps, and therefore was dependent upon nodalization. Anomalous behavior originating from the pressure and mass computation in the steam generator secondary (related to "pancaking") had little overall impact upon the global transient behavior in this analysis.

2.2.2.2 Loss of Main Feedwater to One Steam Generator

A two-loop McGuire Unit 2 model was used for this analysis. Boundary conditions used were MFW and AFW flows. Charging and letdown flows were not modeled.

The prediction of PZR pressure diverged (overpredicted) from the data. DPC

explained the early portion of the overprediction as being due to the absence of modeling of steam-liquid heat transfer in the PZR, and the latter portion as being due to an error in modeling the PZR heaters.

Imprecision in modeling the loop A steam line PORV and the condenser dump valves was postulated by DPC to be the source of the failure of the RETRAN computation to model the spikes in steam line pressure.

2.2.2.3 Steam Line PORV Failure

This was an event initiated by a test conducted at the Catawba Nuclear Station Unit 2 which went beyond the intended range due to an operator error. The plant was operating at 24% power when the test was initiated. When the control breakers were tripped, all four steam line PORVs opened and remained open for six minutes.

DPC specified AFW flow, auxiliary steam loads, charging and letdown flows and safety injection flow as boundary conditions. The steam line PORV junction area was adjusted to match the steam line depressurization rate.

Using the one-loop Catawba Unit 2 model, DPC obtained good agreement with the plant data for the key plant parameters presented in the topical report with the exception of the SG level. DPC stated that the underprediction was due to low initial SG inventory and uncertainty in AFW.

2.2.2.4 Reactor Coolant Pump Coastdown Tests

The reactor coolant (RCP) pump coastdown tests were performed as part of the pre-critical startup testing under isothermal conditions with the reactor subcritical. These tests serve to confirm the flow coastdown characteristics.

For this benchmark analyses, DPC used the model consisting of only the primary loops without any thermal modeling. In addition, both one- and three-loop models were used after unit specific models were developed to

determine impact of any unit design dependent differences.

RETRAN predicted parameters were comparable to those obtained during the tests. These results validated DPC's RCP model to simulate RCP coastdown characteristics over the range of flows indicated in the report.

2.2.2.5 Natural Circulation Testing

Two types of natural circulation tests were submitted to support natural circulation modeling for McGuire and Catawba: steady-state natural circulation tests conducted at 1% and 3% full power at both plants, although there is some uncertainty in the core power; and a test conducted at McGuire to evaluate the plant response to isolating two SGs in sequence after achieving a stable natural circulation condition with the reactor critical at approximately 1% power. In this latter test, SGs were isolated by closing the MSIV, isolating feedwater, and isolating blowdown.

For the steady-state test, the one-loop McGuire Unit 1 model was used for analysis while a three-loop McGuire Unit 1 model was used for the natural circulation with SG isolation test simulation.

The computed trend was in the same direction as the test data in the steady-state natural circulation tests; however, no further conclusion can be drawn from this comparison due to plant power level uncertainties.

In the natural circulation with SG isolation test simulation, the predicted and test data did not agree well.

The differences were attributed to inaccurate modeling of reactor power, overprediction primary-to-secondary heat transfer, potential steam leaks and ambient cooling from isolated SGs.

2.2.2.6 Reactor Coolant Pump Trip from 89% Full Power

An RCP trip from 89% full power occurred at McGuire Unit 1 when the DPC "C"

bus feeder breaker opened. Because of the asymmetric nature of the event, DPC used the two-loop McGuire Unit 1 RETRAN model for analysis. The RETRAN simulation was performed by adjusting the RCS flow to match core delta T. The steam line pressure data was input by DPC as a boundary condition during the simulation to better match the actual plant performance, since plant valve position data was unavailable and using a best-estimate resulted in discrepant results.

RETRAN predicted plant parameters were comparable to plant data. The difficulty in matching the steam generator level in the first 40 seconds of the transient was again attributed by DPC to non-physical mass redistributions caused by the RETRAN modeling of two phase flows in the steam generator secondary side.

2.2.2.7 Loss of Offsite Power

Plant data were obtained during the loss of offsite power event initiated by a spurious high power range flux rate which tripped the reactor at 100% full power operation. A one-loop plant model was used. The RCS flow was specified to match delta T.

Plant steam line pressure, MFW, AFW, charging and letdown flows, and status of PZR heater banks were specified as boundary conditions.

DPC's computation of the loss of offsite power event resulted in an underprediction in the pressurizer pressure beginning at about 100 seconds reaching a 150 psi underprediction by roughly 400 seconds and remaining there for the balance of the computation. The loop delta T's were similarly underpredicted by roughly 20%, with T_{hot} being underpredicted by approximately 10 degrees and T_{cold} being matched. DPC attributed these differences to underprediction of loop hydraulic losses at low flow.

2.2.2.8 Turbine Trip Test from 68% Full Power

A Turbine Trip Test from 68% Full Power was conducted as an Operational

Transient Without Reactor Trip at the Catawba Nuclear Station Unit 1. This test is performed to demonstrate the effectiveness of plant control systems to stabilize the plant without tripping the reactor. In the one-loop Catawba Unit 1 RETRAN model, DPC stated that it built in detailed modeling of the pressurizer pressure controller and the plant control systems including operator actions.

The RCS flow was specified in the simulation to match delta T. The boundary conditions include the main feedwater flow rate and the reference T-ave as a function of time.

The results indicated only general trend agreement, since the power was inaccurately simulated after approximately 90 seconds and therefore the other plant parameters were not well matched.

2.2.3 Summary

DPC was able to get better agreement in the McGuire/Catawba benchmark analyses than in Oconee analysis, largely because the primary-to-secondary heat transfer was less dependent upon the secondary side modeling because the SG tubes remain covered in most transients.

However, as before, the RETRAN results consistently showed inaccurate modeling of natural circulation flow although this may be caused by uncertainties associated with test data.

In most instances when the measured data and RETRAN predicted results did not agree, the sources of differences were generally attributed by DPC to be due to inaccuracies or lack of sufficient details in the measured data.

Finally, the controller model of the steam generator level continuously gave spurious indications due to the manner in which RETRAN computed the steam generator pressures in the stacked volumes.

3.0 CONCLUSIONS

DPC topical reports DPC-NE-3000 and its supporting documents, including the DPC responses to NRC questions, were reviewed.

Based upon the submitted materials and through analysis of plant transient behavior using RETRAN, DPC has exhibited a high degree of staff technical competence, both in knowledge of the plants themselves and in understanding plant transient behavior. In addition DPC staff has demonstrated an excellent analytical knowledge of the code and code models. Furthermore, DPC staff has demonstrated sophistication in its use of the RETRAN control systems.

DPC's RETRAN models for the McGuire/Catawba nuclear power plants are generally acceptable, and acceptability extends to application to the licensing type analyses provided that analyses contain adequate conservatisms to produce acceptable results, and subject to the limitations set forth in the SERs on DPC-NE-3001 and 3002, and provided further that the following condition is satisfied:

With respect to modeling under-cooling transients caused by loss of or reduction in feedwater flow, use of the steam generator modeling is acceptable for all transients in that category subject to the following condition:

- (1) if the affected steam generator(s) is/(are) relied upon for heat removal, the secondary side inventory never decreases below an amount which, if collapsed to zero void fraction, would cover enough tube height to remove decay heat.

DPC's RETRAN models for the Oconee plants require further justification of the steam generator model before it can be used in either best-estimate or licensing type analyses and in particular DPC must demonstrate that;

- (1) its steam generator secondary side modeling produces conservative results for each such transient;
- (2) its nodalization for the reactor vessel is appropriate for the transient to be analyzed and conservative;
- (3) its selection of RETRAN internal models and correlations is conservative; and
- (4) its RETRAN control systems are accurate and conservative.

4.0 REFERENCES (Part 1 - RETRAN)

1. "Thermal-Hydraulic Transient Analysis Methodology," DPC-NE-3000, July 1987.
2. Licensee Qualification for Performing Safety Analyses in Support of Licensing Actions (Generic Letter No. 83-11), USNRC, February 8, 1983.
3. "RETRAN-02 - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems," EPRI NP-1850-CCM Revision 2, EPRI, November 1984.
4. "VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores," EPRI NP-2511-CCM Revision 2, EPRI, July 1985.
5. Letter, C.O. Thomas (NRC) to T.W. Schnatz (UGRA), September 4, 1984, (Transmittal of RETRAN-02 Safety Evaluation Report).
6. Letter, C.E. Rossi (NRC) to J.A. Blaisdell (UGRA), May 1, 1986, (Transmittal of VIPRE-01 Safety Evaluation Report).
7. Letter from H.B. Tucker (DPC) to USNRC, Attachment "DPC-NE-3000 Revision 1," May 11, 1989.
8. Letter from H.B. Tucker (DPC) to USNRC, Attachment "Duke Power Responses to NRC Questions Dated April 7, 1989 Regarding DPC-NE-3000," June 15, 1989.
9. Letter from H.B. Tucker (DPC) to USNRC, "Responses to Questions Regarding Differences Between Duke Topical Reports DPC-NE-2003 and DPC-NE-3000," June 19, 1989.
10. Letter from H.B. Tucker (DPC) to USNRC, "Duke Power Response to NRC Questions Regarding Steam Generator Heat Transfer Modeling with the RETRAN Code," August 9, 1989.
11. Letter from H.B. Tucker (DPC) to USNRC, Attachment 1 "Response to NRC

Questions on the McGuire/Catawba Sections of DPC-NE-3000" and Attachment 2 "Revisions to Section 4 of DPC-NE-3000," September 13, 1989.

12. Letter from M.S. Tuckman (DPC) to USNRC, "Supplemental Information to Assist in Review of Topical Reports DPC-NE-3000 and DPC-NE-2004," August 29, 1991.
13. Letter from H.B. Tucker (DPC) to USNRC, "Handouts Presented in the October 7 & 8, 1991 Meeting with NRC Staff and Contract Reviewers," October 16, 1991.
14. Letter from H.B. Tucker (DPC) to USNRC, "Final Response to Questions Regarding the Topical Reports Associated with the M1C8 Reload Package," November 5, 1991.

TECHNICAL EVALUATION
OF THE THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY
TOPICAL REPORT DPC-NE-3000
FOR THE
DUKE POWER COMPANY
OCONEE, MCGUIRE AND CATAWBA NUCLEAR STATIONS
Part 2

1.0 INTRODUCTION

DPC-NE-3000, dated July 1987 (Ref. 1), documents results of a series of studies performed by Duke Power Company (DPC) to support the development of thermal-hydraulic transient analysis methods. Part 1 of this Technical Evaluation Report (TER) documents evaluation, in accordance with the RETRAN Safety Evaluation Report (SER) (Ref. 2), of DPC's use of the RETRAN computer code (Ref. 3) and the acceptability of the DPC RETRAN models for analysis of Oconee and McGuire/Catawba Nuclear Stations. Part 2 contains evaluation, in accordance with the VIPRE SER (Ref. 4), of DPC's intended use of the VIPRE-01 computer code (Ref. 5) in transient DNBR calculation and its conformity of the DPC submittals to the VIPRE SER requirements.

During the course of review of DPC-NE-3000, the chapter presenting Oconee VIPRE models was replaced in its entirety with Revision 1 of the topical report, at which time the McGuire/Catawba VIPRE model qualification chapter was added to the subject topical report as part of Chapter 3 (Ref. 6). Therefore, this review is based upon review of Revision 1 to DPC-NE-3000.

Two different VIPRE models for the core thermal-hydraulic analysis have been developed by DPC for use in steady-state, documented in DPC-NE-2003 and DPC-NE-2004, and transient applications for both types of plants (Refs. 7 and 8). Transient application of VIPRE-01 for both Oconee and McGuire/Catawba are

reviewed herein. DPC documented the differences between the models used for steady state and those used for transient applications (Refs. 6 and 9); the steady-state model is used in support of core reload analysis and the transient model is used for FSAR Chapter 15 type analysis. For these two applications, DPC uses different assumptions, nodalizations, thermal-hydraulic models and correlations, and other input data selections. Therefore, it was necessary for DPC to fully justify its intended use of VIPRE in transient applications.

The DPC submittal contains DPC's geometric representation of the core, its selection of thermal-hydraulic models and correlations, and a description of the methodology used for FSAR Chapter 15-type licensing transient analysis. Although DPC's basic methodology and conservative assumptions to be used for FSAR Chapter 15-type analysis are the same in both Oconee and McGuire/Catawba plants, evaluation is presented here separately for each type of plants.

2.0 EVALUATION

2.1 VIPRE Model Description

VIPRE-01 has been previously reviewed and approved for application to pressurized water reactor (PWR) plants in steady-state and transient analyses with heat transfer regimes up to critical heat flux. The VIPRE-01 SER includes conditions requiring each user to document and submit to the NRC for approval its procedure for using VIPRE-01 and to provide justification for its specific modeling assumptions, choice of particular two-phase flow models and correlations, heat transfer correlations, CHF correlation and DNBR limit, input values of plant specific data such as turbulent mixing coefficient and grid loss coefficient including defaults. This topical report was prepared to address these issues.

2.2 Oconee Core Analysis

The Oconee reactor core consists of 177 BAW Mark-BZ fuel assemblies. Each fuel assembly is a 15 x 15 array containing 208 fuel rods, 16 control rod

guide tubes, and one incore instrument guide tube.

2.2.1 Core Nodalization

In its sensitivity studies, DPC used the final set of thermal-hydraulic models and correlations which DPC intends to use in future licensing analysis.

2.2.1.1 Radial Noding Sensitivity

Since the VIPRE-01 code performs the thermal-hydraulic calculations simultaneously for all subchannels (a single-pass approach) and permits flexibility in selection of channel sizes and shapes, a sensitivity study was performed to determine the sensitivity of predicted DNBR to the subchannel model sizes. DPC intends to use the symmetrical case for the normal steady-state operation and most of the transients.

For asymmetrical cases, DPC will submit for NRC approval descriptions and justification of modeling of asymmetrical transients in separate submittals for NRC approval.

To assess nodalization sensitivity, DPC selected three different numbers of channels for core models using the same thermal-hydraulic correlations and models which DPC intends to use in future licensing analysis.

Sensitivity to the core model size was studied by comparing the results obtained with the coarse and fine size channel models. The coarse channel model was found to yield comparable MDNBRs as those obtained with the fine model. We therefore find DPC's use of the coarse channel model acceptable for Oconee thermal-hydraulic analysis.

2.2.1.2 Axial Noding Sensitivity

Using the coarse core model, three parametric calculations, each with BWC CHF correlation, were performed to assess sensitivity to the axial noding sizes.

The axial node lengths were selected by dividing the axial length into equal length of nodes. Two smaller node sizes correspond to the range of the code developer's recommended values. The results indicated that the mid-sized axial noding produced nearly identical MDNBR with those using the fine noding. We, therefore, find that use of the mid-sized uniform length axial nodes (Ref. 10) is acceptable for Ocone thermal-hydraulic analyses.

2.2.2 VIPRE-02 Input Data

DPC's approach to generation of input to the VIPRE-01 code was reviewed for acceptability. No review was conducted of the input data in comparison to the actual physical geometry.

2.2.2.1 Active Fuel Length

Since power is distributed over the length of the active fuel, a shorter aggregate fuel length yields higher power density, causing greater heat flux and is therefore conservative. DPC's choice for the active fuel length is conservative and acceptable. When a different assumption is used, DPC will justify its conservatism.

2.2.2.2 Spacer Grid Form Coefficients

Pressure losses across the spacer grids impact the axial pressure distribution and therefore the axial location of DNB. The spacer grid form loss coefficients were obtained from tests conducted by B&W. To determine the individual subchannel form loss coefficient, DPC stated that the vendor used its computer code, GRIL. The input data to the GRIL code are the individual subchannel geometry, drag areas and coefficients, and the coolant information. From this input, the code calculates individual subchannel loss coefficients, an overall grid loss coefficient and subchannel velocities based on single-phase flow input data by a iterative process. The calculated overall grid loss coefficient is matched with the measured value by adjusting the velocity field in the subchannel until consistency between the measured and predicted values is achieved. DPC has stated that the calculated

velocity profiles were compared by the vendor with the experimental data and showed good agreement (Ref. 11).

2.2.2.3 Core Bypass Flow

DNB is influenced by the aggregate flow rate past the location being examined, and therefore by the core bypass flow. Since the bypass flow depends on the number of control rod and burnable poison rod assemblies in the core, this is a cycle dependent parameter. Therefore, the core bypass flow data used in the analysis should be based on a bounding value or on cycle specific data. For the purpose of this submittal, the value DPC used is acceptable.

2.2.2.4 Inlet Flow Distribution

CHF is decreased and the probability of DNB is enhanced if flowrate is reduced due to a flow maldistribution. The use of 5% inlet flow maldistribution to the hot assembly with all four reactor coolant pumps operating was previously approved for Oconee FSAR analysis.

For operation with less than four reactor coolant pumps operating, more restrictive flow reduction factors are applied.

2.2.2.5 Flow Area Reduction Factor

DPC reduced the hot subchannel flow area by 2% to account for variations in as-built subchannel coolant flow area.

2.2.2.6 Radial Power Distribution

The reference design power distribution was developed using a radial-local hot pin peak which has been previously approved for Oconee FSAR analysis. DPC will submit for NRC approval a description and justification of applicability of its findings involving an asymmetrical radial power distribution.

2.2.2.7 Axial Power Distribution

The axial power shape used in the symmetric radial power distribution transients was a cosine shape with a peaking factor consistent with the current practice. DPC will justified any specific power shape for use on a case-by-case basis.

Prior to increasing the axial peaking factor, DPC will perform a complete evaluation of all potential safety concerns and submit it to the NRC for approval.

2.2.2.8 Hot Channel Factors

The power factor, F_q , used to account for variations in average pin power caused by differences in the fuel loading per rod is 1.0107 and is statistically determined from uncertainties associated with fuel.

DPC stated that their use of the local heat flux factor, F_q'' , used to account for the uncertainty in the manufacturing tolerances, is consistent with the current application of the NRC approved methodology described in the DPC topical report NFS-1002.

2.2.2.9 Fuel Pin Conduction Model

DPC stated that for most of the transient analyses, the RETRAN heat flux boundary condition is used instead of the VIPRE-01 fuel pin conduction model. DPC further stated that for transient analyses in which the fuel enthalpy or cladding temperature is the protective criteria, the VIPRE-01 fuel pin conduction model may be used. DPC stated that evaluation of an appropriate approach would be made on a case-by-case basis for each analysis. DPC will provide justification for its selection of the conduction model.

2.2.2.10 Numerical Solution Technique

For the Oconee analyses presented in the submittal, DPC used the iterative solution method. However, should convergence be a problem, DPC will use the RECIRC solution method for Oconee FSAR type transient analyses.

2.2.3 VIPRE-01 Correlations

VIPRE-01 requires empirical correlations for the following models:

- a. turbulent mixing
- b. two-phase flow correlations (subcooled and saturated void, and void-quality relation)
- c. critical heat flux

2.2.3.1 Turbulent Mixing

The lateral momentum equation requires two parameters: a turbulent momentum factor and a turbulent mixing coefficient.

The turbulent momentum factor (FTM) describes the efficiency of the momentum mixing: 0.0 indicating that crossflow mixes enthalpy only; 1.0 indicating that crossflow mixes enthalpy and momentum at the same strength. DPC selected values for both of these parameters are conservative.

2.2.3.2 Subcooled Void, Bulk Void and Two-Phase Flow Correlations

For subcooled and bulk void correlations, a sensitivity study using five different combinations of three subcooled and five bulk void correlations was performed using four cases varying only one boundary condition at a time. In all cases, the Columbia/EPRI two-phase friction multiplier was used. The results indicated that the DPC selected set of correlations predicted acceptably conservatively DNBRs relative to other combinations of correlations. DPC intends to use this combination in Oconee FSAR Chapter 15

analysis.

2.2.3.3 Critical Heat Flux Correlation

The B&W BWC CHF correlation using the LYNX-2 computer code has been reviewed and approved by the NRC for licensing analysis of BAW Mark-BZ fuel with Zircaloy grids with the design MDNBR limit of 1.18. The use of BWC correlation with VIPRE-01 has been also reviewed and approved by the NRC with the design MDNBR limit of 1.18 (Ref. 11).

Other correlations that may be utilized to cover other ranges of pressures are: W-3S (less than 1600 psia), MacBeth and Bowring (WSC-2) for low pressure and low flow conditions. DPC will provide justification when applying these correlation in future analyses.

2.2.4 Summary

We find that the subject topical report, together with DPC responses, contains sufficient information to satisfy the VIPRE-01 SER requirement that each VIPRE-01 user submit a document describing proposed use, sources of input variables, and selection and justification of correlations as it relates to use by DPC for FSAR Chapter 15 analyses.

For asymmetric transients, DPC intends to use other models not described in this submittal. Therefore, it is recommended that NRC approval be given for analysis of symmetric transients only.

In some instances, DPC selected default options since results are found to be insensitive to selection of parameters. In future licensing analyses, if changing any parameter results in less conservative prediction, DPC should submit justification of the change.

The B&W BWC CHF correlation with VIPRE-01 has been approved by the NRC with the design MDNBR limit of 1.18. DPC will provide justification as necessary when using other CHF correlation in future analyses.

Because the core bypass flow is cycle dependent, DPC will demonstrate, in future application, that its use of a particular core bypass flowrate is conservative.

Acceptability of DPC Oconee VIPRE-01 model is based upon selection of models/correlations supported by the sensitivity study results submitted. Should DPC change any of these items, DPC will submit justification for the change to the NRC for approval.

2.3 McGuire and Catawba Core Analysis

McGuire and Catawba Nuclear Stations each have two Westinghouse units and are assumed identical for the purpose of core thermal-hydraulic calculations. The analyses presented in the submittals assume BAW Mark-BW fuel assemblies which are assumed to be mechanically and hydraulically compatible with Westinghouse standard and optimized 17x17 fuel.

2.3.1 Core Nodalization

DPC used the final set of thermal-hydraulic models and correlations in the nodalization sensitivity studies which DPC intends to use in future licensing analysis.

2.3.1.1 Radial Noding Sensitivity

A parametric study was performed to determine the sensitivity of predicted DNBR to the subchannel model sizes. The thermal-hydraulic calculations were performed for three different core subchannel models using steady-state and transient conditions. Four transient cases were analyzed varying one boundary condition while keeping the others fixed.

The coarse channel model was found to yield acceptably conservative MDNBRs. Therefore, DPC intends to use the coarse channel model for FSAR type transient analyses for the McGuire and Catawba Nuclear Station.

However, for asymmetrical transients, DPC will submit a description and justification of modeling of asymmetrical transients coarse channel model in separate submittals.

2.3.1.2 Axial Noding Sensitivity

A sensitivity analysis for axial node length was performed with the coarse core channel model using three different sets of equal length axial nodes. Two finer node sizes correspond to the range of the code developer's recommended values. The results indicated that the mid size noding is adequately conservative. Therefore, we find that use of the mid-size uniform length axial nodes (Ref. 10) is acceptable for McGuire and Catawba thermal-hydraulic analyses.

2.3.2 VIPRE-01 Input Data

DPC's approach to generation of input to the VIPRE-01 code was reviewed for acceptability. No review was conducted of the input data in comparison to the actual physical geometry.

2.3.2.1 Active Fuel Length

For B&W's low densification fuel, the amount of fuel densification is off-set by the fuel thermal expansion. Therefore, it is more conservative to use the cold nominal active fuel length for calculation and this is acceptable.

2.3.2.2 Spacer Grid Form Coefficients

The same procedure used to determined these coefficients for Oconee core analysis was used for McGuire/Catawba grid form coefficients.

2.3.2.3 Core Bypass Flow

Since the bypass flow depends on the number of control rod and burnable

poison rod assemblies in the core, this is a cycle dependent parameter. Therefore, the core bypass flow data used in the analysis should be based on a bounding value or on justified cycle specific data. For the purpose of this submittal, the value DPC used is acceptable.

2.3.2.5 Inlet Flow Distribution

CHF is decreased and the probability of DNB is enhanced if flowrate is reduced due to a flow maldistribution. The use of 5% inlet flow maldistribution to the hot assembly with all four reactor coolant pumps operating yielded slightly more conservative results than a uniform inlet flow distribution.

For operation with less than four reactor coolant pumps operating, more restrictive flow reduction factors are applied.

2.3.2.6 Flow Area Reduction Factor

DPC reduced the hot subchannel flow area by 2% to account for variations in as-built subchannel coolant flow area.

2.3.2.7 Radial Power Distribution

The assembly and pin radial power distributions were selected assuming maximum peaking factors. A shape assumed for the assembly power distribution is designed to minimize flow redistribution. The same rational is used for the pin radial power distribution.

2.3.2.8 Axial Power Distribution

The axial ~~power~~ shape was selected to yield DNBR margin in the Chapter 15 transients and peaking margin compared to cycle specific power distributions. Use of this power shape and the radial power distribution is to use a design power distribution to ensure DNB protection.

2.3.2.9 Hot Channel Factor

The hot channel factor $F_{\Delta H}^E$ used for the McGuire/Catawba analysis is 1.03 and is the allowance on enthalpy rise to account for manufacturing tolerances. The value was determined by B&W.

2.3.2.10 Numerical Solution Technique

For the McGuire/Catawba analyses presented in the submittal, DPC used the RECIRC solution method. DPC will use the RECIRC solution method in future FSAR-type transient analyses (Ref. 10).

2.3.3 VIPRE-01 Correlations

VIPRE-01 requires empirical correlations for the following models:

- a. turbulent mixing
- b. two-phase flow correlations (subcooled and saturated void, and void-quality relation)
- c. critical heat flux

2.3.3.1 Turbulent Mixing

The lateral momentum equation requires two parameters: a turbulent momentum factor and a turbulent mixing coefficient.

The turbulent momentum factor (FTM) describes the efficiency of the momentum mixing: 0.0 indicating that crossflow mixes enthalpy only; 1.0 indicating that crossflow mixes enthalpy and momentum at the same strength. DPC selected a conservative value for FTM.

Since the turbulent mixing coefficient determines the flow mixing rate, it is an important parameter. Based upon tests using a 5x5 heated bundle conducted by B&W, where the subchannel exit temperatures were measured, a mixing

coefficient was conservatively determined for B&W Mark-BW fuel which is proportional to the turbulence intensity (Ref. 10). For conservatism, DPC used a number smaller than the B&W determined coefficient and this reduced value will be used in the McGuire and Catawba core thermal-hydraulic analysis (Ref. 10).

2.3.3.2 Subcooled Void, Bulk Void and Two-Phase Flow Correlations

For subcooled and bulk void correlations, a sensitivity study using five different combinations of three subcooled void and five bulk void correlations was performed for steady-state and transient boundary conditions. The results indicated that the use of the DPC selected combination of correlations in conjunction with Columbia/EPRI two-phase friction multiplier predicted conservatively computed DNBR relative to other combinations of correlations. DPC intends to use this combination in McGuire and Catawba analysis.

This is consistent with the VIPRE-01 SER findings.

2.3.3.3 BWCMV Critical Heat Flux Correlation

Use of BWCMV CHF correlation with the LYNX2 code has been approved by the NRC for the DNBR limit of 1.21. Its use with VIPRE-01 has been also approved (Ref. 12).

2.3.4 Statistical Core Design Methodology

The DPC developed statistical core design methodology (SCD) statistically combines uncertainties associated with key parameters used in determination of the DNBR. Details of the methodology with respect to the steady-state application is documented in DPC-NE-2004. The transient application is performed in the same manner as described in that topical report.

During the review of DPC-NE-2004, in response to the NRC question, DPC provided results of sensitivity cases using models developed in DPC-NE-2004

and DPC-NE-3000. There were negligible differences between the predicted DNBRs (Refs. 13 and 14). Therefore, the SCD methodology developed in the DPC-NE-2004 is applicable in transient applications since the methodology allows enough margin in the DNBR limits to account for the small differences between two models. However, the same conditions cited in the technical evaluation report for DPC-NE-2004 are applicable to use of the SCD methodology in transient applications.

2.3.5 Summary

For asymmetric transients, DPC intends to use other models not described in this submittal. Therefore, it is recommended that NRC approval be given for use in analysis of symmetric transients only.

Because the core bypass flow is cycle dependent, DPC will demonstrate, in future application, that its use of a particular core bypass flowrate is conservative.

Acceptability of DPC M/C VIPRE-01 model is based upon selection of models/correlations supported by the sensitivity study results submitted. Therefore, whenever DPC changes any of these items documented in the topical report, DPC will submit justification for the change to the NRC for approval.

Furthermore, the use of the SCD methodology in transient application is acceptable provided that the range of applicability of the RSM is not violated. The conditions cited (Refs. 12 and 13) in the review of DPC-NE-2004 are applicable to transient application as well.

3.0 CONCLUSIONS

We find that the subject topical report, together with DPC responses, contains sufficient information to satisfy the VIPRE-01 SER requirement that each VIPRE-01 user submit a document describing proposed use, sources of input variables, and selection and justification of correlations as it relates to use by DPC for FSAR Chapter 15 analyses.

We further find that the manner in which the code is to be used for such analyses, selection of nodalization, models, and correlations provides, except as listed below, adequate assurances of conservative results and is therefore acceptable. Furthermore, the use of the DPC developed statistical core design methodology as approved in the Technical Evaluation Report on DPC-NE-2004 (Ref. 12) is approved for the transient application subject to the same conditions.

The following items are limitations regarding VIPRE-01 application presented in DPC-NE-3000 and its supplemental materials:

- (1) Determination of acceptability is based upon review of selection of models/correlations for symmetric transients only. DPC submitted its asymmetric models in DPC-NE-3001 for NRC review and approval.
- (2) When using the DPC developed SCD method, the licensee must satisfy the conditions set forth in Reference 12.
- (3) Whenever DPC intends to use other CHF correlations, power distribution, fuel pin conduction model or any other input parameters and default options which were not part of the original review of the VIPRE-01 code, DPC must submit its justification for NRC review and approval.
- (4) Core bypass flow should be determined on cycle-by-cycle bases.

4.0 REFERENCES (Part 2 - VIPRE)

1. "Duke ~~Power~~ Company - The Thermal-Hydraulic Transient Analysis Methodology - Oconee Nuclear Station, McGuire Nuclear Station, Catawba Nuclear Station," DPC-NE-3000, July 1987.
2. Letter, C.O. Thomas (NRC) to T.W. Schnatz (UGRA), September 4, 1984, (Transmittal of RETRAN-02 Safety Evaluation Report).
3. "RETRAN-02 - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems," EPRI NP-1850-CCM Revision 2, EPRI, November

1984.

4. Letter, C.E. Rossi (NRC) to J.A. Blaisdell (UGRA), May 1, 1986, (Transmittal of VIPRE-01 Safety Evaluation Report).
5. "VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores," EPRI NP-2511-CCM Revision 2, EPRI, July 1985.
6. Letter from H.B. Tucker (DPC) to USNRC, Attachment to "Thermal-Hydraulic Transient Analysis Methodology," May 11, 1989.
7. "Duke Power Company Oconee Nuclear Station Core Thermal-Hydraulic Methodology Using VIPRE-01," DPC-NE-2003, August 1988.
8. "Duke Power Company McGuire and Catawba Nuclear Stations Core Thermal-Hydraulic Methodology Using VIPRE-01," DPC-NE-2004, December 1988.
9. Letter from H.B. Tucker (DPC) to USNRC, "Response to Questions Regarding Differences Between Duke Topical Reports DPC-NE-2003 and DPC-NE-3000," June 19, 1989.
10. Letter from G.B. Swindlehurst (DPC) to USNRC, "Response to NRC Questions on DPC-NE-3000 Dated July 25, 1989," February 20, 1990.
11. "Technical Evaluation of the Core Thermal-Hydraulic Methodology Using VIPRE-01 Topical Report DPC-NE-2003 for the Duke Power Company Oconee Nuclear Station," ITS/NRC/89-2, July 3, 1989.
12. "Technical Evaluation of the Core Thermal-Hydraulic Methodology Using VIPRE-01 Topical Report DPC-NE-2004 for the Duke Power Company McGuire and Catawba Nuclear Stations," ITS/NRC/91-1, October 1991.
13. Letter from M.S. Tuckman (DPC) to USNRC, "Supplemental Information to Assist in Review of Topical Reports DPC-NE-3000 and DPC-NE-2004," August 29, 1991.
14. Letter from H.B. Tucker (DPC) to USNRC, "Handouts Presented in the October 7 & 8, 1991 Meeting with NRC Staff and Contract Reviewers," October 16, 1991.

Oconee Nuclear Station
McGuire Nuclear Station
Catawba Nuclear Station

**THERMAL-HYDRAULIC TRANSIENT
ANALYSIS METHODOLOGY**

DPC-NE-3000-A
Revision 3

September 2004

Nuclear Engineering Division
Nuclear Generation Department
Duke Power Company

Abstract

This report is the Duke Power Company response to Generic Letter 83-11, "Licensee Qualification for Performing Safety Analyses in Support of Licensing Action." G. L. 83-11 requires that licensees performing their own safety analyses demonstrate their analytical capabilities. Comparisons of computer code results to experimental data, plant operational data, or other benchmarked analyses were identified as areas of interest. This report describes the RETRAN-02 transient thermal-hydraulic models developed for the Oconee, McGuire, and Catawba Nuclear Stations, and the VIPRE-01 core thermal-hydraulic models developed for the Oconee, McGuire, and Catawba Nuclear Stations. Comparisons of Oconee RETRAN model predictions to nine plant transients, and comparisons of McGuire/Catawba RETRAN model predictions to eight plant transients, are detailed. VIPRE model predictions are validated by comparisons to the COBRA-IIIC/MIT code for the Oconee core design. The report concludes that the analytical capability to perform non-LOCA transient thermal-hydraulic analyses has been demonstrated.

Revision 1 describes the methodology revision for the McGuire and Catawba Unit 1 replacement steam generators and other minor revisions.

Revision 2 describes the methodology revision for the FANP Mk-B11 fuel assembly design for Oconee and other minor revisions.

Revision 3 describes the methodology revisions for the Oconee replacement steam generators, the RETRAN-3D MOD003.1/DKE code, the Westinghouse RFA fuel assembly design, and other minor revisions.

THERMAL-HYDRAULIC TRANSIENT ANALYSIS METHODOLOGY

TABLE OF CONTENTS

Abstract

Table of Contents

List of Tables

List of Figures

List of Acronyms

1.0 INTRODUCTION

1.1 Objective

1.2 RETRAN-02 Code Description

1.3 RETRAN-3D Code Description

1.4 VIPRE-01 Code Description

1.5 Methodology Development

1.6 Model and Code Qualification

1.7 Quality Assurance

1.8 Methodology Applications

1.9 Interface with Topical Report DPC-NE-2009P-A

1.10 Appendices

1.11 References

2.0 OCONEE TRANSIENT ANALYSIS

2.1 Plant Description

2.1.1 Overview

2.1.2 Primary System

2.1.2.1 Reactor Core

Table of Contents (cont.)

2.1.2.2	Reactor Vessel
2.1.2.3	Reactor Coolant Loops
2.1.2.4	Reactor Coolant Pumps
2.1.2.5	Steam Generators
2.1.2.6	Pressurizer
2.1.2.7	Makeup and Letdown
2.1.2.8	Instrumentation
2.1.3	Secondary System
2.1.3.1	Steam Generators
2.1.3.2	Main Feedwater
2.1.3.3	Main Steam
2.1.3.4	Turbine Generator
2.1.3.5	Instrumentation
2.1.4	Control Systems
2.1.4.1	Non-Nuclear Instrumentation
2.1.4.2	Turbine Control System
2.1.4.3	Integrated Control System
2.1.5	Safety Systems
2.1.5.1	Reactor Protective System
2.1.5.2	Engineered Safeguards System
2.1.5.3	Emergency Feedwater System
2.1.5.4	Automatic Feedwater Isolation System
2.1.6	Dissimilarities Between Units
2.2	<u>Oconee RETRAN Model</u>
2.2.1	Primary System Nodalization
2.2.1.1	Reactor Vessel
2.2.1.2	Reactor Coolant Loops
2.2.1.3	Steam Generators
2.2.1.4	Pressurizer
2.2.1.5	Core Flood Tanks
2.2.2	Secondary System Nodalization
2.2.2.1	Main Feedwater Lines
2.2.2.2	Steam Generators
2.2.2.3	Main Steam Lines
2.2.3	Heat Conductor Nodalization
2.2.3.1	Reactor Core
2.2.3.2	Steam Generators
2.2.3.3	Structural Conductors
2.2.4	Control System Models
2.2.4.1	Process Variable Indications

Table of Contents (cont.)

- 2.2.4.2 Reactor Protective System Functions
- 2.2.4.3 Plant Control Systems
- 2.2.4.4 Transient Boundary Conditions
- 2.2.4.5 Miscellaneous

- 2.2.5 Boundary Condition Models
 - 2.2.5.1 Fill Junctions
 - 2.2.5.2 Critical Flow and Time Dependent Volumes

- 2.2.6 Code Models
 - 2.2.6.1 Power Generation
 - 2.2.6.2 Centrifugal Pumps
 - 2.2.6.3 Valves
 - 2.2.6.4 Phase Separation
 - 2.2.6.5 Non-Equilibrium Pressurizer
 - 2.2.6.6 Non-Conducting Heat Exchangers
 - 2.2.6.7 Local Conditions Heat Transfer

- 2.2.7 Code Options
 - 2.2.7.1 Steady-State Initialization
 - 2.2.7.2 Iterative Numerics
 - 2.2.7.3 Enthalpy Transport
 - 2.2.7.4 Temperature Transport Delay
 - 2.2.7.5 Heat Transfer Map
 - 2.2.7.6 Film Boiling
 - 2.2.7.7 Critical Heat Flux
 - 2.2.7.8 Volume Flow Calculation
- 5.4.1.1 Wall Friction
- 5.4.1.2 General Transport Model

- 2.2.8 Dissimilarities Between Units

- 2.2.9 Summary of Experience

2.3 Oconee VIPRE Model

- 2.3.1 Core and Fuel Assembly Description

- 2.3.2 Model Development
 - 2.3.2.1 One-Pass Hot Channel Analysis
 - 2.3.2.2 Transient Analysis Models
 - 2.3.2.3 Simplified Models Justification
 - 2.3.2.4 Axial Noding

- 2.3.3 Code Option and Input Selections
 - 2.3.3.1 Thermal-Hydraulic Correlations
 - 2.3.3.2 Conservative Factors
 - 2.3.3.3 Fuel Pin Conduction Model

List of Tables (cont.)

- 2.3.3.4 Power Distribution
- 2.3.3.5 Flow Rate
- 2.3.3.6 Direct Coolant Heating
- 2.3.3.7 Miscellaneous

2.3.4 Discussions of Modeling Differences Between DPC-NE-3000 and DPC-NE-2003 Reports

- 2.3.5 Comparison With COBRA-IIIC/MIT
 - 2.3.5.1 COBRA-IIIC/MIT Code Description
 - 2.3.5.2 COBRA-IIIC Channel Simplified Model
 - 2.3.5.3 COBRA-IIIC/MIT Code Options
 - 2.3.5.4 COBRA-VIPRE Steady-State Comparison
 - 2.3.5.5 COBRA-VIPRE Transient Comparison
 - 2.3.5.6 COBRA-VIPRE Comparison Conclusions

2.3.6 Summary of Experience

2.4 References

3.0 McGUIRE/CATAWBA TRANSIENT ANALYSIS

3.1 Plant Description

3.1.1 Overview

3.1.2 Primary System

- 3.1.2.1 Reactor Core
- 3.1.2.2 Reactor Vessel
- 3.1.2.3 Reactor Coolant Loops
- 3.1.2.4 Reactor Coolant Pumps
- 3.1.2.5 Steam Generators
- 3.1.2.6 Pressurizer
- 3.1.2.7 Charging and Letdown
- 3.1.2.8 Instrumentation

3.1.3 Secondary System

- 3.1.3.1.1 Preheat Steam Generators
- 3.1.3.1.2 Feedring Steam Generators
- 3.1.3.2 Main Feedwater
- 3.1.3.3 Main Steam
- 3.1.3.4 Turbine Generator
- 3.1.3.5 Instrumentation

3.1.4 Control Systems

- 3.1.4.1 Pressurizer Pressure Control
- 3.1.4.2 Rod Control
- 3.1.4.3 Steam Dump Control

Table of Contents (cont.)

- 3.1.4.4 Pressurizer Level Control
- 3.1.4.5 Steam Generator Level Control
- 3.1.4.6 Feedwater Pump Speed Control

3.1.5 Safety Systems

- 3.1.5.1 Reactor Protection System
- 3.1.5.2 Engineered Safeguards System

3.1.6 Dissimilarities Between Units and Stations

- 3.1.6.1 Steam Generator Type
- 3.1.6.2 Auxiliary Feedwater Runout Protection
- 3.1.6.3 Steam Line Layout
- 3.1.6.4 Miscellaneous Differences

3.2 McGuire/Catawba RETRAN Model

3.2.1 Primary System Nodalization

- 3.2.1.1 Reactor Vessel
- 3.2.1.2 Reactor Coolant Loops
- 3.2.1.3 Steam Generators
- 3.2.1.4 Pressurizer
- 3.2.1.5 Cold Leg Accumulators

3.2.2 Secondary System Nodalization

- 3.2.2.1 Main Feedwater Lines
 - 3.2.2.2.1 Preheat Steam Generators
 - 3.2.2.2.2 Feeding Steam Generators
- 3.2.2.3 Main Steam Lines

3.2.3 Heat Conductor Nodalization

- 3.2.3.1 Reactor Core
- 3.2.3.2 Steam Generator Tubes
- 3.2.3.3 Structural Conductors

3.2.4 Control System Models

- 3.2.4.1 Process Variable Indications
- 3.2.4.2 Reactor Protection System Functions
- 3.2.4.3 Engineered Safeguards Functions
- 3.2.4.4 Plant Control Systems
- 3.2.4.5 Transient Boundary Conditions

3.2.5 Boundary Condition Models

- 3.2.5.1 Fill Junctions
- 3.2.5.2 Critical Flow and Fixed Pressure Boundary Conditions

3.2.6 Code Models

- 3.2.6.1 Power Generation
- 3.2.6.2 Centrifugal Pumps
- 3.2.6.3 Valves

Table of Contents (cont.)

- 3.2.6.4 Phase Separation
- 3.2.6.5 Non-Equilibrium Pressurizer
- 3.2.6.6 Non-Conducting Heat Exchangers
- 3.2.6.7 Local Conditions Heat Transfer

- 3.2.7 Code Options
 - 3.2.7.1 Steady-State Initialization
 - 3.2.7.2 Iterative Numerics
 - 3.2.7.3 Enthalpy Transport
 - 3.2.7.4 Temperature Transport Delay
 - 3.2.7.5 Heat Transfer Map
 - 3.2.7.6 Film Boiling
 - 3.2.7.7 Critical Heat Flux
 - 3.2.7.8 Volume Flow Calculation
 - 3.2.7.9 Wall Friction
 - 3.2.7.10 General Transport Model

3.2.8 Dissimilarities Between Units

3.2.9 Summary of Experience

3.3 McGuire/Catawba VIPRE Model

- 3.3.1 Core and Fuel Assembly Description
 - 3.3.2.1 One-Pass Hot Channel Analysis
 - 3.3.2.2 Transient Analysis Models
 - 3.3.2.3 Simplified Models Justification
 - 3.3.2.4 Axial Noding

- 3.3.3 Code Option and Input Selections
 - 3.3.3.1 Thermal-Hydraulic Correlations
 - 3.3.3.2 Conservative Factors
 - 3.3.3.3 Fuel Pin Conduction Model
 - 3.3.3.4 Power Distribution
 - 3.3.3.5 Flow Rate
 - 3.3.3.6 Direct Coolant Heating
 - 3.3.3.7 Miscellaneous

3.3.4 Discussions of Modeling Differences Between DPC-NE-3000 and DPC-NE-2004 Reports

3.3.5 Summary of Experience

3.4 Methodology Revisions for Westinghouse RFA Fuel

3.5 References

Table of Contents (cont.)

4.0 OCONEE RETRAN BENCHMARK ANALYSES

4.1 Loss of Secondary Heat Transfer

- 4.1.1 Oconee Nuclear Station Unit 3
Loss of Main Feedwater
August 14, 1984

4.2 Excessive Secondary Heat Transfer

- 4.2.1 Oconee Nuclear Station Unit 1
Turbine Bypass Valve Failure
Following Reactor Trip
September 10, 1982
- 4.2.2 Oconee Nuclear Station Unit 3
Steam Generator Overfeed
Following Reactor Trip
March 14, 1980
- 4.2.3 Oconee Nuclear Station Unit 3
Overcooling Following Loss of ICS Power
November 10, 1979

4.3 Loss of Forced Circulation

- 4.3.1 Arkansas Nuclear One Unit 1
Loss of Offsite Power
June 24, 1980
- 4.3.2 Oconee Nuclear Station Unit 1
Reactor Coolant Pump Coastdowns
Unit Startup Tests
- 4.3.3 Oconee Nuclear Station
Steady-State Natural
Circulation Flow Comparisons

4.4 Reactivity Transient

- 4.4.1 Oconee Nuclear Station Unit 1
Control Rod Group Drop
August 8, 1982

Table of Contents (cont.)

4.5 Operational Transients Without Reactor Trip

4.5.1 Oconee Nuclear Station Unit 1
Main Feedwater Pump Trip
July 15, 1985

4.5.2 Oconee Nuclear Station Unit 1
Turbine Bypass Valve Failure
May 4, 1981

4.6 Other Operational Transients

4.6.1 Oconee Nuclear Station Unit 3
Reactor Trip From Three Reactor
Coolant Pump Operation
July 23, 1985

5.0 McGUIRE/CATAWBA RETRAN BENCHMARK ANALYSES

5.1 Loss of Secondary Heat Transfer

5.1.1 McGuire Nuclear Station Unit 2
Loss of Main Feedwater from 30% Full Power
June 10, 1983

5.1.2 McGuire Nuclear Station Unit 2
Loss of Main Feedwater to One Steam Generator
June 24, 1985

5.2 Excessive Secondary Heat Transfer

5.2.1 Catawba Nuclear Station Unit 2
Steam Line PORV Failures
June 27, 1986

5.3 Loss of Forced Circulation

5.3.1 McGuire and Catawba Nuclear Stations
Reactor Coolant Pump Coastdown Tests

5.3.2 McGuire and Catawba Nuclear Stations
Natural Circulation Testing

Table of Contents (cont.)

5.3.3 McGuire Nuclear Station Unit 1
Reactor Coolant Pump Trip from 89% Full Power
June 6, 1984

5.4.1 McGuire Nuclear Station Unit 1
Loss of Offsite Power
August 21, 1984

5.4 Operational Transients Without Reactor Trip

5.4.1 Catawba Nuclear Station - Unit 1
Turbine Trip Test from 68% Full Power
March 27, 1985

6.0 SUMMARY

Appendix A - Methodology Revisions for Mk-B11 Fuel

Appendix B - Methodology Revision for Oconee Replacement Steam Generators

Appendix C - Evaluation of RETRAN-3D SER Conditions and Limitations
For Oconee RETRAN Model With ROTSGs

List of Tables

2.2-1	Oconee Base Model Heat Conductors
2.3-1	Mark-B Fuel Assembly Component Dimensions Used for Thermal-Hydraulic Analysis
2.3-2	Steady-State Results Comparison
2.3-3	Transient Results Comparison
2.3-4	Active Fuel Node Size Comparison
2.3-5	Correlations Used in the COBRA-VIPRE Comparison
2.3-6	VIPRE-01 – COBRA-IIIC/MIT Steady-State Results Comparison
2.3-7	VIPRE-01 – COBRA-IIIC/MIT Transient Results Comparison
3.2-1	McGuire/Catawba Preheat SG Base Model Heat Conductors
3.2-2	McGuire/Catawba Feedring SG Base Model Heat Conductors
3.3-1	Mark-BW Fuel Assembly Component Dimensions Used for Thermal-Hydraulic Analysis
3.3-2	Steady-State Results Comparison
3.3-3	Transient Results Comparison
3.3-4	Active Fuel Node Size Comparison
4.1.1-1	Oconee Nuclear Station Unit 3 Loss of Main Feedwater - August 14, 1984 Sequence of Events
4.2.1-1	Oconee Nuclear Station Unit 1 Turbine Bypass Valve Failure Following Reactor Trip - September 10, 1982 Sequence of Events
4.2.2-1	Oconee Nuclear Station Unit 3 Steam Generator Overfeed Following Reactor Trip March 14, 1980 Sequence of Events

List of Tables (cont.)

- 4.2.3-1 Oconee Nuclear Station Unit 3
Overcooling Following Loss of ICS Power
November 10, 1979
Sequence of Events
- 4.3.1-1 Arkansas Nuclear One Unit 1
Loss of Offsite Power - June 24, 1980
Sequence of Events
- 4.3.2-1 Oconee Nuclear Station Unit 1
Reactor Coolant Pump Coastdowns
RCS Flow Initializations
- 4.3.2-2 Oconee Nuclear Station Unit 1
Reactor Coolant Pump Coastdowns
Pump Trip Combinations
- 4.3.2-3 Oconee Nuclear Station Unit 1
Reactor Coolant Pump Coastdowns
Steady-State Core Flow
- 4.4.1-1 Oconee Nuclear Station Unit 1
Control Rod Group Drop - August 8, 1982
Sequence of Events
- 4.5.1-1 Oconee Nuclear Station Unit 1
Main Feedwater Pump Trip - July 15, 1985
Sequence of Events
- 4.5.2-1 Oconee Nuclear Station Unit 1
Turbine Bypass Valve Failure - May 4, 1981
Sequence of Events
- 4.6.1-1 Oconee Nuclear Station Unit 3
Reactor Trip From Three Reactor Coolant Pump Operation
July 23, 1985
Sequence of Events
- 5.1.1-1 McGuire Nuclear Station Unit 2
Loss of Main Feedwater from 30% Power - June 10, 1983
Sequence of Events
- 5.1.2-1 McGuire Nuclear Station Unit 2
Loss of Main Feedwater to One Steam Generator
June 24, 1985
Sequence of Events
- 5.2.1-1 Catawba Nuclear Station Unit 2
Steam Line PORV Failures - June 27, 1986
Sequence of Events

List of Tables (cont.)

5.3.3-1	McGuire Nuclear Station Unit 1 Reactor Coolant Pump Trip from 89% Power - June 6, 1984 Sequence of Events
5.3.4-1	McGuire Nuclear Station Unit 1 Loss of Offsite Power - August 21, 1984 Sequence of Events
5.4.1-1	Catawba Nuclear Station Unit 1 Turbine Trip Test from 68% Power - March 27, 1985 Sequence of Events
A-1	Mk-B11 Fuel Assembly Component Dimensions Used For Thermal-Hydraulic Analysis

List of Tables (cont.)

List of Figures

- 2.1-1 Oconee Reactor Coolant System
- 2.1-2 Oconee Reactor Vessel
- 2.1-3 Oconee Reactor Vessel Vent Valves
- 2.1-4 Oconee Reactor Coolant Piping
- 2.1-5 Oconee Reactor Coolant Piping
- 2.1-6 Oconee Once-Through Steam Generator
- 2.1-7 Oconee Pressurizer
- 2.1-8 Oconee HPI System
- 2.1-9 Oconee Main Steam System
- 2.1-10 Oconee Steam Generator Level Instruments
- 2.1-11 Oconee Emergency Feedwater System
- 2.2-1 Oconee RETRAN Model Nodalization Diagram
(two-loop)
- 2.2-2 Oconee RETRAN Model Nodalization Diagram
(one-loop)
- 2.3-1 ONS Reactor Core Cross Section
- 2.3-2 ONS Fuel Assembly
- 2.3-3 Assembly Radial Power for Transient Resulting
Symmetrical Power Distributions
- 2.3-4 Hot Assembly Pin Radial - Local Power for Transient
Resulting in Symmetrical Power Distributions
- 2.3-5 VIPRE[]Channel Model
- 2.3-6 VIPRE[]Channel Model
- 2.3-7 VIPRE[]Channel Model
- 2.3-8 [] Axial Shape Peaked at $X/L = []$
- 2.3-9 COBRA[]Channel Model

List of Tables (cont.)

- 3.1-1 McGuire/Catawba Reactor Coolant System
- 3.1-2 McGuire/Catawba Fuel Assembly
- 3.1-3 McGuire/Catawba Fuel Rod
- 3.1-4 McGuire Unit 1 Ag-In-Cd Rod Cluster Control Assembly
- 3.1-5 McGuire/Catawba B₄C Absorber Rod
- 3.1-6 McGuire/Catawba Upper Internals
- 3.1-7 Counterflow Preheater Steam Generator
- 3.1-8 Split Flow Preheater Steam Generator
- 3.1-9 McGuire/Catawba Pressurizer
- 3.1-10 McGuire Main Steam System
- 3.1-11 Catawba Main Steam System
- 3.1-12 Feeding Steam Generator
- 3.2-1 McGuire/Catawba RETRAN Model
Preheat Steam Generator
Nodalization Diagram (two-loop)
- 3.2-2 McGuire/Catawba RETRAN Model
Preheat Steam Generator
Nodalization Diagram (one-loop)
- 3.2-3 McGuire/Catawba RETRAN Model
Feeding Steam Generator
Nodalization Diagram
- 3.3-1 MNS/CNS Reactor Core Cross Section
- 3.3-2 Assembly Radial Power for Transient Resulting
in Symmetrical Power Distribution
- 3.3-3 Hot Assembly Pin Radial - Local Power for Transient Resulting
in Symmetrical Power Distribution
- 3.3-4 VIPRE[]Channel Model
- 3.3-5 VIPRE[]Channel Model

List of Tables (cont.)

3.3-6 VIPRE [] Channel Model

3.3-7 [] Axial Shape Peaked at $X/L = []$

ONS-3 Loss of Main Feedwater
August 14, 1984

4.1.1-1 RCS Pressure

4.1.1-2 Pressurizer Level

4.1.1-3 RCS Hot Leg Temperature

4.1.1-4 RCS Cold Leg Temperature

4.1.1-5 SG Pressure

4.1.1-6 SG Level

ONS-1 Turbine Bypass Valve Failure
Following Reactor Trip
September 10, 1982

4.2.1-1 RCS Pressure

4.2.1-2 Pressurizer Level

4.2.1-3 RCS Hot Leg Temperature

4.2.1-4 RCS Cold Leg Temperature

4.2.1-5 SG Pressure

4.2.1-6 SG Level

ONS-3 Steam Generator Overfeed
Following Reactor Trip
March 14, 1980

4.2.2-1 RCS Pressure

4.2.2-2 Pressurizer Level

4.2.2-3 RCS "A" Hot Leg Temperature

4.2.2-4 RCS "A" Cold Leg Temperature

4.2.2-5 RCS "B" Hot Leg Temperature

4.2.2-6 RCS "B" Cold Leg Temperature

List of Figures (cont.)

- 3.1-1 McGuire/Catawba Reactor Coolant System
- 3.1-2 McGuire/Catawba Fuel Assembly
- 3.1-3 McGuire/Catawba Fuel Rod
- 3.1-4 McGuire Unit 1 Ag-In-Cd Rod Cluster Control Assembly
- 3.1-5 McGuire/Catawba B₄C Absorber Rod
- 3.1-6 McGuire/Catawba Upper Internals
- 3.1-7 Counterflow Preheater Steam Generator
- 3.1-8 Split Flow Preheater Steam Generator
- 3.1-9 McGuire/Catawba Pressurizer
- 3.1-10 McGuire Main Steam System
- 3.1-11 Catawba Main Steam System
- 3.1-12 Feeding Steam Generator
- 3.2-1 McGuire/Catawba RETRAN Model
Preheat Steam Generator
Nodalization Diagram (two-loop)
- 3.2-2 McGuire/Catawba RETRAN Model
Preheat Steam Generator
Nodalization Diagram (one-loop)
- 3.2-3 McGuire/Catawba RETRAN Model
Feeding Steam Generator
Nodalization Diagram
- 3.3-1 MNS/CNS Reactor Core Cross Section
- 3.3-2 Assembly Radial Power for Transient Resulting
in Symmetrical Power Distribution
- 3.3-3 Hot Assembly Pin Radial - Local Power for Transient Resulting
in Symmetrical Power Distribution
- 3.3-4 VIPRE 93 Channel Model
- 3.3-5 VIPRE 47 Channel Model

List of Figures (cont.)

- 3.3-6 VIPRE 14 Channel Model
- 3.3-7 1.55 Chopped Cosine Axial Shape Peaked at $X/L = 0.5$
ONS-3 Loss of Main Feedwater
August 14, 1984
- 4.1.1-1 RCS Pressure
- 4.1.1-2 Pressurizer Level
- 4.1.1-3 RCS Hot Leg Temperature
- 4.1.1-4 RCS Cold Leg Temperature
- 4.1.1-5 SG Pressure
- 4.1.1-6 SG Level
ONS-1 Turbine Bypass Valve Failure
Following Reactor Trip
September 10, 1982
- 4.2.1-1 RCS Pressure
- 4.2.1-2 Pressurizer Level
- 4.2.1-3 RCS Hot Leg Temperature
- 4.2.1-4 RCS Cold Leg Temperature
- 4.2.1-5 SG Pressure
- 4.2.1-6 SG Level
ONS-3 Steam Generator Overfeed
Following Reactor Trip
March 14, 1980
- 4.2.2-1 RCS Pressure
- 4.2.2-2 Pressurizer Level
- 4.2.2-3 RCS "A" Hot Leg Temperature
- 4.2.2-4 RCS "A" Cold Leg Temperature
- 4.2.2-5 RCS "B" Hot Leg Temperature
- 4.2.2-6 RCS "B" Cold Leg Temperature

List of Figures (cont.)

- 4.2.2-7 SG "A" Pressure
- 4.2.2-8 SG "B" Pressure
- 4.2.2-9 SG "A" Level
- 4.2.2-10 SG "B" Level
- ONS-3 Overcooling Following
Loss of ICS Power
November 10, 1979
- 4.2.3-1 Reactor Power
- 4.2.3-2 RCS Pressure
- 4.2.3-3 Pressurizer Level
- 4.2.3-4 RCS "A" Hot Leg Temperature
- 4.2.3-5 RCS "B" Hot Leg Temperature
- 4.2.3-6 RCS "A" Cold Leg Temperature
- 4.2.3-7 RCS "B" Cold Leg Temperature
- 4.2.3-8 MFW Flow
- 4.2.3-9 SG "A" Level
- 4.2.3-10 SG "B" Level
- 4.2.3-11 RCS Pressure
- 4.2.3-12 Pressurizer Level
- 4.2.3-13 RCS "A" Hot Leg Temperature
- 4.2.3-14 RCS "B" Hot Leg Temperature
- 4.2.3-15 RCS "A" Cold Leg Temperature
- 4.2.3-16 RCS "B" Cold Leg Temperature
- 4.2.3-17 SG "A" Pressure
- 4.2.3-18 SG "B" Pressure
- 4.2.3-19 SG "A" Level

List of Figures (cont.)

4.2.3-20 SG "B" Level

4.2.3-21 MFW Flow

4.2.3-22 SG "B" Level

ANO-1 Loss of Offsite Power
June 24, 1980

4.3.1-1 RCS Pressure

4.3.1-2 Pressurizer Level

4.3.1-3 RCS Temperature

4.3.1-4 SG Pressure

4.3.1-5 SG Level

4.3.1-6 RCS Flow (RETRAN prediction)

4.3.1-7 RCS Flow (RETRAN prediction)

ONS-1 Reactor Coolant Pump
Flow Coastdowns

4.3.2-1 4/0 Flow Coastdown

4.3.2-2 4/3 Flow Coastdown

4.3.2-3 4/2 Flow Coastdown (1 per loop)

4.3.2-4 4/2 Flow Coastdown (same loop)

4.3.2-5 4/1 Flow Coastdown

4.3.2-6 3/0 Flow Coastdown

4.3.2-7 3/2 Flow Coastdown (1 per loop running)

4.3.2-8 3/1 Flow Coastdown (1 per loop)

4.3.2-9 3/1 Flow Coastdown (same loop)

4.3.2-10 2/0 Flow Coastdown (1 per loop)

4.3.2-11 2/1 Flow Coastdown

4.3.2-12 2/0 Flow Coastdown (same loop)

List of Figures (cont.)

4.3.2-13 2/1 Flow Coastdown

ONS Steady State Natural
Circulation Comparisons

4.3.3-1 Natural Circulation Flow Predictions

ONS-1 Control Rod Group Drop
August 8, 1982

4.4.1-1 Reactor Power

4.4.1-2 Reactor Power

4.4.1-3 RCS Pressure

4.4.1-4 Pressurizer Level

4.4.1-5 RCS Hot Leg Temperature

4.4.1-6 RCS Cold Leg Temperature

4.4.1-7 SG Pressure

4.4.1-8 SG level

ONS-1 Main Feedwater Pump Trip
July 15, 1985

4.5.1-1 Reactor Power

4.5.1-2 RCS Pressure

4.5.1-3 Pressurizer Level

4.5.1-4 RCS Hot Leg Temperature

4.5.1-5 RCS Cold Leg Temperature

4.5.1-6 SG Level

4.5.1-7 Main Steam Line Pressure

ONS-1 Turbine Bypass Valve Failure
May 4, 1981

4.5.2-1 Reactor Power

4.5.2-2 RCS Pressure

List of Figures (cont.)

4.5.2-3 Pressurizer Level

4.5.2-4 RCS "A" Hot Leg Temperature

4.5.2-5 RCS "B" Hot Leg Temperature

4.5.2-6 RCS "A" Cold Leg Temperature

4.5.2-7 RCS "B" Cold Leg Temperature

4.5.2-8 Main Steam Line "A" Pressure

4.5.2-9 Main Steam Line "B" Pressure

ONS-3 Reactor Trip From Three
Reactor Coolant Pump Operation
July 23, 1985

4.6.1-1 Reactor Power

4.6.1-2 Reactor Power

4.6.1-3 Group 7 Rod Position

4.6.1-4 RCS Pressure

4.6.1-5 Pressurizer Level

4.6.1-6 RCS "A" Hot Leg Temperature

4.6.1-7 RCS "A" Cold Leg Temperature

4.6.1-8 RCS "A" Loop Temperatures (RETRAN prediction)

4.6.1-9 RCS "A" Loop Temperatures (plant data)

4.6.1-10 RCS "B" Hot Leg Temperature

4.6.1-11 RCS "B" Cold Leg Temperature

4.6.1-12 RCS "B" Loop Temperatures (RETRAN prediction)

4.6.1-13 RCS "B" Loop Temperatures (plant data)

4.6.1-14 SG "A" Pressure

4.6.1-15 SG "B" Pressure

4.6.1-16 SG "A" Level

List of Figures (cont.)

4.6.1-17 SG "B" Level

McGuire Nuclear Station - Unit 2
Loss of Main Feedwater from 30% Power
June 10, 1983

5.1.1-1 Reactor Power

5.1.1-2 Pressurizer Pressure

5.1.1-3 Pressurizer Level

5.1.1-4 RCS T-ave

5.1.1-5 RCS Loop ΔT

5.1.1-6 SG Pressure

5.1.1-7 SG Level

McGuire Nuclear Station - Unit 2
Loss of Main Feedwater to One Steam Generator
June 24, 1985

5.1.2-1 Pressurizer Pressure

5.1.2-2 Pressurizer Level

5.1.2-3 Steam Line "C" Pressure

5.1.2-4 Steam Line "A" Pressure

5.1.2-5 SG "C" Level

5.1.2-6 SG "A" Level

5.1.2-7 RCS Loop "C" T-ave

5.1.2-8 RCS Loop "A" T-ave

5.1.2-9 RCS Loop "C" ΔT

5.1.2-10 RCS Loop "A" ΔT

Catawba Nuclear Station - Unit 2
Steam Line PORV Failures
June 27, 1986

List of Figures (cont.)

5.2.1-1 Pressurizer Pressure

5.2.1-2 RCS Pressure

5.2.1-3 Pressurizer Level

5.2.1-4 RCS T-ave

5.2.1-5 RCS T-hot

5.2.1-6 RCS T-cold

5.2.1-7 Steam Line Pressure

5.2.1-8 SG Level

5.2.1-9 CCP SI Flow

McGuire and Catawba Nuclear Stations Reactor Coolant Pump Flow Coastdown Tests

5.3.1-1 CNS-1 - 4/4 Pump Coastdown

5.3.1-2 MNS-1 - 4/4 Pump Coastdown

5.3.1-3 MNS/CNS - 4/4 Pump Coastdown

5.3.1-4 MNS-1&2 / CNS-1 - 4/4 Pump Coastdown

5.3.1-5 CNS-2 - 4/4 Pump Coastdown

5.3.1-6 MNS-1&2 / CNS-1 - 1/4 Pump Coastdown
(flow in loop with tripped pump)

5.3.1-7 MNS-1&2 / CNS-1 - 1/4 Pump Coastdown (core flow)

5.3.1-8 CNS-2 - 1/4 Pump Coastdown
(flow in loop with tripped pump)

5.3.1-9 MNS-1&2 - 3/3 Pump Coastdown

5.3.1-10 MNS-1&2 - 1/3 Pump Coastdown
(flow in loop with tripped pump)

5.3.1-11 MNS-1&2 - 1/3 Pump Coastdown (core flow)

McGuire and Catawba Nuclear Stations Natural Circulation Testing

MNS/CNS Steady-State Natural Circulation

List of Figures (cont.)

- 5.3.2-1 Natural Circulation ΔT vs. Power
- 5.3.2-2 Natural Circulation Flow vs. Power
 - MNS-1 Natural Circulation with SG Isolation
(1 of 4 SGs Isolated Test)
- 5.3.2-3 Isolated and Active Loops ΔT (plant data)
- 5.3.2-4 Isolated and Active Loops ΔT (RETRAN prediction)
- 5.3.2-5 ΔT in the Isolated Loop
- 5.3.2-6 ΔT in the Active Loops
- 5.3.2-7 SG Pressure (plant data)
- 5.3.2-8 SG Pressure (RETRAN prediction)
- 5.3.2-9 SG Pressure in the Isolated Loop
- 5.3.2-10 T-hot and T-cold in the Isolated Loop (RETRAN prediction)
- 5.3.2-11 T-hot and T-cold in the Active Loops (RETRAN prediction)
- 5.3.2-12 RCS Loop Flow (RETRAN prediction)
 - (2 of 4 SGs Isolated Test)
- 5.3.2-13 RCS Loop ΔT (plant data)
- 5.3.2-14 RCS Loop ΔT (RETRAN prediction)
- 5.3.2-15 RCS Loop ΔT in the Previously Isolated Loop
- 5.3.2-16 RCS Loop ΔT in the Second Isolated Loop
- 5.3.2-17 RCS Loop ΔT in the Active Loops
- 5.3.2-18 SG Pressure (plant data)
- 5.3.2-19 SG Pressure (RETRAN prediction)
- 5.3.2-20 RCS T-hot and T-cold in the Previously Isolated Loop
(RETRAN prediction)
- 5.3.2-21 RCS T-hot and T-cold in the Second Isolated Loop
(RETRAN prediction)

List of Figures (cont.)

5.3.2-22 RCS T-hot and T-cold in the Active Loops
(RETRAN prediction)

5.3.2-23 RCS Loop Flow (RETRAN prediction)

McGuire Nuclear Station - Unit 1
Reactor Coolant Pump Trip from 89% Power
June 6, 1984

5.3.3-1 Pressurizer Pressure

5.3.3-2 Pressurizer Level

5.3.3-3 RCS T-ave (active loops)

5.3.3-4 RCS T-hot (loop with tripped pump)

5.3.3-5 RCS T-hot (active loops)

5.3.3-6 RCS T-cold (loop with tripped pump)

5.3.3-7 RCS T-cold (active loops)

5.3.3-8 Steam Line Pressure (loop with tripped pump)

5.3.3-9 Steam Line Pressure (active loops)

5.3.3-10 SG Level (loop with tripped pump)

5.3.3-11 SG Level (active loops)

5.3.3-12 RCS Loop Flow (loop with tripped pump)

5.3.3-13 RCS Loop Flow (active loops)

McGuire Nuclear Station - Unit 1
Loss of Offsite Power
August 21, 1984

5.3.4-1 Steam Line Pressure

5.3.4-2 SG Level

5.3.4-3 Pressurizer Pressure

5.3.4-4 Pressurizer Level

5.3.4-5 RCS Loop ΔT

List of Figures (cont.)

- 5.3.4-6 RCS T-hot
- 5.3.4-7 RCS T-cold
- 5.3.4-8 Reactor Vessel Upper Head Temperature
- 5.3.4-9 RCS Loop Flow
- 5.3.4-10 RCS Loop Flow

Catawba Nuclear Station - Unit 1
Turbine Trip Test from 68% Power
March 27, 1986

- 5.4.1-1 Reactor Power
 - 5.4.1-2 Pressurizer Pressure
 - 5.4.1-3 Pressurizer Level
 - 5.4.1-4 RCS T-ave
 - 5.4.1-5 RCS Loop ΔT
 - 5.4.1-6 Steam Line Pressure
 - 5.4.1-7 SG Level
- A-1 Mk-B11 Fuel Assembly

List of Acronyms

AFW	Auxiliary Feedwater
ANO	Arkansas Nuclear One
ANS	American Nuclear Society
ASP	Auxiliary Shutdown Panel
BWR	Boiling Water Reactor
BWST	Borated Water Storage Tank
B&W	Babcock & Wilcox
CCI	Control Components Inc.
CCP	Centrifugal Charging Pump
CFR	Code of Federal Regulations
CFT	Core Flood Tank
CHF	Critical Heat Flux
CLA	Cold Leg Accumulator
CNS	Catawba Nuclear Station
CVCS	Chemical and Volume Control System
DNBR	Departure from Nucleate Boiling Ratio
EFW	Emergency Feedwater
EHC	Electro-Hydraulic Control
EPRI	Electric Power Research Institute
ESFAS	Engineered Safety Features Actuation System
ESS	Engineered Safeguards System
FA	Fuel Assembly
FANP	Framatome Advance Nuclear Power
FP	Full Power
FSAR	Final Safety Analysis Report
HEM	Homogeneous Equilibrium Model
HHSI	High Head Safety Injection
HPI	High Pressure Injection
ICS	Integrated Control System
ID	Inside Diameter
IHSI	Intermediate Head Safety Injection
LER	Licensee Event Report
LHSI	Low Head Safety Injection
LOCA	Loss of Coolant Accident
LPI	Low Pressure Injection
MDNBR	Minimum Departure from Nucleate Boiling Ratio
MFW	Main Feedwater
MIT	Massachusetts Institute of Technology
MNS	McGuire Nuclear Station
MS	Main Steam
MSIV	Main Steam Isolation Valve
MSRV	Main Steam Relief Valve
MWt	Megawatt Thermal
NNI	Non-Nuclear Instrumentation
NRC	Nuclear Regulatory Commission
NSSS	Nuclear Steam Supply System
OD	Outside Diameter

List of Acronyms (cont.)

ONS	Oconee Nuclear Station
OTSG	Once-Through Steam Generator
PI	Proportional Plus Integral
PORV	Pilot-Operated Relief Valve (ONS)
PORV	Power-Operated Relief Valve (MNS/CNS)
PWR	Pressurized Water Reactor
PZR	Pressurizer
QA	Quality Assurance
RCCA	Rod Cluster Control Assembly
RCP	Reactor Coolant Pump
RCS	Reactor Coolant System
RFA	Robust Fuel Assembly
ROTSG	Replacement Once-Through Steam Generator
RPS	Reactor Protective System (B&W)
RPS	Reactor Protection System (W)
RTD	Resistance Temperature Detector
RWST	Refueling Water Storage Tank
Rx	Reactor
SDM	Shutdown Margin
SER	Safety Evaluation Report
SG	Steam Generator
SI	Safety Injection
TBS	Turbine Bypass System
TBV	Turbine Bypass Valve
TCS	Turbine Control System
TMF	Turbulent Momentum Factor
UHI	Upper Head Injection

1.0 INTRODUCTION

1.1 Objective

The objective of this report is to present the development and validation of thermal-hydraulic transient analysis methods at Duke Power Company in order to address the requirements of Generic Letter 83-11 "Licensee Qualification for Performing Safety Analyses in Support of Licensing Actions" (Reference 1-1). This letter requires that licensees performing their own safety analyses demonstrate their capability and technical competence. In particular, comparisons of computer code results to experimental data, plant operational data, or other benchmarked analyses, were identified as areas of interest. This report provides the details of extensive benchmarking efforts which utilize actual plant transient data from the Oconee, McGuire, and Catawba Nuclear Stations for comparisons to system code predictions. The capabilities of the RETRAN-02 system simulation code (Reference 1-2) and the VIPRE-01 core thermal-hydraulic simulation code (Reference 1-3) are demonstrated using plant and core simulation models developed by Duke Power Company.

Revisions to modernize the methodology and to maintain the methodology current with the plant design have been submitted for NRC review and approval. Revision 1 describes the methodology revision for the McGuire and Catawba Unit 1 replacement steam generators and other minor revisions. Revision 2 describes the methodology revision for the FANP Mk-B11 fuel assembly design for Oconee and other minor revisions. Revision 3 describes the methodology revisions for the Oconee replacement steam generators, the RETRAN-3D MOD003.1/DKE code, the Westinghouse RFA fuel assembly design, and other minor revisions.

1.2 RETRAN-02 Code Description

RETRAN-02 was developed by Energy Incorporated for the Electric Power Research Institute (EPRI) to provide utilities with a code capable of simulating most thermal-hydraulic transients of interest in both PWRs and BWRs. RETRAN-02 has the flexibility to model any general fluid system by partitioning the system into a one-dimensional network of fluid volumes and connecting flowpaths or junctions. The mass, momentum, and energy equations are then solved by employing a semi-implicit solution technique. The time step selection logic is based on

algorithms that detect rapid changes in physical processes and limit time steps to ensure accuracy and stability. Although the equations describe homogeneous equilibrium fluid volumes, phase separation can be modeled by separated bubble rise volumes and by a dynamic slip model. The pressurizer and other volumes can be modeled as non-equilibrium volumes when such phenomena are present. Reactor power generation can be represented by either a point kinetics model or a one-dimensional kinetics model. Heat transfer across steam generator tubes and to or from structural components can be modeled. Special component models for centrifugal pumps, valves, trip logic, control systems, and other features useful for fluid system modeling are available. The RETRAN-02 MOD003 code version is used for the analyses presented in this report.

1.3 RETRAN-3D Code Description

RETRAN-3D (Reference 1-18) was developed by Computer Simulation & Analysis, Inc. for EPRI to enhance and extend the simulation capabilities of the RETRAN-02 code. RETRAN-3D has many new and enhanced capabilities relative to RETRAN-02, in particular, a 3-D kinetics core model, improved two-phase models, an improved heat transfer correlation package, and an implicit numerical solution method. Most of the capabilities of the RETRAN-02 code have been retained within RETRAN-3D as options, except for a limited number of models and correlations that were not in use. The NRC SER for RETRAN-3D is dated January 25, 2001 (Reference 1-19). The SER includes limitations and conditions on the use of the code for licensing applications

1.4 VIPRE-01 Code Description

VIPRE-01 was developed for EPRI by Battelle Pacific Northwest Laboratories for steady-state and transient core thermal-hydraulic analysis. The basic structure and computational philosophy of the VIPRE-01 code are derived from COBRA-IIIC (Reference 1-4). The subchannel analysis approach is applied in both codes. With this approach the nuclear fuel element is divided into a number of quasi-one-dimensional channels that communicate laterally by diversion crossflow and turbulent mixing. Conservation equations of mass, axial and lateral momentum, and energy are solved for the fluid enthalpy, axial flowrate, lateral flow per unit length, and momentum pressure drop. The flow field is assumed to be incompressible and homogeneous, although models are added to reflect subcooled boiling and co-current liquid/vapor slip. VIPRE uses an

implicit boundary value solution scheme where the boundary conditions are inlet enthalpy, inlet mass flowrate, and core exit pressure. The VIPRE-01 Cycle-01 code version is used for the analyses presented in this report.

1.5 Methodology Development

The development of inhouse plant transient simulation capability, which has evolved into the submittal of this report, began in April 1978. Initial efforts focused on following the development of the RETRAN-01 system simulation code (Reference 1-5) by EPRI. Following the first release of a production version of RETRAN-01 in December 1978, work began on assembling a simulation model of the Oconee Nuclear Station and was completed in July 1979. The Oconee Nuclear Station is a three unit site with similar 2568 MWt Babcock & Wilcox pressurized water reactors. The Oconee RETRAN model was then exercised during the next year by comparison to several plant transient events (References 1-6, 1-7), as well as some separate effects tests conducted at the plant. Based on the generally positive results of these initial transient simulation efforts, it was decided in mid-1980 to begin applications of the technology towards the resolution of technical and safety concerns. Additional Oconee RETRAN model comparisons to plant transients are described in References 1-8 and 1-9.

A separate and parallel effort was initiated in June 1979 to develop core thermal-hydraulic analysis technology. Although most of this effort was directed towards steady-state core reload design, models for predicting the departure from nucleate boiling phenomenon during transients were also developed. The early transient analysis applications utilized the COBRA-IIIC/MIT code (Reference 1-10). Beginning in October 1983 with the EPRI release of the first production version of the VIPRE-01 code, subsequent transient core thermal-hydraulic simulations have been performed with VIPRE-01.

The McGuire and Catawba Nuclear Stations are both two unit sites with similar 3411 MWt Westinghouse 4-loop pressurized water reactors. Development of RETRAN plant transient

simulation models for the McGuire and Catawba Nuclear Stations began in early 1981. The McGuire/Catawba RETRAN model benchmark analyses were completed just prior to this report.

1.6 Model and Code Qualification

The model and code qualification process can be thought of as a sequence of three major milestones. The first milestone is the verification of the computer code. Verification activities associated with the RETRAN-02 code culminated in the issuance of the NRC SER dated September 2, 1984 (Reference 1-12). The VIPRE-01 NRC SER was issued on May 1, 1986 (Reference 1-3). The SER approves the utilization of the licensed code version within the limits or restrictions imposed by the SER. The RETRAN- and VIPRE-01 code versions used in this report are identical to the versions reviewed in the NRC SERs, with the exception of minor error corrections. Duke Power is a member of the Utility Group for Regulatory Applications (UGRA) which requested and sponsored the NRC review of the RETRAN-02 and VIPRE-01 codes. The second milestone is the verification of the simulation model, i.e. the input deck that describes the system being simulated. This milestone has been completed for the Oconee and McGuire/Catawba RETRAN models and the Oconee VIPRE model. The RETRAN and VIPRE models are described in detail in Sections 2 and 3 of this report. The third milestone is the validation of the predictive capability of the code/ model by comparison to a standard. The standard selected for validation of the RETRAN models is actual plant transient data. The results of these validation or benchmarking activities are detailed in Sections 4 and 5 of this report. The plant transients utilized for benchmarking were selected with attention to the overall goal of exercising the code and model to as broad a range of transient conditions and phenomena as possible. The recent operating history at Oconee and the entire operating histories at McGuire and Catawba were reviewed to identify transients or tests that presented worthwhile challenges to the code and model. Provided that the plant data was logged and available, the most dynamic transients were of the greatest interest. Typically the plant data includes a nearly complete set of parameters logged at a one second frequency, so that a very good characterization of the event is obtained. The transients that have occurred at Duke nuclear plants do not include many that can be characterized as significant, at least when compared to the design basis transient spectrum. Nevertheless, a good spectrum of different transient event types are available for benchmarking.

The review for benchmarking data attempted to identify transient events at both Oconee and at McGuire or Catawba in each of the following transient type categories:

- Loss of coolant transients
- Loss of heat sink transients
- Overcooling transients
- Partial loss of forced flow transients
- Natural circulation transients
- Reactivity change transients
- Asymmetric transients
- Transients not resulting in a reactor trip
- Transients initiating below full power

A review of the contents of Sections 4 and 5 shows that the available plant transient data met most of the goals. Since there have not been any significant loss of coolant events at any Duke plants, no benchmark data for that type exist. The other transient types are well represented for both the B&W and Westinghouse plants. It should be noted that data was obtained from Arkansas Power & Light Company for a loss of offsite power event that occurred at Arkansas Nuclear One - Unit 1, which is a sister plant of Oconee. This data was used due to an absence of similar data at Oconee.

For each benchmark transient in Sections 4 and 5 the capability of the code and model to accurately simulate the plant response can be assessed. The primary phenomena of interest associated with each transient are highlighted. For several events it is pointed out that some degree of uncertainty exists in the timing of specific events and the performance of certain systems and components. This limitation is typical of plant data used for code comparisons. The quality of the data is sufficient for the purposes of this report.

Since applicable plant data does not exist for detailed validation of the Oconee VIPRE Model, comparisons to the COBRA-IIIC/MIT code are utilized. Very comparable core simulation models were developed for each code, such that when combined with a selection of similar code options, a meaningful code-to-code comparison could be obtained. A set of arbitrary transient cases was then simulated. The resulting VIPRE-01 and COBRA-IIIC/MIT predictions of local

subchannel conditions and DNBR are presented in Section 2. Additional VIPRE validation by code comparison has been submitted by Duke Power Company in Reference 1-14 for Oconee and in Reference 1-15 for McGuire/Catawba.

1.7 Quality Assurance

The development, utilization, and documentation of transient analysis technology incorporated several stages of formal quality assurance (QA) activities. The major activities are controlled by formal QA procedural requirements as part of the Duke Power Company Quality Assurance Manual. Other activities are administratively controlled by workplace procedures or by training that serves to maintain a high level of consistency in the application of the codes and model. A major QA activity is the certification of computer codes to be used in safety-related analyses. Both the RETRAN-02 and VIPRE-01 code versions used for the analyses documented in this report have undergone this certification process.

A second major QA activity is the documentation of the simulation model. Due to the very large volume of information that is necessary to develop a model for a system simulation code such as RETRAN-02, a separate document is compiled to detail all calculations and references utilized in the model. These model documents describe a "base deck" which consists of all the code input necessary to initialize at 100% full power with all parameters at nominal conditions. A thorough review of the model document is performed along with a review of the derived input listing. The model document and the base deck are then controlled such that any changes must be documented, reviewed, and approved prior to implementation. Applications of the base deck with analysis-specific modifications are performed such that the base deck itself is not modified. Modifications are added at the end of the base deck so that the QA review can be limited to the analysis-specific additions. A model document is not developed for the VIPRE-01 code models since the volume of calculations necessary to develop the model and code input is much less than that of a system code. The VIPRE models are documented and reviewed during the first application of a new model. Base deck configuration controls similar to that described above are utilized to ensure accountability and consistency in all applications of the model.

All safety-related analyses include an independent review by a qualified reviewer. The calculation file is then subject to approval by supervision. In the event that at a later date an

error is identified or new information brings into question the results or conclusions of a calculation file, all individuals are responsible for bringing it to the attention of the cognizant supervisor. All such occurrences are logged, investigated, and dispositioned. A determination is made of the significance of the error and the potential reportability of the item per 10 CFR 50.73 or other regulation. All potentially affected calculation files are reviewed to evaluate the potential impact of the error or new information, and reanalyses are initiated as necessary. Final resolution of significant errors is contingent on management approval.

Analysis activities are subject to internal audit by the QA department on a periodic basis. Conformance with established procedures and QA requirements are evaluated. In addition, analysis activities have been inspected by NRC on two occasions. A special safety inspection was conducted during June 7-9, 1982, which focused on the subject of validation of the RETRAN computer code. The inspection report (Reference 1-16) stated that no deviations or violations were disclosed. The one unresolved item which resulted from the inspection has been addressed. The second inspection was conducted as part of a Safety System Functional Inspection of the Oconee Emergency Feedwater System (EFW), which was conducted during the period May 5 to June 11, 1986. An inspection of a calculation file which documented a RETRAN model of the EFW system identified several minor errors. The inspection report (Reference 1-17) states that these errors would not (and did not) substantially alter the conclusions of the analyses.

In summary, appropriate QA measures have been employed during the development of transient analysis codes and models, and during the application of the technology. The Duke QA system is structured to ensure configuration control, traceability, and accountability.

1.8 Methodology Applications

Thermal-hydraulic transient analysis methods have been and will continue to be used for a wide range of purposes. The most pertinent applications in the context of this report are those related to the resolution of licensing concerns. Licensing concerns include:

- Evaluation of the consequences of equipment failures and other items for documentation in LERs.
- Evaluation of the impact of proposed plant modifications, changes in technological specifications, and revisions to operating procedures on the design basis transients and accidents
- Reanalysis of design basis transients due to changes in plant parameters, such as those associated with a fuel reload
- Resolution of generic safety issues applicable to Duke nuclear stations
- Analytical basis for justification of continued operation under off-normal operating conditions

Other applications of the technology include:

- Analytical basis for emergency operating procedures
- Data for validation of plant-specific control room simulators
- Developing responses to station concerns regarding plant transients
- Data for emergency drills
- Success criteria for PRA systems analysis

Based on a foundation of thorough analytical model development and substantial model benchmarking efforts, the capability to employ methodology applications towards the resolution of technical and safety concerns has been demonstrated.

1.9 Interface with Topical Report DPC-NE-2009P-A

This report is referenced by DPC-NE-2009, "Duke Power Company Westinghouse Fuel Transition Report." (Reference 1-20). DPC-NE-2009 describes the revisions to Duke Power's NRC-approved topical reports that are necessary to support the transition to the Westinghouse Robust Fuel Assembly (RFA) fuel design at the McGuire and Catawba Nuclear Stations. The revisions specific to DPC-NE-3000-PA are discussed in Section 6.1 of DPC-NE-2009P-A. New Section 3.4, "Methodology Revisions for Westinghouse RFA Fuel," merges the appropriate content from DPC-NE-2009, into DPC-NE-3000-PA, Revision 3. Some of the content, such as descriptions of the RFA design and the WRB-2M CHF correlation, is taken from other sections of DPC-NE-2009.

1.10 Appendices

Appendix A was added in Revision 2 to describe the Mk-B11 fuel assembly used at Oconee and how it will be simulated with the RETRAN-02 and VIPRE-01 models. This modeling of the Mk-B11 fuel assembly is also applicable to RETRAN-3D MOD003.1/DKE.

Appendix B was added in Revision 3 to describe the Oconee replacement steam generator (ROTSG) modeling with RETRAN-3D MOD003.1/DKE.

Appendix C was added in Revision 3 to address the RETRAN-3D SER conditions and limitations as related to the modeling for Oconee with replacement steam generators.

1.11 References

- 1-1 Licensee Qualification for Performing Safety Analyses in Support of Licensing Actions (Generic Letter No. 83-11), USNRC, February 8, 1983
- 1-2 RETRAN-02 - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems, EPRI NP-1850-CCM Revision 4, EPRI, November 1988
- 1-3 VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores, EPRI NP-2511-CCM Revision 3, EPRI, August 1989
- 1-4 COBRA-IIIC: A Digital Computer Program for Steady-State and Transient Core Thermal-Hydraulic Design Methodology, BNWL-1695, PNL, March 1973
- 1-5 RETRAN-- A Program for One-Dimensional Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems, EPRI CCM-5, EPRI, December 1978

- 1-6 Oconee RETRAN Model Comparisons With Plant Transient Data, Gregg B. Swindlehurst, Duke Power Co., Conference Proceedings: First International RETRAN Conference, EPRI WS-80-50, EPRI, April 1981
- 1-7 Oconee RETRAN Model Comparisons With Plant Transient Data, Gregg B. Swindlehurst, Duke Power Co., Nuclear Technology Vol. 54 No. 3, September 1981
- 1-8 Qualification of the Oconee RETRAN Model by Comparison With Plant Transient Data, S. P. Nesbit, R. J. Gerling, and G. B. Swindlehurst, Proceedings: Fifth International RETRAN Conference, April 1988
- 1-9 Qualification of the Oconee RETRAN Model by Comparison With Plant Transient Data, S. P. Nesbit, R. J. Gerling, and G. B. Swindlehurst, Duke Power Co., Nuclear Technology Vol. 83, December 1988
- 1-10 COBRA-IIIc/MIT Computer Code Manual, R. W. Bowring, MIT, March 1976
- 1-11 Simulation of McGuire and Catawba Transient Data and Qualification of RETRAN Plant Model, H. J. Lee, M. E. Henshaw, P. A. Goodwin, R. S. Johnson, Duke Power Co., Proceedings: Fifth International RETRAN Conference, April 1988
- 1-12 Letter, C. O. Thomas (NRC) to T. W. Schnatz (UGRA), September 4, 1984, (Transmittal of RETRAN-02 Safety Evaluation Report)
- 1-13 Letter, C. E. Rossi (NRC) to J. A. Blaisdell (UGRA), May 1, 1986, (Transmittal of VIPRE-01 Safety Evaluation Report)
- 1-14 Duke Power Company Oconee Nuclear Station Core Thermal-Hydraulic Methodology Using VIPRE-01, DPC-NE-2003, Revision 1, September 2000
- 1-15 Duke Power Company McGuire and Catawba Nuclear Stations Core Thermal-Hydraulic Methodology Using VIPRE-01, DPC-NE-2004, Revision 1, February 1997

- 1-16 Letter, H. C. Dance (NRC) to W. O. Parker, Jr. (Duke), June 29, 1982, Inspection Report Nos. 50-269/82-25, 50-270/82-25, 50-287/82-25, and 50-369/82-22
- 1-17 Letter, J. M. Taylor (NRC) to H. B. Tucker (Duke), August 1, 1986, Safety System Functional Inspection Report Numbers 50-269/86-16, 50-270/86-16, and 50-287/86-16
- 1-18 RETRAN-3D - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems, EPRI, NP-7450(A), Volumes 1-4, Revision 5, July 2001
- 1-19 Letter, S. A. Richards (NRC), to G. L. Vine (EPRI), Safety Evaluation Report on EPRI Topical Report NP-7450(P), Revision 4, "RETRAN-3D - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems", January 25, 2001
- 1-20 Duke Power Company Westinghouse Fuel Transition Report, DPC-NE-2009P-A, Revision 2, Duke Power, December 2002

2.0 OCONEE TRANSIENT ANALYSIS

2.1 Plant Description

2.1.1 Overview

The Oconee Nuclear Station consists of three 2568 MW thermal Babcock and Wilcox (B&W) pressurized water reactor (PWR) units located next to Lake Keowee near Clemson, South Carolina. Construction began on the plant in 1967, and the operating licenses were received on February 6, 1973, October 6, 1973, and July 19, 1974, for Units 1, 2, and 3, respectively. The three units are identical in most respects. Auxiliary systems are generally shared between Units 1 and 2, with separate systems for Unit 3. The Oconee units are similar in design to other current pressurized water reactors in most areas. Some unusual characteristics of Oconee include the use of once-through steam generators (SGs) to provide superheated steam, the use of the Keowee Hydro Station as the onsite emergency power source, and the provision for emergency condenser cooling via a gravity flow system in the event of a loss of all condenser circulating water pumps.

Each primary system has two hot legs, two SGs, and four reactor coolant pumps (RCPs). The primary coolant is heated in the core and flows to the SGs, where the energy is transferred to the secondary system. The coolant is then returned to the reactor vessel by the RCPs. The secondary system provides 460°F feedwater to the SGs, where the water is heated into steam and superheated to approximately 595°F. The steam passes through a high pressure and three low pressure turbines and is exhausted to the condensers. The condensate is purified and preheated before it is returned to the SGs.

The plant is controlled by the Integrated Control System (ICS). The ICS regulates overall load demand, steam flow to the turbine, feedwater flow to the SGs, and reactor power in order to provide stable operation and a smooth response to transients and power maneuvers.

Plant safety systems provide protection for various anticipated transients and design basis accidents. The Reactor Protective System (RPS) shuts down the nuclear chain reaction to prevent core damage and exceeding safety limits. The Engineered Safeguards System (ESS) provides emergency core cooling in the event of a loss coolant accident (LOCA). The Emergency Feedwater (EFW) System provides feedwater to the SGs for decay heat removal following a loss of the Main Feedwater (MFW) System.

2.1.2 Primary System

The Oconee Reactor Coolant System (RCS) is shown schematically on Figure 2.1-1.

2.1.2.1 Reactor Core

The reactor core consists of 177 fuel assemblies and the associated control rods. Each fuel assembly is a 15x15 array of 208 fuel pins, 16 control rod guide tubes, and one in-core instrumentation tube. Each fuel pin contains stacked UO_2 fuel pellets surrounded by Zircaloy-4 cladding, with a small gap between the pellets and the cladding. The Zircaloy control rod guide tubes provide a channel for control rod insertion. The instrumentation tube provides a channel for in-core neutron detectors and a core exit thermocouple. 69 of the fuel assemblies are actually provided with control elements, 61 of which are silver-indium-cadmium assemblies for overall power control and shutdown capability, and 8 of which are Inconel-600 part-length assemblies for axial power shaping. Some of the fuel assemblies which do not contain control rods have burnable poison rod assemblies. Their purpose is to reduce core reactivity at the beginning of cycle and therefore enable higher enrichment cores and longer fuel cycles.

2.1.2.2 Reactor Vessel

The reactor vessel consists of a cylindrical shell, a spherically dished bottom head, and a flange to which the removable reactor vessel upper head is bolted during operation. The minimum shell thickness is 8-7/16 inches of carbon steel, and the interior is clad with stainless steel. The general arrangement of the vessel is shown on Figure 2.1-2. Major regions of the vessel include the coolant inlet nozzles, the downcomer, the lower head, the core, the upper plenum, the upper head, the outlet annulus, and the outlet nozzles. Vessel penetrations include the incore instruments, the control rod assemblies, and the core flood lines. The incore instrument nozzles penetrate the lower head and extend into the reactor core region. The control rod assemblies penetrate the upper head and extend through the control rod guide tubes in the upper plenum into the reactor core. Two core flood lines empty into the downcomer and provide a pathway for core flood tank injection and low pressure injection. In addition there is a high point vent which comes off of one of the control rod assemblies near the top of the vessel.

The eight reactor vessel vent valves are unique to the B&W reactor design. These 14 inch flapper valves connect the outlet annulus to the downcomer. The valves are designed to open during a design basis cold leg pipe break in order to facilitate venting of steam out the break. During normal operation the valves are shut by the pressure differential between the downcomer

and the upper plenum. However, when the RCPs are tripped the pressure differential may be reversed due to density differences in the reactor vessel, causing the valves to open. This provides a flowpath for internal vessel circulation. The function of the reactor vessel vent valves is illustrated on Figure 2.1-3.

2.1.2.3 Reactor Coolant Loops

The RCS piping provides a pathway for the coolant to circulate between the reactor vessel and the SGs. Each of the two 36 inch ID hot legs connects the reactor vessel to one of the SGs. Two 28-inch ID cold legs connect each of the steam generators back to the reactor vessel. Each of the four cold legs contains a RCP. The minimum thicknesses of the hot and cold leg piping are 2-7/8 inches and 2-1/4 inches, respectively. The piping is carbon steel clad with stainless steel. The piping arrangement is shown on Figures 2.1-4 and 2.1-5. Oconee, like most B&W plants, has a lowered-loop piping configuration. This refers to the fact that the reactor vessel and the steam generator are at approximately the same elevation.

There are various piping penetrations for interfacing systems and components. These include the pressurizer surge line into one of the hot legs, the decay heat removal suction line off of the bottom of one of the hot legs, the hot leg high point vents at the top of each hot leg, the letdown line off of one of the cold legs, the high pressure injection (HPI) line into each of the cold leg pump discharges, and the pressurizer spray line off of one of the cold leg pump discharges. In addition there are many penetrations for RCS instrumentation such as temperature, pressure, and flow.

The high point of the primary system is located at the bend of the hot leg, before the pipe enters the SGs. This bend is commonly referred to as the "U-bend" or "candy cane." This feature is different from the Westinghouse and Combustion Engineering PWR design, in which the high point in the primary system loop is located at the top of the SG tubes.

2.1.2.4 Reactor Coolant Pumps

Each unit has four RCPs. Unit One has Westinghouse Model 93A pumps, while Units 2 and 3 have Bingham Type RQV pumps. Both types are centrifugal pumps which operate at a constant speed, and both utilize 9000 hp Westinghouse motors. The hydraulic characteristics of the pumps are similar, but the Bingham pumps provide approximately 5% more flow. The Westinghouse pump seals are a hydraulic controlled-leakage design, while the Bingham pumps use mechanical seals.

The units are designed for operation with fewer than four pumps operating. With three pumps operating the maximum power level is 75%. Power operation with two inactive pumps is prohibited.

2.1.2.5 Steam Generators

The two once-through SGs provide for energy removal from the primary system. The primary side of a SG consists of the upper head, the upper tubesheet, the tubes, the lower tubesheet, and the lower head. Primary coolant enters the SG upper head through a nozzle connected to the hot leg piping. The coolant flows down through the 52 foot long SG tubes into the SG lower head. Two nozzles connect the lower head to the cold legs. The SG upper and lower heads are made of carbon steel clad with stainless steel. The tubesheets are also carbon steel.

The Inconel-600 tubes are fixed at the upper and lower ends by the two foot thick tubesheets, which separate the primary and secondary sides. There are approximately 15,500 tubes per SG, each with a nominal OD of 5/8 inches and a thickness of 0.034 inches. A diagram of a once-through SG is shown on Figure 2.1-6.

2.1.2.6 Pressurizer

The pressurizer is a vertical cylindrical vessel with hemispherical upper and lower heads. A surge line penetrates the bottom of the pressurizer and connects it to one of the hot legs. The pressurizer maintains and controls RCS pressure and provides a steam surge volume and liquid water reserve to compensate for changes in reactor coolant density and inventory during operation. A diagram of the pressurizer is shown on Figure 2.1-7.

There are four banks of electric heaters in the lower region of the pressurizer, with a total capacity of 1638 kW. These heaters make up for ambient heat losses during normal operation and restore pressure during operational transients. There is an interlock which turns the heaters off on low pressurizer level, preventing them from being damaged due to uncover.

The 2 1/2 inch pressurizer spray line connects one of the cold leg pump discharges to the pressurizer spray nozzle which is located at the top of the steam space. The spray valve opens when RCS pressure exceeds 2205 psig, providing approximately [] gpm of colder water to the top of the pressurizer where it condenses steam, thus reducing pressure.

The pressurizer pilot-operated relief valve (PORV) is a 1-3/32 inch Dresser relief valve located near the top of the pressurizer. The valve has a 100,000 lbm/hr steam relief capability, and it opens when RCS pressure exceeds 2450 psig.

The pressurizer code safety relief valves are 1.8 inch Dresser valves which also relieve fluid from the top of the pressurizer. The total rated relief capacity of both valves is greater than 630,000 lbm/hr steam. These spring-loaded valves are set to relieve at 2500 psig.

2.1.2.7 Makeup and Letdown

Normal makeup at Oconee is provided by a HPI pump drawing water from the letdown storage tank. A control valve in the injection line modulates to control pressurizer level at the setpoint, which is normally 220 inches. The maximum makeup capacity through this flowpath is approximately [] gpm at nominal system pressure. The makeup capacity can be augmented by starting a parallel HPI pump, opening the Engineered Safeguards injection valve which is parallel to the makeup control valve, or both. Makeup water is injected into the A1 and A2 cold leg pump discharge piping. The HPI System, both normal and emergency functions, is shown on Figure 2.1-8.

A small amount of makeup is also provided by RCP seal injection. Approximately 8 gpm is pumped into the seals of each pump, most of which enters the primary system, and the remainder of which returns via the seal leakoff pathway to the letdown storage tank. Seal injection is provided by the same HPI pump which furnishes normal makeup. If seal injection flow is low, then a second HPI pump is automatically started in order to restore an adequate flow rate.

Letdown is taken from the B1 cold leg pump suction piping through coolers and demineralizers to the letdown storage tank. Normal letdown flow is approximately 70 gpm. After reactor trip, the operators isolate letdown in order to minimize the decrease in pressurizer level which occurs as the reactor coolant cools and contracts.

2.1.2.8 Instrumentation

A large number of instruments monitor the primary system in order to provide information to the operators, inputs to the plant control systems, and signals for the actuation of the RPS and the ESS. Core instrumentation includes neutron power indication (ionization chambers), self-powered incore neutron detectors, and core-exit thermocouples. RCS temperatures are measured by resistance temperature detectors (RTDs) near the top of the hot leg and in the cold

leg pump suction. Loop flow is measured by a Gentile ΔP device in each hot leg. Pressure is measured by pressure taps in each hot leg. The pressurizer contains water level, pressure, and water temperature instruments. In addition, inadequate core cooling instrumentation includes a level measurement for each hot leg and in the reactor vessel (above the level of the bottom of the hot leg). The subcooling margin in each loop and at the core exit is also displayed for operator guidance.

2.1.3 Secondary System

Oconee uses a regenerative-reheat Rankine cycle to convert the thermal energy produced in the reactor core to electric power. Energy is removed from the primary system in the SGs, where feedwater is boiled and then superheated. The steam is exhausted through a high pressure turbine, moisture separator-reheaters, and three low pressure turbines to the condensers. Hotwell pumps take suction from the condenser hotwells and discharge to the condensate booster pumps. After the condensate booster pumps, the condensate passes through the F, E, D, and C feedwater heaters to the suction of the steam-driven MFW pumps. The MFW pumps discharge through the B and A feedwater heaters to the SGs.

2.1.3.1 Steam Generators

The SGs remove energy from the primary system during normal operation, at hot shutdown, and between Decay Heat Removal System conditions (less than 250°F) and hot shutdown. A typical generator is shown on Figure 2.1-6. At full power 5.4 million lbm/hr feedwater enters each SG downcomer through an external feedwater ring which contains 32 MFW nozzles. The downcomer consists of the annular section in the lower part of the SG which is separated from the SG shell region by a baffle plate. The downcomer is open to the SG shell at the aspirator port at the top of the downcomer, and through the water ports at bottom. The condensing action of the relatively cold MFW draws steam from the shell through the aspirator port, and this steam preheats the feedwater from approximately 460°F to near saturation (535°F) at the bottom of the downcomer. The feedwater enters the shell region through the water ports and flows vertically upward. Heat from the primary system boils the feedwater as it rises, and the quality approaches 1.0 approximately halfway up the generator. In the upper portion of the generator the steam is superheated to 590-595°F, close to the primary inlet temperature of 602°F. At the top of the SG the steam flows radially outward through the gap between the baffle and the upper tubesheet, and then downward through the steam outlet annulus. Two 26 inch OD lines exit the steam outlet annulus near the midsection of the generator, and those lines join into the 36 inch OD main steam

line which goes to the high pressure turbine. The nominal SG outlet pressure at full power operation is 910 psig.

Fifteen tube support plates provide structural support for the SG tubes. These plates are distributed axially along the generator at approximately 3 foot intervals. The plates have broached holes at the tubes to allow steam to pass, but they still represent a significant constriction to the flow. Each generator has a lane without tubes extending radially from the middle to the edge. This lane allows some of the interior tubes to be inspected. In addition, there is a small untubed region in the center of the generator. The height of the SG secondary side is 52 feet.

The effective heat transfer area in a once-through SG is directly proportional to the SG level, since the nucleate boiling heat transfer that takes place in the lower, two-phase region is much greater than the heat transfer to single-phase steam which occurs in the upper part of the SG. During normal operation there is no SG level control (except for low level and high level limits); instead, the plant ICS directs the MFW System to provide adequate feedwater to remove the energy produced in the primary system. As primary power goes up, the required heat transfer area is greater, so the SG level increases. At low power the level is maintained at the low level limit (31 inches above the lower tubesheet). At full power operation the level can go as high as 385 inches, or 60% of the total tube length. The high level limit prevents the indicated level from reaching the elevation of the aspirator ports, ensuring that adequate preheating of feedwater in the downcomer can occur.

The elevations of the top and bottom of the reactor core are 57 inches and 198 inches, respectively, above the lower tubesheet of the SG. In order to promote stable natural circulation flow, the thermal center for heat removal must be above the thermal center for heat addition to the primary system. Therefore, during a loss of forced primary system flow, the required SG level automatically increases to 248 inches above the lower tubesheet, ensuring an adequate level for natural circulation flow.

The SGs have penetrations to allow EFW to be injected on the upper portion of the tubes. EFW flows through an external feedwater header, which contains six active nozzles, onto the periphery of the SG tube bundle. The injection elevation is very close to the upper tube sheet. This high elevation injection location is preferred for situations where forced flow is lost in the primary system, because it raises the thermal center for heat removal and thus enhances natural circulation flow in the RCS.

2.1.3.2 Main Feedwater

The MFW System consists of the MFW pumps, the A and B feedwater heaters, and the piping and valves between the pumps and the SGs. The MFW pumps have common suction and discharge lines, so neither of the two pumps is aligned to a particular SG. The variable-speed pumps are turbine-driven by either main steam or low pressure steam. The nominal feedwater temperature at the outlet of the A feedwater heaters is 460°F, at a pressure of approximately 1000 psia. MFW flow to each SG is controlled by the MFW control valves.

The feedwater piping at Oconee is very diverse. The MFW system is normally aligned to the MFW header at the top of the downcomer, but it can be realigned to discharge into the emergency feedwater header at the top of the SG. This realignment is automatic when all four RCPs are tripped, or it can be accomplished by the operators. In addition, the EFW System, which normally discharges into the EFW header, can be manually realigned to discharge into the MFW header if the normal flowpath is unavailable.

2.1.3.3 Main Steam

The main steam lines carry the high pressure, high temperature steam from the SGs to the high pressure turbine. Two 26 inch lines exit each SG and join together into a single 36 inch line. The 36 inch line leaves the Reactor Building and runs to the Turbine Building. Near the high pressure turbine the 36 inch line splits into two 24 inch lines, each containing a turbine stop valve. Downstream of the turbine stop valve the lines from each SG join together in the steam chest, which is simply a large pipe that provides pressure equalization. Four lines leave the steam chest to enter the high pressure turbine, and each line contains a turbine control valve. A schematic diagram of this arrangement is shown on Figure 2.1-9.

Process steam is taken off of each steam line in order to power station auxiliaries. These include the auxiliary steam header, the MFW pumps, the turbine-driven EFW pump, the condensate steam air ejectors, and the steam seals. In addition, main steam is used to reheat the steam between the high and low pressure turbines. Various steam drains and traps are also provided on each steam line. Furthermore, main steam relief is provided by eight main steam relief valves (MSRVs), two turbine bypass valves (TBVs), and one manual atmospheric dump valve per steam line.

The MSRVs provide overpressure protection to the steam lines and SGs. The valve opening setpoints range between 1050 and 1104 psig, and the total relief capacity through the valves is

greater than the nominal full power steam flow rate. The TBVs control steam pressure prior to putting the turbine online and after turbine trip. The four valves (two per steam line) have a total capacity of 25% nominal full power steam flow. The atmospheric dump valves provide the capability for main steam relief in the unlikely event that the TBVs are inoperable and SG depressurization below the main steam relief valve reseal setpoint is required.

Steam line isolation is accomplished by the turbine stop valves, which close automatically upon a turbine trip. However, all penetrations for process steam and steam relief are upstream of the turbine stop valves, so each penetration must be closed individually if complete steam generator isolation is required.

2.1.3.4 Turbine-Generator

The turbine-generator converts the thermal energy of steam produced in the SGs into mechanical shaft power and then into electrical energy. The turbine-generator of each unit consists of a tandem (single shaft) arrangement of a double-flow high pressure turbine and three identical double-flow low pressure turbines driving a direct-coupled generator at 1800 rpm.

Turbine-generator functions under normal and abnormal conditions are monitored and controlled automatically by the Turbine Control System (TCS), which includes redundant mechanical and electrical trip devices to prevent excessive overspeed of the turbine-generator. Once the turbine is brought online (at 15%-20% rated power), the turbine control valves maintain the steam line pressure immediately upstream of the stop valves at 885 psig during steady-state operation. The pressure setpoint can be biased by the ICS to accommodate load changes and unanticipated operational transients. The turbine stop valves close rapidly to preclude turbine damage after the receipt of a turbine trip signal.

2.1.3.5 Instrumentation

A wide variety of secondary system instrumentation is available to the operators. Many of the indications are also used as inputs to the ICS. Pressure is available at the MFW pump discharge, the SG outlet, and the steam line upstream of the turbine. Fluid temperature is indicated in each part of the MFW System, the SG downcomer, the steam generator outlet, and the inlet of the turbine. Feedwater flow is available over a low range (0-1 million lbm/hr) and a high range (0-6 million lbm/hr) for both SGs. Four different SG level indications - startup range, extended startup range, power range, and full range - are provided, with the ranges indicated on Figure 2.1-10.

The SG level instruments are ΔP devices, with the taps located at various elevations in the downcomer and shell. ΔP devices measure the weight of fluid between two taps, not the actual mixture or froth level of a fluid. The void fraction in the SG changes from 0 to 1 over most of the height of the generator, and there is really no precise transition between liquid water and steam. In addition, the ΔP between two taps is composed of two components: gravitational (the weight of the fluid between the taps) and frictional (the pressure drop caused by irrecoverable hydraulic losses in the fluid and between the fluid and the steam generator components). The frictional ΔP increases with fluid velocity, and is a significant fraction of the total pressure drop at high flow, high power conditions. Furthermore, the frictional component changes over the life of the plant due to fouling of the SG tubes and the tube support plates. It should also be noted that the operating range level indication is temperature compensated, while the other three ranges are not. Temperature compensation adjusts the level indication to account for the fact that while the instrument is calibrated at cold conditions, the fluid is much hotter and much less dense at power operation. Therefore, the ranges that are not temperature compensated indicate a collapsed liquid level that is approximately 30% too low at hot conditions.

The various level ranges are used for distinct purposes. The startup range is used for monitoring and control at zero or low power conditions, when the water inventory is low and the level is close to the lower tubesheet. The extended startup range is safety-grade and is used for automatic control of EFW. The operate range covers the middle portion of the SG and is used during power operation, when the SGs have a significant water inventory. The full range covers the entire height of the SG, and it is primarily used for evolutions which take place while shutdown, such as wet layup.

2.1.4 Control Systems

Nuclear plants include a large number of control systems which monitor and adjust the performance of individual components and systems. In this section the control systems which have a major effect on the overall transient response of the plant are discussed.

2.1.4.1 Non-Nuclear Instrumentation

The major function of Non-Nuclear Instrumentation (NNI) is to monitor process variables in the RCS and the secondary side of the plant. NNI also performs the control functions of RCS makeup and RCS pressure control. The control features of NNI are discussed in this section.

NNI controls RCS makeup flow by throttling the makeup control valve to maintain the pressurizer level at the setpoint, which is normally 220 inches. The makeup control flowpath is a 2-1/2 inch line around the normally closed 4 inch emergency injection control valve. The makeup capacity through this flowpath is approximately [] gpm at system pressure. A proportional plus integral (PI) controller adjusts makeup flow to compensate for changes in RCS inventory or density. After reactor trip the reactor coolant contracts, causing a sharp drop in pressurizer level. Normal makeup control is unable to quickly compensate for this drop, and operator action is usually taken to increase makeup by opening the emergency injection control valve.

NNI also controls RCS pressure through the pressurizer heaters, spray, and PORV. There are four banks of pressurizer heaters which compensate for ambient heat loss in steady-state operation and restore system pressure following reactor trip. The 126 kW control bank operates on PI control to maintain RCS pressure at the setpoint, which is normally 2155 psig. These heaters are usually partially energized to make up for ambient heat loss and condensation due to the small amount of pressurizer spray bypass flow. The three backup banks, with a total capacity of 1386 kW, have on-off control with staggered initiation setpoints of 2130 psig, 2115 psig, and 2100 psig. They are generally off, except following reactor trip when the large pressurizer outsurge causes a sharp decrease in RCS pressure. There is an interlock which removes power from the heaters when pressurizer level decreases below 80 inches. The interlock prevents the heaters from being uncovered while they are energized.

The pressurizer spray is used to reduce RCS pressure during operational transients. The spray is controlled by a solenoid valve in the 2 1/2 inch pressurizer spray line. When open, it allows the relatively cold water from the RCP discharge to flow into the top of the pressurizer, where it condenses steam and thus acts to reduce pressure. The valve opens when RCS pressure exceeds 2205 psig and closes when pressure drops below 2155 psig. The nominal spray valve capacity is [] gpm. In addition, there is a 1/2 inch bypass flowpath around the spray valve which allows a constant flow of 1-10 gpm through the spray line. The bypass flow keeps the spray nozzle at a constant temperature, precluding thermal shock to the nozzle when the main spray valve opens.

NNI controls the action of the pressurizer PORV. The PORV opens to relieve fluid to the pressurizer quench tank when RCS pressure exceeds 2450 psig, and it reseats when pressure goes below 2400 psig. The valve design capacity is 100,000 lbm/hr steam at 2300 psig. The lift setpoint used to be lower than the high RCS pressure reactor trip setpoint in order to help to prevent reactor trips during overpressure transients. However, after the Three Mile Island Unit 2 accident in 1979 the PORV lift setpoint was raised to be higher than the reactor trip setpoint.

The primary automatic functions of the PORV now are to prevent challenging the pressurizer code safety valves and to provide low temperature overpressure protection.

2.1.4.2 Turbine Control System

The TCS adjusts the position of the turbine control valves to maintain the turbine header pressure at the control setpoint (normally 885 psig). There are four turbine control valves in parallel, and they move sequentially rather than all at once. Normally the turbine control valves are opened to put the turbine on line at approximately 15% power. At lower power levels the Turbine Bypass System (TBS) controls steam pressure.

2.1.4.3 Integrated Control System

The ICS provides the proper coordination of the reactor, feedwater, and turbine during normal operation and anticipated transients. The ICS maintains the proper conditions during steady-state operation by balancing power production and heat removal. The feed-forward and feedback features of the ICS make the units capable of smooth, responsive changes in load. The ICS is also designed to enable the units to withstand certain transients (e.g. RCP trip, MFW pump trip) without tripping the reactor. ICS feedwater control and turbine bypass control also influence unit behavior following reactor trip.

B&W plants are generally considered to be more sensitive than other PWRs to secondary system perturbations. This is due to the relatively low secondary inventory and variable effective heat transfer that is characteristic of the once-through SG. Thus an effective control system is necessary for the reliable operation of a B&W plant. At the same time the responsiveness of the units makes it possible to rapidly adjust load and prevent unnecessary reactor trips.

The plant can be operated in the integrated, reactor-following, or turbine-following modes. In reactor-following mode, load changes are accomplished by changing steam flow, and the rest of the plant adjusts to the change by controlling steam pressure at the setpoint. In a turbine-following system, the overall power is changed by altering reactor power, and the turbine changes its output by controlling steam pressure at the setpoint. The integrated mode combines the advantages of the other two modes by incorporating feed-forward features which provide rapid load response and stable steam pressure control. The ICS functioning in the integrated mode is the normal operating mode at Oconee.

A complete description of the ICS would be prohibitively involved for this report. Instead, a functional description of the system is provided, focusing on the four subsystems of the ICS - unit load demand (ULD), integrated master, reactor control, and feedwater control.

Core Thermal Power Demand

The CTPD produces the demand signal for the turbine, reactor, and MFW. This is based on the demand for core thermal power. Since the Oconee units are currently operated in a base-loaded mode, that demand is usually 100% of the maximum core thermal power level. The unit operators change the CTPD to start up or shut down the plant and to perform planned power maneuvers. In addition, the CTPD will be automatically limited by any of the following conditions: loss of one or more RCPs, a 5% mismatch between feedwater flow and feedwater demand, a 5% mismatch between reactor power and power demand, loss of one feedwater pump, an asymmetric rod pattern in the reactor core, and a loss of load. This automatic feature increases the chance of withstanding one of these transients without sustaining a reactor trip by limiting the demand to the available capability of the unit.

Integrated Master

The integrated master controls the turbine header pressure setpoint to match generated megawatts with the core thermal power demand. The setpoint is 885 psig in steady-state, and it is adjusted during power maneuvers by the feed-forward features of the ICS. The integrated master also controls the TBVs both before and after reactor trip. Before reactor trip, the bypass valves provide steam pressure control prior to putting the turbine on line, and they furnish steam overpressure relief during transients. After reactor trip, the TBVs control steam pressure to 1010 psig, thus maintaining the RCS at approximately 550°F.

The integrated master also contains a feed-forward feature. In the integrated master the core thermal power demand signal is modified by the turbine header pressure error before being passed along to the SG and reactor subsystems. This provides for a quicker and smoother response to load changes.

Reactor Control

The reactor control subsystem is designed to maintain a constant average coolant temperature between 15% power and 100% power. The load demand signal from the Integrated Master is adjusted by the error between T-ave and the setpoint (normally 579°F) to give a reactor demand. When the indicated reactor power is outside a 1% deadband, the control rods are moved to adjust power to the setpoint.

Feedwater Control

The feedwater subsystem (also known as the SG subsystem) is designed to maintain MFW flow equal to the feedwater demand from the integrated master, maintain the proper feedwater ratio between the two SGs, and maintain the SG levels between the maximum and minimum levels. Adjustments to feedwater flow are made by varying the position of the feedwater flow control valves. The feedwater pump speed is controlled to maintain a constant feedwater control valve ΔP ; therefore, the pump speed will also change with feedwater flow. Feedwater is ratioed between the SGs by a circuit which controls the difference in primary system cold leg temperatures to a setpoint (usually zero). The feedwater demand to each generator is modified to prevent the indicated level from exceeding the maximum (95% on the operate range) or the minimum (25 inches on the startup range). An additional feature of the ICS is the cross-limits, which act to keep the RCS heat addition and heat removal at consistent values. The feedwater-to-reactor cross limit adjusts reactor demand down if the indicated feedwater flow drops significantly below the feedwater demand. The reactor-to-feedwater cross limit adjusts feedwater demand up or down if the reactor power is significantly higher or lower than the reactor demand. The cross limits minimize the severity of operational upsets. After reactor trip the CTPD setpoint is stepped down to zero, rapidly decreasing feedwater to be consistent with the low decay heat power levels.

2.1.5 Safety Systems

Various systems are required to ensure that the plant does not exceed its licensed limits during design basis transients. The major safety-related systems which affect the plant transient response are discussed in this section.

2.1.5.1 Reactor Protective System

The RPS monitors parameters related to safe operation of the core and trips the reactor to protect against fuel and cladding damage. In addition, by tripping the reactor and limiting the energy input into the coolant, the RPS protects against RCS structural damage caused by high pressure. A two out of four logic scheme is used to sense a trip condition. When any two protective channels trip, power is removed to the control rod drives of the safety rods (control rod banks 1-4) and the regulating rods (control rod banks 5-7). These rods fall into the reactor core and shut down the nuclear chain reaction.

The RPS will initiate a reactor trip on the following conditions:

- 1) High power (neutron flux)
- 2) High flux/flow ratio - the combination of reactor power, reactor coolant flow, and imbalance (a measure of axial flux asymmetry) exceeds the allowable limit
- 3) Pump monitor - the reactor power exceeds the allowable limit determined by the number of RCPs in operation
- 4) High hot leg temperature
- 5) Variable low pressure - the combination of RCS pressure and hot leg temperature is outside the allowable range
- 6) High RCS pressure
- 7) Low RCS pressure
- 8) High Reactor Building pressure
- 9) Both MFW pumps tripped
- 10) Main turbine trip with reactor power >20%

The latter two trips are anticipatory functions which were added after the TMI-2 accident. They do not provide direct protection against exceeding a safety limit, but for many transients they will trip the reactor before a high RCS pressure trip is required. The high Reactor Building pressure trip also does not perform a direct safety function. It is a backup for the low RCS pressure trip that would be expected following a loss of coolant accident (LOCA).

2.1.5.2 Engineered Safeguards System

The ESS is designed to provide borated water injection into the RCS and containment cooling to mitigate a LOCA. The system will also provide injection in the event of a significant depressurization caused by excessive primary-to-secondary heat transfer, such as a steam line break. In addition, the ESS will accomplish containment isolation and cooling and penetration room ventilation during an accident situation. The constituents of the ESS are discussed below.

High Pressure Injection System

The HPI System consists of three pumps which take suction from the borated water storage tank (BWST) and inject water into each RCS cold leg pump discharge pipe. The A and B pumps are in parallel and inject water into the A loop of the RCS; the C pump injects into the B loop. One pump through either train will deliver at least [] gpm at normal system pressure (2155 psig). In normal operation either the A or B pump runs to provide RCS makeup and RCP seal injection. All three HPI pumps receive start signals on low RCS pressure (<1600 psig) or high Reactor

Building pressure (4 psig). The same signal automatically switches the suction source from the letdown storage tank to the BWST, and opens the emergency injection valves.

Core Flooding System

The Core Flooding System is a passive part of the Emergency Core Cooling System that performs no function in normal operation. The system consists of two core flood tanks (CFTs), each of which are connected to the reactor vessel by an injection line. The tanks are pressurized to 600 psig by nitrogen. Each 1410 ft tank contains 1040 ft of borated water which, following a large break LOCA, is discharged into the reactor vessel. Each injection line contains two check valves which isolate the tanks from system pressure during normal operation, but open to allow flow during a design basis accident.

In addition to large break LOCAs, the CFTs will inject water into the RCS during any major depressurization event. This includes large steam line breaks and some small break LOCAs.

Low Pressure Injection System

The Low Pressure Injection (LPI) System consists of two pumps which take suction from the BWST and inject water into the reactor vessel downcomer through the core flood tank lines. In normal operation the LPI pumps are idle; they receive a start signal on low RCS pressure (<500 psig) or high Reactor Building pressure (>4 psig). The same signal opens the suction valves from the BWST and the discharge valves to the RCS. Due to the low discharge head of the LPI pumps, they do not actually deliver flow until the RCS pressure is much lower than 500 psig. The pumps have a capacity of 3000 gpm with a discharge head of 150 psi. The LPI System, like the HPI System, is comprised of two separate and independent trains.

Following depletion of the BWST inventory, the LPI pumps can be manually realigned to take suction from the Reactor Building sump. In this mode the injection water is cooled by an LPI cooler in each discharge line.

There is a spare LPI pump in parallel with the other two at each unit. The spare pump performs no ESS function. In addition to their accident mitigation function, the LPI pumps and coolers provide shutdown decay heat removal when the RCS is below 250°F and the SGs are no longer active.

Containment Systems

The other constituents of the Engineered Safeguards Systems are the Reactor Building Cooling System, the Penetration Room Ventilation System, and the Reactor Building Isolation System.

These systems do not have a major impact on the RCS transient response, and thus are not described in detail in this report.

2.1.5.3 Emergency Feedwater System

The EFW System is designed to provide feedwater to the SGs in the event of a complete loss of MFW. The capacity of the system is adequate to remove decay heat and stored energy from the primary system in either forced or natural circulation modes. If necessary, the EFW System will provide feedwater sufficient to enable cooldown from power operation to cold shutdown. A simplified schematic diagram of the system is shown on Figure 2.1-11.

The EFW System consists of two motor-driven and one turbine-driven pump per unit. The turbine-driven pump feeds both SGs, while each of the motor-driven pumps is aligned to one SG. The capacity of the turbine-driven pump is approximately twice that of a motor-driven pump, and only one motor-driven pump is required to mitigate a loss of MFW event. All three pumps take suction from the upper surge tanks which contain at least 30,000 gallons of feedwater at approximately 90°F. Suction can also be taken from the condenser hotwell, which contains in excess of 100,000 gallons. All three pumps receive a start signal following a loss of MFW pumps as indicated by low MFW pump turbine hydraulic control oil pressure. The two motor-driven pumps also start on low steam generator level. The pumps discharge into one injection line per SG. A flow control valve in each line automatically controls the flow to each SG to maintain a constant level. The level setpoint automatically varies between 25 inches on the startup range if the RCPs are on and 242 inches on the startup range (50% on the operate range) if the RCPs are off. The operators can also take manual control of the system.

EFW discharges into the SGs through the EFW header near the top of the shell region. When the RCS is in forced circulation mode, the cold EFW travels down the length of the tubes (approximately 50 feet) to build up a 31 inch pool in the bottom of the generator. This results in more effective heat transfer than the normal post-trip situation, in which the much hotter MFW enters the generator through the MFW nozzles and flows down the downcomer rather than the SG tubes. The upper injection location also enhances natural circulation by raising the thermal center for heat removal toward the top of the steam generator.

2.1.5.4 Automatic Feedwater Isolation System

The Automatic Feedwater Isolation System (AFIS) uses low steam generator outlet pressure and turbine header pressure as the initiating parameter for automatic MFW isolation. Both MFW

pumps are tripped, but the MFW valves close only to a steam generator with a low pressure condition. The turbine-driven EFW pump is stopped. The motor-driven EFW pump to each steam generator is stopped if the depressurization rate in that steam generator exceeds the setpoint, and the low pressure MFW isolation has occurred. Thus, the AFIS design includes automatic isolation of MFW and EFW flow to a depressurizing steam generator.

2.1.6 Dissimilarities Between Units

All three Oconee units are similar, but some differences in components and configurations do exist. The primary systems are essentially identical, while the balance of plant systems tend to differ, although not usually in function as much as in form.

The major difference between units in the primary system is the RCPs. Unit 1 has Westinghouse pumps, while Units 2 and 3 have Bingham pumps. Although the piping configuration is somewhat different in the cold legs, there is no significant difference in overall primary system volume. The Bingham pumps provide slightly more flow than the Westinghouse pumps.

The pressurizer location varies between units. The pressurizer is on Loop A at Unit 1, while it is on Loop B at Units 2 and 3. Similarly, the pressurizer spray line is attached to the A1 cold leg pump discharge pipe of Unit 1 and the B1 pipe of Units 2 and 3.

There can be both mechanical and nuclear differences between the reactor cores of the three units. Fuel assembly design changes are implemented from time to time to enhance fuel performance. These changes can have an impact on the characteristics of the core. Oconee currently uses Mk-B10 and Mk-B11 fuel assemblies, with Mk-B11 being loaded. Refer to Appendix A for a description of Mk-B11 fuel assemblies. In addition, the number of burnable poison assemblies in the core varies between unit and cycle, and this parameter has a small effect on core bypass flow. Furthermore, the nuclear characteristics of each core vary somewhat between cycle and unit, so parameters such as moderator coefficient, Doppler coefficient, and control rod worth will change.

The maximum available HPI flow varies slightly between units. The differences are attributable to piping dissimilarities and variations in performance between HPI pumps.

There are several noticeable differences between the Oconee SGs. The generators of Units 1 and 2 incorporate an external EFW header, while the Unit 3 generators had an external header added in 1982. The internal headers at Unit 3 are still present, but they have been structurally stabilized and hydraulically isolated from the EFW System. In addition, the B generator of Unit 3 has an additional 73 tubes that were inadvertently left out of the inspection lane during fabrication. As a result of the additional carryover in the lane, the steam outlet temperature from this generator is only 570°F, as opposed to 590-595°F in the other generators at full power. Furthermore, the number of tubes plugged varies between all six generators.

As with HPI flow, the maximum available EFW flow is slightly different for each unit and each SG. The differences are due in part to dissimilarities in piping layout and pump performance, and also to the fact that the motor-driven EFW pumps of Unit 1 are of a slightly different design than those of Units 2 and 3. The turbine-driven EFW pumps are the same model for all three units.

The MFW and main steam piping are different between each unit and each SG. These differences are due to variations in balance of plant layout.

(Pages 2-20 to 2-22 intentionally deleted)

Oconee Reactor Coolant System Schematic





Figure 2.1-1

Figure 2.1-2

Ocone Reactor Vessel





Ocone Reactor Vessel Vent Valves



Figure 2.1-4

Oconee Reactor Coolant Piping






Figure 2.1-6

Oconee Once-Through Steam Generator




Figure 2.1-7

Ocone Pressurizer





Figure 2.1-8

Oconee HPI System Simplified Schematic



HP-26 Emergency Safeguards flowpath


HP-120 Normal makeup flowpath

☒ Normally open valve


☒ Normally closed valve

Figure 2.1-9

Oconee Main Steam Schematic



Oconee SG Level Instruments



Startup Range: 6-256" Indication, 6-394" Taps

Extended Startup Range: 6-394" Indication and Taps


Operate Range: 0-100% Indication Over 102-394" Range and Taps

Full Range: 6-648" Indication and Taps

Figure 2.1-10

Figure 2.1-11

Oconee EFW System Simplified Schematic



FDW-315 SG A flow control valve

FDW-316 SG B flow control valve

Normally open valve

Normally closed valve

Check valve

MD Motor-driven

TD Turbine-driven

2.2 Oconee RETRAN Model

The complete two loop, four cold leg Oconee RETRAN model nodalization is shown on Figure 2.2-1. The model is configured like Unit 1, with the pressurizer on the A loop. A one loop model, shown on Figure 2.2-2, is used for transients which exhibit a sufficient amount of symmetry. For certain applications the amount of detail in these nodalizations is excessive and can be reduced to save computer time, while on occasion additional detail is required.

The primary system model is symmetric relative to the two loops. The A loop components (volumes, junctions, and conductors) are assigned a 100 series number. The B loop component numbering scheme is the same, except that they are assigned a 200 series number. Thus Volume 113 is identical to Volume 213, except that the former is in the A loop and the latter in the B loop.

2.2.1 Primary System Nodalization

2.2.1.1 Reactor Vessel

The reactor vessel is modeled by [] fluid volumes. The boundaries between the volumes are chosen due to actual physical separations, or to provide an additional level of detail in the hydrodynamic calculation.

Downcomer

[]
to the cold legs. Flow enters through the four cold legs and exits into the lower plenum.]

Lower Plenum

The reactor vessel lower plenum is represented by []
]. Flow from the downcomer goes through the lower plenum into the core.

Core

[] represent the reactor core region from the []
] There is no physical separation between []
]. Flow enters from the lower

plenum and discharges into the upper plenum. The [] to provide a more accurate simulation of the temperature profile in the core at power.

The core bypass region is modeled by [] The bypass flow channels include the control rod guide tubes and instrument tubes inside the fuel assemblies, as well as the area between the core baffle plate and the core barrel which is exterior to the fuel assemblies. All of the bypass constituents are []. The control rods are assumed to be [] Flow enters the bypass from the lower plenum and exits into the upper plenum.

Upper Plenum

The upper plenum of the reactor vessel, which extends from the [] In the upper plenum the coolant flows upward from the core and then turns radially outward to leave the vessel through the outlet annulus. Some of this flow goes through a series of small holes in the plenum cylinder (the plate which separates the upper plenum from the outlet annulus). The majority of the flow continues upward and then goes through a set of larger holes which are also in the plenum cylinder, but at a higher elevation. The upper plenum is [] into the outlet annulus. There is [] Another flowpath involving the upper plenum is the one between the lower portion of the upper plenum, just above the active fuel, and the control rod guide assemblies. Some flow goes through the guide assemblies into the vessel head.

Control Rod Guide Assemblies

The 69 control rod guide assemblies, [] in the RETRAN model, extend from the top of the core through the plenum cover and discharge into the reactor vessel upper head. Some flow enters the guide assemblies through holes located just above the top of the core, while the rest of the flow comes directly from the fuel assemblies and the control rod guide tubes. Due to modeling limitations, in the model the flow enters the control rod guide assemblies from the lower upper plenum volume.

Upper Head

The reactor vessel upper head is a large cylindrical and hemispherical region which extends between the upper plenum and the vessel head itself. It is modeled by RETRAN [] Flow enters the region through the control rod guide assemblies which penetrate the plenum cover. There is a circumferential gap between the plenum cover and the vessel shell through

which flow leaves the upper head and enters the outlet annulus. The only structural components in the interior of the upper head are parts of the Control Rod Drive System.

Outlet Annulus

The outlet annulus, the annular region between the plenum cylinder and the core support shield, is represented by [

] before exiting the vessel through the hot leg nozzles.

[] the outlet annulus to the downcomer. [] of the eight reactor vessel vent valves, which provide internal vessel circulation under low flow conditions.

[]

2.2.1.2 Reactor Coolant Loops

[] to represent the hot and cold leg piping. In addition, [] to model each RCP. The volumes in the A loop are discussed here and are identical to the corresponding volumes in the B loop.

[]

[] represent the SG outlet piping to the RCPs. []

] by the RETRAN centrifugal pump model. The pump discharge piping is simulated by []. Each extends outward from the pump, bends down a slight amount, and runs horizontally into the reactor vessel. The vessel inlet nozzles []

2.2.1.3 Steam Generators

The SG upper head is modeled by []. The 52 foot length of the SG tubes is represented by []. The detailed nodalization allows an accurate simulation of the SG density gradient, which is an especially important consideration during natural

circulation. The RETRAN [

head [] A nominal value for the number of tubes plugged (1%) is assumed. The SG lower
[] is similar to the upper head. As with the upper head, the fluid volume in the
[]

2.2.1.4 Pressurizer

The Oconee pressurizer is represented by [] connect it to the RCS.
[] which runs between the bottom of the pressurizer to the A hot
leg. The hydraulic losses associated with the surge line []
models the pressurizer spray line which connects one of the cold leg pump discharge volumes to
the top of the pressurizer. The loss coefficient associated with []
[] The PORV and safety valve junctions are modeled at the top of the
pressurizer.

Phase separation in the pressurizer is simulated by the [

[] In some cases []
[] between the liquid and vapor regions.

2.2.1.5 Core Flood Tanks

The two CFTs and their associated injection lines are [] The RETRAN air
model is used to simulate the nitrogen overpressure in the tanks. [] allows the tanks to
discharge when the RCS pressure drops below 600 psig.

2.2.2 Secondary System Nodalization

2.2.2.1 Main Feedwater Lines

[] represents the MFW lines between the [] and the SGs. Fluid
volume and piping elevations are conserved, but the detail of the piping run is not included. The
loss coefficient of the []

2.2.2.2 Steam Generators

The SG downcomer is modeled by Volume [

] in the downcomer, with a steam-liquid mixture near the top, and essentially saturated liquid at the bottom. [] represents the aspirator ports, which provide a recirculation flowpath for saturated steam to preheat the feedwater. [] represents the water ports, through which feedwater flows into the SG shell.

[] RETRAN volumes are used to simulate the shell side next to the SG tubes. The bottom [

] around the elevation of the normal post-trip SG level setpoint.

The RETRAN [], to assist in providing a good full power initialization.

Emergency feedwater injection is modeled [

] near the top of the tubes. This approach is taken to [

] to the bottom of the SG.

The steam outlet annulus is usually [

]

2.2.2.3 Main Steam Lines

Volume 134 includes the steam outlet annulus and the main steam piping between the SG and the turbine stop valves. The total volume is conserved, but there is no attempt to completely model the bends, flowpaths, etc., which make up the main steam lines. The loss coefficient of the SG outlet (Junction 138) is adjusted to give the nominal 25 psi pressure drop between the SG and the high pressure turbine. Junction 139 represents the flow to the high pressure turbine. Junction 140 models the steam relief function of the TBVs. The two TBVs on each steam line are lumped into a single junction. Junctions 141-146 simulate the eight MSRVs; the two sets of valves which share a common lift setpoint are lumped together.

2.2.3 Heat Conductor Nodalization

2.2.3.1 Reactor Core

[] are used to model the fuel pins in the reactor core. The conductors are separated into []. Material properties (thermal conductivity and heat capacity) are []. The fuel gap [] to give the [] fuel temperature, which varies with core average burnup. This approach is used to properly account for the stored energy in the fuel. The RETRAN core conductor model is used for these conductors in order to allow power generation in the fuel material. 2.7% of the power generated in the core is assigned to direct heating of the moderator rather than deposition of energy in the fuel pellets.

2.2.3.2 Steam Generators

[] heat conductors are used to represent the tubes in each of the SGs. The [] conductors to represent the remaining length of the tubes. The nominal Inconel-600 heat capacity is used, but the input []

]

2.2.3.3 Structural Conductors

These conductors represent the plant components which do not generate power or conduct heat from the primary to the secondary, but which can affect the plant transient response by transferring energy to or from the working fluid. The stored energy and heat capacitance of these conductors tend to dampen changes in RCS conditions. During an overcooling event the structural conductors transfer heat to the primary coolant and thus retard the cooldown. Conversely, during an overheating transient the structural conductors act as a heat sink and reduce the magnitude of the increase in the primary coolant temperature. The effect of the structural conductors is most apparent during long-term transients. During short transients which do not exhibit severe undercooling or overcooling, the heat transferred from the structural conductors is insignificant relative to the large amount of decay heat in the core. However, the

structural conductors represent a significant heat load for long-term cooldown, once decay heat has decreased.

The key parameters for the structural conductors are the mass and the heat transfer area. These determine the initial stored energy and the effectiveness as a heat sink. In order to [

] structural conductors are modeled as [the coolant. Those structures which are] conductor.

Certain structural components are not included in the model because they are considered to have no potential impact on a plant transient. These components include the [

Passive heat conductors representing the pressurizer walls are included in the Oconee model. The pressurizer vessel metal is [

The conductors which are used in the Oconee base model are listed and described in Table 2.2-1.

2.2.4 Control System Models

2.2.4.1 Process Variable Indications

RETRAN control systems are used to take the calculated plant thermodynamic conditions and put them into the form in which they are output by the plant instrumentation. This provides indications which are useful for comparison to plant data and which are familiar to the plant operators and engineering personnel.

RCS Pressure

The fluid pressure at the elevation of the hot leg pressure tap is converted to gauge pressure by subtracting 14.7 psi. This pressure is an input to RPS and ES functions in the model.

Pressurizer Level

The level indication is derived from the pressure difference between two taps in the pressurizer. The pressure difference is converted to an equivalent water level, which is then converted to a

0-100% reading. A RETRAN control system is used to simulate this process using the [] This level is input to the interlock which turns off the pressurizer heaters on low pressurizer level.

Hot Leg Temperature

The hot leg temperature is indicated by RTDs located in thermowells in the hot leg piping. A change in fluid temperature is not indicated immediately at the plant due to the time required to transfer heat through the thermowell to the RTD and change the temperature of the measuring device. Experimental data indicates that the time delay can be approximated by [] hot leg fluid temperature. A RETRAN control system is used to apply this [] to the hot leg water temperature to obtain the transient temperature response that would be seen at the plant. The output is used in the high temperature and variable low pressure reactor trips.

SG Pressure

In a manner similar to the RCS pressure indication, the fluid pressure at the outlet of the steam generator is adjusted by a RETRAN control system to output pressure in psig. This pressure is used as an input to the TBV controller, the MFW isolation system, and the TCV controller.

SG Level

The operate range SG level instrument displays level from 0-100%, as shown on Figure 2.1-10. The SG extended startup level instrument displays level from 0-388", which corresponds to the 6-394" range shown on Figure 2.1-10. The level indications are derived from the pressure difference between taps in the steam generator. The pressure difference is converted to an equivalent water level, which is also converted to a 0-100% reading for the operate range. RETRAN control systems are used to simulate this process using the [] Neither output level indication performs a control or trip function in the RETRAN base model.

2.2.4.2 Reactor Protective System Functions

Two RPS functions are modeled with control systems - the variable low pressure trip and the flux/flow trip. The variable low pressure trip uses an algebraic relationship to determine whether the indicated RCS pressure and temperature are within the acceptable envelope. The flux/flow trip compares the flux/flow ratio to ensure that the RCS flow is large enough at a given power level to provide adequate heat removal from the core. The plant flux/flow trip also accounts for

the axial flux imbalance, but [

]

2.2.4.3 Plant Control Systems

RETRAN control systems are used to model the performance of the plant control systems during transient analyses. The Oconee model [

]

2.2.4.4 Transient Boundary Conditions

The RETRAN control system models can effectively model known transient boundary conditions, including those produced by automatic plant actions and those resulting from operator action. In general, RETRAN control systems simulate control actions by modulating valves, changing positive or negative fill flow rates, changing reactivity, and activating or defeating trips.

Operator actions can significantly affect the plant response during plant transients. Experience at Oconee has shown that the operators will promptly take action in order to prevent reactor trips or, failing that, to ensure a normal post-trip response. A common response is for the operators to put feedwater control in manual in an attempt to correct a sudden change in feedwater flow following an ICS malfunction. Following a trip, the operators monitor MFW (or EFW) flow to ensure that proper SG level control is maintained. In many cases the operators will also put the

TBVs in manual to control SG pressure. It is also common procedure, following a trip, for the operators to isolate letdown flow and increase makeup flow (by starting another HPI pump, opening an injection valve, or both) in order to more quickly turn around the rapid decrease in pressurizer inventory and restore the normal operating level.

The normal procedure to simulate [

]

2.2.4.5 Reactor Vessel Vent Valves

A RETRAN control system is used to calculate the [] in the reactor vessel vent valves (2.1.2.2). The valve position and frictional loss coefficient as a function of ΔP across the valve are known based on test data. A control system is used to [

] The control system also determines the [

] In normal operation the downcomer pressure is significantly higher than the pressure in the outlet annulus, so the vent valves are closed. It is only after all four reactor coolant pumps are tripped that vent valve flow will occur.

2.2.5 Boundary Condition Models

2.2.5.1 Fill Junctions

Fill junctions are used to specify flow between a volume and an infinite source or sink. Positive fill junctions provide flow into a volume, while negative fill junctions remove mass from a volume. The flow rate can be specified as a function of time or pressure in the volume, or it can be controlled by a control system.

Systems which provide flow to the RCS or the SGs are modeled by []. These include MFW, EFW, and HPI. The flow of steam from the turbine header to the turbine is modeled by a []. For most applications there is a reactor trip at the beginning of the problem, either immediately before or after a turbine trip, so the steam flow to the turbine is cut off. For applications which do not involve a rapid turbine

trip, the flow through the steam line [

]

2.2.5.2 Critical Flow and Time Dependent Volumes

The RETRAN critical flow model, in conjunction with a time dependent volume, is used to model flow through relief valves on the RCS and the main steam lines. Relief valves are modeled by junctions between the associated upstream volumes and a time dependent volume, which is an infinite sink with a user-specified backpressure. The Henry (subcooled) and Moody (saturated) choking option is used with the relief valve junctions. Because of the large pressure differences between the upstream volumes and the time dependent volume, RETRAN calculates any flow through the junctions to be choked. Since the best estimate flow rates of saturated steam through the valves are known, the [

] The choked flow model then

automatically calculates the flow rate as the fluid conditions in the upstream volume change.

This modeling technique is used for the [

]

2.2.6 Code Models

2.2.6.1 Power Generation

RETRAN offers the user several options for modeling core power generation. Several different methods are used, depending on the application. For a best estimate transient analysis, the point kinetics model is generally used. This model calculates neutron power assuming that the flux shape is constant while the magnitude changes with time. The code uses one prompt neutron group and six delayed groups. A moderator temperature coefficient and a fuel temperature coefficient are used to account for reactivity feedback from changes in those parameters. Control rod scram worths are input in order to model reactivity insertion after reactor trip. Post-trip decay heat is calculated with the built-in 1979 ANS Standard (Reference 2-2) decay heat option. Input data for the decay heat model is selected consistent with the application. The point kinetics model is adequate for most PWR applications.

For a benchmark analysis which [

]

[

1

For benchmarks in which [

]

2.2.6.2 Centrifugal Pumps

The RETRAN centrifugal pump model is used to simulate the performance of the RCPs. For benchmark analyses the pump input data is [] for other applications, the flow is typically specified to be 112.5% of 88,000 gpm per pump, and the head is taken to be that of the [

] The two-phase pump performance is simulated through the use of two-phase multipliers and two-phase difference curves developed from CE-EPRI test data (Reference 2-15).

2.2.6.3 Valves

The basic RETRAN valve model is used for most of the valves in the Oconee base model. With this model the valves open and reseal according to the action of their associated trips. Modeled in this manner are the pressurizer spray, PORV, and safety valves; the core flood tank discharge check valves; the turbine stop valves; and the MSRVs. The turbine bypass valves use the RETRAN valve model option in which the junction area is controlled by a control system, which opens or shuts the valves based on SG pressure. The reactor vessel vent valves are also controlled by a control system, with the []

2.2.6.4 Phase Separation

RETRAN has two methods of modeling phase separation within a fluid volume: the bubble rise model and slip. The bubble rise model [] in the Oconee model, while slip [] used.

The bubble rise model is a correlation which allows the enthalpy in a volume to vary with height. It is a semi-empirical fit to data from a number of high pressure blowdown experiments. The void fraction in the volume is assumed to vary linearly with height from the bottom of the volume to the mixture level. Above the mixture level, the fluid is 100% steam. The model is [] which have a definite separation between vapor and liquid, i.e. []. In addition, the bubble rise model is []

Phase separation is not normally expected in the [] because it usually remains in a subcooled state. In some cases, however, voids may develop in the []. The non-equilibrium bubble rise model is []

Slip models provide for unequal velocities between the liquid and vapor phases. Since Oconee is a PWR with subcooled water in the primary coolant loops, unequal phase velocities normally exist only in the steam generator secondary side. RETRAN has two slip models: algebraic slip and dynamic slip. The algebraic slip model uses a drift flux approach to calculating the relative velocity between the vapor and liquid phases, while the dynamic slip model uses a differential equation to determine the inter-phase velocity difference. Current RETRAN development efforts are geared toward improving the dynamic slip model and providing a true two-phase representation of transient fluid behavior. Extensive testing has shown that the current dynamic slip model []

[] in the base model.

For applications in which there is significant voiding and phase separation in the primary system (notably small break LOCA or extended loss of feedwater), the dynamic slip model can provide a reasonable simulation of two-phase phenomena in the RCS. In these instances the dynamic slip option [].

RETRAN has a general non-equilibrium volume option which can be used with any bubble rise volume. This option allows the liquid and vapor regions of the volume to have different temperatures. The [

Accurate modeling of the pressurizer is necessary to correctly predict the transient RCS pressure response. During normal operation the pressurizer is at near equilibrium conditions - heat from the pressurizer heaters balances condensation from pressurizer spray bypass flow and ambient heat losses, so both the liquid and vapor regions of the pressurizer are essentially at saturation. During a pressurizer outsurge, such as that characteristically seen immediately following reactor trip, the pressure decreases as the steam bubble expands. Bulk flashing of the saturated liquid occurs as the pressure decreases, and the temperature in the liquid decreases with the pressure along the saturation line. In both cases the standard RETRAN homogeneous equilibrium model (HEM) technique will adequately simulate pressurizer phenomena.

During a pressurizer insurge, however, non-equilibrium effects can be significant. Subcooled water from the hot leg mixes with the saturated water in the pressurizer liquid region to produce a somewhat subcooled liquid region or, in some cases, a layered effect of saturated water over subcooled liquid. As the liquid level increases the steam bubble compresses and, since the steam behaves like an ideal gas, the temperature increases. The overall result is superheated steam above subcooled liquid, separated by a layer of saturated water. Since the temperature of the steam is higher than both the liquid and the pressurizer walls, the steam will tend to condense on the metal and the steam-water interface, reducing the pressure and temperature of the vapor. A one volume HEM representation of the pressurizer would instantaneously mix the subcooled fluid from the hot leg with all of the saturated fluid in the pressurizer, and it would not account for the different temperatures in the liquid and vapor regions. It is evident that a HEM representation of the pressurizer cannot account for the important phenomena during an insurge.

Use of the non-equilibrium option enhances the ability of a one volume pressurizer model to simulate the transient response during an insurge. Since the liquid region is considered separately from the steam bubble, an insurge does not result in rapid condensation of the pressurizer vapor. The non-equilibrium option allows the steam bubble to superheat during an insurge. The non-equilibrium option also includes the ability to specify a heat transfer coefficient between the pressurizer vapor and liquid regions, so inter-phase heat transfer can be modeled.

However, this model is somewhat non-mechanistic, since the heat transfer coefficient is user-input rather than being calculated based on fluid conditions.

Another facet of the non-equilibrium representation is the pressurizer spray junction model. Using the spray junction option causes the spray water to condense steam while moving through the pressurizer steam bubble, thus removing both energy and mass from the region, rather than simply mixing with the fluid in the vapor region and de-superheating the steam. The spray junction model is used since it is considered to be more mechanistic than a normal junction for this application.

The non-equilibrium pressurizer model is used for best estimate safety analysis for Oconee. This model does not fully account for condensation effects in the pressurizer steam space and thus over-predicts RCS pressure during an insurge. However, it is superior to an equilibrium modeling approach. For some applications it is appropriate to use

]

2.2.6.6 Non-Conducting Heat Exchangers

The RETRAN non-conducting heat exchanger model allows energy to be transferred to or from a fluid volume without using a conductor. This model is used to simulate the energy addition to the pressurizer liquid from the pressurizer heaters.

]

It is also possible to use a non-conducting heat exchanger to model the

]

2.2.6.7 Local Conditions Heat Transfer

The local conditions heat transfer model may be defined for a stack of at least two heat conductors which are connected to the same separated volume. The model allows the heat transfer coefficient of the conductors to vary based on the axial change in fluid conditions in the volume. For example, in a two conductor stack if the midpoint of one conductor is below the mixture level of the adjacent volume, and the midpoint of the other conductor is above the mixture level, the code will calculate different heat transfer regimes and coefficients for the two conductors.

The local conditions model is [] in the Oconee base model. Although the void fraction of the separated volume may vary with height, the temperature of that volume must be constant. Thus a [] For long-running analyses in which [].

The local conditions heat transfer option is used to model the wall heat transfer in the []. This model gives a more accurate calculation of heat transfer in the presence of a mixture level and can be important for some applications. This modeling approach may also be used for other passive structural conductors when additional accuracy is needed.

2.2.7 Code Options

2.2.7.1 Steady-State Initialization

The RETRAN steady-state initialization option is used to obtain stable initial conditions for each transient analysis. This option greatly simplifies the specification of the initial conditions of a RETRAN run. The steady-state initialization routine solves the mass, momentum, and energy equations without the time-dependent terms and thus obtains consistent initial values with a minimal amount of input data.

Primary system conditions at Oconee are set by specifying [

]

The initial SG power removal fraction is normally set at 0.5 for each generator in order to provide a symmetric initialization. In special cases the heat removal from one generator may exceed that of the other. For example, when initializing the model with one of the RCPs off, the SG in the loop with two operating pumps removes most of the power, so the power removal fractions must be adjusted accordingly.

2.2.7.2 Iterative Numerics

The iterative numerics option is used for time step control. Iterative numerics is a semi-implicit numerical solution method which allows the results of the time step advancement to be evaluated before the solution is accepted. Predictive algorithms are used to calculate an appropriate time step size which will give a stable, accurate solution to the fluid conservation equations. If a converged solution is not achieved in a given number of iterations, a reduced time step size is used. This is similar to restarting a job with smaller time steps, but it has the advantage of being automatic.

2.2.7.3 Enthalpy Transport

The enthalpy transport option is used to account for situations in which the fluid in a volume exchanges a significant amount of energy with an external source or sink. In those situations, the fluid enthalpy will vary between the volume inlet, center, and outlet, and the enthalpy transport option accounts for this variation. The option is used [

].

The enthalpy transport option is [

].

2.2.7.4 Temperature Transport Delay

The temperature transport delay option accounts for the fact that temperature changes move through piping as a front, while the finite difference HEM approach instantaneously and homogeneously mixes the incoming fluid with the contents of a volume. Using the temperature transport delay option with a volume treats the movement of fluid more mechanistically by establishing a mesh substructure within the volume to track temperature front movement.

The temperature transport delay option is used for [

]

2.2.7.5 Heat Transfer Map

Two sets of heat transfer correlations are available for use with RETRAN-02. The forced convection map is a set of heat transfer correlations which cover single phase, two-phase, and supercritical fluid conditions. The correlations are generally appropriate for the fluid velocities associated with forced flow. The combined map uses the same heat transfer relationships as the forced map, except that correlations more appropriate for low flow conditions are used if the Reynolds number is less than 2500 (single-phase) or if the mass flux is less than 200,000 lbm/ft-hr (two-phase). The combined map also includes a correlation for condensation.

The forced convection map is [

]

for most applications.

The standard RETRAN-02 forced convection heat transfer map does not have a correlation for condensing heat transfer. A code change has been implemented to add the condensation heat transfer correlation to the forced convection heat transfer map.

For transient situations of very low flow which are outside the range of conditions covered by the plant benchmark analyses, the combined map may be necessary to provide reasonable results.

2.2.7.6 Film Boiling

The available correlations for use in the film boiling heat transfer regime include Groeneveld 5.7, Groeneveld 5.9, and Dougall-Rohsenow (Reference 2-3, Section III.3.2.5). The Dougall-Rohsenow correlation is based on liquid flow at low pressure. Groeneveld 5.9 is based on data from vertical and horizontal flow in round tubes and vertical flow in annuli, while Groeneveld 5.7 is based on the annuli data alone. is used in the Oconee model because it is considered that the basis of that correlation is most similar to situations which would be encountered during PWR transients. The choice of the film boiling correlation is

initial conditions.

2.2.7.7 Critical Heat Flux

There are three options for the calculation of critical heat flux in the forced convection heat transfer map. The default option is a combination of three correlations: B&W-2, Barnett, and modified Barnett. A General Electric correlation or a Savannah River Laboratory correlation may be specified instead of the default. If the mass flux is less than 200,000 lbm/hr-ft², then an interpolation between the chosen correlation and a minimum value is used to calculate the critical heat flux. These correlations are discussed in Reference 2-3, Section III 3.3. The Oconee model employs the

initial conditions.

2.2.7.8 Volume Flow Calculation

The donor cell option method is used for calculating the volume flow for momentum flux. The choice of the donor cell option or the arithmetic average option is not important for the intended applications.

2.2.7.9 Wall Friction

RETRAN calculates the pressure drop due to wall friction using the Fanning friction factor, which is a function of Reynolds number. Several options are available to model the change in wall friction due to two-phase effects. The Baroczy, homogeneous, or Beattie multipliers can be applied to the calculated single phase pressure drop. The [] model is used in the Oconee RETRAN model.

2.2.7.10 General Transport Model

The general transport model is used to calculate the boron concentration in the reactor core volumes. The boron is assumed to be soluble in the transport medium and to have no direct effect on the fluid equations. The basic equation computes the time rate of change of boron mass in a control volume from the net inflow through connected junctions.

2.2.8 Dissimilarities Between Units

The differences between the units at Oconee are insignificant enough that one base model is adequate for all three units. Several adjustments to this model are made for benchmark analyses. The unit-specific main feedwater and main steam line characteristics are input, and the nodalization is adjusted to reflect the appropriate location of the pressurizer. The pump head which is characteristic of a particular unit is used, and the RCS flow rate is matched. Unit specific HPI and EFW capacities are used. The RETRAN kinetics input is based on the specific cycle and time-in-cycle of the benchmark transient. These adjustments ensure that the initial conditions are matched as closely as possible and that the boundary conditions are accurate.

For safety analyses which are applicable to all three units, the geometries are used, and the pressurizer is located on Loop A. The pump capacity is used and RCS flow is assumed to be the transient analysis design flow. The EFW and HPI capacities are taken from the bounding unit, which varies depending on

whether maximum or minimum flow is conservative. Kinetics parameters are based on Unit 1, Cycle 11, which is considered to be typical of current cores. None of the differences between the units has a significant effect on the plant transient response. The variation of reactor kinetics parameters with cycle and time-in-cycle can have a significant impact if the transient does not begin with reactor trip.

2.2.9 Summary of Experience

The major positive conclusions concerning the application of the code and its models are listed below.

- The basic constitutive equations accurately describe the fluid behavior in the RCS and the SGs during operational transients.
- The nodalization scheme is extremely flexible, allowing the user to construct a detailed plant model or to conduct separate effects analyses on components such as the pressurizer or the core flood tanks. This flexibility has also enabled the modeling of other plant systems, including HPI, EFW, and the condensers.
- The heat transfer package provides a good representation of heat transfer, both single phase and two-phase.
- The water properties are accurate in the range of application.
- Steady-state initialization greatly simplifies the process of obtaining a desired set of initial conditions when compared to other thermal-hydraulic systems analysis codes.
- Iterative numerics generally provides reasonable time step control and reduces the necessity of restarting jobs to circumvent time step related errors.
- The generalized restart and reedit capabilities of RETRAN are very useful, and they significantly increase the efficiency with which the code is used.
- The time dependent volume, fill, and critical flow models allow a complete and reasonable specification of fluid boundary conditions for various types of analyses.

- The non-equilibrium pressurizer model provides an accurate simulation of RCS pressure trends.
- The point kinetics model adequately predicts the reactor power response to the types of reactivity changes which arise during typical operational transients.
- The reactor coolant pump model accurately reflects the interaction of the pumps and the primary fluid during normal pump operation and coastdown.
- The control system models and trip logic are extremely flexible and useful for modeling automatic control actions as well as operator action.

Similar to other one-dimensional HEM codes, the current models in RETRAN-02 have been found to have shortcomings in some areas when simulating particular phenomena. These areas are discussed below.

- The lack of a good, general purpose phase separation model for use in a once-through SG impairs the ability of the code to perform some analyses. The HEM representation of the fluid in the SG secondary side leads to mixture levels which are too high under low flow conditions. As a result, the code tends to slightly over-predict the primary-to-secondary heat transfer in such circumstances. In addition, the inability to model counter-current flow necessitates the non-mechanistic modeling of the location of emergency feedwater injection. Generally accurate simulation of primary-to-secondary heat transfer can be achieved without detailed modeling of phase separation. The overall model response to EFW injection has proven to be more than adequate without mechanistic modeling of the injection location.
- The lack of a general non-equilibrium modeling capability detracts from the ability of the code to simulate some small break LOCA behavior. This limitation must be recognized whenever such applications are undertaken.

In general, the overall experience with modeling the Oconee transient response using RETRAN has been good. Despite the shortcomings in the above areas, the code has been proven capable of accurately simulating the transient thermal-hydraulic behavior of a B&W 177 fuel assembly lowered-loop plant.

(Pages 2-56 to 2-59 intentionally deleted)

Oconee Base Model Heat Conductors

2-60

Table 2.2-1 (cont.)

<u>Conductor Number</u>	<u>Adjacent Volume Number</u>	<u>Description</u>	<u>Material</u>

Table 2.2-1 (cont.)

<u>Conductor Number</u>	<u>Adjacent Volume Number</u>	<u>Description</u>	<u>Material</u>
[
]			

Figure 2.2-1

Oconee RETRAN Model
Nodalization Diagram
(two-loop)

Figure 2.2-2

Oconee RETRAN Model
Nodalization Diagram
(one-loop)

2.3 Oconee VIPRE Model

2.3.1 Core and Fuel Assembly Description

The Oconee reactor core consists of 177 BAW Mark-BZ fuel assemblies (Figure 2.3-1). Spacer grids, end fittings, fuel rods, and guide tubes form the basic structure of a fuel assembly as shown in Figure 2.3-2. The lower and upper end spacer grids are made of Inconel, while the six intermediate spacer grids are made of Zircaloy-4. Each fuel assembly is a 15 by 15 array containing 208 fuel rods, 6 control rod guide tubes, and one incore instrument guide tube. The fuel rod consists of dished-end, cylindrical pellets of uranium dioxide clad in cold-worked Zircaloy-4. The fuel assembly and fuel rod dimensions, and other related fuel parameters used in the thermal-hydraulic analyses are given in Table 2.3-1.

2.3.2 Model Development

2.3.2.1 One-Pass Hot Channel Analysis

VIPRE-01 (Reference 2-4) is capable of performing one-pass hot channel analysis. A subchannel is defined as the flow area between adjacent fuel rods in an array. By definition, the hot channel in a PWR core is the subchannel with the most limiting departure from nucleate boiling ratio (DNBR) on one of its adjacent fuel rods. In one-pass analysis the objective is to model the hot subchannel and those nearest to it in detail, and then surround these with larger and larger lumped channels proceeding outward toward the periphery of the core. In this way the entire core can be modeled with a limited number of channels, while maintaining a fine level of detail and accuracy in the area of the hot subchannel. This methodology is an improvement on the multi-pass or "cascade" approach used in other methodologies, where two or three separate simulations in series are necessary using boundary conditions taken from the preceding ones. One-pass analysis is not only more efficient but it allows for explicit modeling of the coupling between the hot subchannel and the rest of the core.

2.3.2.2 Transient Analysis Models

The geometry setup for one-pass analysis is based on the location of the hot subchannel. For a given geometry and inlet fluid condition, the location of the hot subchannel is determined by the pin radial-local power distribution and the critical heat flux (CHF) correlation utilized. Figures 2.3-3 and 2.3-4 show the assembly radial and pin radial-local power distributions, respectively, used to analyze transients resulting in symmetrical core radial power distributions. These power distributions originated from

[] with modifications. The major modification is the [] in the hot

assembly. However, the maximum pin radial-local peak of ρ_{max} and the maximum assembly radial peak of ρ_{max} are preserved.

Three core models, comprised of N channels, have been developed as shown in Figures 2.3-5 to 2.3-7. The detailed N channel model has been constructed in order to identify the location of the hot subchannel and to show that the simplified models can accurately predict the local coolant flow rate and thermal-hydraulic properties of the core and most importantly of the hot channel.

In the N channel model, the N is modeled as an array of subchannels (Figure 2.3-5) while the N is modeled as six lumped channels. Twenty fuel assemblies in the same eighth-core of the hot assembly are modeled as individual channels as shown in Figure 2.3-5. Finally, the N

Utilizing the BWC CHF correlation (Reference 2-5), the hot subchannel is identified to be N channel. However, should CHF correlations other than the BWC correlation be utilized (for example: the BAW2 correlation), the hot subchannel can be identified as N subchannel.

After the location of the hot subchannel has been identified, the N channel model (Figure 2.3-6) is constructed to show that N

1.

Since, depending on the CHF correlation utilized, N

]

2.3.2.3 Simplified Models Justification

To show that the simplified model can properly and correctly predict the local coolant flow rate and thermal-hydraulic properties for steady-state and transient analyses, simplified model results are

compared to results from the more detailed models. If the simplified model results are equivalent or conservative compared to the more detailed model results, then it is justified to use the simplified models for analyses. MDNBRs presented in this section are calculated with the BWC critical heat flux correlation.

Steady-State Comparisons

Input Conditions:	Power	= 78.123 kW/rod (112%FP)
	Pressure	= 2135 psia
	Core flow	= 2.4996 Mlbm/hr-ft ²
	Inlet enthalpy	= 555.0 Btu/lbm

Results for this case are presented in Table 2.3-2. The similarity of all the results verifies that the simplified [] channel model can be used without impacting the accuracy of more detailed and expensive models.

Transient Comparisons

An arbitrary transient case with the inlet core mass flow rate ramped from 100% to 75% and power ramped from 100% to 80% of their initial state values has been run for 2.0 seconds. Results are given in Table 2.3-3.

Results show that the agreement between the predictions of MDNBR during the transient as well as other local fluid parameters is excellent. The capability of the simplified model for transient analysis has been demonstrated.

Conclusion

In conclusion, the results of both detailed and simplified nodalizations are very similar for both steady-state and transient cases. Thus, instead of using the more detailed and expensive models, the simplified [] channel model will be used for core thermal-hydraulic analyses for normal symmetrical transients. For transients resulting in asymmetrical flow distributions or inlet coolant temperature gradients outside the hot assembly, such as the steam line break, the [] channel model may be modified so that [] can be modeled for proper simulation of the inlet temperature gradients. Also, the RECIRC solution method must be utilized instead of the iterative

method because of the large density gradient between channels and because of the low flow velocity due to the reactor coolant pumps tripping in the offsite power unavailable situation.

2.3.2.4 Axial Noding

In general, VIPRE predictions are sensitive to axial noding in that enough nodes must be provided to resolve the detail in the flow field and in the axial power profile. However, once a point of sufficient accuracy is reached, VIPRE is relatively insensitive to further axial refinement. In order to demonstrate the correctness of the above statement, five cases were analyzed with the [] channel model divided into [] axial increments corresponding to [] inches per active fuel node, respectively. The results in Table 2.3-4 show that for [] or more axial nodes, the local coolant conditions are insensitive to the number of axial increments. The hot channel MDNBR changes by only [] when the number of nodes are decreased from []. Since the MDNBR [

] This indicates that [] axial nodes is a sufficiently large number for accurately calculating hot channel conditions. However, [] axial nodes will be used for thermal-hydraulic transient analyses.

2.3.3 Code Option and Input Selections

2.3.3.1 Thermal-Hydraulic Correlations

Flow correlations are used in VIPRE-01 to model two-phase flow effects. In the flow solution, correlations model the effects of two-phase flow and friction pressure losses, subcooled boiling, and the relationship between flowing quality and void fraction.

For transient analyses, the subcooled void, the bulk void, and the two-phase friction multiplier are modeled by using the [

].

The energy and momentum equations of the VIPRE-01 code contain terms describing the exchange of energy and momentum between adjacent channels due to turbulent mixing. The effect of turbulent mixing is empirically accounted for in VIPRE-01. The turbulent cross flow, w' , has the form:

Where:

Re	= Reynolds number
S	= gap width, inches
G	= mass flux, lbm/sec-ft ²
A	= [
B	= []

$$w' = w'/N_R \text{ (Reference 2-4)}$$
$$A = \begin{bmatrix} & \\ & \end{bmatrix}$$

Turbulent mixing in two-phase flow is generally assumed to be []

Pressure Losses

Pressure losses due to frictional drag are calculated in the code for both axial and transverse flow. The friction factor for the pressure loss in the axial direction is determined from empirical correlation as:

$$f = A \times Re^B$$

The code evaluates both a turbulent and laminar set of coefficients and selects the maximum. The values selected for parameters A and B are based on smooth tubes and are taken from Reference 2-4.

Turbulent Flow:	$A = [\quad]$	$B = [\quad]$
Laminar Flow:	$A = [\quad]$	$B = [\quad]$

The coefficient of form drag in the gap between adjacent channels is on the order of [] for the transverse pressure loss (Reference 2-4). Thus, it is set equal to [] for transient analyses.

Local Hydraulic Form Loss

The local hydraulic form loss coefficient is set as a constant to model the irrecoverable axial pressure loss as shown below.

$$\Delta P = KG^2/2\rho g_c$$

Where:	K	= spacer grid form loss coefficient
	G	= mass flux, lbm/sec-ft ²
	ρ	= density, lbm/ft ³
	g_c	= 32.174 lb-ft/sec ² lbf

The spacer grid form loss coefficients for the resident fuel assemblies, currently the MK-BZ fuel assembly, are used in the transient analyses.

Critical Heat Flux Correlations

One of the critical heat flux correlations used to perform DNB analysis is the B&W BWC CHF correlation. The BWC CHF correlation has been reviewed and approved by the NRC for licensing analysis of BAW 15 x 15 Mark-BZ geometry fuel with Zircaloy grids. Using the LYNX-2 open subchannel code (Reference 2-6), the design MDNBR limit of 1.18 was determined. The range of use for the BWC correlation is:

Pressure, psia	1600 to 2600
Mass velocity, 10^6 lbm/hr-ft ²	0.43 to 3.8
Quality, %	-20 to +26

The design MDNBR limit of 1.161 has been achieved using VIPRE-01 (Reference 2-7). However, a design DNBR of 1.18 will be used for transient analysis. The statistical core design methodology (SCD) of Reference 2-14 may also be used. The SCD methodology is generally used unless the analysis parameters are not bounded by the ranges considered in the methodology. A typical SCD limit using VIPRE-01 and the BWC correlation is 1.43.

For transients with system pressure less than 1600 psia, the W-3S CHF correlation will be utilized. The range of use for the W-3S correlation is (Reference 2-4):

Pressure, psia	1000 to 2300
Mass velocity, 10^6 lbm/hr-ft ²	1.0 to 5.0
Quality, (equilibrium)	-0.15 to 0.15

However, it has been shown recently (Reference 2-8) that the W-3S correlation is also applicable for pressure and mass flux as low as 700 psia and 0.5×10^6 lbm/hr-ft², respectively.

Other CHF correlations that have been reviewed and approved by the NRC may also be used to perform DNBR analyses.

2.3.3.2 Conservative Factors

The use of conservative factors depends on whether or not the statistical core design methodology (SCD) of Reference 2-14 is used. The SCD methodology is generally used unless the analysis parameters are not bounded by the ranges considered in the methodology. The SCD approach includes all of the conservative factors described below except the reduction of the hot assembly flow. If the SCD approach is not used, then all of the conservative factors are applied in the VIPRE analyses.

Reduction of the Hot Channel Flow Area

The hot subchannel flow area is reduced by 2% for the hot unit subchannel, and by 3% (Reference 2-7) for the hot instrument subchannel to account for variations in as-built subchannel flow areas.

Reduction of the Hot Assembly Flow

Based on the vessel model flow tests and Oconee core pressure drop measurement, the reductions in the hot assembly flow due to flow maldistribution are shown on the next page (Reference 2-9).

<u>Operation</u>	<u>Flow reduction factor</u>
4-pump	0.950
3-pump	[]
2-pump	

Hot Channel Factors

The hot channel factor is the B&W power factor, F_q . The power factor, F_q , is computed statistically from the average or overall variation on rod diameter, enrichment, and fuel weight per rod. It is applied to the heat generation rate in the pin; thus it will have an effect on all terms that are computed from this heat rate with the exception of the heat flux for DNB ratio computation. The value of F_q used is 1.0132.

2.3.3.3 Fuel Pin Conduction Model

For most of the transient analyses, the RETRAN heat flux boundary condition is used; the fuel pin conduction model will not be used in the VIPRE-01 transient models. This means that heat is added directly from the cladding surface to the fluid as a boundary condition on the calculation, and the heat transfer solution is not required. However, for transient analyses in which the fuel enthalpy or cladding temperature is the protective criteria (for example: rod ejection, rod withdrawal accident at rated power, and locked rotor), the VIPRE fuel pin conduction model may be used with the neutron power as the transient forcing function.

2.3.3.4 Power Distribution

Radial Power Distribution

For transients resulting in symmetrical power distributions, the 15 x 15 1/8 core assembly radial power distribution and hot assembly pin radial-local power distributions shown in Figures 2.3-3 and 2.3-4 are applied. The hot assembly has a radial peak of [] (Figure 2.3-3), and contains the maximum pin radial-local peak of [] (Figure 2.3-4). For transients resulting in asymmetric radial power

distributions, nuclear design analyses generate radial power distributions. Radial power distribution as a function of transient time is then input to VIPRE-01.

Axial Power Distribution

For transients resulting in symmetric radial power distributions, the [] axial power shape is typically applied (Figure 2.3-8). For transients resulting in asymmetric radial power distributions, nuclear design analyses generate axial power distributions during transients. On a case-by-case basis, either these axial power distributions or the [] shape will be utilized as justified.

2.3.3.5 Flow Rate

Vessel Flow Rate

For all three Oconee units, the transient thermal-hydraulic analyses will typically be based on 105.5% (107.5% for SCD) of the original design flow rate of 88,000 gpm per pump. Reactor coolant flow rates for various reactor coolant pump operating configurations are as follows (Reference 2-10):

4 pumps = 100.0% of the total flow
3 pumps = 74.7% of the total flow
2 pumps = 49.0% of the total flow

Where: Total flow = $1.075 \times 4 \times 88,000$ gpm

Core Bypass Flow

The difference between the reactor vessel flow and the reactor core flow is defined as that part of the flow that does not contact the active heat transfer surface area. Some flow bypasses the heat transfer area primarily through three different paths. They are (1) through the core shroud, (2) between all interfaces separating the inlet and outlet regions, and (3) through the control rod guide tubes and instrument tubes. The amount of flow through paths (1) and (2) is fixed. However, the flow through path (3) depends on whether the assemblies contain control components or not; thus, the core bypass flow is determined by the number of empty fuel assemblies. An empty fuel assembly is simply an assembly without a control rod, axial power shaping rod, lumped burnable poison rod, orifice rod, or source rod assembly. The number of empty fuel assemblies may vary from fuel cycle to fuel cycle. A correlation of percent bypass flow versus the number of empty fuel assemblies is utilized. For current Oconee reload designs, a

maximum bypass flow of []% has been determined corresponding to a maximum number of [] empty assemblies. The typical range of bypass flow is []

2.3.3.6 Direct Coolant Heating

The amount of heat generated in the coolant is 2.7% of the total power (Reference 2-11).

2.3.3.7 Miscellaneous

Miscellaneous inputs for VIPRE-01 are shown below. These parameters control the execution of the run. Default values for these inputs are used for the transient analyses (Section 2.12.1, Volume 2, of Reference 2-4).

Solution option	Iterative solution
Maximum number of external iterations	20 (30 for [] ch. Model)
Maximum number of internal iterations	50
Pressure/energy convergence limit for internal iterations	0.00001
Minimum number of external iterations	2
Cross flow convergence limit	0.1
Axial flow convergence	0.001
Damping factor for cross flow	0.9
Damping factor for axial flow	0.9

2.3.4 Discussions of Modeling Differences Between DPC-NE-3000 and DPC-NE-2003 Reports

The modeling and input differences between this report (transient analysis) and DPC-NE-2003 (steady-state analysis) (Reference 2-7) are described below. These differences are due to modeling requirements unique to transient DNBR analyses, or incorporating additional conservatism to minimize the impact of changes in core reload design methods or fuel assembly design.

Model Geometry

The geometry setups for the transient analysis models are different from those of steady-state analysis because the DNBR calculations associated with FSAR Chapter 15 transient analyses require more

flexible models than the calculations associated with steady-state core reload design require. The steady-state analysis models only need to simulate the most limiting region of the core and symmetrical core phenomena. The geometry setup of the transient models must be capable of simulating the whole core, and also situations including asymmetrical core radial power distributions, core flow maldistributions, and inlet coolant temperature gradients. The transient models also [] that are not needed for steady-state analysis.

Core Radial Power Distributions

The steady-state and transient analysis models utilize different assembly radial and hot assembly pin radial-local power distributions. The transient analysis core radial power distribution originated from [] as mentioned in Section 2.3.2.2 and has a maximum hot assembly radial power of [] whereas the steady-state analysis model has a maximum hot assembly power of []. Nevertheless, the maximum pin peak value of [] is utilized by both steady-state and transient analysis models. Furthermore, in the transient models the [] peaks; whereas in the steady-state models, [] peak. The transient model pin peaks are therefore slightly more limiting and ensure that conservative DNBR results will be maintained for any future core reload design with a maximum pin peak of [].

Axial Node Size

In the transient analysis models, the axial node size within the active fuel length is [] inches per node; whereas in the steady-state models, it is [] inches per node. However, Section 2.3.2.4 shows that DNBR is insensitive for axial node size less than [] inches per node.

Turbulent Momentum Factor

In the transient analysis models, the turbulent momentum factor (FTM) is specified as [] to indicate that the turbulent crossflow mixes enthalpy only and not momentum; whereas FTM is set to [] in the steady-state models. The use of [] for FTM would provide conservative results.

Lumped Channel Turbulent Mixing Coefficient

The turbulent mixing coefficient, ABETA, is [] in the transient analysis models; whereas in the steady-state models ABETA of the [] channels. The use of [] channel ABETA provides conservative results.

Gap/Length Factor

In the steady-state models, the gap/length factor is calculated []; whereas the [] is used in the transient models due to the fact that the [] geometries. However, this parameter is recognized as being insensitive.

2.3.4 Comparison with COBRA-IIIC/MIT

As mentioned in Section 1.0, the basic structure and computational philosophy of the VIPRE-01 code are derived from COBRA-IIIC (Reference 2-12). The COBRA family of codes, including several NSSS vendor versions, are in wide use in the nuclear industry. Thus, it is appropriate to compare the steady-state as well as transient results calculated by these two codes.

2.3.4.1 COBRA-IIIC/MIT Code Description

The COBRA-IIIC/MIT code (Reference 2-13) developed at MIT for EPRI. The organization of the code is based on COBRA-IIIC, but allows for larger problems, a faster solution scheme, and simplified data input. A complete description of the modifications is documented in the EPRI code manual for COBRA-IIIC/MIT. For all practical purpose the two codes are essentially based on the same set of equations and will solve the same problems with very similar results. COBRA-IIIC/MIT has expanded capabilities and several additional or replacement correlations; however, none of the modifications significantly affect the basic calculations of heat transfer and fluid flow.

The version of the COBRA-IIIC/MIT code used in the comparison is COBRA-IIIC/MIT-DUKE-02. The DUKE-02 version consists only of error corrections and editorial changes so that the constitutive equations, correlations, and solution schemes of the COBRA-IIIC/MIT code have been preserved.

2.3.4.2 COBRA [] Channel Simplified Model

COBRA-IIIC/MIT also has the capability to perform one-pass analysis similar to VIPRE-01. A [] channel simplified model (Figure 2.3-9) has been constructed for the purpose of COBRA-VIPRE code comparisons. This [] channel model, which is identical in geometry to the VIPRE [] channel model described in Section 2.3.2.2, simulates the B&W MK-B4 fuel assembly by using the BAW-2 CHF correlation to determine the MDNBR. (The BAW2 CHF correlation is used because there is no BWC CHF correlation in the COBRA-IIIC/MIT-DUKE-02 code.) The [] channel VIPRE model has been modified for the Mark-B4 fuel simulation. (The difference between the Mark-B4 fuel and the Mark-BZ

fuel is the spacer grid.) The two [] channel models are essentially identical with the exception of the difference in indexing the subchannels and rods.

2.3.4.3 COBRA-IIIC/MIT Code Options

Although the VIPRE-01 code was derived from the COBRA-IIIC code with similar basic structure and computational philosophy, VIPRE-01 contains a greater selection of correlations for CHF, two-phase flow, solution schemes, and other features than COBRA-IIIC/MIT. However, by selecting similar code options and utilizing identical thermal-hydraulic boundary conditions, a valid comparison of the two codes can be performed. Table 2.3-5 shows the thermal-hydraulic correlations used in the VIPRE-01 and COBRA-IIIC/MIT comparison.

2.3.4.4 COBRA-VIPRE Steady-State Comparison

Four cases with different operating conditions have been compared. The intent of this comparison is to show that VIPRE-01 gives similar predictions to COBRA-IIIC/MIT in a wide operating range. The first case represents the normal operating condition with nominal power, pressure, core flow, and inlet enthalpy values. The second case compares low power and low mass flux condition results. The third case compares high power, low pressure, and low inlet enthalpy condition results. The fourth case compares high pressure, and high inlet enthalpy results.

The operating condition values for these four cases are listed below:

Case 1

Power	= 0.1775 MBtu/hr-ft ² (100% FP)
Pressure	= 2226 psia
Core flow	= 2.584 Mlbm/hr-ft ²
Inlet enthalpy	= 554.6 Btu/lbm

Case 2

Power	= 0.1495 MBtu/hr-ft ²
Pressure	= 2226 psia
Core flow	= 1.628 Mlbm/hr-ft ²
Inlet enthalpy	= 554.6 Btu/lbm

Case 3

Power	= 0.1988 MBtu/hr-ft ²
Pressure	= 1900 psia
Core flow	= 2.574 Mlbm/hr-ft ²
Inlet enthalpy	= 553.7 Btu/lbm

Case 4

Power	= 0.1988 MBtu/hr-ft ²
Pressure	= 2300 psia
Core flow	= 2.714 Mlbm/hr-ft ²
Inlet enthalpy	= 579.0 Btu/lbm

Table 2.3-6 shows the calculated hot channel MDNBR and local fluid properties for all four cases. The VIPRE-01 results agree extremely well with those of COBRA-IIIC/MIT for every operating condition. The largest MDNBR difference is only []% (Case 4).

2.3.4.5 COBRA-VIPRE Transient Comparison

An arbitrary transient case with the inlet core mass flow rate ramped from 100% to 75% and power ramped from 100% to 80% of their initial state values has been run for 2.0 seconds. Results are given in Table 2.3-7. Again the results agree very well.

2.3.4.6 COBRA-VIPRE Comparison Conclusions

In conclusion, the overall evaluation is that the VIPRE-01 computer code gives essentially identical solutions to those of COBRA-IIIC/MIT. The very slight differences in predictions which do exist can be explained by slight differences in the solution method or model options.

2.3.5 Summary of Experience

The VIPRE-01 code was developed to meet the utility need for a versatile and user-oriented analytical tool for performing core thermal-hydraulic design. VIPRE-01 includes numerous modeling options and correlations in order to satisfy a wide spectrum of utility needs. The model development and analysis results documented in this section demonstrate that VIPRE-01 is well suited for Oconee transient analysis. Some of the highlights of this application of the VIPRE-01 code include:

- The nodalization reduction and optimization study performed to justify the use of simplified models was highly successful. Although the intent of this effort was to reduce computer usage, there was no significant loss of accuracy in the predicted thermal-hydraulic conditions or MDNBR.
- VIPRE-01 accepts all necessary boundary conditions that originate either from the plant transient simulation code or the core neutronics simulation code. Included is the capability to subject different boundary conditions to different segments of the core model. For example, different transient inlet enthalpies, heat flux transients, and even different transient pin radial powers or axial flux shapes can be modeled. With this capability virtually any desired application is achievable.
- The results of a comparison between VIPRE-01 and COBRA-IIIC/MIT showed excellent agreement. This was not unexpected due to the similar origins of the codes. Furthermore, this comparison highlights the similarity between most open-channel one-pass thermal-hydraulic codes that are currently in use for PWR core simulation.
- The selection of code options is consistent with the experience base developed by the utilities that have been utilizing VIPRE-01.

It is expected that the VIPRE-01 code will be utilized indefinitely for Oconee transient core thermal-hydraulic applications. The modeling capabilities and the analysis results provided in this section demonstrate that VIPRE-01 can be utilized for accurate and conservative prediction of DNBR during plant transients. This technology remains at or near the current state-of-the-art. Applications will include reanalysis of those FSAR Chapter 15 transients requiring a DNBR evaluation, evaluation of operational events, and resolution of regulatory concerns.

Table 2.3-1

Mark-B Fuel Assembly
Component Dimensions Used for Thermal-Hydraulic Analysis

Fuel Pin Diameter	0.431 in.
Control Rod Guide Tube Diameter	0.531 in.
Instrumentation Guide Tube Diameter	0.555 in.
Effective Pin Pitch	0.567 in.
Assembly Flow Area	40.389 in. ²
Assembly Wetted Perimeter	309.907 in.
Assembly Heated Perimeter	281.474 in.
Unit Channel Flow Area	0.176 in. ²
Unit Channel Wetted Perimeter	1.353 in.
Unit Channel Heated Perimeter	1.353 in.
Control Rod Guide Tube Channel Flow Area	0.157 in. ²
Control Rod Guide Tube Channel Wetted Perimeter	1.432 in.
Control Rod Guide Tube Heated Perimeter	1.015 in.
Instrumentation Guide Tube Channel Flow Area	0.152 in. ²
Instrumentation Guide Tube Channel Wetted Perimeter	1.451 in.
Instrumentation Guide Tube Channel Heated Perimeter	1.015 in.
Peripheral Channel Flow Area	0.102 in. ²
Peripheral Channel Wetted Perimeter	0.677 in.
Peripheral Channel Heated Perimeter	0.677 in.
Corner Channel Flow Area	0.065 in. ²
Corner Channel Wetted Perimeter	0.338 in.
Corner Channel Heated Perimeter	0.338 in.
Active Fuel Length	142.29 in.

(Pages 2-81 to 2-84 intentionally deleted)

Table 2.3-2

Steady-State Results Comparison

<u>Model</u>	<u>MDNBR</u> <u>(BWC)</u>	<u>MDNBR at</u> <u>Axial</u> <u>Location</u> <u>(in.)</u>	<u>Enthalpy</u> <u>at MDNBR</u> <u>(Btu/lbm)</u>	<u>Void</u> <u>Fraction</u> <u>at MDNBR</u>	<u>Mass Flux</u> <u>at MDNBR</u> <u>(Mlbm/hr-ft²)</u>	<u>Pressure</u> <u>Drop up to</u> <u>MDNBR</u> <u>(psi)</u>
[]						

Table 2.3-3
Transient Results Comparison

Time (sec)	MDNBR (BWC)			Axial Location at MDNBR (in.)		
	<u>M1*</u>	<u>M2**</u>	<u>M3***</u>	<u>M1</u>	<u>M2</u>	<u>M3</u>
0.0						
0.2						
0.4						
0.6						
0.8						
1.0						
1.2						
1.4						
1.6						
1.8						
2.0						

Time (sec)	Enthalpy at MDNBR (Btu/lbm)			Void Fraction at MDNBR		
	<u>M1</u>	<u>M2</u>	<u>M3</u>	<u>M1</u>	<u>M2</u>	<u>M3</u>
0.0						
0.2						
0.4						
0.6						
0.8						
1.0						
1.2						
1.4						
1.6						
1.8						
2.0						

Time (sec)	Mass Flux at MDNBR (Mlbm/hr-ft ²)			Pressure Drop up to MDNBR Location (psi)		
	<u>M1</u>	<u>M2</u>	<u>M3</u>	<u>M1</u>	<u>M2</u>	<u>M3</u>
0.0						
0.2						
0.4						
0.6						
0.8						
1.0						
1.2						
1.4						
1.6						
1.8						
2.0						

*M1 - Channel Model
**M2 - Channel Model
***M3 - Channel Model

Table 2.3-4

Active Fuel Node Size Comparison

Number of Active Fuel Rods	[]
MDNBR (BWC)		
MDNBR Axial Location (in.)		
Enthalpy (Btu/lbm)		
Void Fraction		
Mass Flux (Mlbm/hr-ft ²)		
Pressure Drop up to MDNBR (psi)		

Table 2.3-5

Correlations Used in the COBRA-VIPRE Comparison

Flow Correlations

Subcooled Void
Bulk Void
Two-phase Friction Multiplier
Hot Wall Friction Correction

[]

Turbulent Mixing Correlations

Single-phase Mixing
Two-phase Mixing
Turbulent Momentum Factor

$w' = A Re^B SG$ with $A = []$ $B = []$
[]

Friction Loss Correlations

Axial Friction Loss
Lateral Resistance

$f_{tub} = []$
[]

Spacer Grid Pressure Loss

$$\Delta P = KG^2/2\rho g_c$$

Critical Heat Flux Correlation

BAW2

Where:

Re = Reynolds number
S = gap width, inches
G = mass flux, lbm/sec-ft²
K = spacer grid form loss coefficient
 ρ = density, lbm/ft³
 g_c = 32.174 lbm · ft/sec² - lbf

Solution Method

Direct Method

Table 2.3-6

VIPRE-01 - COBRA-IIIC/MIT Steady-State
Results Comparison

<u>Case</u>	<u>MDNBR</u> (BAW-2)		<u>Enthalpy</u> at MDNBR		<u>Void</u> Fraction at MDNBR		<u>Mass Flux</u> at MDNBR	
	<u>VIP</u>	<u>COB</u>	<u>VIP</u>	<u>COB</u>	<u>VIP</u>	<u>COB</u>	<u>VIP</u>	<u>COB</u>
1	[]
2								
3								
4								

<u>Case</u>	<u>Pressure Drop</u> up to MDNBR (psi)		<u>MDNBR</u> Axial Location (in.)	
	<u>VIP</u>	<u>COB</u>	<u>VIP</u>	<u>COB</u>
1	[]
2				
3				
4				

Table 2.3-7

VIPRE-01 - COBRA-IIIC/MIT Transient
Results Comparison

Time (Sec)	MDNBR (BAW-2)		Axial Location at MDNBR (in.)		Enthalpy at MDNBR (Btu/lbm)	
	<u>VIP</u>	<u>COB</u>	<u>VIP</u>	<u>COB</u>	<u>VIP</u>	<u>COB</u>
0.0						
0.2						
0.4						
0.6						
0.8						
1.0						
1.2						
1.4						
1.6						
1.8						
2.0						

Time (Sec)	Void Fraction at MDNBR		Mass Flux at MDNBR (Mlbm/hr-ft ²)		Pressure Drop up to MDNBR (psi)	
	<u>VIP</u>	<u>COB</u>	<u>VIP</u>	<u>COB</u>	<u>VIP</u>	<u>COB</u>
0.0						
0.2						
0.4						
0.6						
0.8						
1.0						
1.2						
1.4						
1.6						
1.8						
2.0						

Figure 2.3-2 ONS Fuel Assmebly






Figure 2.3-3. Assembly Radial Power for Transient Resulting
in Symmetrical Power Distributions




Figure 2.3-4. Hot Assembly Pin Radial-Local Power for Transient
Resulting in Symmetrical Power Distributions




Figure 2.3-5. VIPRE [] Channel Model

Figure 2.3-6. VIPRE [] Channel Model

Figure 2.3-7. VIPRE [] Channel Model



Fuel Rod



Control Rod



Instrumentation Guide Tube


Figure 2.3-8. [

] Axial Shape Peaked at $X/L = [\quad]$

P/P_0

X/L

Figure 2.3-9. COBRA[]Channel Model



2.4 References

2-1 Deleted

2-2 American National Standard for Decay Heat Power in Light Water Reactors, ANSI/ANS-5.1, American Nuclear Society, August 29, 1979.

2-3 RETRAN-02 - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems, EPRI NP-1850-CCM Revision 4, EPRI, November 1988.

2-4 VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores, EPRI NP-2511-CCM Revision 3, EPRI, August 1989.

2-5 BWC Correlation of Critical Heat Flux, BAW-10143P-A, April 1985.

2-6 LYNX2 - Subchannel Thermal-Hydraulic Analysis Program, BAW-10130, October 1976.

2-7 Duke Power Company Oconee Nuclear Station Core Thermal-Hydraulic Methodology Using VIPRE-01, DPC-NE-2003P-A, Revision 1, September 2000.

2-8 Prairie Island Nuclear Generating Plant Final Safety Analysis Report, Northern States Power Company.

2-9 Oconee FSAR Section 4.4.

2-10 Oconee Nuclear Station Technical Specifications, DPC.

2-11 Decay Heat Peaking, BAW-10033, October, 1971.

2-12 COBRA-IIIC: A Digital Computer Program for Steady-State and Transient Core Thermal-Hydraulic Design Methodology, BNWL-1695, PNL, March 1973.

- 2-13 COBRA-IIIC/MIT Computer Code Manual, MIT, March 1976.
- 2-14 Duke Power Company Thermal-Hydraulic Statistical Core Design Methodology, DPC-NE-2005P-A, Revision 3, September 2002
- 2-15 W. G. Kennedy, et. Al., "Pump Two-Phase Performance Program: Volumes 1-8", EPRI NP-1556, September 1980

3.0 MCGUIRE/CATAWBA TRANSIENT ANALYSIS

3.1 Plant Description

3.1.1 Overview

The McGuire and Catawba Nuclear Stations each consist of two 3411 MW thermal Westinghouse pressurized water reactor units. McGuire is located next to Lake Norman near Huntersville, N.C. Construction began on the plant in 1971, and full power operating licenses were received on June 12, 1981 and March 3, 1983 for Units 1 and 2 respectively. Catawba is located next to Lake Wylie near Fort Mill, S.C. Construction began on the plant in 1974, and full power operating licenses were received on January 17, 1985 and May 15, 1986 for Units 1 and 2 respectively. The four units are identical in most respects. The main unusual characteristic of the plants is the use of a dual containment ice condenser design. This features separation of the containment vessel and reactor building by a sub-atmospheric pressure region to inhibit leakage and the use of stored, borated ice to absorb the energy released during high energy line breaks inside containment.

Each primary system has four loops, each with a steam generator, reactor coolant pump and associated piping. The primary coolant is heated in the core and flows to the steam generators, where the energy is transferred to the secondary system. The coolant is then returned to the reactor vessel by the reactor coolant pumps. At full power the secondary system provides 440°F feedwater to the steam generators, where the feedwater is boiled to steam at approximately 1000 psia. The steam passes through a high pressure and three low pressure turbines and is exhausted to the condensers. The condensate is purified and preheated before it is returned to the steam generators.

Plant safety systems provide protection for various anticipated transients and design basis accidents. The Reactor Protection System shuts down the nuclear chain reaction to prevent damaging the core and exceeding safety limits. The Engineered Safeguards Systems provide numerous functions to mitigate design basis accidents, particularly emergency core cooling in the event of a loss of Reactor Coolant System inventory and auxiliary feedwater for decay heat removal.

3.1.2 Primary System

The McGuire/Catawba Reactor Coolant System is shown in Figure 3.1-1.

3.1.2.1 Reactor Core

The reactor core consists of 193 fuel assemblies and the associated control rods. Each fuel assembly is a 17x17 array of 264 fuel rods, 24 guide thimbles, and one in-core instrumentation tube. Two fuel assembly designs are currently in use. The Framatome Advanced Nuclear Power Mk-BW fuel assembly, and the Westinghouse Robust Fuel Assembly (RFA). The Mk-BW fuel rod contains stacked UO_2 fuel pellets inside Zircaloy-4 cladding, with a small gap initially between the pellets and the cladding. The Mk-BW design has Zircaloy-4 guide thimbles to provide a channel for control rod insertion. The RFA fuel assembly design is similar, but uses ZIRLOTM for the cladding and guide thimble material. The RFA fuel also has three intermediate flow mixing grids to improve thermal performance. The instrumentation tube provides a channel for incore neutron detectors. 53 of the fuel assemblies are provided with rod cluster control assemblies for power control and shutdown capability. McGuire Unit 1 uses silver-indium-cadmium absorber rods. The other three units use a hybrid B_4C design. Some of the fuel assemblies which do not contain control rods have burnable poison rod assemblies. Their purpose is to reduce core reactivity at the beginning of cycle and therefore enable higher enrichment cores and longer fuel cycles. Figures 3.1-2 through 3.1-5 show a fuel assembly, a fuel rod, a Ag-In-Cd rod cluster control rod assembly, and a B_4C absorber rod.

3.1.2.2 Reactor Vessel

The reactor vessel consists of a cylindrical shell, a hemispherical bottom head, and a flange to which the removable reactor vessel upper head is bolted during operation. The minimum shell thickness is 8.46 inches of carbon steel, and the interior is clad in stainless steel. Major regions of the vessel include the coolant inlet nozzles, the downcomer, the lower plenum, the core, the upper plenum, the upper head, and the outlet nozzles. Vessel penetrations include the incore instrument sheaths, the control rod mechanism housings, and the upper head injection lines. The incore instrument sheaths penetrate the lower head and the associated conduits extend into the reactor core region. The control rod mechanism housings penetrate the upper head and extend through the upper plenum. Four capped upper head injection lines extend through the upper head. In addition there is a high point vent line which comes off the top of the vessel.

The upper support plate is shaped like an inverted top hat as illustrated in Figure 3.1-6. Around the rim are [] holes which, together with mating holes in the core barrel flange, contain nozzles

through which a portion of the vessel inlet flow is diverted upward to cool the upper head. Currently [] of the nozzles are open, which results in an upper head flow of approximately [] of the total vessel inlet flow. This is a sufficient flowrate to maintain the upper head at the cold leg temperature. Flow passes between the upper head and upper plenum through four different types of structures: flow columns, UHI support columns, 17x17 guide tubes, and 15x15 guide tubes. The flow and support columns are hollow tubes extending from the top of the upper core plate through the upper support plate. The guide tubes also start at the upper core plate but extend further up into the upper head. Most of the 17x17 guide tubes actually house RCCAs. The remainder, as well as the 15x15 guide tubes, serve only as flow paths. The support columns terminate in bottom nozzles directly above the corresponding fuel assembly outlet nozzles. Most of the support columns contain core exit thermocouples.

3.1.2.3 Reactor Coolant Loops

The reactor coolant piping provides a pathway for the coolant to circulate between the reactor vessel and the steam generators. Each of the four 29-inch ID hot legs connects the reactor vessel to one of the steam generators. One 31-inch ID pump suction pipe connects each of the steam generators to the reactor coolant pump. One 27.5-inch ID cold leg connects each reactor coolant pump to the reactor vessel. The minimum thicknesses of the hot leg, pump suction, and cold leg piping is 2.42 inches, 2.58 inches, and 2.30 inches, respectively. The piping is carbon steel clad with stainless steel.

There are various piping penetrations for interfacing systems and components. These include the pressurizer surge line into the loop B hot leg, the decay heat removal suction line(s) off of the bottom of the hot legs, the letdown line off of the loop C cold leg, the safety injection lines into each of the cold legs, and the pressurizer spray lines off of the A and B cold legs. In addition there are many penetrations for Reactor Coolant System instrumentation such as temperature, pressure, flow, and level. The high point of the primary loops is the top of the steam generator tubes.

3.1.2.4 Reactor Coolant Pumps

Each unit has four Westinghouse Model 93A reactor coolant pumps (RCPs). These are centrifugal pumps which operate at a constant speed and utilize 7000 hp Westinghouse motors. The pump seals are of a hydraulic controlled-leakage design. Within the discharge nozzle of each pump is a weir plate completely blocking the [] of the circular flow channel into the cold leg piping. This prevents safety injection water which has accumulated in the

bottom of the cold leg from flowing back through the pump and blocking the loop seal in the pump discharge piping during a LOCA.

3.1.2.5 Steam Generators

Four recirculating steam generators (SGs) provide for energy removal from the primary system. The primary side of a SG consists of the inlet plenum, the tubesheet, the tubes, and the outlet plenum. Primary coolant enters the SG inlet plenum through a nozzle connected to the hot leg piping. The coolant flows up and down the U-shaped SG tubes into the SG outlet plenum. A nozzle connects the outlet plenum to the pump suction piping. The SG inlet and outlet plena are made of carbon steel clad with stainless steel. The tubesheet is also carbon steel.

The preheat SGs consist of Inconel-600 tubes that are fixed at the ends by the 21 inch thick tubesheet, which separates the primary and secondary sides. There are approximately 4600 tubes per SG. Each tube has a nominal OD of 3/4 inches and a thickness of 0.043 inches.

The preheat SGs used at McGuire and Catawba are of two basic types. Catawba Unit 2 has the counter flow D5 design shown in Figure 3.1-7. The other three units originally had the split flow D2/D3 design shown in Figure 3.1-8. Differences between the two designs are discussed in Section 3.1.6.

The preheat steam generators at McGuire Units 1 and 2 and Catawba Unit 1 have been replaced with new feeding steam generators manufactured by Babcock & Wilcox International. The design of the feeding steam generators (FSGs) is shown in Figure 3.1-12. There are 6633 tubes per FSG that are made of Inconel-690. The tubes are fixed at the ends by the 27 inch thick tubesheet which is made of carbon steel and clad with stainless steel. Each tube has a nominal OD of 0.6875 inches and a thickness of 0.04 inches. Differences between the preheat and feeding designs are discussed in Section 3.1.6.

3.1.2.6 Pressurizer

The pressurizer is a vertical cylindrical vessel with hemispherical upper and lower heads. A surge line penetrates the bottom of the pressurizer and connects it to one of the hot legs. The pressurizer maintains and controls the RCS pressure and provides a steam surge chamber and liquid water reserve to compensate for changes in reactor coolant density during operation. A diagram of the pressurizer is shown on Figure 3.1-9.

There are four banks of electric heaters in the lower region of the pressurizer, with a total capacity of 1800 kW. These heaters make up for ambient heat losses during normal operation and restore pressure during operational transients. There is a low level interlock which prevents the heaters from being damaged due to uncover during operation.

The pressurizer spray lines connect two of the cold legs to the pressurizer spray nozzle, which is located at the top of the steam space. Spray valve position is modulated by a proportional plus integral controller providing a maximum of approximately 900 gpm of colder water to the top of the pressurizer where it condenses steam, thus reducing pressure.

The three pressurizer PORVs are CCI drag valves located on lines connected to the top of the pressurizer. Each valve has a 210,000 lbm/hr steam relief capability and opens when RCS pressure exceeds approximately 2335 psig.

The three McGuire pressurizer code safety valves are 2.15 inch Crosby valves which also relieve fluid from the top of the pressurizer. The three Catawba code safety valves are 2.25 inch Dresser valves. The total relief capacity of the valves at each station is greater than 1,200,000 lbm/hr steam. These spring-loaded valves are set to relieve at 2485 psig.

3.1.2.7 Charging and Letdown

Normal charging at McGuire and Catawba is provided by a centrifugal charging pump (CCP) drawing water from the volume control tank. A control valve in the charging line modulates to control pressurizer level at the programmed setpoint, which is a function of reactor coolant average temperature. Makeup capacity through this flowpath is approximately 140 gpm at nominal system pressure. The makeup capacity can be augmented by starting a parallel CCP, opening the Engineered Safeguards injection flowpath, which is parallel to the charging flowpath, or both. Normal charging injects into the A cold leg piping. An alternate charging line injects into the D cold leg piping. A small amount of makeup is also provided by RCP seal injection. Approximately 8 gpm is pumped into the seals of each pump, most of which enters the primary system, and the remainder of which returns via the seal leakoff pathway to the volume control tank. Seal injection is provided by the same CCP which furnishes normal charging. Letdown is taken from the C loop pump suction piping through heat exchangers and demineralizers to the volume control tank. Normal letdown flow is approximately 75 gpm.

3.1.2.8 Instrumentation

A large number of instruments monitor the primary system in order to provide information to the operators, inputs to the plant control systems, and signals for the actuation of the Reactor Protection System (RPS) and the Engineered Safety Features Actuation System (ESFAS). Core instrumentation includes neutron power indication (ionization chambers), movable incore neutron detectors, and core exit thermocouples. RCS temperatures are measured by resistance temperature detectors (RTDs) in the hot leg and pump suction piping. Loop flow is measured by elbow taps in each pump suction leg. Pressure is measured by pressure taps in two of the four hot legs (B and C at Catawba, C and D at McGuire). The pressurizer contains water level, pressure, and water temperature instruments. In addition, inadequate core cooling instrumentation includes a static level measurement for the reactor vessel from top to bottom and a dynamic pressure drop measurement for bulk void fraction indication.

3.1.3 Secondary System

McGuire and Catawba use a regenerative-reheat Rankine cycle to convert the thermal energy produced in the reactor core to electric power. Energy is removed from the primary system by feedwater boiled in the SGs. The steam is exhausted through a high pressure turbine, moisture separator reheaters, and three low pressure turbines to the condensers. Hotwell pumps take suction from the condenser hotwells and discharge to the condensate booster pumps. The condensate passes through G and F feedwater heaters upstream of the booster pumps and then through E, D, and C feedwater heaters to the suction of the steam-driven main feedwater (MFW) pumps. The MFW pumps discharge through the B and A feedwater heaters to the SGs.

3.1.3.1.1 Preheat Steam Generators

The SGs remove energy from the primary system during normal operation, at hot standby, and if necessary at hot shutdown. A typical generator is shown in Figures 3.1-7 and 3.1-8. At full power most of the approximately 3.8 million lbm/hr feedwater enters each SG preheater through the 16 inch lower nozzle. The downcomer consists of the annular section in the lower part of the SG which is separated from the SG shell region by the cylindrical wrapper. Recirculated water flows under the wrapper and into the bundle region surrounding the U-tubes containing the primary coolant. Water emerging from the preheater region mixes with the recirculation flow in the bundle region. Heat transferred from the U-tubes boils some of the secondary fluid in the bundle region, and the resulting two phase mixture enters the primary and secondary separators. In the separators the steam is dried to a minimum quality of 0.9975 before passing through the

outlet nozzle into the steam line. The separated liquid collects in the downcomer. The nominal SG outlet pressure at full power operation is 1000 psia.

Tube support plates provide structural support for the SG U-tubes. The plates are distributed axially along the tube bundle and are more closely spaced near the bottom. They have clearance holes through which the U-tubes pass. In addition there are circulation holes in the plates to allow fluid to pass up the tube bundle at higher flow rates. Each tube bundle has a lane under the bend apex at the top of the tube bundle. This lane allows some of the interior tubes to be inspected. In addition there are untubed regions through which vertical stayrods pass. These stayrods connect the tube support plates for additional support. The height of the tallest U-tube is approximately 28 feet above the top of the tubesheet.

The elevations of the top and bottom of the reactor core are 155" and 299", respectively, below the top of the lower tubesheet of the SG. In order to promote stable natural circulation flow the thermal center for heat removal must be above the thermal center for heat addition to the primary system. This condition is therefore automatically satisfied because of loop geometry. The SGs have an upper nozzle to allow auxiliary feedwater (AFW) to be injected into the downcomer above the tubes.

3.1.3.1.2 Feeding Steam Generators

The feeding steam generator (FSG) is shown in Figure 3.1-12. At full power, most of the approximately 3.8 million lbm/hr feedwater is delivered to the feeding through the main feedwater nozzle and gooseneck. The 32 J-tubes connected to the feeding distribute the feedwater axi-symmetrically around the downcomer, where the feedwater mixes with the recirculation flow. The downcomer consists of the annular section in the lower part of the FSG which is separated from the shell region by the cylindrical wrapper. Recirculated water flows under the wrapper and into the bundle region surrounding the U-tubes containing the primary coolant. Heat transferred from the U-tubes boils some of the secondary fluid in the bundle region, and the resulting two-phase mixture enters the primary and secondary separators. In the separators, the steam is dried to a minimum quality of 0.9975 before passing through the steam outlet nozzle into the steam line. The separated liquid collects in the downcomer. The nominal FSG outlet pressure at full power is 1020 psia.

A lattice bar grid arrangement provides structural support for the U-tubes while minimizing resistance to fluid flow. The lattice grids are distributed axially along the tube bundle, with one high resistance lattice grid at the bottom of the bundle and eight low or medium resistance lattice

grids above the high resistance lattice grid. The height of the tallest U-tube is approximately 35 feet above the top of the tubesheet.

The elevations of the top and bottom of the reactor core are 170" and 314", respectively, below the top of the tubesheet of the FSG. Thus, the difference in thermal centers promotes stable natural circulation flow.

The FSGs have an auxiliary feedwater nozzle approximately 3 feet above the main feedwater J-tubes to allow auxiliary feedwater to be injected into the downcomer above the tubes.

3.1.3.2 Main Feedwater

The MFW System consists of the MFW pumps, the A and B feedwater heaters, and the piping and valves between the pumps and the SGs. The MFW pumps have common suction and discharge lines, so neither of the two pumps is aligned to particular SGs. The variable speed pumps are turbine-driven by either main steam or low pressure steam. The nominal feedwater temperature at the outlet of the A feedwater heaters is 440°F, at a pressure of approximately 1100 psia. MFW flow to each SG is controlled by the MFW control valves.

The MFW flow is normally aligned predominantly to the lower nozzle during power operation. At low power levels MFW is swapped to inject into the upper nozzle. AFW is aligned only to the upper nozzle.

For the FSGs, main feedwater flow is normally aligned to the main feedwater nozzle during power operation. It is not expected that main feedwater will be swapped to inject into the auxiliary feedwater nozzle at lower power levels for FSG operation at McGuire. For FSG operation at Catawba, MFW is swapped to inject into the upper nozzle at lower power levels. Auxiliary feedwater is aligned only to the auxiliary feedwater nozzle.

3.1.3.3 Main Steam

The main steam lines carry the high pressure, high temperature steam from the SGs to the high pressure turbine. One 32" line exits each SG and expands to a 34" line. The 34" line leaves the Reactor Building and enters the Doghouse. Inside the Doghouse there is a main steam isolation valve (MSIV) on each line. Downstream of the MSIV each line leaves the Doghouse, goes across the yard and enters the Turbine Building. From then on the configuration is station-specific and is discussed in Section 3.1.6.4.

Process steam is taken off of the steam headers to power station auxiliaries. These include the auxiliary steam header, the MFW pumps, the turbine-driven AFW pump, the condensate steam air ejectors, and the steam seals. In addition, main steam is used to reheat the steam between the high and low pressure turbines. Various steam drains and traps are also provided on each steam line. Main steam relief is provided by five steam line safety valves and one Power Operated Relief Valve (PORV) per steam line. Downstream of the MSIVs, further steam relief is provided by condenser dump valves and atmospheric dump valves.

The steam line safety valves provide overpressure protection to the steam lines and SGs. The valve opening setpoints range between 1170 and 1230 psig. The total relief capacity through the valves is greater than the nominal full power steam flow rate. The condenser dump valves control steam pressure prior to putting the turbine on-line and after turbine trip. The nine valves have a total capacity of 40% of nominal full power steam flow. The atmospheric dump valves provide additional steam relief for load rejection transients. These valves have a total capacity of 45% of nominal steam flow. The two sets of valves, together with the steam line PORVs, are designed to allow a full load rejection without tripping the reactor or opening the steam line safety valves.

3.1.3.4 Turbine-Generator

The turbine-generator converts the thermal energy of steam produced in the SGs into mechanical shaft power and then into electrical energy. The turbine-generator of each unit consists of a tandem (single shaft) arrangement of a double-flow high pressure turbine and three identical double-flow low pressure turbines driving a direct-coupled generator at 1800 rpm. Turbine-generator functions under normal and abnormal conditions are monitored and controlled automatically by the Turbine Control System, which includes redundant mechanical and electrical trip devices to prevent excessive overspeed of the turbine generator. Once the turbine is brought online (at approximately 10% rated power) the turbine control valves maintain the first stage (impulse chamber) pressure at a programmed value that is proportional to power level. The turbine stop valves close rapidly to preclude turbine damage after the receipt of a turbine trip signal.

3.1.3.5 Instrumentation

A wide variety of secondary system instrumentation is available to the operators. Pressure is available at the MFW pump discharge and on the steam lines upstream and downstream of the

MSIVs. Fluid temperature is indicated for each part of the Main Feedwater System and for the steam lines. Feedwater flow is available for each SG. Two SG level indications, wide range and narrow range, are provided, with the ranges indicated on Figures 3.1-7 and 3.1-8. Two FSG level indications, wide range and narrow range, are provided with the ranges indicated on Figure 3.1-12. The SG level instruments are ΔP devices, with the taps located at various elevations in the downcomer and shell. ΔP devices measure collapsed liquid levels, not the actual mixture or froth level of a fluid. The two level ranges are used for distinct purposes. The narrow range covers the middle portion of the SG and is used during normal operation, when the SGs have a significant water inventory. The wide range covers the middle and lower portions and is primarily used for evolutions which take place while at shutdown, such as wet layup.

3.1.4 Control Systems

Nuclear plants include a large number of control systems which monitor and adjust the performance of individual components and systems. In this section the control systems which have a major effect on the overall transient response of the plant are discussed.

3.1.4.1 Pressurizer Pressure Control

The Pressurizer Pressure Control System controls the three pressurizer PORVs, the two pressurizer spray valves, the bank of proportional control heaters, and the three banks of backup heaters. Either channel 1 or channel 3 of the pressurizer pressure instrumentation is used as an input signal. This signal directly controls two of the three PORVs, causing them to lift at 2335 psig and reseal at [] psig. To control the other components an error signal is formed by subtracting the reference pressure setpoint, 2235 psig, from the input signal. This error signal is then input to a proportional plus integral controller. The controller output signal operates the remaining components according to the following setpoints, with zero psi indicating controller output at the reference pressure.

Backup heaters on	-25 psi
Backup heaters off	[]
Control heaters full on	-15 psi
Control heaters off	+15 psi
Spray valves begin to open	+25 psi
Spray valves full open	+75 psi
Pressurizer PORV NC-34 reseals	[]
Pressurizer PORV NC-34 opens	+100 psi

3.1.4.2 Rod Control

The Rod Control System enables the nuclear unit to follow load changes automatically, including the acceptance of step load increases or decreases of 10 percent and ramp increases or decreases of 5 percent per minute, within the load range of 15 percent to 100 percent, without reactor trip, steam dump, or pressure relief, subject to possible xenon limitations. The system is also capable of restoring coolant average temperature to within the programmed temperature deadband following a change in load. Manual control rod operation may be performed at any time. The Rod Control System controls the reactor coolant average temperature by regulation of control rod bank position. The reactor coolant loop average temperatures are determined from hot leg and cold leg measurements in each reactor coolant loop.

The error between the programmed reference temperature (based on turbine impulse chamber pressure) and the highest of the average measured temperatures (which is processed through a lead-lag compensation unit) from each of the reactor coolant loops constitutes the primary rod control signal. An additional control input signal is derived from the reactor power versus turbine load mismatch signal. This additional control input signal improves system performance by enhancing response and reducing transient peaks. The system is capable of restoring coolant average temperature to the programmed value following a change in load. The programmed coolant temperature increases linearly with turbine load from zero to full power.

The Rod Control System generates rod speed and direction signals which vary over the range of 5 to 45 inches per minute (8 to 72 steps/minute) depending on the magnitude of the input signal. The rod direction demand signal is determined by the positive or negative value of the input signal. Manual control is provided to move a control bank in or out at a prescribed fixed speed.

When the turbine load reaches approximately 15 percent of rated load, the operator may select the automatic mode, and rod motion is then controlled by the Rod Control System. A permissive interlock derived from measurements of turbine impulse chamber pressure prevents automatic control when the turbine load is below 15 percent. In the automatic mode, the rods are withdrawn (or inserted) in a predetermined programmed sequence by the automatic programming equipment.

The five shutdown banks are always in the fully withdrawn position during normal operation, and are moved to this position at a constant speed by manual control prior to criticality. A reactor trip signal causes them to fall by gravity into the core. The four control banks are the

only rods that can be manipulated under automatic control. Each control bank is divided into two groups to obtain smaller incremental reactivity changes per step. All rod cluster control assemblies in a group are electrically paralleled to move simultaneously. There is individual position indication for each rod cluster control assembly.

3.1.4.3 Steam Dump Control

The Steam Dump Control System has three modes of operation: plant trip, load rejection, and steam header pressure.

Plant Trip Controller

Following reactor trip only the nine condenser steam dump valves are allowed to open. The atmospheric steam dump valves are interlocked closed. The condenser dump valves are organized into banks, two at McGuire and three at Catawba. The opening and closing of banks of valves is determined by a temperature error signal. One component of the error signal is the lead-lag compensated, auctioneered high coolant average temperature indication. From this is subtracted the no-load average temperature. The magnitude of this difference determines the operation of a given valve bank. Each bank has a trip setpoint, a reset setpoint, and a modulation range. The ranges are continuous, i.e., the trip setpoint of a given bank is at the bottom of the modulation range of the next bank. The reset setpoint for a given bank is [] below the trip setpoint. The trip setpoints are as follows:

<u>McGuire</u>		<u>Catawba</u>	
Bank 1 (five valves)	[]	Bank 1 (three valves)	[]
Bank 2 (four valves)		Bank 2 (three valves)	
		Bank 3 (three valves)	

If the temperature error signal is at or above the trip setpoint, all valves in the corresponding bank trip fully open and are kept open until the error signal decreases below the reset setpoint for that bank. If the error signal never increases to the trip setpoint, the valve position is a linear function of the error signal with 100 percent open corresponding to the trip setpoint of that bank and zero percent open corresponding to the trip setpoint of the next lowest bank. Bank 1 is zero percent open when the error signal is zero.

Load Rejection Controller

Following a large, sudden load rejection or turbine trip without a reactor trip, all condenser dump valves (McGuire and Catawba) and atmospheric dump valves (Catawba only) may be enabled, depending on the magnitude of the load rejection. The load rejection controller operates in a manner similar to the plant trip controller and is also driven by an error signal derived from a temperature difference. The components of the temperature difference are the average temperature, as used in the plant trip controller, and the reference temperature, which is based on turbine impulse chamber pressure and is therefore indicative of turbine power. There is a [] deadband on the temperature difference before the first bank begins to open in load rejection control mode. The trip setpoints are

<u>McGuire</u>		<u>Catawba</u>
Bank 1 (five valves)	[]	Bank 1 (three valves)
Bank 2 (four valves)		Bank 2 (three valves)
		Bank 3 (three valves)
		Bank 4 (four valves)
		Bank 5 (five valves)

Steam Header Pressure Controller

Residual heat removal is maintained by the steam header pressure controller (manually selected) which controls the amount of steam flow to the condensers. This controller operates three of the condenser dump valves.

3.1.4.4 Pressurizer Level Control

The pressurizer water level is programmed as a function of coolant average temperature, with the highest average temperature (auctioneered) being used. The pressurizer water level decreases as the load is reduced from full load. This is a result of coolant contraction following programmed coolant temperature reduction from full power to low power. The programmed level is designed to match as nearly as possible the level changes resulting from the coolant temperature changes.

3.1.4.5 Steam Generator Level Control

Each McGuire steam generator is equipped with a three-element feedwater flow controller which maintains a programmed water level as a function of neutron flux. The three element feedwater controller regulates the feedwater valve by continuously comparing the feedwater flow signal, the water level signal, the programmed level and the pressure compensated steam flow signal.

The Catawba Digital Feedwater Control System (DFCS) automatically controls feedwater flow to each steam generator to maintain programmed steam generator water levels. The level setpoint is a function of nuclear power. At power levels above approximately 25 percent, the feedwater flow to individual steam generators is controlled by a three element DFCS which uses temperature compensated feedwater flow, main steam flow, and steam generator water level as control parameters for the feedwater control valves. At power levels below approximately 25 percent, the DFCS automatically positions the feedwater bypass control valve and feedwater control valve to each steam generator based on the level setpoint.

3.1.4.6 Feedwater Pump Speed Control

The feedwater pump speed is varied to maintain a programmed pressure differential between the steam header and the feed pump discharge header. The speed controller continuously compares the actual ΔP with a programmed ΔP_{ref} which is a linear function of steam flow.

3.1.5 Safety Systems

Various systems are required to ensure that the plant does not exceed applicable limits during design basis transients. The major safety-related systems which affect the plant transient response are discussed in this section.

3.1.5.1 Reactor Protection System

The Reactor Protection System (RPS) monitors parameters related to safe operation of the core and trips the reactor to protect against fuel and cladding damage. In addition, by tripping the reactor and limiting the energy input to the coolant, the RPS protects against Reactor Coolant System structural damage caused by high pressure. A coincidence logic scheme is used to sense a trip condition. When the minimum number of channels trip, power is removed from the control rod drives of the shutdown banks, $S_a - S_e$, and the control banks, A-D. The rods fall into the reactor core and shut down the nuclear chain reaction.

The RPS will initiate a reactor trip on the following conditions:

- 1) Power range high neutron flux, high setting
- 2) Power range high neutron flux, low setting
- 3) Intermediate range high neutron flux

- 4) Source range high neutron flux
- 5) Loop temperature difference higher than the DNB limit (Overtemperature ΔT)
- 6) Loop temperature difference higher than the centerline fuel melt limit (Overpower ΔT)
- 7) Reactor coolant pump undervoltage
- 8) Reactor coolant pump underfrequency
- 9) High pressurizer pressure
- 10) Low pressurizer pressure
- 11) High pressurizer level
- 12) Low reactor coolant loop flow
- 13) Low-low steam generator level
- 14) Power range neutron flux high positive rate
- 15) Safety injection
- 16) Turbine trip while above a certain power level (48% at McGuire and 69% at Catawba)

Trips 2, 3, and 4 are enabled only at various low power levels. Trips 7, 8, 10, 11, and 12 are modified or disabled at various low power levels. Trips 1, 5, 6, 9, 13, 14, and 15 are always enabled while the reactor is critical.

3.1.5.2 Engineered Safeguards System

The Engineered Safeguards System consists of the Engineered Safety Features Actuation System (ESFAS) and various safeguards components. These components may also have dual functions, being used during normal operation as well serving as Engineered Safety Features. The ESFAS is divided into the following functions:

- 1) Safety injection
- 2) Containment heat removal
- 3) Containment isolation
- 4) Steam line isolation
- 5) Turbine trip and feedwater isolation
- 6) Auxiliary feedwater
- 7) Automatic switchover to recirculation
- 8) Loss of essential auxiliary power system

These functions and the components actuated by them are discussed below.

Safety Injection

The Safety Injection System can be divided into four subsystems:

- 1) Two high head safety injection (HHSI) pumps
- 2) Two intermediate head safety injection (IHSI) pumps
- 3) Two low head safety injection (LHSI) pumps
- 4) Four passive cold leg accumulator tanks (CLAs)

All six pumps start on a safety injection signal. This signal is automatically generated on any of the following conditions:

- 1) Pressurizer pressure decreases below 1845 psig
- 2) Containment pressure increases above 1.1 psig (McGuire) or 1.2 psig (Catawba)

The first actuation signal can be blocked when the reactor is being cooled down. The second actuation signal is always enabled.

The HHSI pumps have a shutoff pressure of approximately [] psig and runout flows of approximately []. These flow rates are for operation through the boron injection flowpath which terminates in 1½ inch lines which inject into each cold leg. The HHSI pumps also provide normal charging and reactor coolant pump seal injection. On a safety injection signal the suction source for the HHSI pumps is automatically switched from the volume control tank to the Refueling Water Storage Tank (RWST).

The IHSI pumps have a shutoff pressure of approximately [] psig and runout flows of approximately []. The IHSI pumps are normally aligned to the RWST. The IHSI pumps initially inject through four 2 inch lines which empty into the 6 inch lines from the LHSI pumps. If injection flow is to be maintained after 6 hours, the IHSI pumps are realigned to inject into four 6 inch lines which connect directly to each hot leg. This realignment prevents unacceptable concentration of boron following a LOCA.

The LHSI pumps have a shutoff pressure of approximately [] psig and runout flows of []. The LHSI pumps initially inject through four 6 inch lines which empty into the 10 inch lines from the cold leg accumulator tanks. If injection flow is maintained long enough to empty the RWST, the suction of the LHSI pumps is automatically swapped to the containment sump. The operator then aligns the HHSI and IHSI pumps to take suction from the LHSI pumps.

The four CLAs constitute a passive part of the Emergency Core Cooling System that performs no function during normal operation. Each of the four tanks is connected to its corresponding cold leg by a 10 inch injection line. The tanks are pressurized to approximately 600 psig by nitrogen. Each 1393 ft³ tank contains 918 ft³ of borated water at McGuire and 1020 ft³ of borated water at Catawba which, following a large break LOCA, is discharged into its cold leg. Each injection line contains two check valves which isolate the tank from RCS pressure during normal operation, but open to allow flow during a design basis accident. In addition to large break LOCAs, the CLAs will inject water into the RCS during major depressurization events, e.g., some small break LOCAs.

In addition to actuating the pumps discussed above, a safety injection signal will do the following:

- 1) Start the motor driven AFW pumps
- 2) Initiate a Phase A containment isolation
- 3) Initiate a containment purge and exhaust isolation

Containment Heat Removal

The containment heat removal portion of the ESFAS and the components it controls, such as spray pumps and air return fans, do not play a major role in NSSS transient analysis and are not described here.

Containment Isolation

The containment isolation portion of the ESFAS and the isolation valves it controls are divided into two groups, Phase A and Phase B, depending on the signal which generated the isolation. Both signals can result in the closure of valves in lines which affect the NSSS. Although no general explanation is given here, such effects are modeled appropriately in the RETRAN analyses of applicable transients.

Steam Line Isolation

Steam line isolation occurs automatically from pressurization of the containment or uncontrolled depressurization of the steam lines. The containment pressure setpoint is 2.9 psig (McGuire) or 3.0 psig (Catawba). Steam line isolation on uncontrolled steam line depressurization depends on plant status. For normal pressurized operation steam line pressure is compared with a setpoint of 775 psig. For depressurized operation the operator blocks this actuation to allow cooldown with the SGs. The blocking enables an automatic isolation on any steam line pressure rate more

negative than -100 psi/second. A steam line isolation signal closes the MSIVs, the MSIV bypass valves, and the steam line PORVs.

Turbine Trip and Feedwater Isolation

If narrow range SG level exceeds the high-high setpoint, 82% (McGuire), 82.4% (Catawba), or 83.9% (FSG), the ESFAS will initiate closure of the turbine stop valves and of all valves supplying MFW flow to the SGs. These actions protect the turbine from damage due to moisture entrainment and stop MFW flow to help prevent SG overfill. In addition MFW isolation can occur on high water level in one of the Doghouses. This protects against continued MFW addition for a feedwater line break in the Doghouse. Feedwater isolation signals will also be generated by safety injection or by low RCS average temperature coincident with reactor trip, although not technically a part of the McGuire ESFAS, as defined by Technical Specifications.

Auxiliary Feedwater

The Auxiliary Feedwater (AFW) System has two 50% capacity motor-driven pumps and one 100% capacity turbine-driven pump. One motor-driven pump is aligned to SGs A and B, the other to SGs C and D. The turbine-driven pump is aligned to all four SGs. The motor-driven pumps are automatically started on any of the following:

- 1) Low-low narrow range level in any SG
- 2) Safety injection
- 3) Loss of offsite power
- 4) Trip of both MFW pumps

The turbine-driven pump is automatically started on either of the following:

- 1) Low-low narrow range level in two or more SGs
- 2) Loss of offsite power

AFW flow is manually controlled by the operator following reactor trip to achieve and maintain the programmed narrow range SG level for zero power.

Automatic Switchover to Recirculation

On low RWST level the LHSI pump suction is automatically swapped from the RWST to the containment sump.

Loss of Essential Auxiliary Power System

Upon low voltage on the 4160 volt essential electrical busses, the diesel generators automatically start. The diesel generator load sequencers open the breakers for loads on the busses, close the diesel generator breakers to energize the busses, and then re-close the breakers for the various load according to prescribed timed sequences. The presence of a safety injection signal starts the diesel generator safeguards loading sequence, while a loss of offsite power with no safety injection signal starts the diesel generator blackout loading sequence.

3.1.6 Dissimilarities Between Units and Stations

3.1.6.1 Steam Generator Type

The McGuire units and Catawba Unit 1 originally had split flow preheater regions. In such a preheater the MFW flow enters the middle of the region on the side and divides into two flow streams. The upper stream flows across a series of baffle plates and upward, counter to the direction of RCS flow in the U-tubes. This stream exits into the upper tube bundle on the cold leg side. The lower flow stream flows across a different series of baffle plates and downward, along the direction of RCS flow in the U-tubes. This stream exits into a mixing region below the preheater where it joins with recirculated flow from the downcomer and flows over the lower tube bundle on the hot leg side.

Catawba Unit 2 has a counterflow preheater region. In this preheater design the MFW flow enters the middle of the region, is diverted to the bottom, and divides into two streams. One stream flows across the tube bundle to the hot leg side and joins recirculated flow from the downcomer. The other flows across a series of baffle plates and upward, counter to the direction of RCS flow in the U-tubes. This stream exits into the upper tube bundle on the cold leg side.

In addition to the preheater, the Catawba Unit 2 SGs differ from those of the other units in several other respects. There are [] primary separators (risers) on the Catawba Unit 2 SGs but [] on SGs at the other units. Fitting the [] risers through the plate at the top of the tube bundle necessitated raising it to a higher and thus wider area in the transition cone. This results in a larger tube bundle region relative to the other units. The 4578 Catawba Unit 2 SG U-tubes are taller than the corresponding 4674 U-tubes on the other three units. The longer U-tubes at Catawba Unit 2 increase the resistance of the primary loop. This necessitated an increase in the rated head of the reactor coolant pumps for that unit to a value greater than the rated value for the reactor coolant pumps on the other three units. Finally, the split flow preheater configuration flow patterns necessitated a wide variation in programmed water level

with power. The Catawba Unit 2 SG level program has a narrow variation in programmed water level as a function of power.

In order to correct U-tube wear problems associated with high MFW flow into the counterflow preheater region, the MFW flow delivery characteristics of the Catawba Unit 2 generators were modified. A flow restricting orifice was installed in the MFW line to the lower nozzle, limiting flow to this nozzle at full power to [] of total flow. The remaining [] of full power MFW flow is diverted to the upper nozzle. In contrast, the other units have upper nozzle MFW flows at full power of approximately [] of total flow, enough to prevent heatup of the discharge lines and upper nozzle.

The preheat SGs at McGuire Units 1 and 2 and Catawba Unit 1 have been replaced with feedring SGs. The main difference between the preheat and feedring designs is the manner in which main feedwater is delivered to the steam generators. In the feedring SG, the main feedwater flow is delivered to the feedring through the main feedwater nozzle and gooseneck. The J-tubes connected to the feedring distribute the feedwater axi-symmetrically around the downcomer, where the feedwater mixes with the recirculation flow.

In addition, the feedring SGs differ from the preheat SGs in several other respects. Each FSG has a greater number of primary separators that are smaller than the preheat SG separators. The FSG tube bundle is taller than that of the preheat SGs and has a greater number of tubes. Thus, the FSGs have a much larger heat transfer area. The FSG level program is constant as a function of power, as is the Catawba Unit 2 SG level program.

3.1.6.2 Auxiliary Feedwater Runout Protection

Travel stops on the auxiliary feedwater discharge valves in the lines from each AFW pump to each SG are set to allow no more than a certain amount of flow to any SG assuming it is fully depressurized while the other SGs are at the setpoint of the steam line safety valves.

3.1.6.3 Steam Line Layout

The McGuire main steam lines exit the four SGs and go to the MSIVs in the Doghouse. Downstream of the MSIVs the 34" steam lines enter the side of a 48" diameter header. At one end of this header a 24" line goes to the nine condenser dump valves. From the side of the header four 34" lines carry main steam to the turbine inlet via the stop and control valves. The McGuire arrangement is shown in Figure 3.1-10. At Catawba the arrangement is similar through

the MSIVs. Downstream of the MSIVs each 34" line maintains its identity separately from the other lines, reducing to 28" each before reaching the turbine stop and control valves. At the stop valves is a 35" equalization header connecting each steam line. Further upstream, a 28" line separates from each steam line. These four lines join to form a 28" header. At one end of this header a 24" line goes to the nine atmospheric dump valves. From the other end another 24" line goes to the nine condenser dump valves. The Catawba arrangement is shown in Figure 3.1-11.

3.1.6.4 Miscellaneous Differences

There are several miscellaneous differences between stations and units which affect transient analysis modeling:

- 1) The outlet nozzle on the McGuire Unit 1 reactor vessel is not as sharply edged as the nozzles on the other three units, giving it a loss coefficient approximately half as large as the nozzles on the other units.
- 2) The number and types of the various upper internals structures is different for McGuire Unit 1 than for the other three units as shown below:

<u>McGuire Unit 1</u>	<u>Other Units</u>
17 x 17 guide tubes	17 x 17A guide tubes
15 x 15 guide tubes	15 x 15 guide tubes
support columns	support columns
flow columns	flow columns
thermocouple columns	thermocouple columns

- 3) McGuire Unit 1 has thermocouple instrumentation in the reactor vessel upper head while the other three units do not.
- 4) The original RCS average temperature program for McGuire Units 1 and 2 and Catawba Unit 1 was 588.2°F. With the replacement FSGs this temperature has been lowered to 585.1°F. The original RCS average temperature for Catawba Unit 2 was 590.8°F. This temperature has been lowered to 587.5°F.
- 5) Due to noise problems encountered with the pressurizer pressure transmitters on initial startup, the McGuire pressure signals have a 1 second lag imposed before

being used for control and protection purposes. The Catawba pressure signals have no lag.

- 6) There are several minor setpoint differences between McGuire and Catawba, e.g., the ΔT reactor trip gains and time constants and the pressurizer level program.
- 7) Because of the variation in operating time among the four units, differences exist in the number of tubes plugged on the various SGs. These differences are modeled, where appropriate, in RETRAN transient analyses.

(Pages 3-23 to 3-25 intentionally deleted)

Figure 3.1-1
McGuire/Catawba Reactor Coolant System Schematic




Figure 3.1-2 Westinghouse Robust Fuel Assembly





Figure 3.1-3
McGuire/Catawba Fuel Rod



SPECIFIC DIMENSIONS DEPEND ON DESIGN VARIABLES SUCH AS
PRE-PRESSURIZATION, POWER HISTORY, AND DISCHARGE BURNUP

Figure 3.1-4
McGuire/Catawba Ag-In-Cd Rod Cluster Control Assembly




Figure 3.1-5
McGuire/Catawba B₄C Absorber Rod




Figure 3.1-6
McGuire/Catawba Upper Internals




Figure 3.1-7
Counterflow Preheater Steam Generator





Figure 3.1-8
Split Flow Preheater Steam Generator



Split Flow Preheat
Steam Generator
McGuire Unit 1
McGuire Unit 2
Catawba Unit 1

Figure 3.1-9
McGuire/Catawba Pressurizer




Figure 3.1-10
McGuire Main Steam Schematic




Figure 3.1-11
Catawba Main Steam Schematic





Figure 3.1-12
Replacement Steam Generator



Replacement Steam Generator

McGuire Unit 1
McGuire Unit 2
Catawba Unit 1

3.2 McGuire/Catawba RETRAN Model

The McGuire/Catawba RETRAN model nodalizations are shown in Figures 3.2-1 and 3.2-2 for the two-loop and one-loop models respectively. For feedring SG transient analysis, the feedring SG nodalization shown in Figure 3.2-3 replaces the preheat steam generator nodalization shown in Figures 3.2-1 and 3.2-2. The one-loop model is used for transients which exhibit a sufficient amount of symmetry. For certain applications the amount of detail is excessive and can be reduced to save computer time, while on occasion additional detail e.g., a three-loop model, is required.

The primary system model is symmetric relative to the two loops. The single-loop components (volumes, junctions, and conductors) have numbers in the 100s. The triple-loop component numbering scheme is the same, except that the numbers are in the 300s. Thus Volume 113 corresponds to Volume 313, the former being in the single loop and the later in the triple loop.

3.2.1 Primary System Nodalization

3.2.1.1 Reactor Vessel

The reactor vessel is modeled by [] fluid volumes. The boundaries between the volumes are chosen due to actual physical separations, or to provide an additional level of detail in the hydrodynamic calculation.

Downcomer

[

]. Flow enters through the four cold legs and exits into the lower plenum.

Lower Plenum

The reactor vessel lower plenum is represented by [

] Flow from the downcomer goes through the lower plenum into the core and the core bypass.

Core

[] represent the reactor core region from the [

] There is no physical separation between [

]. Flow enters from the lower

plenum and discharges into the upper plenum. The [] to provide a more accurate simulation of the temperature profile in the core at power.

Core Bypass

The core bypass region is modeled by []. The bypass flow channels include the control rod guide tubes and instrument tubes inside the fuel assemblies. In addition, it includes the area between the core baffle plate and the core barrel which is exterior to the fuel assemblies. All of the bypass constituents are []. The control rods are assumed to be [] Flow enters the bypass from the lower plenum and exits into the upper plenum.

Upper Plenum

The upper plenum of the reactor vessel, which extends from the [] In the upper plenum the coolant flows upward from the core and then turns radially outward to leave the vessel through the outlet nozzles. Another flowpath involving the upper plenum is the one between the lower portion of the upper plenum, just above the active fuel, and the control rod guide tubes and UHI support columns. Some flow goes through these structures into the vessel head.

Upper Head

The reactor vessel upper head is a large cylindrical and hemispherical region which extends between the upper plenum and the vessel head itself. It is modeled by RETRAN [] Flow enters the region through the [] unplugged spray nozzles from the top of the downcomer and leaves through the control rod guide tubes and UHI support columns. The only structural components in the interior of the upper head are parts of the Control Rod Drive System.

UHI Support Columns

The UHI support columns, cylindrical flowpaths from the lower part of the upper plenum to the lower part of the upper head, are represented []. The flow column structure interior volumes are []

Control Rod Guide Tubes

The control rod guide tubes, [] in the RETRAN model, extend from the top of the core through the upper support plate and discharge into the reactor vessel upper head. Some flow enters the guide tubes through slots in the tube sides in the upper plenum, while the rest of the flow comes directly from the fuel assemblies and control rod guide thimbles.

3.2.1.2 Reactor Coolant Loops

[] fluid volumes are used to represent the loop piping. In addition, [] to model each RCP. The volumes in the single loop are discussed here and correspond in location to the volumes in the triple loop.

[] represents the SG outlet piping to the RCPs.

[] by the RETRAN centrifugal pump model. The cold leg piping is simulated by [] extends outward from the pump and runs horizon-tally into the reactor vessel. The vessel inlet nozzles [].

3.2.1.3 Steam Generators

The SG volumes in the single loop are discussed here and correspond in location to the volumes in the triple loop. The SG inlet plenum is modeled by []

[]. The SG tubes

are represented by [] The detailed nodalization allows an accurate simulation of the SG density gradient, which is an especially important consideration during natural circulation. The RETRAN []

[]. The percentage of plugged tubes that is modeled is specified based on the particular analysis. The SG outlet plenum, [], is similar to the inlet plenum. As with the inlet plenum, the fluid volume [].

3.2.1.4 Pressurizer

The McGuire/Catawba pressurizer is represented by [] connect it to the RCS. [], which runs from the bottom of the pressurizer to the B hot leg. [] models the pressurizer spray line, which connects each cold leg volume to the top of the pressurizer. The loss coefficients associated with []

[] The PORV and safety valve junctions are modeled at the top of the pressurizer.

Phase separation in the pressurizer is simulated by the [

] . In some cases an []
] between the liquid and vapor regions.

3.2.1.5 Cold Leg Accumulators

The four cold leg accumulators and their associated injection lines are [] .

The RETRAN air model is used to simulate the nitrogen overpressure on top of the tanks.

[] allows the tanks to discharge when the RCS pressure drops below 600 psig.

3.2.2 Secondary System Nodalization

3.2.2.1 Main Feedwater Lines

[] represents the MFW lines between the []
] represents the MFW lines between the [] and the SGs.

3.2.2.2.1 Preheat Steam Generators

The preheat steam generator secondary side is modeled by a total of [] volumes. []
]. Both McGuire units and Catawba Unit 1 originally had split-
flow preheat steam generators, which have [] full power feedwater flows out
the top and side preheater outlets, [], respectively. Catawba Unit 2 has
counter-flow preheat steam generators, which have [] during
power operation. Flow through []

]

The basis for the SG secondary nodalization is twofold. The tube bundle has been [] encountered there. The downcomer has been []

The RETRAN []

3.2.2.2.2 Feeding Steam Generators

The feeding SG secondary side is modeled by a total of [] volumes. The downcomer is

The basis for the FSG secondary nodalization is similar to that for the preheat SGs. The tube bundle has been encountered there. The downcomer has been

The RETRAN

3.2.2.3 Main Steam Lines

Downstream of the MSIVs the nodalization used is station and transient dependent. Section 3.1.3.3 describes the actual plant steam line layouts. Since flows from individual SGs at McGuire are not separated all the way to the turbine,

At Catawba,

at Catawba since the steam lines are separate between the MSIVs and the turbine stop valves. For load rejection transients the atmospheric dump header is modeled as

The main steam lines are not physically different for the FSGs; however, the volume representing the main steam lines is for the FSG nodalization.

3.2.3 Heat Conductor Nodalization

3.2.3.1 Reactor Core

[] conductors are used to model the fuel rods in the reactor core. The conductors are separated into [].

Material properties (thermal conductivity and heat capacity) are []. The fuel gap [] to give the [] fuel temperature, which varies with core average burnup. This approach is used to properly account for the stored energy in the fuel. The RETRAN core conductor model is used for these conductors in order to allow power generation in the fuel material. 2.6% of the power generated in the core is assigned to direct heating of the moderator rather than deposition of energy in the fuel pellets.

3.2.3.2 Steam Generator Tubes

[] heat conductors are used to represent the tubes in each of the SGs. There is [] . Material properties are []

3.2.3.3 Structural Conductors

These conductors represent the plant components which do not generate power or conduct heat from the primary to the secondary, but which can affect the plant transient response by transferring energy to or from the working fluid. The stored energy and heat capacity of these conductors tend to dampen changes in RCS conditions. During an overcooling event the structural conductors transfer heat to the primary coolant and thus retard the cooldown. Conversely, during an overheating transient the structural conductors act as a heat sink and reduce the magnitude of the increase in the primary coolant temperature. The effect of the structural conductors is most apparent during long transients. During short transients which do not exhibit severe undercooling or overcooling, the heat transferred from the structural conductors is unimportant relative to the large amount of decay heat in the core. However, the structural conductors represent a significant heat load for long-term cooldown, once decay heat has decreased.

The key parameters for the structural conductors are the mass and the heat transfer area. These determine the initial stored energy and the effectiveness as a heat source or sink. In order to

[]

Certain structural components are not included in the model because they are considered to have no potential impact on the plant transient. These components include the

Passive heat conductors representing the pressurizer walls in the McGuire/Catawba model. The pressurizer vessel metal is

The McGuire and Catawba tubesheet for both the preheat SGs and the feeding SGs is modeled by

The heat conductors which are used in the McGuire/Catawba base model are listed and described in Table 3.2-1. The heat conductors which are used in the FSG model are listed and described in Table 3.2-2.

3.2.4 Control System Models

3.2.4.1 Process Variable Indications

RETRAN control systems are used to take the calculated plant thermodynamic conditions and put them into the form in which they are output by the plant instrumentation. This provides indications which are useful for comparison to plant data and which are familiar to the plant operators and engineering personnel.

Pressurizer Pressure

The fluid pressure at the elevation of the pressurizer upper pressure tap is converted to gauge pressure by subtracting 14.7 psi. This pressure is used as input to RPS and ESF functions in the model.

Pressurizer Level

The cross-sectional area of the RETRAN pressurizer volume is different than that of the plant pressurizer. This is due to the fact that the plant pressurizer is a right circular cylinder plus hemispherical top and bottom sections, while RETRAN volumes are right circular cylinders. Therefore, a control system is used to relate the pressurizer liquid level in the model to the level that would be indicated at the plant. This level is input to the interlock which turns off the pressurizer heaters on low pressurizer level and to the high pressurizer level reactor trip.

Wide Range RCS Loop Temperatures

The wide range hot leg and cold leg temperatures are indicated by RTDs located in thermowells in the loop piping. A change in fluid temperature is not indicated immediately at the plant due to the time required to transfer heat through the thermowell to the RTD and change the temperature of the measuring device. Experimental data indicates that the time delay can be approximated by a [] applied to the actual fluid temperature.

Narrow Range RCS Loop Temperatures

The narrow range hot leg and cold leg temperatures, as well as the average temperature and ΔT signals, are derived from RTDs located in bypass piping connected to the main coolant loops. A change in fluid temperature is not indicated immediately at the plant due to the time required for the change to propagate through the bypass loop and to change the temperature of the measuring device. Experimental data indicates that the time delay can be approximated by a [] applied to the actual fluid temperature. To simulate average temperature and ΔT indications, [] is applied consistent with the plant Technical Specifications since the control room indications are the same signals as those used for the RPS.

Steam Line Pressure

The volume pressures [] . This pressure is used as an input to the ESF functions in the model.

SG Level

The narrow range and wide range SG level instruments display level from 0-100%, as shown on Figures 3.1-7, 3.1-8, and 3.1-12. The level indication is derived from the pressure difference between taps in the steam generator. A RETRAN control system is used to simulate this process using the []. The output narrow range level indication is input to the RPS and ESF functions in the model. The wide range indication is used for information only. Control system simulated level indications []

3.2.4.2 Reactor Protection System Functions

Five RPS functions are modeled with control systems:

- 1) Overtemperature ΔT
- 2) Overpower ΔT
- 3) Low pressurizer pressure
- 4) Low-low SG narrow range level
- 5) High flux

The control systems for the ΔT trips compute the appropriate ΔT setpoints based on the Technical Specification equations and subtract the indicated ΔT values from these setpoints to determine whether trip occurs. The overtemperature ΔT trip equation reduces the ΔT setpoint for low coolant pressure and high coolant temperature to protect against departure from nucleate boiling. The overpower ΔT trip equation reduces the ΔT setpoint for high or increasing coolant temperature to protect against centerline fuel melt. Both ΔT trip equations also reduce the setpoints for excessive axial flux imbalance, []

[]. Lead-lag compensation is applied to the low pressurizer pressure reactor trip via a control system before the relevant value is compared against a fixed setpoint. The low-low SG narrow range level trip setpoint is a lagged programmed function of neutron flux for the preheat SGs. The feedring SG low-low narrow range level trip setpoint does not vary with neutron flux. A lagged value of indicated level is then compared with the setpoint to determine whether trip occurs. []

3.2.4.3 Engineered Safeguards Functions

Four ESFAS functions are modeled with control systems:

- 1) Steam line isolation on low steam line pressure
- 2) ECCS pump start on safety injection
- 3) AFW pump start on low-low SG narrow range level
- 4) Turbine trip and MFW isolation on high-high SG narrow range level

The first three actions are coincident with reactor trip and use the same control systems. The fourth function is similar to the reactor trip on low-low SG narrow range level but uses a higher setpoint.

3.2.4.4 Plant Control Systems

RETRAN control systems are used to model the performance of certain plant control systems during transient analyses. These control systems fall into two general types. Some control systems, examples of which are given below, are modeled directly as designed. Other control systems are modeled indirectly. Indirect modeling is used when the desired control system action is known beforehand. This method saves time over direct modeling and can also be used to simulate controller action with undocumented setpoints, e.g. a field adjusted gain setting, or with failed components, e.g. a valve which cycles erratically.

Pressurizer Pressure Control

A proportional plus integral controller is used which models the actual plant controller including setpoints, signal range limits, and anti-windup limits.

Rod Control

The actual plant controller is modeled in detail for transients in which automatic rod control is deemed to be important. Since the turbine is not modeled in general, the turbine dependent Rod Control System inputs are predicted separately if unknown or are input from plant data if available.

Steam Dump Control

The actual plant controller is modeled with a [the opening and closing of the dump valves.

3.2.4.5 Transient Boundary Conditions

The RETRAN control system models can effectively model known or postulated transient boundary conditions, such as those resulting from operator action. In general, RETRAN control

systems simulate control actions by modulating valves, changing positive or negative fill flow rates, changing reactivity, and activating or defeating trips.

Operator actions significantly affect the plant response during almost all realistic plant transients. Experience at McGuire and Catawba has shown that the operators will promptly take action in order to prevent reactor trips or, failing that, to ensure a normal post-trip response. Following a trip, the operators monitor AFW flow to ensure that proper SG level is achieved. The normal procedure to simulate [

].

3.2.5 Boundary Condition Models

3.2.5.1 Fill Junctions

Fill junctions are used to specify flow between a volume and an infinite source or sink. Positive fill junctions provide flow into a volume, while negative fill junctions remove mass from a volume. The flow rate can be specified as a function of time or of pressure in the volume, or it can be controlled by a control system.

Systems which provide flow to the RCS or the SGs are modeled by[]. These include MFW, AFW, HHSI, and IHSI. The flow of steam through the turbine control valves is modeled by[]. For most applications there is a reactor trip at the beginning of the problem, either immediately before or after a turbine trip, so the steam flow to the turbine is cut off. For applications which do not involve a rapid turbine trip, the flow through the steam line [

].

3.2.5.2 Critical Flow and Fixed Pressure Boundary Conditions

The RETRAN critical flow model, in conjunction with a fixed pressure boundary condition volume, is used to model flow through relief valves on the RCS and the main steam lines. Relief valves are modeled by junctions between the associated upstream volumes and the fixed pressure volume, which is an essentially infinite sink with a user-specified backpressure. The Henry (subcooled) and Moody (saturated) choking option is used with the relief valve junctions. Because of the large pressure differences between the upstream volumes and the fixed pressure volume, RETRAN calculates any flow through the junctions to be choked. Since the design flow

rates of saturated steam through the valves are known, the []. The choked flow model then automatically calculates the flow rate as the fluid conditions in the upstream volume change. This modeling technique is used for the [].

3.2.6 Code Models

3.2.6.1 Power Generation

RETRAN offers the user several options for modeling core power generation. Several different methods are used, depending on the application. For a best estimate transient analysis, the point kinetics model is generally used. This model calculates neutron power assuming that the flux shape is constant while the magnitude changes with time. The code uses one prompt neutron group and six delayed groups. A moderator temperature coefficient and a fuel temperature coefficient are used to account for reactivity feedback from changes in those parameters. Control rod scram worths are input in order to model reactivity insertion after reactor trip. Post-trip decay heat is calculated with the built-in 1979 ANS Standard (Reference 3-2) decay heat option. Input data for the decay heat model is selected consistent with the application. The point kinetics model is adequate for most PWR applications.

For a benchmark analysis in which []

].

3.2.6.2 Centrifugal Pumps

The RETRAN centrifugal pump model is used to simulate the performance of the RCPs. The input data are from the pump technical manuals with the exception of the []

]

3.2.6.3 Valves

The basic RETRAN valve model is used for most of the valves in the McGuire/ Catawba base model. With this model the valves open and reseal according to the action of their associated trips. Modeled in this manner are the pressurizer and steam line PORVs and safety valves, the cold leg accumulator discharge check valves, the turbine stop valves, the MFW isolation valves, and the MSIVs. The condenser dump and pressurizer spray valves use the RETRAN valve model option in which the junction area is controlled by a control system.

3.2.6.4 Phase Separation

RETRAN has two methods of modeling phase separation within a fluid volume: the bubble rise model and slip. The bubble rise model is [] in the McGuire/Catawba model, while slip [] used.

The bubble rise model is a correlation which allows the enthalpy in a volume to vary with height. It is a semi-empirical fit to data from a number of high pressure blowdown experiments. The void fraction in the volume is assumed to vary linearly with height from the bottom of the volume to the mixture level. Above the mixture level, the fluid is 100% steam. The model is [] which have a definite separation between vapor and liquid, i.e. the [] In addition, the bubble rise model is []

Slip models provide for unequal velocities between the liquid and vapor phases. Since McGuire and Catawba are PWRs with subcooled water in the primary coolant loops, unequal phase velocities normally exist only in the steam generator secondary side. RETRAN has two slip models: algebraic slip and dynamic slip. The algebraic slip model uses a drift flux approach to calculating the relative velocity between the vapor and liquid phases. The dynamic slip model is

[

]

For applications in which there is significant voiding and phase separation in the primary system (notably small break LOCA or extended loss of feedwater), the dynamic slip model can provide a reasonable simulation of two-phase phenomena in the RCS. The non-equilibrium bubble rise model is used in the reactor vessel head to allow for void formation and separation from the water.

3.2.6.5 Non-Equilibrium Pressurizer

RETRAN has a general non-equilibrium volume option which can be used with any bubble rise volume. This option allows the liquid and vapor regions of the volume to have different temperatures. The [

]

Accurate modeling of the pressurizer is necessary to correctly predict the transient RCS pressure response. During normal operation the pressurizer is at near equilibrium conditions - heat from the pressurizer heaters balances condensation from pressurizer spray bypass flow and ambient heat losses - so both the liquid and vapor regions of the pressurizer are essentially at saturation. During a pressurizer outsurge, such as that characteristically seen immediately following reactor trip, the pressure decreases as the steam bubble expands. Bulk flashing of the saturated liquid occurs as the pressure decreases, and the temperature in the liquid decreases with the pressure along the saturation line. In both cases the standard RETRAN homogeneous equilibrium model (HEM) technique will adequately simulate pressurizer phenomena.

During a pressurizer insurge, however, non-equilibrium effects can be significant. Subcooled water from the hot leg mixes with the saturated water in the pressurizer liquid region to produce a somewhat subcooled liquid region or, in some cases, a layered effect of saturated water over subcooled liquid. As the liquid level increases the steam bubble compresses and, since the steam behaves like an ideal gas, the temperature increases. The overall result is superheated steam above subcooled liquid, separated by a layer of saturated water. Since the temperature of the steam is higher than both the liquid and the pressurizer walls, the steam will tend to condense on the metal and the steam-water interface, reducing the pressure and temperature of the vapor. A one volume HEM representation of the pressurizer would instantaneously mix the subcooled fluid from the hot leg with all of the saturated fluid in the pressurizer, and it would not account

for the different temperatures in the liquid and vapor regions. It is evident that a HEM representation of the pressurizer cannot account for the important phenomena during an insurge.

Use of the non-equilibrium option enhances the ability of a one volume pressurizer model to simulate the transient response during an insurge. Since the liquid region is considered separately from the steam bubble, an insurge does not result in rapid condensation of the pressurizer vapor. The non-equilibrium option allows the steam bubble to superheat during an insurge. The non-equilibrium option also includes the ability to specify a heat transfer coefficient between the pressurizer vapor and liquid regions, so interphase heat transfer can be modeled. However, this model is somewhat non-mechanistic, since the heat transfer coefficient is user-input rather than being calculated based on fluid conditions.

Another facet of the non-equilibrium representation is the pressurizer spray junction model. Using the spray junction option causes the spray water to condense steam while moving through the pressurizer steam bubble, thus removing both energy and mass from the region, rather than simply mixing with fluid in the vapor region and desuperheating the steam. The spray junction model is used since it is considered to be more mechanistic than a normal junction for this application.

The non-equilibrium pressurizer model is used for best estimate safety analyses on McGuire and Catawba. This model does not fully account for condensation effects in the pressurizer steam space and thus overpredicts RCS pressure during an insurge. However, it is superior to an equilibrium modeling approach. For some applications it is appropriate to use [

]

3.2.6.6 Non-Conducting Heat Exchangers

The RETRAN non-conducting heat exchanger model allows energy to be transferred to or from a fluid volume without using a conductor. This model is used to simulate the energy addition to the pressurizer liquid from the pressurizer heaters. Two heater banks are modeled. Bank C is controlled by a proportional plus integral controller in the plant. Since RETRAN []

controlled by a proportional plus integral controller in the plant. Since RETRAN[
]Banks A, B, and
D in the plant have simple on/off control which is duplicated in RETRAN. The total capacity of
Bank C is[
].

It is also possible to use a non-conducting heat exchanger to model the[
]

3.2.6.7 Local Conditions Heat Transfer

The local conditions model allows the approximation of variable heat transfer in a volume in
which void fraction varies substantially with elevation, particularly in the case of a separated
volume with a variable mixture level. This model[
]

The local conditions heat transfer option is also used to model the pressurizer wall heat transfer.
This modeling approach may also be used for other passive structural components when
additional accuracy is needed.

3.2.7 Code Options

3.2.7.1 Steady-State Initialization

The RETRAN steady-state initialization option is used to obtain stable initial conditions for each transient analysis. This option greatly simplifies the specification of the initial conditions of a RETRAN run. The steady-state initialization routine solves the mass, momentum, and energy equations without the time-dependent terms and thus obtains consistent initial values with a minimal amount of input data.

Primary system conditions for McGuire/Catawba models are set by specifying [

]

The initial SG power removal fraction is set at 0.25 for each generator in order to provide a symmetric initialization.

3.2.7.2 Iterative Numerics

The iterative numerics option is used for time step control. Iterative numerics is a semi-implicit numerical solution method which allows the results of the time step advancement to be evaluated before the solution is accepted. Predictive algorithms are used to calculate an appropriate time step size which will give a stable, accurate solution to the fluid conservation equations. If a converged solution is not achieved in a given number of iterations, a reduced time step size is used. This is similar to restarting a job with smaller time steps, but it has the advantage of being automatic.

3.2.7.3 Enthalpy Transport

The enthalpy transport option is used to account for situations in which the fluid in a volume exchanges a significant amount of energy with an external source or sink. In those situations, the fluid enthalpy will vary between the volume inlet, center, and outlet, and the enthalpy transport option accounts for this variation. The option is used [

].

The enthalpy transport option is useful in obtaining a good steady-state initialization at full power conditions. However, it can lead to anomalous results in low flow, low heat transfer situations, particularly in the two-phase volumes on the secondary side of the SG. When this situation occurs, the enthalpy transport option may be turned off during a generalized restart.

3.2.7.4 Temperature Transport Delay

The temperature transport delay option accounts for the fact that temperature changes move through piping as a front, while the finite difference HEM approach instantaneously and homogeneously mixes the incoming fluid with the contents of a volume. Using the temperature transport delay option with a volume treats the movement of fluid more mechanistically by establishing a mesh substructure within the volume to track temperature front movement.

The temperature transport delay option is used for [

]

3.2.7.5 Heat Transfer Map

Two sets of heat transfer correlations are available for use with RETRAN-02. The forced-convection map is a set of heat transfer correlations which cover single-phase, two-phase, and supercritical fluid conditions. The correlations are generally appropriate for the fluid velocities associated with forced flow. The combined map uses the same heat transfer relationships as the forced map, except that correlations more appropriate for low flow conditions are used if the Reynolds number is less than 2500 (single-phase) or if the mass flux is less than $200,000 \text{ lbm/ft}^2\text{-hr}$ (two-phase). The combined map also includes a correlation for condensation. The [] is used for McGuire/Catawba transient analysis.

3.2.7.6 Film Boiling

The available correlations for use in the film boiling heat transfer regime include Groeneveld 5.7, Groeneveld 5.9, and Dougall-Rohsenow (Reference 3-3, Section 111.3.2.5). The Dougall-Rohsenow correlation is based on liquid flow at low pressure. Groeneveld 5.9 is based on data from vertical and horizontal flow in round tubes and vertical flow in annuli, while Groeneveld 5.7 is based on the annuli data alone. [] is used in the McGuire/Catawba model because it is considered that the basis of that correlation is most similar to situations which would be encountered during PWR transients. The choice of the film boiling correlation is [] initial conditions.

3.2.7.7 Critical Heat Flux

There are three options for the calculation of critical heat flux. The default option for the combined heat transfer map is a combination of four correlations: B&W-2, Barnett, and modified Barnett for high flow rates and Kutateladze for low flow rates. A General Electric correlation or a Savannah River Laboratory correlation may be specified instead of the high flow rate-portion of the default option. These correlations are discussed in Reference 3-3, Section 111.3.2.5. The McGuire/Catawba model employs the [] initial conditions.

3.2.7.8 Volume Flow Calculation

The choice of the donor cell option vs. the arithmetic average option is not important for the intended applications.

3.2.7.9 Wall Friction

RETRAN calculates the pressure drop due to wall friction using the Fanning friction factor, which is a function of Reynolds number. Several options are available to model the change in wall friction due to two-phase effects. The Baroczy, homogeneous, or Beattie multipliers can be applied to the calculated single phase pressure drop. The [] model is used in the McGuire/Catawba RETRAN model.

3.2.7.10 General Transport Model

The general transport model is used to calculate the boron concentration in []
The boron is assumed to be soluble in the transport medium and to have no direct effect on the fluid equations. The basic equation computes the time rate of change of boron mass in a control volume from the net inflow through connected junctions.

3.2.8 Dissimilarities Between Units

The differences in RCS loop geometry are significant enough to warrant separate base models for each unit. For a given unit model the coolant loops are lumped or separated depending on the asymmetry of the transient being analyzed. Differences between units, including the major differences discussed in Section 3.1.6, are included in unit specific models depending on the degree to which such differences affect the transient being analyzed.

3.2.9 Summary of Experience

The major positive conclusions concerning the applications of the code and its models are listed below.

- The basic constitutive equations accurately describe the fluid behavior in the RCS and SGs during operational transients.

- The nodalization scheme is extremely flexible, allowing the user to construct a detailed plant model or to conduct separate effects analyses on components such as the pressurizer. This flexibility has also enabled the modeling of other plant systems, including HHSI, IHSI, and LHSI.
- The heat transfer package provides a good representation of heat transfer, both single phase and two-phase.
- The water properties are accurate in the range of application.
- Steady-state initialization greatly simplifies the process of obtaining a desired set of initial conditions.
- Iterative numerics generally provides reasonable time step control and reduces the necessity of restarting jobs to circumvent time step related errors.
- The generalized restart and reedit capabilities of RETRAN are very useful, and they significantly increase the efficiency with which the code is used.
- The fixed pressure volume, fill, and critical flow models allow a complete and reasonable specification of fluid boundary conditions for various types of analyses.
- The non-equilibrium pressurizer model provides an accurate simulation of RCS pressure trends.
- The point kinetics model adequately predicts the reactor power response to the types of reactivity changes which arise during typical operational transients.
- The reactor coolant pump model accurately reflects the interaction of the pumps and the primary fluid during normal pump operation and coastdown.
- The control system models and trip logic are extremely flexible and useful for modeling automatic control actions as well as operator action.

Similar to other one-dimensional HEM codes, the current models in RETRAN have been found to have shortcomings in some areas and are incapable of adequately simulating particular phenomena. One recognized shortcoming is that the lack of a general non-equilibrium modeling

capability detracts from the ability of the code to simulate some small-break LOCA behavior. This limitation must be recognized whenever such applications are undertaken.

In general, the overall experience with modeling the McGuire and Catawba transient response using RETRAN has been good. Despite shortcomings in some areas, the code has been proven capable of accurately simulating the transient thermal-hydraulic behavior of a Westinghouse PWR with preheater-type steam generators. Due to the relatively minor differences between the preheater-type steam generator and the feeding steam generator, the code should be capable of accurately simulating the transient thermal-hydraulic behavior with the feeding steam generators.

L
L
C
C
L
L
L
L
L
L
C
L
L
L
L
L
L
L

L
L
U
C
L
L
L
L
L
L
L
L
L
L
L
L
L
L

II II II II II II II II II II II II II II II II II

[illegible]

Adjacent Conductor <u>Number</u>	Volume <u>Number(s)</u>	<u>Description</u>	<u>Material</u>
--	----------------------------	--------------------	-----------------

[illegible]

Table 3.2-2
McGuire/Catawba Base Model
Feeding Steam Generator Heat Conductors

<u>Adjacent Conductor Number</u>	<u>Volume Number(s)</u>	<u>Description</u>	<u>Material</u>

(Page 3-63 intentionally deleted)

Figure 3.2-1
McGuire/Catawba RETRAN Model
Nodalization Diagram (two-loop)




Figure 3.2-2
McGuire/Catawba RETRAN Model
Nodalization Diagram (one-loop)





Figure 3.2-3
McGuire/Catawba RETRAN Model
Feeding Steam Generator
Nodalization Diagram



3.3 McGuire/Catawba VIPRE Model

3.3.1 Core and Fuel Assembly Description

The McGuire/Catawba reactor core consists of 193 fuel assemblies as shown in Figure 3.3-1. Spacer grids, end fittings, fuel rods, and guide tubes form the basic structure of a fuel assembly as shown in Figure 3.1-2. The lower and upper end spacer grids are made of Inconel, while the six intermediate spacer grids are made of Zircaloy-4. Each fuel assembly is a 17 by 17 array containing 264 fuel rods, 24 control rod guide tubes, and one incore instrument guide tube. The fuel rod consists of dished-end, cylindrical pellets of uranium dioxide clad in cold-worked Zircaloy-4. The fuel assembly and fuel rod dimensions, and other related fuel parameters used in the thermal-hydraulic analyses are given in Table 3.3-1.

3.3.2 Model Development

3.3.2.1 One-Pass Hot Channel Analysis

VIPRE-01 (Reference 3-4) is capable of performing one-pass hot channel analysis. A subchannel is defined as the flow area between adjacent fuel rods in an array. By definition, the hot channel in a PWR core is the subchannel with the most limiting departure from nucleate boiling ratio (DNBR) on one of its adjacent fuel rods. In one-pass analysis the objective is to model the hot subchannel and those nearest to it in detail, and then surround these with larger and larger lumped channels proceeding outward toward the periphery of the core. In this way the entire core can be modeled with a limited number of channels, while maintaining a fine level of detail and accuracy in the area of the hot subchannel. This methodology is an improvement on the multi-pass or "cascade" approach used in other methodologies, where two or three separate simulations in series are necessary using boundary conditions taken from the preceding ones. One-pass analysis is not only more efficient but it allows for explicit modeling of the coupling between the hot subchannel and the rest of the core.

3.3.2.2 Transient Analysis Models

The geometry setup for one-pass analysis is based on the location of the hot subchannel. For a given geometry and inlet fluid condition, the location of the hot subchannel is determined by the pin radial-local power distribution and the critical heat flux (CHF) correlation utilized. Figures 3.3-2 and 3.3-3 show the assembly radial and pin radial-local power distributions, respectively, used to analyze transients resulting in symmetrical core radial power distributions. These power distributions originated from [] power distributions. The major modification

is the [] in the hot assembly. However, the maximum pin radial-local peak of [] is preserved.

Three core models, comprised of [] channels, have been developed as shown in Figures 3.3-4 to 3.3-6. The detailed [] channel model has been constructed in order to identify the location of the hot subchannel and to show that the simplified models can accurately predict the local coolant flow rate and thermal-hydraulic properties of the core and most importantly of the hot channel.

In the [] channel model, the [] is modeled as an array of subchannels (Figure 3.3-4) while the [] are modeled as individual channels as shown in Figure 3.3-4. Finally, the [] Utilizing the BWCMV CHF correlation (Reference 3-5), the hot subchannel is identified to be [] channel. However, should CHF correlations other than the BWCMV correlation be utilized (for example: the W3-S correlation), the hot subchannel can be identified as Channel [] subchannel. The solution method utilized for the calculation is the direct method.

After the location of the hot subchannel has been identified, the [] channel model (Figure 3.3-5) is constructed to show that []

].

Since, depending on the CHF correlation utilized, []

]

3.3.2.3 Simplified Models Justification

To show that the simplified model can properly and correctly predict the local coolant flow rate and thermal-hydraulic properties for steady-state and transient analyses, simplified model results are compared to results from the more detailed models. If the simplified model results are equivalent or conservative compared to the more detailed model results, then it is justified to use the simplified models for analyses. The solution method utilized is the RECIRC method. MDNBRs presented in this section are calculated with the BWCMV critical heat flux correlation.

Steady-State Comparisons

Input Conditions:	Power	= 66.945 kW/rod (100%FP)
	Pressure	= 2285.9 psia
	Core flow	= 2.5574 Mlbm/hr-ft ²
	Inlet enthalpy	= 562.4 Btu/lbm

Results for this case are presented in Table 3.3-2. The similarity of all the results verifies that the simplified [] channel model can be used without losing the accuracy of more detailed and expensive models.

Transient Comparisons

An arbitrary transient case with power maintained at 100% and the inlet mass flux ramped from 100% to 75% of its initial state value has been run for 2.0 seconds. Results are given in Table 3.3-3. Results show that the agreement between the predictions of MDNBR during the transient as well as other local fluid parameters is excellent. The capability of the simplified model for transient analysis has been demonstrated.

Conclusion

In conclusion, the results of both detailed and simplified nodalizations are very similar for both steady-state and transient cases. Thus, instead of using the more detailed and expensive models, the simplified [] channel model will be used for core thermal-hydraulic analyses for normal symmetrical transients. For transients resulting in asymmetrical flow distributions or inlet coolant temperature gradients outside the hot assembly, such as the steam line break, the [] channel model may be modified so that []

can be modeled for proper simulation of the inlet temperature gradients. Also, the RECIRC solution method must be utilized because of the large density gradient between channels and because of the low flow velocity due to the reactor coolant pumps tripping in the offsite power unavailable situation.

3.3.2.4 Axial Noding

In general, VIPRE predictions are sensitive to axial noding in that enough nodes must be provided to resolve the detail in the flow field and in the axial power profile. However, once a point of sufficient accuracy is reached, VIPRE is relatively insensitive to further axial refinement. In order to demonstrate the correctness of the above statement, three cases were analyzed with the [] channel symmetrical power distribution model divided into [] axial increments corresponding to [] inches per active fuel node, respectively. The results in Table 3.3-4 show that for [] or more axial nodes, the local coolant conditions are insensitive to the number of axial increments. The hot channel MDNBR changes by only []% when the number of nodes are decreased from []. Since the MDNBR [

] This indicates that [] axial nodes is a sufficiently large number for accurately calculating hot channel conditions. However, [] axial nodes will be used for thermal-hydraulic transient analyses.

3.3.3 Code Option and Input Selections

3.3.3.1 Thermal-Hydraulic Correlations

Flow correlations are used in VIPRE-01 to model two-phase flow effects. In the flow solution, correlations model the effects of two-phase flow and friction pressure losses, subcooled boiling, and the relationship between flowing quality and void fraction. For transient analyses, the subcooled void, the bulk void, and the two-phase friction multiplier are modeled by using the

[

]

Turbulent Mixing Correlations

The energy and momentum equations of the VIPRE-01 code contain terms describing the exchange of energy and momentum between adjacent channels due to turbulent mixing. The effect of turbulent mixing is empirically accounted for in VIPRE-01. The turbulent cross flow, w' , has the form:

$$w' = A \times Re^B \times S \times G$$

Where:

Re = Reynolds number

S = gap width, inches

G = mass flux, lbm/sec-ft²

A =

$$B = \left[\begin{array}{c} \\ \\ \end{array} \right]$$

Turbulent crossflow mixing is a subchannel phenomenon, and is not generally applicable to lumped channel analysis. The turbulent cross flow is correlated in terms of flow exchange through a single gap. In lumped channel modeling, the crossflow mixing must be reduced to take into account the effects of lumping many gaps such that

$$w' = w'/N_R \text{ (Reference 3-4)}$$

where N_R = number of rod rows between adjacent channel centroids. Thus, for MK-BW fuel which has 17x17 fuel rods in an assembly, the mixing coefficient, A, between two lumped assembly channels becomes

$$A = \left[\begin{array}{c} \\ \\ \end{array} \right]$$

However, the mixing coefficients between any two lumped channels are set to $\left[\begin{array}{c} \\ \\ \end{array} \right]$.

The turbulent momentum factor (FTM) tells how efficiently the turbulent crossflow mixes momentum. For the $\left[\begin{array}{c} \\ \\ \end{array} \right]$

$\left[\begin{array}{c} \\ \\ \end{array} \right]$

Turbulent mixing in two-phase flow is generally assumed to be []

Pressure Losses

Pressure losses due to frictional drag are calculated in the code for both axial and transverse flow. The friction factor for the pressure loss in the axial direction is determined from empirical correlation as:

$$f = A \times Re^B$$

The code evaluates both a turbulent and a laminar set of coefficients and selects the maximum. The values selected for parameters A and B are based on []

Turbulent Flow:	$A = [\quad]$	$B = [\quad]$
Laminar Flow:	$A = [\quad]$	$B = [\quad]$

The coefficient of form drag in the gap between adjacent channels is on the order of [] for the transverse pressure loss (Reference 3-4). Thus, it is set equal to [] for transient analyses.

Local Hydraulic Form Loss

The local hydraulic form loss coefficient is set as a constant to model the irrecoverable axial pressure loss as shown below.

$$\Delta P = KG^2/2\rho g_c$$

Where:	K	= spacer grid form loss coefficient
	G	= mass flux, lbm/sec-ft ²
	ρ	= density, lbm/ft ³
	g_c	= 32.174 lb-ft/sec ² lbf

The spacer grid form loss coefficients for the MK-BW fuel assembly are used in the transient analyses.

Critical Heat Flux Correlations

One of the critical heat flux correlations used to perform DNB analysis is the B&W BWCMV CHF correlation. The BWCMV CHF correlation has been reviewed and approved by the NRC for licensing analysis of BAW 17 x 17 Mark-BW geometry fuel with Zircaloy grids. Using the LYNX-2 open subchannel code (Reference 3-6), the design MDNBR limit of 1.21 was determined. The range of use for the BWCMV correlation is:

Pressure, psia	1500 to 2455
Mass velocity, 10^6 lbm/hr-ft ²	1.0 to 3.5
Quality, (equilibrium)	-0.22 to 0.22

A statistical core design (SCD) limit of 1.40 (Reference 3-14) has been established for the BWCMV correlation using the VIPRE code (Reference 3-7). Either the SCD limit of 1.40 or the correlation limit of 1.21 will be used for transient core thermal-hydraulic analyses, with a sufficient margin applied to account for applicable DNBR parameters.

The second CHF correlation used to perform DNB analysis is the BWU-Z CHF correlation (Reference 3-11). The BWU-Z correlation was reviewed and approved by the NRC for use in McGuire/Catawba analyses in References 3-12 and 3-13. The range of applicability of the BWU-Z correlation is:

Pressure, psia	400 to 2465
Mass velocity, 10^6 lbm/hr-ft ²	0.36 to 3.55
Quality, (equilibrium)	< 0.74

A set of correlation limits for four pressure ranges have been determined to maintain a 95 percent confidence that 95 percent of the limiting fuel pins are not in film boiling:

<u>Pressure Range (psia)</u>	<u>DNBR Limit</u>
400-700	1.590
700-1000	1.199
1000-1500	1.125
1500-2400	1.193

An SCD limit, which incorporates many of the uncertainties, may also be applied as a MDNBR limit. A statistical core design (SCD) limit of 1.37 has been established for the BWU-Z correlation using the VIPRE code (Reference 3-14). Either the SCD limit of 1.37 or the pressure range dependent correlation limits will be used for transient core thermal-hydraulic analyses, with a sufficient margin applied to account for applicable DNBR penalties.

For transients with system pressure less than 1600 psia, the W-3S CHF correlation may also be used. The range of use for the W-3S correlation is (Reference 3-4):

Pressure, psia	1000 to 2300
Mass velocity, 10^6 lbm/hr-ft ²	1.0 to 5.0
Quality, %	-0.15 to 0.15

However, it has been shown recently (Reference 3-8) that the W-3S correlation is also applicable for pressure and mass flux as low as 700 psia and 0.5×10^6 lbm/hr-ft², respectively.

Other CHF correlations that have been reviewed and approved by the NRC may also be used to perform DNBR analyses.

3.3.3.2 Conservative Factors

When predicting DNBR with the BWCMV or BWU-Z correlations, the SCD design limit will generally be used. The SCD design limit accounts for all of the uncertainties (with one exception), and therefore additional conservative factors are unnecessary. Only the conservative factor to account for a possible core inlet flow maldistribution, which is detailed below, is applied with the SCD design limit.

If the SCD design limit is not used (all uncertainties explicitly considered) or if CHF correlations other than BWCMV or BWU-Z are used, then the following conservative factors are applied.

Hot Channel Flow Area Reduction

The hot subchannel flow area is reduced by 2% to account for variations in as-built subchannel flow areas (Reference 3-9).

Hot Assembly Flow Reduction

The hot assembly inlet flow is conservatively reduced by 5% (Reference 3-9) from the nominal assembly flow. The flow to the remainder of the core is adjusted such that the entire core flow remains normalized.

Hot Channel Factors

The $F_{\Delta H}^E$ hot channel factor accounts for variation in the fabrication variables which affect the heat generation rate along the flow channel (pellet diameter, density, U_{235} enrichment, and fuel rod diameter). An $F_{\Delta H}^E$ value of 1.03 is considered conservative.

3.3.3.3 Fuel Pin Conduction Model

For most of the transient analyses, the RETRAN heat flux boundary condition is used; the fuel pin conduction model will not be used in the VIPRE-01 transient models. This means that heat is added directly from the cladding surface to the fluid as a boundary condition on the calculation, and the heat transfer solution is not required. However, for transient analyses in which the fuel enthalpy or cladding temperature is the protective criteria (for example: rod ejection, rod withdrawal accident at rated power, and locked rotor), the VIPRE fuel pin conduction model may be used with the neutron power as the transient forcing function.

3.3.3.4 Power Distribution

Radial Power Distribution

For transients resulting in symmetrical power distributions, the 17 x 17 1/8 core assembly radial and hot assembly pin radial-local power distributions shown in Figures 3.3-2 and 3.3-3 are applied. The hot assembly has a radial peak of [] (Figure 3.3-2), and contains the maximum pin radial-local peak of [] (Figure 3.3-3). For transients resulting in asymmetrical power distributions, nuclear design analyses generate core radial power distributions. Radial power distribution as a function of transient time is then input to VIPRE-01.

Axial Power Distribution

For transients resulting in symmetrical radial power distributions, a [] axial power shape is typically applied (Figure 3.3-7). For transients resulting in asymmetrical power distributions, nuclear design analyses generate axial power distributions during transients. On a

case-by-case basis, either these axial power distributions or a [] shape will be utilized as justified.

3.3.3.5 Flow Rate

Vessel Flow Rate

For McGuire/Catawba units, the transient thermal-hydraulic analyses will be based on the technical specifications flowrate, for example, a value of 382,000 gpm. For non-statistical analyses, a -2.2% penalty is applied to account for uncertainties. Reactor coolant flow rates for various reactor coolant pump operating configurations are as follows (Reference 3-10):

4 pumps = 100.0% of the total flow

3 pumps = 72.8% of the total flow

2 pumps = 46.0% of the total flow

Core Bypass Flow

The portion of the coolant flow which is not effective in cooling the fuel is considered bypass flow. There are five areas which contribute to the bypass flow:

- 1) Flow entering the control rod guide tubes and instrument tubes for control rod cooling
- 2) Leakage flow into the outlet nozzle through the gap between the reactor vessel and barrel
- 3) Flow through the spray nozzles into the upper head for head cooling purposes
- 4) Flow in the gap between the peripheral fuel assemblies and the adjacent baffle wall
- 5) Flow associated with the baffle-barrel region

The nominal core bypass flow is []% (Reference 3-9) of the vessel flow. For non-statistical analyses, a []% bypass flow is used to account for uncertainties.

3.3.3.6 Direct Coolant Heating

The amount of heat generated in the coolant is 2.6% of the total power (Reference 3-9).

3.3.3.7 Miscellaneous

Miscellaneous inputs for VIPRE-01 are shown below. These parameters control the execution of the run. Default values for these inputs are used for the transient analyses (Section 2.12.1, Volume 2, of Reference 3-4).

Solution option	RECIRC solution
Maximum number of external iterations	30
Maximum number of internal iterations	20
Minimum number of external iterations	2
Cross flow convergence limit	0.1
Axial flow convergence	0.0001
Damping factor for cross flow	0.9
Damping factor for axial flow	0.9

3.3.4 Discussions of Modeling Differences Between DPC-NE-3000 and DPC-NE-2004 Reports

The modeling and input differences between the DPC-NE-3000 (transient analysis) and DPC-NE-2004 (steady-state analysis) (Reference 3-7) reports are described below. These differences are due to modeling requirements unique to transient DNBR analyses, or incorporating additional conservatism to minimize the impact of changes in core reload design methods or fuel assembly design.

Model Geometry

The geometry setups for the transient analysis models are different from those of steady-state analysis because the DNBR calculations associated with FSAR Chapter 15 transient analyses require more flexible models than the calculations associated with steady-state core reload design require. The steady-state analysis models only need to simulate the most limiting region of the core and symmetrical core phenomena. The geometry setup of the transient models must be capable of simulating the whole core, and also situations including asymmetrical core radial power distributions, core flow maldistributions, and inlet coolant temperature gradients. The transient models also [] that are not needed for steady-state analysis.

Core Radial Power Distributions

The steady-state and transient analysis models utilize different assembly radial and hot assembly pin radial-local power distributions. The transient analysis core radial power distribution originated from a [] power distribution as mentioned in Section 3.3.2.2 and has a maximum hot assembly radial power of []; whereas the steady-state analysis model has a maximum hot assembly power of []. Nevertheless, the maximum pin peak value of [] is utilized by both steady-state and transient analysis models. Furthermore, in the transient models the [] peaks; whereas in the steady-state models, [] peak. The transient model pin peaks are therefore slightly more limiting and ensure that conservative DNBR results will be maintained for any future core reload design with a maximum pin peak of [].

Axial Node Size

In the transient analysis models, the axial node size within the active fuel length is [] inches per node; whereas in the steady-state models, it is [] inches per node. However, Section 3.3.2.4 shows that DNBR is insensitive for axial node size less than [] inches per node.

Turbulent Momentum Factor

In the transient analysis models, the turbulent momentum factor (FTM) is specified as [] to indicate that the turbulent crossflow []; whereas FTM is set to [] in the steady-state models. The use of [] for FTM would provide conservative results.

Lumped Channel Turbulent Mixing Coefficient

The turbulent mixing coefficient, ABETA, is [] in the transient analysis models; whereas in the steady-state models ABETA of the [] channels. The use of [] channel ABETA provides conservative results.

Gap/Length Factor

In the steady-state models, the gap/length factor is calculated []; whereas the [] is used in the transient models due to the fact that the [] geometries. However, this parameter is recognized as being insensitive.

3.3.5 Summary of Experience

The VIPRE-01 code was developed to meet the utility need for a versatile and user-oriented analytical tool for performing core thermal-hydraulic design. VIPRE-01 includes numerous modeling options and correlations in order to satisfy a wide spectrum of utility needs. The model development and analysis results documented in this section demonstrate that VIPRE-01 is well suited for McGuire/Catawba transient analysis. Some of the highlights of this application of the VIPRE-01 code include:

- The nodalization reduction and optimization study performed to justify the use of simplified models was highly successful. Although the intent of this effort was to reduce computer usage, there was no significant loss of accuracy in the predicted thermal-hydraulic conditions or MDNBR.
- VIPRE-01 accepts all necessary boundary conditions that originate either from the plant transient simulation code or the core neutronics simulation code. Included is the capability to subject different boundary conditions to different segments of the core model. For example, different transient inlet enthalpies, heat flux transients, and even different transient pin radial powers or axial flux shapes can be modeled. With this capability virtually any desired application is achievable.
- The selection of code options is consistent with the experience base developed by the utilities that have been utilizing VIPRE-01.

It is expected that the VIPRE-01 code will be utilized indefinitely for McGuire/Catawba transient core thermal-hydraulic applications. The modeling capabilities and the analysis results provided in this section demonstrate that VIPRE-01 can be utilized for accurate and conservative prediction of DNBR during plant transients. This technology remains at or near the current state-of-the-art. Applications will include reanalysis of those FSAR Chapter 15 transients requiring a DNBR evaluation, evaluation of operational events, and resolution of regulatory concerns.

3.4 Methodology Revisions for Westinghouse RFA Fuel

The 14 channel model described previously for the Mark-BW fuel design is also used to model the Westinghouse RFA design. The reference radial pin power distribution remains unchanged, but the peak pin is increased from 1.50 to 1.60. The WRB-2M CHF correlation (Reference 3-16) and the SCD limit of 1.30 developed in Reference 3-17 are used. The axial node size is adjusted to be compatible with the WRB-2M CHF correlation. The RFA design geometry and form loss coefficients are used. The remaining code inputs and options are unchanged.

(Pages 3-81 and 3-82 intentionally deleted)

Table 3.3-1

Mark-BW Fuel Assembly
Component Dimensions Used for Thermal-Hydraulic Analysis

Fuel Pin Diameter	0.37468 in.
Control Rod Guide Tube Diameter	0.48288 in.
Instrumentation Guide Tube Diameter	0.48288 in.
Effective Pin Pitch	0.49690 in.
Assembly Flow Area	38.731 in. ²
Assembly Wetted Perimeter	348.679 in.
Assembly Heated Perimeter	310.749 in.
Unit Channel Flow Area	0.1367 in. ²
Unit Channel Wetted Perimeter	1.1771 in.
Unit Channel Heated Perimeter	1.1771 in.
Control Rod Guide Tube Channel Flow Area	0.1184 in. ²
Control Rod Guide Tube Channel Wetted Perimeter	1.2621 in.
Control Rod Guide Tube Heated Perimeter	0.8828 in.
Instrumentation Guide Tube Channel Flow Area	0.1184 in. ²
Instrumentation Guide Tube Channel Wetted Perimeter	1.2621 in.
Instrumentation Guide Tube Channel Heated Perimeter	0.8828 in.
Peripheral Channel Flow Area	0.0838 in. ²
Peripheral Channel Wetted Perimeter	0.5885 in.
Peripheral Channel Heated Perimeter	0.5885 in.
Corner Channel Flow Area	0.0506 in. ²
Corner Channel Wetted Perimeter	0.2943 in.
Corner Channel Heated Perimeter	0.2943 in.
Active Fuel Length	144.000 in.

Table 3.3-2

Steady-State Results Comparison

<u>Model</u>	<u>MDNBR (BWCMV)</u>	<u>MDNBR at Axial Location (in.)</u>	<u>Enthalpy at MDNBR (Btu/lbm)</u>	<u>Void Fraction at MDNBR</u>	<u>Mass Flux at MDNBR (Mlbm/hr-ft²)</u>	<u>Pressure Drop up to MDNBR (psi)</u>
[]

Table 3.3-3

Transient Results Comparison

Time (sec)	MDNBR (BWCMV)			Axial Location at MDNBR (in.)		
	<u>M1</u>	<u>M2</u>	<u>M3</u>	<u>M1</u>	<u>M2</u>	<u>M3</u>
0.0						
0.2						
0.4						
0.6						
0.8						
1.0						
1.2						
1.4						
1.6						
1.8						
2.0						

Time (sec)	Enthalpy at MDNBR			Void Fraction at MDNBR		
	<u>M1</u>	<u>M2</u>	<u>M3</u>	<u>M1</u>	<u>M2</u>	<u>M3</u>
0.0						
0.2						
0.4						
0.6						
0.8						
1.0						
1.2						
1.4						
1.6						
1.8						
2.0						

Time (sec)	Mass Flux at MDNBR			Pressure Drop up to MDNBR		
	<u>M1</u>	<u>M2</u>	<u>M3</u>	<u>M1</u>	<u>M2</u>	<u>M3</u>
0.0						
0.2						
0.4						
0.6						
0.8						
1.0						
1.2						
1.4						
1.6						
1.8						
2.0						

M1 = [Channel Model
M2 = [Channel Model
M3 = [Channel Model

Table 3.3-4

Active Fuel Node Size Comparison

Number of Active Fuel Rods	[
MDNBR (BWCMV)	
MDNBR Axial Location (in.)	
Enthalpy (Btu/lbm)	
Void Fraction	
Mass Flux (Mlbm/hr-ft ²)	
Pressure Drop up to MDNBR (psi)]

Figure 3.3-1

MNS/CNS Reactor Core Cross Section




Figure 3.3-2
Assembly Radial Power for
Transient Resulting In
Symmetrical Power Distributions

Figure 3.3-3

Hot Assembly Pin Radial-Local Power
For Transient Resulting In
Symmetrical Power Distributions



Fuel Rod



Control Rod



Control Rod with Ferrules



Instrumentation Guide Tube

Figure 3.3-4

VIPRE[[]] Channel Model

Figure 3.3-5

VIPRE [] Channel Model


Figure 3.3-6

VIPRE [] Channel Model



Figure 3.3-7

Peaked at $X/L =$ [] Axial Shape



3.5 References

- 3-1 Deleted
- 3-2 American National Standard for Decay Heat Power in Light Water Reactors, ANSI/ANS-5.1, American Nuclear Society, August 29, 1979
- 3-3 RETRAN-02 - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems, EPRI NP-1850-CCM Revision 4, EPRI, November 1988
- 3-4 VIPRE-01: A Thermal-Hydraulic Code for Reactor Cores, EPRI NP-2511-CCM Revision 3, EPRI, August 1989
- 3-5 BWCMV Correlation of Critical Heat Flux, BAW-10159P-A, May 1986
- 3-6 LYNX2 - Subchannel Thermal-Hydraulic Analysis Program, BAW-10130, October 1976
- 3-7 Duke Power Company McGuire and Catawba Nuclear Stations Core Thermal-Hydraulic Methodology Using VIPRE-01, DPC-NE-2004P-A, Revision 1, February 1997
- 3-8 Prairie Island Nuclear Generating Plant Final Safety Analysis Report, Northern States Power Company
- 3-9 Reactor Model Flow Tests, BAW-10037, Revision 2, Babcock & Wilcox, November 1972
- 3-10 McGuire Nuclear Station Technical Specifications, DPC
- 3-11 The BWU Critical Heat Flux Correlations, BAW-10199P-A, Framatome Advanced Nuclear Products, August 1996
- 3-12 Letter, H. N. Berkow (NRC) to M. S. Tuckman (Duke), November 7, 1996
- 3-13 Letter, P. S. Tam (NRC) to M. S. Tuckman (Duke), February 20, 1997

- 3-14 Duke Power Company Thermal-Hydraulic Statistical Core Design Methodology, DPC-NE-2005P-A, Revision 3, September 2002
- 3-15 W. G. Kennedy, et. Al., "Pump Two-Phase Performance Program: Volumes 1-8", EPRI NP-1556, September 1980"
- 3-16 Modified WRB-2 Correlation, WRB-2M, for Predicting Critical Heat Flux in 17 x 17 Rod Bundles with Modified LPD mixing Vane Grids, Westinghouse Energy Systems, February 1998
- 3-17 Duke Power Company Westinghouse Fuel Transition Report, DPC-NE-2009P-A, Revision 2, Duke Power, December 2002

4.0 OCONEE RETRAN BENCHMARK ANALYSES

The nine plant transients selected for benchmarking the Oconee RETRAN model include a broad spectrum of initial conditions, initiating events, and transient evolutions. A large set of plant transient monitor data is recorded, typically at a one second frequency, during a transient. The simulation is conducted by first initializing the RETRAN model as close as possible to the plant initial conditions. Next, boundary conditions such as actuation of interfacing pumps and valves and operator actions are identified and modeled. In some instances a data void or an atypical plant response, due for example to a spurious valve opening, may require assuming a boundary condition. The simulation is then performed for a duration that includes the plant parameter responses of interest. The results of the simulation are then compared to the plant data for a set of parameters that characterize the overall plant response. The end result provides an assessment of the capability of the Oconee RETRAN model and the RETRAN-02 code to simulate certain thermal-hydraulic phenomena and the category of transients typical of the benchmarked event.

4.1 Loss of Secondary Heat Transfer

4.1.1 Oconee Nuclear Station Unit 3
Loss of Main Feedwater
August 14, 1984

Transient Description

Oconee Unit 3 was operating at 100% full power when an anticipatory reactor trip occurred on the loss of both main feedwater (MFW) pumps. A rapid pressurizer outsurge, which is characteristic of the normal post-trip response, immediately followed the reactor trip. The Reactor Coolant System (RCS) inventory contracts due to a sudden reduction in the RCS average temperature. The temperature reduction results from a transitional mismatch between the reactor heat source and the steam generator heat sink. Letdown was manually isolated in the first 10 seconds and reestablished at 850 seconds, and RCS makeup flow was increased by manually opening a second makeup valve. Only one

high pressure injection (HPI) pump operated during the transient. All three emergency feedwater (EFW) pumps started immediately following the loss of the MFW pumps and controlled steam generator (SG) levels to the normal post-trip value of 25 inches on the extended startup range level indication. RCS pressure decreased to a minimum value of 1832 psig at 50 seconds while the pressurizer level decreased to a minimum level of 76 inches at 60 seconds. RCS pressure and pressurizer level then recovered to normal post-trip operating values as RCS conditions stabilized.

At a later time during the transient, EFW flow was inadvertently isolated due to a valve alignment error. Flow was lost at approximately 940 seconds and was reestablished at approximately 1310 seconds. RCS temperatures increased approximately 20 degrees during this time period as SG levels decreased below the 25 inch level control setpoint. Both of these parameters returned to normal post-trip values after EFW flow and then MFW flow were reestablished.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN and the Oconee RETRAN Model to accurately simulate the plant response. These phenomena include steam generator secondary void fraction profile and primary-to-secondary heat transfer (including the effect of SG dryout), main steam relief and secondary pressure control capabilities, non-equilibrium pressurizer behavior, and the effect of pressurizer spray. These phenomena will be important, each to a varying degree, for most of the simulations discussed in this chapter of the report. Therefore, they will only be discussed in great detail in this first benchmark analysis.

Accurate simulation of the steam generator void fraction profile is important since it determines the effective boiling length in the generator and thus the primary-to-secondary heat transfer rate. This is especially important during low SG level conditions and when EFW is delivered at a higher elevation than MFW (see Section 2.2.2.2 for a discussion of the modeling of this phenomenon). The heat transfer rate then determines the RCS temperature response and consequently the pressurizer level response through the expansion and contraction of the reactor coolant. The RCS pressure response is then mainly affected by

changes in pressurizer level. Therefore, it is evident that accurate steam generator modeling is necessary in order to achieve an accurate overall plant transient simulation.

Accurate simulation of pressurizer phenomena is also important since these phenomena determine the RCS pressure response. Non-equilibrium effects accompanying the compression of the steam bubble during the pressurizer refilling phase are the most important of these. The efficiency of the pressurizer spray in desuperheating/condensing the steam bubble has a large effect on the RCS pressure response. Heat transfer between the liquid and vapor regions at the interface can be important, as can heat transfer to the pressurizer vessel. The importance of these phenomena can vary significantly, and is transient specific.

Secondary pressure control also has a major effect on the post-trip primary-to-secondary heat transfer rate, and therefore the RCS temperature and pressure response. The main steam code safety relief valves lift in the first few seconds after turbine trip in order to relieve the steam that continues to be generated after reactor trip. The safety valves then reseal as the steaming rate decreases in order to limit the RCS temperature reduction. The immediate post-trip RCS temperature response as well as the magnitude of the pressurizer outsurge and the RCS pressure decrease is determined by the action of the relief valves in conjunction with the SG level. The Turbine Bypass System (TBS) valves also open immediately following turbine trip in order to assist in steam relief, by steaming to the condenser. Once the relief valves have reseated, the turbine bypass valves continue to steam and control SG pressure to the post-trip setpoint. Thereafter, RCS temperature is controlled by the Turbine Bypass System.

Model Description and Boundary Conditions

The plant response during this event showed little asymmetry between loops so the one-loop Oconee RETRAN Model (Figure 2.2-2) was used for the analysis. In addition, the Unit 3 specific feedwater and main steam line models were incorporated into the model. The parameters used as initial conditions were matched, where possible, to the plant data. The parameters which deviate from the plant data use the base model steady state full power values.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	100% (2568.0 MWt)	100% (2568.0 MWt)
RCS Pressure	2136 psig	2136 psig
PZR Level	222 inches	222 inches
T hot	600.3 °F	601.1 °F (ave)
T cold	556.1 °F	555.3 °F (ave)
SG Pressure	910 psig	891 psig (ave)
SG Level (OR)	55%	68% (ave)
SG Level (SUR)	163 inches	160 inches
MFW Temperature	455 °F	455 °F (ave)
RCS Flow	148×10^6 lbm/hr	148×10^6 lbm/hr
MFW Flow	10.8×10^6 lbm/hr	10.8×10^6 lbm/hr

[The base model SG level (55% operating range) used in the simulation is

]

The problem boundary conditions used are cycle specific post-trip delayed neutron power and decay heat, MFW flow, EFW flow, HPI flow, and a reduction in the turbine bypass valve setpoint. []

[

]

The EFW flow used in the simulation is based on an interpretation of event report and the available transient monitor data. All three pumps start immediately after the trip with flow throttled to control SG level to 25 inches. A maximum of approximately [] gpm total flow is available from the three EFW pumps. However, this flowrate is not delivered immediately as the pumps must come up to speed and the inventory in the steam generators must boil off to the 25 inch setpoint. Normal EFW flow into the steam generators continued until 948 seconds. At this time, the EFW valves were inadvertently closed and the turbine-driven EFW pump was shut off. This condition remained until the valves were manually opened at 1310 seconds. Level control was then reestablished via the two motor-driven EFW pumps still running, with a maximum of [] gpm assumed to be available. It should be noted that EFW flow data is not available, and therefore to accurately simulate the EFW flow a control system is used to throttle EFW in order to match the simulated level to the plant data.

MFW flow was lost at the beginning of the transient. Later on in the event a MFW pump was restarted. At approximately 27 minutes the MFW pump speed had increased sufficiently that the discharge pressure was higher than the SG pressure and MFW flow to the SGs resumed. From that time through the end of the simulation MFW flow was adjusted in order to match the RETRAN SG level to the plant data.

The HPI flow used in the simulation consists of the maximum possible injection from one pump between 57 and 211 seconds, and normal pressurizer level control via the makeup flowpath at all other times. Nominal letdown flow of 75 gpm is modeled from 850 seconds to the end of the simulation. The turbine bypass setpoint is reduced from the normal post-trip value of 1010 psig to 995 psig to match the actual SG pressure response as indicated by the data.

Simulation Results

The simulation begins with the anticipatory reactor trip on loss of main feedwater and continues for 30 minutes. The simulation is terminated at the point where EFW is reestablished and all major plant parameters have returned to normal post-trip values. The sequence of events is given in Table 4.1.1-1, and the results of the simulation are compared to the plant data in Figures 4.1.1-1 through 4.1.1-6.

The RCS pressure response (Figure 4.1.1-1) shows the predicted pressure decreasing slightly below the plant data during the initial contraction of the RCS inventory after the trip. There is a consistently larger decrease in the predicted RCS temperatures at this same time (see Figures 4.1.1-3 and 4.1.1-4.) This indicates that RETRAN is predicting a slightly greater heat transfer rate through the steam generators. The model then tracks the RCS repressurization with the pressure reaching the pressurizer spray setpoint of 2205 psig at 478 seconds as compared to 461 seconds in the data. The predicted pressurizer spray cycling frequency is higher than the data until approximately 900 seconds and then compares better with the data. The predicted RCS pressure agrees well with the data after EFW is reestablished and the RCS heatup stops (1310 seconds). However, the RCS pressure decrease following restoration of EFW at 1310 seconds is overpredicted by RETRAN. This

is attributed to two causes. First, RETRAN has more subcooled water in the pressurizer since a larger insurge is predicted during the loss of all feedwater between 940 and 1310 seconds. Second, the RETRAN pressurizer model liquid region is at a uniform subcooled temperature following an insurge, while the plant pressurizer is expected to have stratification in the liquid region, specifically a saturated or slight subcooled region on top of more subcooled water from the hot leg. Both factors result in a code prediction of less pressurizer liquid flashing during an outsurge and thus a greater pressure decrease.

The pressurizer level response is shown in Figure 4.1.1-2. The RETRAN prediction trends the plant data, similar to the predicted RCS pressure response, during the initial post-trip outsurge and the subsequent refill from primary system makeup. After the normal pressurizer level of 220 inches is recovered, primary makeup is secured, but pressurizer level continues to increase due to the heatup of the RCS. This heatup is caused by the lack of feedwater as a result of the inadvertent closure of the EFW control valves from 940 to 1310 seconds. RETRAN overpredicts the insurge during this period, possibly due to some leakage past the EFW control valves in the plant. Following restoration of EFW at 1310 seconds, the predicted pressurizer level stabilizes, but at a higher value than the data. Following restoration of MFW at 1632 seconds, the level decreases in a manner consistent with the plant.

The predicted RCS temperature response (Figure 4.1.1-3 and 4.1.1-4) up to the point of EFW isolation at 940 seconds is typical for a normal reactor trip. The temperatures then increase due to the termination of EFW. The model predicts a slightly greater increase than the data in this time period (23 °F as compared to 18 °F). As previously mentioned, the smaller temperature increase at the plant may be attributable to leakage past the EFW control valves. This temperature increase is the driving force for the increase in pressurizer level and RCS pressure, and results in the prolonged period of pressurizer spray cycling.

The SG pressure response is shown in Figure 4.1.1-5. The main steam relief valves open and reseal correctly and then the turbine bypass valves control SG pressure at 995 psig. The simulated Turbine Bypass System controller allows a

slight undershoot in the SG pressure before controlling to the setpoint. The plant data for the "B" steam generator, however, shows the same undershoot, at a slightly later time. Therefore, it does not contribute significantly to the initial RCS contraction and cooldown. Another discrepancy exists later in the event when EFW flow is terminated and SG levels decrease. The plant data showed a decrease in the "B" SG pressure during this time period. This is due to steam leakage, mainly from auxiliary steam loads, in the "B" steam line. Since a single-loop model was used for this simulation, steam leakage was not modeled and therefore this response is not simulated. It is noted that this response had no impact on any other plant parameters, since the SGs were not an active heat sink at the time.

The SG level response is shown in Figure 4.1.1-6. The predicted level response shows a slight undershoot to the data, similar to the SG pressure, in the first minute of the simulation. The predicted level is then controlled to the post-trip setpoint of 25 inches. The RETRAN level tracks the data closely for the remainder of the transient, which is expected since the SG level is used as a boundary condition to determine MFW and EFW flow.

Analysis of Simulation Results

The ability of the Oconee RETRAN model to accurately predict the plant response during this event is primarily determined by two factors: once-through steam generator heat transfer modeling and pressurizer modeling. Steam generator heat transfer determines the magnitude and rate of change of primary system temperatures, and thereby influences RCS pressure and pressurizer level. The level and pressure on the SG secondary are also affected by the primary-to-secondary heat transfer. The compression and expansion of the pressurizer steam bubble determines the RCS pressure and pressurizer level response. These factors, as they pertain to the results of this benchmark transient, are discussed in detail below.

The [

] heat transfer map (2.2.7.5), provides reasonably accurate primary and secondary temperature profiles at full power steady-state condi-

tions. The amount of SG exit superheat matches plant data, and predicted secondary mass inventory is close to other code-predicted reference values.

After trip, the code generally overpredicts primary-to-secondary heat transfer, as reflected in several of the plant data indications. First and foremost, RCS hot and cold leg temperatures decrease more rapidly than the plant data (Figures 4.1.1-3 and 4.1.1-4). This indicates that the calculated boiloff of the SG secondary inventory is more rapid than the data, and this fact is reflected by the SG level comparison (Figure 4.1.1-6). In addition, since the code underpredicts the RCS temperature, it also underpredicts RCS pressure and pressurizer level (Figures 4.1.1-1 and 4.1.1-2).

The overprediction of post-trip primary-to-secondary heat transfer is attributed to the lack of an unequal phase velocity model in the SG secondary (2.2.6.4). This causes the code to overpredict the boiling length, which effectively determines the heat transfer area in a once-through steam generator, and results in closer coupling between the RCS T-cold and the steam generator saturation temperature. It should be noted, however, that the disagreements between predicted and measured plant parameters are not extreme, and that they tend to lessen as steady-state post-trip conditions are approached. Thus there is only a limited impact on the transient results. During the latter portions of the transient, the overall SG heat transfer agreement is good based on the available data, and differences are attributed primarily to the uncertainty in feedwater flow boundary conditions.

A [] of the pressurizer is used in the Oconee model in order to take advantage of the [] option (2.2.6.5). The liquid flow into and out of the pressurizer is primarily determined by the shrinkage or expansion of the reactor coolant, which relates back to SG heat transfer, and makeup and letdown. During most of the transient the insurge/outsurge rate is predicted accurately enough to allow an assessment of the other factors which influence RCS pressure response, i.e. heat transfer to the pressurizer steam space from the metal walls and from the liquid region, condensation of steam by the pressurizer spray, and flashing of water in the pressurizer liquid space.

Pressurizer level increases between 60 and 1320 seconds, first in response to makeup and then as a result of the RCS heatup (Figure 4.1.1-2). RETRAN overpredicts the pressurization resulting from this sustained insurge, as reflected by the pressurizer spray cycling frequency. This is primarily attributed to the lack of a mechanistic interphase heat transfer model in RETRAN, since the other phenomena which act to reduce RCS pressure during an insurge[

] It is known that interphase heat transfer rates can be significant, especially during pressurizer spray operation when the steam-water interface is somewhat agitated.

There are two means of implementing an [

]

The predicted pressurizer level decreases slightly between 1320 and 1550 seconds, and then rapidly between 1150 and 1800 seconds. The code greatly overpredicts the corresponding RCS pressure decrease relative to the plant data during this time frame. This is attributed to the fact that the RETRAN model does not account for the[

] is employed, and the model gives reliable results except in certain situations, such as the one discussed here.

In conclusion, a good comparison between predicted and measured plant parameters is demonstrated. Those instances in which the prediction differs from the data are attributable to uncertainties in the transient boundary conditions or limitations of the code models. The identified limitations are understood and do not preclude the use of the code and model for this type of application.

Table 4.1.1-1

Oconee Nuclear Station Unit 3
Loss of Main Feedwater
August 14, 1984

Sequence of Events

<u>Event Description</u>	<u>Plant</u>	<u>Time (sec)</u>	<u>RETRAN</u>
Rx/Turbine and MFW pumps trip*	0		0
Letdown isolated, EFW pumps start*	0-10		0-10
Minimum RCS pressure	50		50
HPI flow increased*	57		57
Minimum pressurizer level	60		52
HPI flow reduced*	211		211
PZR spray setpoint reached	461		478
Letdown reestablished	850		850
EFW flow isolated*	948		948
PZR level reaches 220 inches	993		1011
EFW flow reestablished*	1310		1310
MFW flow reestablished*	1632		1632
End of simulation	N/A		1800

Note: The asterisks designate boundary conditions

ONS-3 LOSS OF MAIN FEEDWATER

8/14/84 EVENT




Figure 4.1.1-1

ONS-3 LOSS OF MAIN FEEDWATER

8/14/84 EVENT





Figure 4.1.1-2

ONS-3 LOSS OF MAIN FEEDWATER

8/14/84 EVENT



ONS-3 LOSS OF MAIN FEEDWATER

8/14/84 EVENT




Figure 4.1.1-4

DATA(LOOP A) — DATA(LOOP B) - - - RETRAN

ONS-3 LOSS OF MAIN FEEDWATER

8/14/84 EVENT




Figure 4.1.1-5

ONS-3 LOSS OF MAIN FEEDWATER

8/14/84 EVENT




Figure 4.1.1-6

4.2 Excessive Secondary Heat Transfer

4.2.1 Oconee Nuclear Station Unit 1 Turbine Bypass Valve Failure Following Reactor Trip September 10, 1982

Transient Description

Oconee Unit 1 was operating at 85% full power when an anticipatory reactor trip occurred on a main turbine trip signal. The main turbine Electro-Hydraulic Control (EHC) System initiated the turbine trip. Due to a malfunction in the Turbine Bypass System, the turbine bypass valves failed to control steam generator (SG) pressure to the normal post-trip value of 1010 psig. Instead, pressure decreased to approximately 860 psig before the valves began to close automatically. Shortly thereafter the operators manually closed the valves. The result of the extended depressurization was an overcooling of the Reactor Coolant System (RCS). RCS pressure decreased to a minimum of 1664 psig and pressurizer level decreased to 4 inches before recovering. The RCS cold leg temperature decreased to a minimum of 544 °F. Letdown was manually isolated in the first 10 seconds and RCS makeup flow was increased by manually opening a second makeup valve. Only one high pressure injection (HPI) pump operated during the transient. Main feedwater (MFW) was available throughout the event. Once the turbine bypass valves were closed, the plant returned to a normal post-trip condition.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN and the Oconee RETRAN Model to accurately simulate the plant response. These phenomena include steam generator secondary void fraction profile and primary-to-secondary heat transfer, main steam relief and secondary pressure control capabilities, and pressurizer behavior. In this particular event the most significant of these is the increase in primary-to-secondary heat transfer due to the excessive steaming.

Model Description and Boundary Conditions

The plant response during this event showed little asymmetry between loops so the one-loop Oconee RETRAN Model (Figure 2.2-2) was used for the analysis. The parameters used as initial conditions were matched, where possible, to the plant data. The plant data used for this analysis was interpreted from transient monitor plots and post-trip review program data. The transient monitor digital data was not available for this event.

	<u>Model</u>	<u>Plant</u>
Power Level	85% (2182.8 MWt)	85% (2182.8 MWt)
RCS Pressure	2124 psig	2124 psig
PZR Level	215 inches	215 inches
T hot	596.3 °F	596.8 °F
T cold	559.1 °F	559.1 °F
SG Pressure	897.5 psig	897.5 psig
SG Level	141 inches (XSUR)	155 inches (XSUR)
	41% (OR)	57% (OR)
MFW Temperature	441.6 °F	441.6 °F
RCS Flow	149×10^6 lbm/hr	144×10^6 lbm/hr
MFW Flow	9.0×10^6 lbm/hr	8.9×10^6 lbm/hr

The RCS and MFW flows are adjusted to give the correct primary and secondary temperatures. Since SG level decreases with power level, an adjustment to the nominal level at 100% power must be made. The 100% full power level in the plant prior to the trip was approximately [

]

The problem boundary conditions used are cycle specific post-trip delayed neutron power and decay heat, MFW and HPI flow, and a reduction in the turbine bypass valve setpoint. The MFW and HPI flows used in the simulation are from the post-trip review program data for this event. The turbine bypass valve setpoint is reduced from the normal post-trip value of 1010 psig to 880 psig to match the actual SG pressure response as indicated by the data.

Simulation Results

The simulation begins with the anticipatory reactor trip on main turbine trip and continues for 120 seconds. The simulation is terminated at the point where the plant has recovered from the overcooling event and the major parameters of interest have approached their normal post-trip values. The sequence of events is given in Table 4.2.1-1, and the results of the simulation are compared to the plant data in Figures 4.2.1-1 through 4.2.1-6.

Due to the unavailability of the digital transient monitor data, the plant data was interpreted from the analog transient monitor plots and the post-trip review printout (which is given in ten second intervals). Therefore, the figures may not contain the exact maximum or minimum values for a particular parameter. Also, many of the inflections and changes in slope may not be accounted for, particularly due to the lifting and reseating of the main steam relief valves. However, the trend for all the parameters plotted is correct.

The RCS pressure response is shown in Figure 4.2.1-1. The RETRAN predicted pressure decreases faster than the data during the initial contraction of the RCS inventory after the trip. There is a consistent trend in the pressurizer level (see Figure 4.2.1-2) and hot leg temperature (see Figure 4.2.1-3) during this time period. This indicates that RETRAN may be predicting a slightly greater heat transfer rate through the steam generators at this time. The predicted RCS pressure also decreases farther than the data during the time when the minimum value occurs at approximately 80 seconds. As discussed earlier, the plant data for this event is not optimal and the RCS pressure data in particular may not be as accurate as the other parameters since it is a wide range pressure indication. The predicted pressure trends the data well towards the end of the simulation once the turbine bypass valves are closed.

The pressurizer level response is shown in Figure 4.2.1-2. The RETRAN prediction trends the plant data in a manner similar to the predicted RCS pressure response during the initial post-trip outsurge. However, the predicted level response shows better agreement with the data in the second minute than does RCS pressure. The predicted RCS temperatures (see Figures 4.2.1-3 and 4.2.1-4) also show better agreement during this time period. This indicates that the steam generator heat transfer rate is being predicted accurately by RETRAN and supports the assertion that the plant RCS pressure data is not highly accurate.

The SG pressure response is shown in Figure 4.2.1-5. The close agreement to the data seen in the first 80 seconds of the simulation (to the point at which the turbine bypass valves are closed) indicates that the main steam relief valves lift and reseal correctly, and that the steam blowdown rate through the turbine bypass valves is accurately modeled.

The predicted SG repressurization following closure of the TBVs is not as great as the plant data indicates. This indicates that some differences may exist in the inventory and heat transfer rate in the RETRAN and plant steam generators at that time.

The SG level response in Figure 4.2.1-6 shows a consistent offset from the plant data (which was incorporated in the initial conditions of the model) until the time when the turbine bypass valves begin to close. After the valves are closed the predicted level and the data merge as level approaches the minimum level controlling setpoint. The level offset is due to [

Table 4.2.1-1

Oconee Nuclear Station Unit 1
Turbine Bypass Valve Failure
Following Reactor Trip
September 10, 1982

Sequence of Events

<u>Event Description</u>	<u>Plant</u>	<u>Time (sec)</u>	<u>RETRAN</u>
Rx/Turbine trip*	0		0
HPI flow increased*	0-10		0-10
Turbine bypass valves fail to reseat at SG pressure of 1010 psig	28		30
Minimum RCS pressure and pressurizer level, minimum cold leg temperature, minimum SG pressure, turbine bypass valves closed	80		80
End of simulation	N/A		120

Note: Asterisks designate boundary conditions

ONS 1 TURBINE TRIP 9/10/82

RETRAN AND PLANT DATA




Figure 4.2.1-1

ONS 1 TURBINE TRIP 9/10/82

RETRAN AND PLANT DATA




Figure 4.2.1-2

ONS 1 TURBINE TRIP 9/10/82

RETRAN AND PLANT DATA




Figure 4.2.1-3

ONS 1 TURBINE TRIP 9/10/82

RETRAN AND PLANT DATA





Figure 4.2.1-4


ONS 1 TURBINE TRIP 9/10/82

RETRAN AND PLANT DATA



ONS 1 TURBINE TRIP 9/10/82

RETRAN AND PLANT DATA



4.2.2 Oconee Nuclear Station - Unit 3
Steam Generator Overfeed Following Reactor Trip
March 14, 1980

Transient Description

Oconee Unit 3 was operating at 100% full power when an anticipatory reactor trip occurred on a main turbine trip signal. The main turbine Electro-Hydraulic (EHC) System initiated the turbine trip. Due to an Integrated Control System (ICS) failure, the main feedwater (MFW) pumps did not run back properly in response to the reduced demand signal. This resulted in over-feeding the steam generators, and caused both pumps to trip automatically on high level in steam generator (SG) "A" at approximately 2 minutes into the event. Both motor-driven and the turbine driven emergency feedwater (EFW) pumps then started and feedwater was reestablished to the steam generators. Makeup to the RCS was increased after the trip by opening a second makeup valve and starting a second high pressure injection (HPI) pump.

The post-trip plant response indicated little asymmetric behavior between the "A" and "B" loops even though the overfeeding of the steam generators was very asymmetric. The RCS pressure and pressurizer level post-trip responses were below normal for a turbine trip. The RCS pressure decreased to 1762 psig at approximately 60 seconds before recovering and the pressurizer level decreased to 50 inches at the same time. The post-trip SG pressures drifted below the 1010 psig setpoint in the second minute after the trip due to the overfeed and the auxiliary steam demand. Once the MFW pumps tripped and EFW was initiated, a normal cooldown resumed and SG pressures increased.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN and the Oconee RETRAN Model to accurately simulate the plant response. These phenomena include steam generator secondary void fraction profile and primary-to-secondary heat transfer, main steam relief, and pressurizer behavior. In this particular event, the SG overfeed is the most significant of these. The model prediction of the heat transfer resulting

from the overfeed, and the slight secondary depressurization due to the overfeed, are of particular interest.

Model Description and Boundary Conditions

The plant response during this event showed a significant asymmetric overfeed to the steam generators so the two-loop Oconee RETRAN Model (see Figure 2.2-1) was used for this simulation. In addition, the Unit 3 specific feedwater and main steam line models were incorporated into the model. The parameters used as initial conditions were matched, where possible, to the plant data. The plant data used for this analysis consists of digital transient monitor data and post-trip review program data.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	100% (2568.0 MWt)	100% (2568.0 MWt)
RCS Pressure	2139 psig	2139 psig
PZR Level	228 inches	228 inches
T hot	600.3 °F "A"	600.3 °F "A"
	600.3 °F "B"	601.2 °F "B"
T cold	556.5 °F "A"	556.5 °F "A"
	554.0 °F "B"	556.7 °F "B"
SG Level	61% (OR) "A"	61% (OR) "A"
	68% (OR) "B"	68% (OR) "B"
SG Pressure	910 psig "A"	898 psig "A"
	910 psig "B"	895 psig "B"
MFW Temperature	454 °F	454 °F
RCS Flow	145 x 10 ⁶ lbm/hr	149 x 10 ⁶ lbm/hr
MFW Flow	5.5 x 10 ⁶ lbm/hr "A"	5.3 x 10 ⁶ lbm/hr "A"
	5.4 x 10 ⁶ lbm/hr "B"	5.3 x 10 ⁶ lbm/hr "B"

Unlike several other benchmark analyses, the initial SG levels in the analysis were set equal to the plant data. This approach was taken for two reasons.

The problem boundary conditions used are cycle specific post-trip delayed neutron power and decay heat, MFW and HPI flow, and a reduction in the turbine

bypass valve setpoint. The MFW flow used in the simulation comes from the transient monitor and the post-trip review program. The HPI flow consists of normal makeup from one pump for the first 30 seconds and the maximum possible injection from two pumps from 30 to 120 seconds. The turbine bypass valve setpoint is reduced from the normal post-trip value of 1010 psig for both steam generators to 1004 psig for SG "A" and 992 psig for SG "B". These values match the actual SG pressure response as indicated by the data.

Simulation Results

The simulation begins with the anticipatory reactor trip on main turbine trip and continues for 120 seconds. The simulation ends at the point where the steam generator overfeed is terminated by the trip of the MFW pumps and the major plant parameters have started to return to normal post-trip values. The sequence of events is given in Table 4.2.2-1, and the results of the simulation are compared to the plant data in Figures 4.2.2-1 through 4.2.2-10.

The RCS pressure response is shown in Figure 4.2.2-1. The RETRAN predicted pressure response trends the plant data with only slight deviations at 20 and 60 seconds. The pressurizer level response shown in Figure 4.2.2-2 trends the plant data closely for the entire simulation. This is due mainly to the accurate steam generator heat transfer prediction immediately after the trip and during the overfeed.

The RCS temperature response is shown in Figures 4.2.2-3 through 4.2.2-6. The predicted temperature response trends the data well, in particular after the first 20 seconds. A discrepancy does exist immediately following the trip which can be attributed to the time lags associated with the plant RTDs. This time lag is approximately [] seconds and was not accounted for in the RETRAN model used in this simulation.

The SG pressure response is shown in Figures 4.2.2-7 and 4.2.2-8. The RETRAN prediction of the SG pressure trends the plant data closely for both steam generators. The reseating action of the main steam safety valves and the resulting pressure response compares well. The slight depressurization due to the overfeed, and the repressurization at the time that the MFW pumps trip is also predicted.

The SG level responses are shown in Figures 4.2.2-9 and 4.2.2-10. Beginning at 40 seconds, a nearly constant offset in indicated level is maintained in both steam generators. This reflects an accurate comparison during the over-feeding phase of the transient. The cause for the development of the offset during the initial post-trip phase cannot be ascertained, but is most likely associated with the uncertainty in the total delivered feedwater during the SG pressurization following turbine trip.

Table 4.2.2-1

Oconee Nuclear Station Unit 3
 Steam Generator Overfeed
 Following Reactor Trip
 March 14, 1980

Sequence of Events

<u>Event Description</u>	<u>Plant</u>	<u>Time (sec)</u>	<u>RETRAN</u>
Rx/Turbine trip*	0		0
HPI flow increased*	30		30
Minimum RCS pressure, and minimum PZR level	60		60
MFW pumps trip on high SG level*	113		113
End of simulation	N/A		120

Note: Asterisks designate boundary conditions

ONS-3 TURBINE TRIP

3/14/88 EVENT




Figure 4.2.2-1

4-32

— DATA

--- RETRAN

ONS-3 TURBINE TRIP

3/14/80 EVENT




Figure 4.2.2-2

ONS-3 TURBINE TRIP

3/14/80 EVENT




Figure 4.2.2-3

ONS-3 TURBINE TRIP

3/14/80 EVENT




Figure 4.2.2-4

ONS-3 TURBINE TRIP

3/14/80 EVENT




Figure 4.2.2-5

ONS-3 TURBINE TRIP

3/14/80 EVENT




Figure 4.2.2-6

ONS-3 TURBINE TRIP

3/14/80 EVENT




Figure 4.2.2-7

ONS-3 TURBINE TRIP

3/14/88 E/EVT




Figure 4.2.2-8

ONS-3 TURBINE TRIP

3/14/80 EVENT




Figure 4.2.2-9

— DATA (LOOP A) ---- RETRAN (LOOP A)

ONS-3 TURBINE TRIP

3/14/80 EVENT




Figure 4.2.2-10

4-41

4.2.3 Oconee Nuclear Station Unit 3
 Overcooling Following Loss of ICS Power
 November 10, 1979

Transient Description

Oconee Unit 3 was operating at 99% full power when a spurious low hotwell level signal tripped the hotwell pumps. One condensate booster pump then tripped on low suction pressure, and the Integrated Control System (ICS) initiated a reactor runback due to low feedwater flow. The reactor/feedwater mismatch resulted in a reactor trip on high Reactor Coolant System (RCS) pressure at 55 seconds from 71% power. At 73 seconds the power supply to the ICS was lost for a period of 150 seconds. Both main feedwater pumps tripped as designed, and all three emergency feedwater pumps started automatically. Two additional high pressure injection (HPI) pumps were started at 154 seconds. With the loss of ICS power a large percentage of the control room instrumentation displayed invalid indications. Once power was restored to the ICS, the affected instrumentation functioned normally.

During the loss of ICS power (73-223 seconds), the turbine bypass valves apparently failed to an unknown partially open position, between 0 and 50% open. This resulted in a loss of steam generator pressure control and overcooling. Consequently, RCS pressure decreased to 1671 psig and pressurizer level decreased to less than 11 inches indicated level at 223 seconds. When ICS power was restored, the turbine bypass valves repositioned at 12% and 23% open on the "A" and "B" steam generators, respectively, and remained in this position for the next 20-30 minutes. The continued loss of pressure control resulted in further overcooling. At 535 seconds a hotwell pump and condensate booster pump were restarted. By this time both steam generators pressures had decreased to 400 psig, less than the developed head of the hotwell/booster pump combination, and an overfeed of SG "B" resulted. The overfeed continued for 225 seconds until the feedwater control valves were closed. SG "B" level reached 85% on the operating range, well in excess of the normal post-trip level of 25 inches on the startup range. The overfeed enhanced the overcooling transient, with RCS cold leg temperatures decreasing below the normal post-trip value of 550 °F to 455 °F in 15 minutes, and to 420 °F in 30 minutes. At 30 minutes plant conditions had stabilized.

Discussion of Important Phenomena

Due to the complexity of the transient, many phenomena occurred which challenge the predictive capability of the Oconee RETRAN Model. During the initial reactor runback due to low feedwater flow, the resulting degradation in primary-to secondary heat transfer due to decreasing SG inventory is of interest. Subsequently, the overcooling due to continued turbine bypass steaming and sustained feedwater delivery by the EFW pumps, and then the MFW pump overfeed, result in significant heat transfer phenomena. Prior to the MFW overfeed, the "A" SG and possibly the "B" SG approach a boiled-dry condition, another significant phenomenon.

The primary system response is dominated by the contraction of the primary inventory due to the overcooling, and then the refilling of the RCS by the HPI System. The initial expansion of the primary inventory during the loss of feedwater phase also challenges the non-equilibrium pressurizer modeling.

During this transient essentially all plant data, except RCS pressure, were unavailable from 73 to 223 seconds. Although no data exists in this timeframe, the presence or absence of any major phenomena can be assessed if the simulation compares well with the data before and after the data void. Any assumptions necessary to model unknown system and component performance during this timeframe can also be assessed.

Model Description and Boundary Conditions

This event was characterized by asymmetric boundary conditions on the SG secondary side, and so the two-loop Oconee RETRAN Model (Figure 2.2-1) was used in the analysis. The parameters used as initial conditions are mainly taken from the base model initialization due to the similarity of the event initial conditions. Several parameters were modified to be event specific.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	100% (2568 MWt)	99.2% (2548 MWt)
RCS Pressure	2134.3 psig	2134.3 psig
PZR Level	217.4 inches	217.4 inches
T-hot	601.9 °F	600.5 °F (ave)
T-cold	555.2 °F	556.5 °F (ave)
RCS Flow	140 x 10 ⁶ lbm/hr	147 x 10 ⁶ lbm/hr
SG Pressure	910.0 psig	902.9 psig (ave)
SG Levels	63.0%, 69.9% OR	63.0%, 70.5% OR
MFW Flow	10.8 x 10 ⁶ lbm/hr	10.8 x 10 ⁶ lbm/hr
MFW Temperature	460.0 °F	454.3 °F

The small deviations in reactor power level and hot and cold leg temperatures are consistent with the deviation in RCS flow. Since this event resulted in large changes in all parameters, these small initial discrepancies are insignificant. The small deviation in initial steam generator pressure is also insignificant. Initial steam generator levels were closely matched in order to accurately simulate the pre-trip decrease in steam generator inventory following the feedwater transient. [

]

The boundary conditions used include the reactor power runback, event specific delayed neutron power and decay heat, MFW flow data, EFW and HPI actuation, a post-trip auxiliary steam demand, and a turbine control system. The reactor power runback data from 4 - 55 seconds has been corrected to account for the

[

]

All three EFW pumps actuate on the MFW pump trip

caused by the loss of ICS power. The EFW flow is throttled by a control system to maintain the minimum post-trip steam generator level. The second and third HPI pumps were started at 154 seconds. These EFW and HPI boundary conditions are assumed in the simulation since actual performance cannot be confirmed by plant data.

The most important boundary condition in this analysis is the steam relief flowrate resulting from the partially failed-open turbine bypass valves. It is assumed that the valves failed to the 50% open position during the loss of ICS power. Subsequent to the restoration of ICS power the valves repositioned to 11.9% (SG "A") and 22.5% (SG "B"). The relief capacity of these valves in a partially open position is not known. It is assumed that the capacity is a linear function of valve position. This assumption is known to underpredict the capacity at positions between 0 - 50% open.

Simulation Results

The simulation begins with the partial loss of feedwater and continues for 14 minutes. The simulation is terminated shortly after the overfeed of the "B" SG is manually terminated and the overcooling rate stabilizes. The sequence of events is given in Table 4.2.3-1, and the results of the simulation are presented in Figures 4.2.3-1 through 4.2.3-22.

The first 73 seconds of the transient, that phase prior to the loss of ICS power, constitute a gradual loss of heat sink event. The reactor power response, which consists of the runback from 99% to 71% power between 4 seconds and the reactor trip on high pressure at 55 seconds, is shown in Figure 4.2.3-1. The initial RCS pressure response, shown in Figure 4.2.3-2, indicates that RETRAN predicts a faster rate of pressurization than the data. The predicted time of reactor trip is 42 seconds rather than 55 seconds. Insights into the cause of this discrepancy exist in the pressurizer level and RCS temperature responses. The initial pressurizer level comparison is given in Figure 4.2.3-3. RETRAN only slightly overpredicts the pressurizer insurge, which is the driving force behind the rate of RCS pressurization. The deviation in the pressure comparison is partially due to this slight overprediction in pressurizer level. The remaining contribution is due to

[] The initial hot and cold leg comparisons are shown in Figures 4.2.3-4 through 4.2.3-7. The trends are very consistent with the data, with the predicted cold leg temperatures increasing slightly faster than the data. This indicates that RETRAN predicts a more rapid degradation of the heat sink due to the reduction in feedwater flow. The initial main feedwater flow transient data used as boundary conditions are shown in Figure 4.2.3-8. The resulting predicted decrease in steam generator levels are in excellent agreement with the data as shown in Figures 4.2.3-9 and 4.2.3-10.

The time interval from 73 to 223 seconds corresponds to the duration of the loss of ICS power. During this interval only RCS pressure data, shown in Figure 4.2.3-11, exists for comparison to the prediction. RETRAN underpredicts the actual pressure transient. By observing the longer term responses in pressurizer level (Figure 4.2.3-12) and RCS temperature (Figures 4.2.3-13 through 4.2.3-16), in particular when the lost indications are restored at 223 seconds, the enhanced overcooling predicted by RETRAN is evident. The source of the overprediction of the rate of overcooling appears in the comparison of the SG pressures in Figures 4.2.3-17 and 4.2.3-18. Due to the assumed failure position of the turbine bypass valves during the loss of ICS power, SG "A" pressure is underpredicted by 180 psig and SG "B" by 150 psig, at 223 seconds. The trends in other parameters are consistent with this deviation.

Between 223 and 535 seconds the overcooling process continues as the EFW pumps deliver excess feedwater and steaming through the turbine bypass valves continues. The turbine bypass valves are now positioned at 11.9% and 22.5%, respectively, so the steaming rate has decreased. The reduction in the steaming rate is confirmed by the increase in SG pressures at 223 seconds, with the exception of the "B" SG data. The rate of depressurization is also influenced by a decrease in SG inventory during this time period. The SG downcomer level is shown in Figures 4.2.3-19 and 4.2.3-20. It is apparent that the steam generators are near a boiled-dry condition in SG "A" after 360 seconds, and in SG "B" between 300 and 535 seconds. Since both cold leg temperatures continue to decrease during this period, the delivered EFW inventory must be boiling off and not accumulating on the SG lower tube sheet. RETRAN continues

to overpredict primary-to-secondary heat transfer. At 535 seconds the "B" steam generator is overfired by the hotwell/booster pump combination. The MFW flowrate is shown in Figure 4.2.3-21, and the resulting change in steam generator level is shown in Figure 4.2.3-22. The rate of overcooling increases in the data, although the predicted rate remains approximately the same. This deviation may result from the prediction of [

The pressurizer level and RCS pressure data show that RCS inventory remained relatively stable between 360 and 660 seconds. It is suspected that HPI flow was being manually throttled during this time period, although no confirmatory data exists. Since the RETRAN simulation modeled unthrottled HPI flow during this time period, the deviations between the predictions and data are consistent. The good comparison between the predicted pressurizer level and data between 660 and 840 seconds suggests that full HPI flow was restored at 660 seconds..

The absence of a complete knowledge of the sequence of events for this event, which was complicated by the loss of data indications caused by the loss of ICS power, does not detract from many insights gained by the simulation. In fact, it is possible to infer some important aspects of system and component performance from the simulation.

Table 4.2.3-1

Oconee Nuclear Station Unit 3
Overcooling Following Loss of ICS Power
November 10, 1979

<u>Event Description</u>	<u>Time (sec)</u>	
	<u>Plant</u>	<u>RETRAN</u>
Partial loss of feedwater*	0	0
Reactor runback begins*	4	4
Reactor trip on high RCS pressure	55	42 (Note 1)
Loss of ICS _f power*	73	75 (Note 2)
- MFW pumps trip		
- EFW pumps start		
- Turbine bypass valves fail open		
- Most instrumentation indications lost		
Three HPI pumps injecting*	154	154
ICS power restored*	223	223
- Turbine bypass valves partially close		
- Instrumentation indications restored		
SG "A" boiled dry (EFW still delivering)	335	N/A (Note 3)
SG "B" boiled dry (EFW still delivering)	385	N/A (Note 3)
SG "B" overfeed begins*	535	535
SG "B" overfeed ends*	760	760
End of simulation	N/A	840

Note: Asterisks designate boundary conditions

Note 1: Simulated reactor power includes matching the reactor trip time at 55 seconds. The simulated pressure would have resulted in a predicted trip at the same pressure setpoint at 42 seconds.

Note 2: Different data sources give different times for the loss of ICS power. The simulation assumed 75 seconds, but some of the data indicates that 73 seconds is more accurate.

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-1

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/10/79




Figure 4.2.3-2

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79





Figure 4.2.3-3

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 9 - 11/18/79

4-52

Figure 4.2.3-4



OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/70

4-53




Figure 4.2.3-5

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-6

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-7

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/10/79




Figure 4.2.3-8

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-9

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/10/79





Figure 4.2.3-10

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/10/79



OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-12

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79

4-61





Figure 4.2.3-13

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/10/79

Figure 4.2.3-14

4-62



OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/10/70




Figure 4.2.3-15

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/10/70




Figure 4.2.3-16

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 9 - 11/18/79




Figure 4.2.3-17

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-18

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-19

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79

4-68




Figure 4.2.3-20

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-21

OVERCOOLING FOLLOWING LOSS OF ICS POWER

ONS 3 - 11/18/79




Figure 4.2.3-22

Loss of Forced Circulation

4.3.1 Arkansas Nuclear One - Unit 1

Loss of Offsite Power

June 24, 1980

Transient Description

Arkansas Nuclear One Unit 1 (ANO-1) was operating at 100% full power when a loss of offsite power occurred. The main turbine intercept and governor valves went closed creating a mismatch between reactor power and steam generator demand. This resulted in the RCS pressure increasing rapidly. A manual reactor runback was initiated at approximately the same time the reactor tripped on high RCS pressure. The reactor coolant, main feedwater (MFW) and condenser circulating water pumps also tripped on the reactor/turbine trip.

Shortly after the reactor trip the turbine driven emergency feedwater (EFW) pump was started and immediately tripped on overspeed. Approximately 30 seconds after the trip normal makeup was established. EFW flow was finally established approximately 90 seconds after the reactor trip. Shortly after this, RCS makeup flow was increased by manually starting a second high pressure injection (HPI) pump.

The plant remained in this state with stable natural circulation established and EFW removing decay heat for more than one hour before offsite power was restored.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN and the Oconee RETRAN Model to accurately simulate the plant response. These phenomena include the transition to and the development of natural circulation, primary-to-secondary heat transfer under low flow conditions, main steam relief, RCS flow coastdown, and pressurizer behavior.

Accurate simulation of the steam generator inventory and void profile is important since it determines the effective heat transfer surface area in the generator and thus the primary-to-secondary heat transfer. This is especially important for this transient because all feedwater is lost for the first 90 seconds after the reactor trip. As the inventory is boiled off, the thermal center of the steam generator is lowered, which inhibits the initiation of natural circulation until EFW is restored.

Secondary pressure control is also important in determining the steam generator heat transfer and thus the RCS temperature and pressure response. During this event, power to the air-operated turbine bypass and atmospheric dump valves is lost. These valves gradually go closed as air pressure is lost, therefore losing their ability to control pressure to the post-trip setpoint (approximately 1000 psig). This caused an increase in heat transfer as the valves relieved more steam than necessary.

The RCS flow coastdown is important to predict accurately in this transient because it affects the transition to natural circulation.

Model Description and Boundary Conditions

The ANO-1 plant is very similar to Oconee. Both are Babcock & Wilcox (B&W) 177 fuel assembly (FA) plants with the same Nuclear Steam Supply Systems (NSSS). The plant response during this event showed little asymmetry between loops so the one-loop Oconee RETRAN Model (see Figure 2.2-2) was used for the analysis. The base Oconee model initial conditions were used for this analysis with only a small adjustment to the RCS pressure. The plant-specific data used for this analysis was interpreted from various sources.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	100% (2568 MWt)	100% (2568 MWt)
RCS Pressure	2162.1 psig	2162.1 psig
PZR Level	180 inches	180 inches
T hot	602.0 °F	600.9 °F
T cold	555.3 °F	556.9 °F
T ave	578.7 °F	578.9 °F
SG Pressure	910 psig	909 psig
SG Level	55% (OR)	72% (OR)
RCS Flow	139.7×10^6 lbm/hr	139.4×10^6 lbm/hr
MFW Flow	10.9×10^6 lbm/hr	10.7×10^6 lbm/hr

The problem boundary conditions used are the pre-trip power response as well as the post-trip delayed neutron power and decay heat, a one second MFW flow coastdown, EFW and HPI flows, ANO-1 MSSV lift setpoints, and SG pressure vs. time control.

[Oconee 3 core characteristics at the approximate time in cycle as ANO-1 during the transient are used for both calculations.

The EFW flow used comes from ANO-1 plant data. The HPI flow is assumed to be the same as Oconee. It should be noted that the values for the high RCS pressure trip setpoint (2300 psig) and the RC pump inertia (70000 lbm-ft) at the ANO-1 plant are the same as those for the Oconee plant, and are already in the base model.

Simulation Results

The simulation begins with the closure of the main turbine intercept and governor valves on the loss of offsite power and continues for 300 seconds. The simulation was terminated at 300 seconds because acceptable plant data was only available to this point. Continuous plant data was not available for any of the parameters during this event. However, enough data points were available to accurately determine the plant response. The sequence of events is given in Table 4.3.1-1, and the results of the simulation are compared to the plant data in Figures 4.3.1-1 through 4.3.1-7.

The RCS pressure response is shown in Figure 4.3.1-1. The reactor trip on high RCS pressure is predicted by RETRAN at 3.9 seconds as compared to 4.1 seconds in the plant. This indicates that the pressurizer surge, produced by the turbine intercept valves closing, is being predicted satisfactorily. The predicted RCS pressure response trends the data closely throughout the simulation. Since the SG pressure is being controlled throughout the event (see Figure 4.3.1-4) and no feedwater is being delivered for the first 94 seconds, the SG heat transfer is largely dependent on the inventory and void profile in the steam generator. The predicted RCS temperatures (see Figure 4.3.1-3) trend the data closely, therefore, the modeling of the initial steam generator inventory is accurate.

The pressurizer level response given in Figure 4.3.1-2, as stated above, trends the plant data closely for the entire simulation. This is due mainly to the accurate steam generator heat transfer prediction during the simulation.

The RCS temperature response shown in Figure 4.3.1.3. RETRAN predicts a slightly greater ΔT across the loop during the initial cooldown after the trip. This is possibly due to differences in the predicted RCS flow coastdown and the actual coastdown. By the end of the simulation the predicted temperatures agree closely with the data.

The SG pressure response shown in Figure 4.3.1-4. As stated earlier, the SG pressure vs. time is input as a boundary condition. The SG level response is

shown in Figure 4.3.1-5. There is no plant data for comparison for this parameter, therefore, the figure is given as additional information. It is evident from the figure, however, that the level response is characteristic of a temporary loss of all feedwater. The level decreases below 20 inches in the first 90 seconds of the event and then recovers as feedwater is reestablished at 94 seconds.

At the end of the simulation the ΔT in the prediction closely matches the data. This means that the natural circulation flowrate is predicted very well, with RETRAN predicting 2.4% flow at 300 seconds (see Figure 4.3.1-7). Since the plant ΔT data has not yet stabilized, the natural circulation flowrate is not fully developed. This is consistent with the RETRAN prediction since the SG level has not reached the controlling setpoint, and SG pressure is not stable.

Table 4.3.1-1

Arkansas Nuclear One - Unit 1
Loss of Offsite Power
June 24, 1980

Sequence of Events

<u>Event Description</u>	<u>Plant</u>	<u>Time (sec)</u>	<u>RETRAN</u>
Main turbine intercept and governor valves close*	0		0
Reactor trip on high RCS pressure, reactor coolant and MFW pumps trip	4.1		3.9
Turbine driven EFW pump starts and trips immediately on overspeed*	21		21
Normal makeup is established*	34		34
EFW flow established*	94		94
RCS makeup increased*	104		104
End of simulation	N/A		300

Note: Asterisks designate boundary conditions

ANO-1 LOSS OF OFFSITE POWER

6/24/80




Figure 4.3.1-1

4-77

ANO-1 LOSS OF OFFSITE POWER

6/24/80





Figure 4.3.1-2

ANO-1 LOSS OF OFFSITE POWER

6/24/80



ANO-1 LOSS OF OFFSITE POWER

6/24/80





Figure 4.3.1-4

4-80

RETRAN

ANO-1 LOSS OF OFFSITE POWER

6/24/80



ANO-1 LOSS OF OFFSITE POWER

6/24/80





Figure 4.3.1-6

ANO-1 LOSS OF OFFSITE POWER

6/24/80



4.3.2 Oconee Nuclear Station - Unit 1 Reactor Coolant Pump Coastdowns Unit Startup Tests

Transient Description

A series of reactor coolant pump (RCP) coastdowns were performed during pre-operational startup testing at Oconee Unit 1. All of the coastdown tests were performed at hot zero power (HZP) conditions (approximately 532 °F and 2155 psig, RCS temperature and pressure). The tests performed encompassed all possible pump combinations with respect to the number of pumps initially running and the number tripped. RCS flow data was taken for the first 30 seconds of the coastdown for most of the tests performed.

Discussion of Important Phenomena

Since the coastdown tests were conducted at hot zero power, only hydraulic phenomena are important. The significant phenomena include the interaction between the RCPs and the coolant during coastdown as well as the frictional losses associated with the coolant flow through the loops. The key facets in modeling the interaction between the RCPs and the coolant are the pump flywheel inertia, the homologous curve set, and the frictional torque representation. Accuracy in this area is reflected by satisfactory prediction of transient RCS flow. The steady-state flow splits are determined by the frictional losses in the RCS flowpaths, including reverse flow frictional losses in cold legs with an inactive pump and loops with two inactive pumps. Thus a comparison of predicted and observed steady state flows demonstrates the accuracy of the RCS loss coefficients at various flow rates, including reverse flow.

Model Description and Boundary Conditions

The simulations performed in this analysis did not require a []
Therefore, the two-loop Oconee RETRAN Model (see Figure 2.2-1) is used with the []

The model was set up for four different HZP initializations. The differences between these initializations are simply a different configuration of pumps running initially and the corresponding RCS flow distribution plant data. The following table summarizes the four initializations:

Table 4.3.2-1
RCS Flow Initialization

<u>Case #</u>	<u># of Pumps Operating</u>	<u>Flow (x 10⁻⁶ lbm/hr)</u>
1	4	145.0 (vessel)
2	3	109.0 (vessel)
	Loop A	33.0
	Loop B	76.0
	Idle pump reverse flow	-15.0
3	2 (1 in each loop)	74.0 (vessel)
	Loop A	37.0
	Loop B	37.0
	Idle pump reverse flow	-13.4
4	2 (same loop)	68.3 (vessel)
	Loop A	-12.2
	Loop B	80.5

The pump combinations for which simulations were performed are the following:

Table 4.3.2-2

Pump Trip Combinations

4/0
4/3
4/2 (1 per loop tripped)
4/2 (2 in same loop tripped)
4/1
3/0
3/2 (1 per loop after trip)
3/1 (1 per loop tripped)
3/1 (2 in same loop tripped)
2/1 (1 per loop prior to trip)
2/1 (2 in same loop prior to trip)
2/0 (1 per loop prior to trip)
2/0 (2 in same loop prior to trip)

Simulation Results

The results of the coastdown simulations are presented in Figures 4.3.2-1 through 4.3.2-13. Continuous plant data was available for the first 30 seconds for most of the cases simulated as well as the eventual steady-state vessel flow for partial pump operation.

The RETRAN simulations trend the data for the duration of the coastdown for most cases. It is evident that for some data the quality is suspect, since the expected smooth curve characteristic of a pump coastdown was not recorded. The table below gives the results of the predicted steady state flows. It is apparent from these results that all cases agree reasonably well with the data.

Table 4.3.2-2

Steady-State Core Flow

<u>Pumps Operating</u>	<u>(% of 4 pump flow)</u>	
	<u>RETRAN</u>	<u>DATA</u>
3	74.5	75.2
2 (1 per loop)	47.9	51.0
2 (same loop)	46.3	47.1
1	21.3	22.6

ONS RCP COASTDOWN

4/0




Figure 4.3.2-1

ONS RCP COASTDOWN

4/3




Figure 4.3.2-2

ONS RCP COASTDOWN

4/2 (1 IN EACH LOOP)




Figure 4.3.2-3

ONS RCP COASTDOWN

4/2 (BOTH IN SAME LOOP)




Figure 4.3.2-4

4-91

ONS RCP COASTDOWN

4/1




Figure 4.3.2-5

4-92

— DATA

- - - RETRAN

ONS RCP COASTDOWN

3/0




Figure 4.3.2-6

4-93

ONS RCP COASTDOWN

3/2 (1 PER LOOP RUNNING)





Figure 4.3.2-7

ONS RCP COASTDOWN

3/1 (1 PER LOOP TRIPPED)



— DATA

- - - RETRAN

Figure 4.3.2-8

ONS RCP COASTDOWN

3/1 (BOTH TRIPPED SAME LOOP)





Figure 4.3.2-9

ONS RCP COASTDOWN

2/8 (ONE PER LOOP)



— DATA

- - - - - RETRAN

Figure 4.3.2-10

ONS RCP COASTDOWN

2/1 (ONE PER LOOP INITIALLY RUNNING)





Figure 4.3.2-11

ONS RCP COASTDOWN

2/0 (SAME LOOP)



— DATA

- - - - - RETRAN

Figure 4.3.2-12

ONS RCP COASTDOWN

2/1 (SAME LOOP)




Figure 4.3.2-13

4.3.3 Oconee Nuclear Station

Steady State Natural Circulation Comparisons

Analysis Description

This analysis is the calculation of stable natural circulation flow rates and hot leg to cold leg temperature differences for various decay heat power levels. At the end of a loss of offsite power simulation, the core power level is set at various values from 80 MW down to 10 MW (at 10 MW decrements) and a new steady state value is achieved. Steam generator (SG) level is maintained at the normal natural circulation setpoint of 50% on the operating range. The RETRAN predictions are compared to calculated natural circulation flow rates from various tests and events at lowered-loop 177 fuel assembly Babcock and Wilcox units.

Discussion of Important Phenomena

The steady-state natural circulation flowrate is determined by the core power level, the elevation difference between the thermal centers, and the frictional losses around the loop. The key phenomena are therefore the primary-to-secondary heat transfer which determines the heat sink thermal center, and the frictional losses at the low loop flowrates characteristic of natural circulation. For each different core power level a different equilibrium loop flowrate will develop.

Model Description and Boundary Conditions

Due to the symmetry of the transient the one-loop Oconee RETRAN Model (Figure 2.2-2) is used. The steady state natural circulation flow calculations are made by restarting a best estimate loss of offsite power simulation at 15 minutes. At this point, the plant is in a stable natural circulation condition, with decay heat being removed by the steam generators. The steady state flow calculations are then made by artificially changing the decay heat power level from 80 MW to 10 MW, as previously described. Emergency feedwater maintains the desired SG level (50% on the operating range) during the simulation.

Simulation Results

The steady state natural circulation flow is analyzed at various core power levels. Predicted natural circulation flow rate as a function of power level is shown in Figure 4.3.3-1 along with data points from various B&W plants. The RETRAN RCS flow prediction curve is at a constant 50% SG level. The data points at 48.8 MW, 57 MW, 62.5 MW, and 80 MW are also at 50% SG level. The three data points below 30 MW were from varying SG conditions and are not considered accurate. The data point at 67 MW is from 40% SG level.

The figure shows the RETRAN prediction to be consistently trending the data with an offset of +0.5% of full flow for all of the data points at 50% SG level. A decrease in the natural circulation flow is evident in the data point at 67 MW and 40% SG level. RETRAN predicts a smaller drop in natural circulation flow due to the decreased SG level. It is indeterminate whether this discrepancy is due to inaccuracy in the data or a model insensitivity.

OCONEE NATURAL CIRCULATION FLOW




Figure 4.3.3-1

4.4 Reactivity Transient

4.4.1 Oconee Nuclear Station Unit 1 Control Rod Group Drop August 8, 1982

Transient Description

Oconee Unit 1 was operating at 100% full power when the Group 6 control rods fell into the reactor core. Reactor power dropped almost immediately to approximately 36%, and the sudden mismatch between power generated in the core and power removed in the steam generators caused the primary coolant temperature to decrease. The resulting contraction of the coolant led to a rapid decrease in Reactor Coolant System (RCS) pressure, and the reactor tripped on variable low pressure approximately five seconds after the beginning of the event. The subsequent post-trip plant response was normal. Main feedwater (MFW) was continually available and the steam generator (SG) pressure control functioned as designed.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN and the Oconee RETRAN Model to accurately simulate the plant response. These phenomena include steam generator secondary void fraction profile and primary-to-secondary heat transfer, main steam relief, and pressurizer behavior. In addition to these, for this particular event, the dynamic reactor response to the dropped control rod group and the response of the plant and the plant instrumentation to the core power decrease are very significant.

When control rod Group 6 dropped into the core, the large negative reactivity insertion caused a sudden decrease in reactor power. This negative reactivity was compensated for, to some extent, by positive reactivity feedback from the decreased moderator and fuel temperatures. The transient core power determined the pre-trip RCS temperature and pressure response and thus the reactor trip time.

Model Description and Boundary Conditions

The plant response during this event (particularly before the reactor trip) showed little asymmetry between loops so the one-loop Ocone RETRAN Model (Figure 2.2-2) was used for the analysis. In addition, the Unit 3 specific feedwater and main steam line models were incorporated into the model. The parameters used as initial conditions were matched, where possible, to the plant data. The plant data used for this analysis is digital transient monitor data and post-trip review program data.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	100% (2568 MWt)	100% (2568 MWt)
RCS Pressure	2133 psig	2133 psig
PZR Level	213 inches	213 inches
T hot	601.5 °F	601.3 °F "A", 601.5 °F "B"
T cold	554.8 °F	555.5 °F "A", 555.1 °F "B"
SG Pressure	910 psig	894 psig "A", 890 psig "B"
SG Level	55% (OR)	71% "A", 70% "B" (OR)
RCS Flow	140 x 10 ⁶ lbm/hr	141 x 10 ⁶ lbm/hr
MFW Flow	10.8 x 10 ⁶ lbm/hr	10.9 x 10 ⁶ lbm/hr

The SG level initial condition deviates from the plant data. The base model initial SG level is used (Refer to Section 4.1.1).

The problem specific boundary conditions used in this analysis include cycle specific control rod worth and reactor physics parameters, RCS makeup flow, decay heat, main feedwater flow, and steam generator pressure control.

The makeup flow used in the simulation consists of pressurizer level control via the normal makeup flowpath as operators did not increase makeup by opening a second valve or starting a second HPI pump. A []

[

The main feedwater flow used in the simulation is from the transient monitor data and the post-trip review program data. Constant feedwater flow and steam flow were assumed until the reactor trip. There was no time for Integrated Control System action to significantly affect the plant response between the time that the control rod bank fell into the core and the time the reactor tripped on variable low pressure-temperature.

The turbine bypass valve setpoint is reduced from the normal post-trip value of 1010 psig to 1005 psig to match the actual SG pressure response as indicated by the data.

The model used for this analysis includes one significant change from the nominal base model. In this instance the [

]characteristic of the time immediately following reactor trip or after a large mismatch between power generated and power removed.

Simulation Results

The simulation begins with the dropped control rod group and continues for 120 seconds. The simulation is terminated at the point where all major plant parameters have returned to normal post-trip values. The sequence of events is given in Table 4.4.1-1, and the results of the simulation are compared to the plant data in Figures 4.4.1-1 through 4.4.1-8.

The normalized reactor power response is shown in Figure 4.4.1-1 and 4.4.1-2. Reactor power is predicted closely prior to the reactor trip. The predicted reactor trip occurs at approximately 4.6 seconds as compared with approximately 4.0 seconds in the plant. This indicates that the RETRAN point kinetics model and the boundary conditions used in the simulation are sufficiently accurate. RETRAN appears to overpredict the power in the latter portion of the simulation because the computer code output includes decay heat and delayed neutron power while the data represents delayed neutron power only.

The RCS pressure response is shown in Figure 4.4.1-3. The RETRAN predicted pressure response trends the data closely throughout the simulation as does the pressurizer level response seen in Figure 4.4.1-4. This is a result of the predicted RCS temperatures (see Figures 4.4.1-5 and 4.4.1-6) also trending the data closely, indicating that RETRAN is predicting the steam generator heat transfer adequately.

The RCS temperatures seen in Figures 4.4.1-5 and 4.4.1-6, as mentioned above, trend the data closely. The RETRAN cold leg temperature does increase more rapidly than the data immediately after reactor trip, [

] In addition, the predicted cold leg temperature decreases to the steady-state post-trip value more rapidly than the data.

The SG pressure response is shown in Figure 4.4.1-7. The predicted pressure response trends the data closely with only slight difference in initial conditions (see page 4-77). This indicates that the SG pressure control used in the RETRAN model is adequate.

The SG level response is shown in Figure 4.4.1-8. The predicted level is [] The plant indication is based on a ΔP signal and is not compensated for temperature. The initial offset is due to the plant indication being low because of the lack of temperature compensation. Since the RETRAN indication is based on [

] However, the long term response of the model trends the data fairly closely, indicating the proper initial inventory and feedwater boundary conditions are used. This is further supported by the accurate prediction of the RCS temperature response.

Table 4.4.1-1

Oconee Nuclear Station Unit 1
Control Rod Group Drop
August 8, 1982

Sequence of Events

<u>Event Description</u>	<u>Plant</u>	Time (sec)	<u>RETRAN</u>
Group 6 control rods fall into core*	0		0
Rx trip on variable low pressure-temperature minimum reactor power	4.0		4.6
Minimum RCS pressure, minimum PZR level	60		60
End of simulation	N/A		120

Note: Asterisks designate boundary conditions

ONS 1 8/6/82 ROD DROP EVENT




Figure 4.4.1-1

ONS 1 8/6/82 ROD DROP EVENT




Figure 4.4.1-2

ONS 1 8/6/82 ROD DROP EVENT




Figure 4.4.1-3

4-112

ONS 1 8/6/82 ROD DROP EVENT




Figure 4.4.1-4

ONS 1 8/6/82 ROD DROP EVENT




Figure 4.4.1-5

4-114

ONS 1 8/6/82 ROD DROP EVENT






Figure 4.4.1-6

ONS 1 8/6/82 ROD DROP EVENT



ONS 1 8/6/82 ROD DROP EVENT



PLANT DATA IS AVERAGE OF BOTH LOOPS

Figure 4.4.1-8

4.5 Operational Transients Without Reactor Trip

4.5.1 Oconee Nuclear Station Unit 1

Main Feedwater Pump Trip

July 15, 1985

Transient Description

Oconee Unit 1 was operating at 100% full power when the 1B main feedwater (MFW) pump tripped on low hydraulic oil pressure. The Integrated Control System (ICS) was in the fully automatic mode and a MFW pump trip reactor runback was initiated at 50% per minute. Seven seconds later feedwater to reactor cross limits were indicated by the ICS, reducing the runback to 20% per minute and putting the ICS in the tracking mode. Four seconds after that, the hydraulic oil pressure increased, reopening the MFW stop valves and clearing the pump trip indication. The automatic runback was stopped but, due to the cross limits which still existed, reactor power continued to runback to approximately 80% by two minutes into the event. The unit stabilized at this point with MFW pump 1A delivering total feedwater flow.

The plant response during the transient was driven by the reduction in feedwater and the action taken by the ICS. Reactor Coolant System (RCS) temperatures and pressure increased temporarily due to the initial reduction in feedwater. Steam generator (SG) levels decreased also as a result of the drop in feedwater flow. Reactor power was driven down by the action of the ICS to run back the unit load demand (ULD), thus inserting control rods. Reactor power was also driven down as a result of negative reactivity produced by the increase in RCS temperatures. Main steam pressure was maintained at a relatively constant value by the turbine control valve controller.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN and the Oconee RETRAN Model to simulate the plant response. These phenomena include primary-to-secondary heat transfer, reactor kinetics and control, and secondary pressure control.

Accurate simulation of the heat transfer through the steam generators is important for this transient since it determines the RCS temperature response and thus the reactivity feedback. The heat transfer surface areas of the steam generators are determined from the initial water inventory and the void fraction profile used. The reactor kinetics parameters are very important for this transient. The reactor power response is determined by the reactivity feedback and control rod movement modeled. The secondary pressure response, via the turbine control valve modeling, is also important since it will influence the RCS response by affecting the RCS temperature.

Model Description and Boundary Conditions

This event has symmetric behavior in each loop, since each steam generator is fed by both MFW pumps. The reduction in feedwater flow following the loss of one pump is therefore the same for each generator. The one-loop Oconee RETRAN Model (Figure 2.2-2) is used to simulate the feedwater runback transient. Reactor control rod and main turbine control valve models are also added to the base model for this analysis. The steady state base model initial conditions are used, with only a small adjustment to RCS pressure and pressurizer level to match the plant data. The plant initial conditions were obtained from digital transient monitor data.

	<u>Initial Conditions</u>	
	<u>Model</u>	<u>Plant</u>
Power Level	100% (2568 MWt)	100% (2568 MWt)
RCS Pressure	2133 psig	2133 psig
PZR Level	223 inches	223 inches
T hot	601.9 °F	601.8 °F (ave)
T cold	555.2 °F	555.8 °F (ave)
MS Pressure	885 psig	889 psig
SG Level	55% (OR)	82% (OR)
RCS Flow	140×10^6 lbm/hr	142×10^6 lbm/hr
MFW Flow	10.8×10^6 lbm/hr	10.7×10^6 lbm/hr

The problem boundary conditions used are cycle specific kinetics parameters, reactor and turbine control valve controls, ULD signal to the reactor control and MFW flow. It should be noted that the

Simulation Results

The simulation begins with the MFW pump trip and continues for 110 seconds. The simulation is terminated at the point where the reactor power level has stabilized following the runback transient. The sequence of events is given in Table 4.5.1-1, and the simulation results are compared to the plant data in Figures 4.5.1-1 through 4.5.1-7.

The normalized reactor power response is shown in Figure 4.5.1-1. The RETRAN prediction trends the data closely during the entire simulation. This indicates that the reactor control and the kinetics parameters used closely represent the conditions of the plant at the time. This is further confirmed by comparing predicted and measured RCS temperatures and control rod positions. The RCS temperatures (see Figures 4.5.1-4 and 4.5.1-5) trend the data in a similar manner, which provides the correct moderator feedback. The change in Group 7 control rod position in the RETRAN simulation shows a 26% insertion as compared with a 25% insertion for the plant measurement.

The RCS pressure response is shown in Figure 4.5.1-2. The simulated response shows the initial pressure increase resulting from the sudden reduction in feedwater starting slightly later than the data. This is a result of a similar trend present in the predicted cold leg temperature response (see Figure 4.5.1-5). The predicted RCS pressure then overshoots the data by approximately 30 psi. The pressurizer level response (Figure 4.5.1-3) shows the RETRAN prediction trending the data similar to the RCS pressure.

The RCS temperature response is shown in Figures 4.5.1-4 and 4.5.1-5. There is little change seen in the predicted hot leg temperature response and, as

mentioned above, the cold leg temperature responds slightly slower than the data. Since the main feedwater flow is input directly from the plant data as a boundary condition and the reactor power trends the data closely, the deviation in predicted temperatures can be attributed to slight differences in steam generator heat transfer.

The SG level response seen in Figure 4.5.1-6 shows the RETRAN predicted operating range level decreasing below the data slightly in the first part of the transient then trending the data for the rest of the simulation. The main steam pressure response (Figure 4.5.1-7) shows the RETRAN prediction trending the data for the entire simulation, and actually controls to the setpoint closer than the plant data.

Table 4.5.1-1

Oconee Nuclear Station Unit 1
Main Feedwater Pump Trip
July 15, 1985

Sequence of Events

<u>Event Description</u>	<u>Plant</u>	<u>Time (sec)</u>	<u>RETRAN</u>
1B MFW pump trip, reactor runback initiated at 50% per minute*	0		0
Feedwater to reactor cross limits reduce runback to 20% per minute*	7		7
Reactor runback stabilizes at approximately 80% power	120		120
End of simulation	N/A		120

Note: Asterisks designate boundary conditions

MFW RUNBACK TRANSIENT

ONS 1 7/15/85




Figure 4.5.1-1

MFW RUNBACK TRANSIENT

ONS 1 7/15/85




Figure 4.5.1-2

MFW RUNBACK TRANSIENT

ONS 1 7/15/85




Figure 4.5.1-3

MFW RUNBACK TRANSIENT

ONS 1 7/15/85





Figure 4.5.1-4

MFW RUNBACK TRANSIENT

ONS 1 7/15/85



MFW RUNBACK TRANSIENT

ONS 1 7/15/85




Figure 4.5.1-6

MFW RUNBACK TRANSIENT

ONS 1 7/15/85




Figure 4.5.1-7

4.5.2 Oconee Nuclear Station - Unit 1
Turbine Bypass Valve Failure
May 4, 1981

Transient Description

Oconee Nuclear Station Unit 1 was operating at 100% full power when the steam generator "A" pressure signal began drifting upwards. Approximately 3 seconds later the "A" turbine bypass valves began to open. The erroneous pressure signal increased by 128 psi (to 1053 psig) in 8 seconds, with the turbine bypass valves opening approximately 80%. Actual SG pressure decreased approximately 25 psi during this period.

Reactor power increased to 103% during the initial stage of the transient. Positive reactivity was inserted in the core due to overcooling of the Reactor Coolant System (RCS) as a result of increased steam flow when the turbine bypass valves opened. A small amount of the power increase was also due to control rod motion as a decrease in electrical output at the main generator sent a signal to the Integrated Control System (ICS) to increase reactor power.

The erroneous SG pressure signal decreased and the turbine bypass valves went closed 14 seconds after initiation of the transient. The reactor power decreased to 98% in the next 6 seconds as actual main steam pressure increased toward the setpoint of 885 psig. The decrease and overshoot past full power was also due to the decreasing reactor demand signal being generated by the ICS. This caused the control rods to travel back into the core, inserting negative reactivity.

The RCS responded during the transient with only minor deviations from the initial conditions. The RCS pressure dropped approximately 20 psi before recovering and then increased approximately 6 psi above its initial value before finally reaching the original steady state value. Pressurizer level decreased 3 inches before recovering to its initial value.

The plant was able to return to steady state full power conditions, once the erroneous SG pressure signal returned to normal. All affected plant parameters were back to their initial steady state values 60 seconds after the initiation of the event.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN to simulate the plant response. These phenomena include primary-to-secondary heat transfer and the dynamic reactor response.

Accurate simulation of the heat transfer through the steam generators is important for this transient since it determines the RCS temperature response and thus the reactivity feedback. The heat transfer surface areas of the steam generators are determined from the initial water inventory and void fraction profile used. The reactor kinetics parameters are very important for this transient. The reactor power response is determined by the reactivity feedback and control rod movement modeled. The secondary pressure response, controlled by the turbine bypass valves and the main turbine control valves, is the most important since it represents the driving force for the entire transient. The heat transfer through the steam generators, the RCS temperature response and thus the reactor power are controlled by the secondary pressure response.

Model Description and Boundary Conditions

In order to model the failure of the "A" turbine bypass valve in this event, a two-loop Oconee RETRAN Model (Figure 2.2-1) was used. In addition, reactor control rod and main turbine control valve models were added to the base model. The steady state base model initial conditions were used, with only a small adjustment to the RCS pressure to match the plant data. The plant initial conditions were obtained from digital transient monitor data.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	100% (2568 MWt)	100% (2568 MWt)
RCS Pressure	2134 psig	2134 psig
PZR Level	220 inches	221 inches
T hot	601.9 °F "A"	601.3 °F "A"
	601.9 °F "B"	601.7 °F "B"
T cold	555.2 °F "A"	556.4 °F "A"
	555.2 °F "B"	554.6 °F "B"
MS Pressure	890 psig	890 psig
SG Level	55% (OR)	69% "A", 70% "B" (OR)
RCS Flow	140 x 10 ⁶ lbm/hr	140 x 10 ⁶ lbm/hr
MFW Flow	10.8 x 10 ⁶ lbm/hr	10.7 x 10 ⁶ lbm/hr

The problem boundary conditions used are cycle specific kinetics parameters, reactor and turbine control, SG pressure signal to the turbine bypass controller, MFW flow, and a reduction in the turbine bypass valve setpoint. The turbine bypass setpoint was reduced from the normal post-trip value of 1010 psig to 960 psig, which is the normal setpoint when the plant is at power and on line.

Simulation Results

The simulation begins with the change in the SG pressure signal and continues for 60 seconds. The simulation is terminated at the point where the erroneous pressure signal terminates and all major plant parameters have returned to normal post-trip values. The sequence of events is given in Table 4.5.2-1, and the results of the simulation are compared to the plant data in Figures 4.5.2-1 through 4.5.2-9.

The normalized reactor power response is shown in Figure 4.5.2-1. The magnitude of the predicted power increase agrees closely with the data, reaching 103%, even though the cold leg temperatures do not decrease as much as the data (see Figures 4.5.2-5 and 4.5.2-7). The general shape of the predicted power response and timing of the changes in power are different than the data. This is due primarily to the predicted main steam pressure response (Figures 4.5.2-8 and 4.5.2-9) and its effect on the RCS temperatures. From the main steam pressure response it is evident that the predicted pressure decreases sooner and more steadily than the data. This causes the RCS temperatures and thus the power response to behave in a similar manner. The same behavior occurs when the false SG pressure signal terminates and the turbine bypass valves close.

The RCS pressure response is shown in Figure 4.5.2-2. The predicted pressure response is a result of the RCS temperature response, particularly the cold leg temperatures shown in Figures 4.5.2-4 and 4.5.2-6. The predicted pressure trend compares well with the data. The pressurizer level response in Figure 4.5.2-3 reflects the same trend as the RCS response.

The RCS temperature response is shown in Figures 4.5.2-4 through 4.5.2-7. As mentioned above, the RCS temperatures are driven by the main steam pressure during most of the transient. During the last 20 seconds of the transient, however, the temperatures are driven primarily by main feedwater. The trends are predicted well with only minor deviations.

Table 4.5.2-1

Oconee Nuclear Station Unit 1
Turbine Bypass Valve Failure
May 4, 1981

Sequence of Events

<u>Event Description</u>	<u>Plant</u>	<u>Time (sec)</u>	<u>RETRAN</u>
Plant operating at 100% full power	0		0
False SG pressure signal is initiated*	4		4
Turbine bypass valves begin to open	7		7
Turbine bypass valves begin to close	18		17
Minimum main steam pressure	18		18
Maximum power level reached	20		18
Minimum power level on overshoot	25		28
End of simulation	N/A		60

Note: Asterisks designate boundary conditions

ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA




Figure 4.5.2-1

4-135

ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA




Figure 4.5.2-2

4-136

— RETRAN - - - - DATA

ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA





Figure 4.5.2-3


ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA



ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA



4-139

Figure 4.5.2-5

ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA





Figure 4.5.2-6


ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA



ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA



ONS 1 TBV FAILURE W/O RX TRIP 5/4/81

RETRAN AND PLANT DATA




Figure 4.5.2-9

4.6 Other Operational Transients

4.6.1 Oconee Nuclear Station Unit 3 Reactor Trip From Three Reactor Coolant Pump Operation July 23, 1985

Transient Description

Oconee Unit 3 was operating at 74% full power with the B2 reactor coolant pump (RCP) secured. At that time a component failure within the Integrated Control System (ICS) caused a reduction in feedwater flow to the "A" steam generator. To compensate, flow to the "B" steam generator was increased until a Btu limit was reached. The overall decrease in total feedwater flow caused a reduction in primary to secondary heat transfer and an increase in Reactor Coolant System (RCS) temperature and pressure, and pressurizer level. Approximately 23 seconds after the initiating event, the reactor tripped on high RCS pressure. The subsequent post-trip response was typical. The turbine trip on reactor trip caused the SG pressure to increase rapidly, and the main steam relief valves (MSRVs) lifted to relieve the excess pressure. After the MSRVs reseated, the SG pressure was controlled near the nominal 1010 psig setpoint by the action of the turbine bypass valves. The primary system depressurized as the RCS temperatures decreased toward the nominal post-trip value of approximately 555 °F. The operators opened a second RCS makeup valve and started on additional high pressure injection (HPI) pump to facilitate the recovery of the pressurizer level, which decreased rapidly due to the contraction of the reactor coolant. Normal main feedwater (MFW) control was available after the trip to maintain a minimum SG level and continue the plant cooldown.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN and the Oconee RETRAN Model to accurately simulate the plant response. These phenomena include steam generator secondary void fraction profile and primary-to-secondary heat transfer, main steam relief, pressurizer behavior, and the pre-trip reactor dynamic response.

The most important phenomena during this event is the primary-to-secondary heat transfer, both before and after the reactor trip. This predominantly determines the RCS pressure and pressurizer level response. The RCS pressure response is particularly significant in the initial portion of this transient because it determines the timing of the reactor trip on high RCS pressure.

Accurate modeling of the reactor kinetic response is also important in order to determine the pre-trip response. As total feedwater flow decreases, the feedwater-to-reactor cross limit will cause the ICS to insert control rods and reduce reactor power. Reactor power will also be reduced to maintain a constant T-ave. Furthermore, the change in moderator temperature will produce reactivity feedback which will also affect reactor power.

Model Description and Boundary Conditions

The transient simulated begins from a steady state condition with only three reactor coolant pumps operating. Therefore, it is necessary to develop a model for this application. The model is based on the two-loop Oconee base model in Figure 2.2-1. Reactor power, flow rates, flow splits, and steam generator levels are characteristic of three pump operation. The three pump base model initial conditions are adjusted to match plant data where appropriate. The plant data used in this analysis is digital transient monitor data.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	74% (1900.3 Mwt)	74% (1900.3 Mwt)
RCS Pressure	2131 psig	2131 psig
Pressurizer Level	213 inches	213 inches
T hot	600.8 °F "A"	600.9 °F "A"
	599.8 °F "B"	601.1 °F "B"
T cold	557.1 °F "A"	556.7 °F "A"
	556.6 °F "B"	556.9 °F "B"
SG Pressure	911 psig "A"	881 psig "A"
	889 psig "B"	885 psig "B"
SG Level	69% (OR) "A"	69% (OR) "A"
	19% (OR) "B"	19% (OR) "B"
RCS Flow	109×10^6 lbm/hr	109×10^6 lbm/hr
MFW Flow	5.51×10^6 lbm/hr "A"	5.46×10^6 lbm/hr "A"
	2.15×10^6 lbm/hr "B"	2.36×10^6 lbm/hr "B"

The model temperature distribution is adjusted to match the loop A hot leg temperature, and the remainder of the primary system temperatures are determined by the flow splits and steam generator power removal fractions. The difference between plant hot leg temperatures is most likely due to imperfect mixing of the loop flows in the reactor vessel. The RETRAN modeling scheme produces perfect mixing, so the small difference in hot leg temperatures is due only to slight differences in loop pressures.

The SG pressures in the model are determined by the assumed 885 psig turbine header pressure, and the steam generator to turbine pressure drop (calculated by RETRAN based on loss coefficients from the full power base model). The SG "A" pressure is higher than the data, but this is not considered to have an

important effect on the course of the transient. For this benchmark analysis the initial SG levels are matched to the plant data[

]

The problem boundary conditions of this analysis include control rod movement, reactor kinetics parameters, the RCS high pressure trip setpoint, RCS makeup flow, decay heat and delayed neutron power, main feedwater flow, and SG pressure control.

Control rod motion based on the feedwater to reactor cross limits is modeled. These cross limits reduce the reactor demand when feedwater flow decreases more than 5% below feedwater demand. Cycle specific kinetics parameters and the differential rod worth of the Group 7 control rods is modeled. The RCS high pressure trip setpoint is assumed to be the nominal plant setpoint of 2290 psig. The HPI flow used in the simulation begins at 39 seconds with two pumps delivering flow through the second makeup valve. Letdown was isolated during the event immediately after the trip and normal makeup is not modeled.

A calculation of decay heat for this transient[

]

The main feedwater flow boundary condition is taken directly from the plant transient monitor data and the SG low level limit control is modeled. Pre-trip SG pressure control is provided by a model of the turbine control valves. The control valves are assumed to modulate to maintain steam header pressure at the 885 psig setpoint prior to the trip. After the trip SG pressure control is accomplished via nominal main steam relief valve and turbine bypass valve performance, except that the bypass valve control setpoint is adjusted to 990 psig on both SGs to match the observed long-term performance.

Simulation Results

The simulation begins with the failure in the ICS and continues for 180 seconds. The simulation is terminated at the point where all major plant parameters have returned to normal post-trip values. The sequence of events is given in Table 4.6.1-1, and the results of the simulation are compared to the plant data in Figures 4.6.1-1 through 4.6.1-17.

Reactor power and control rod position comparisons are shown in Figures 4.6.1-1 through 4.6.1-3. The pre-trip reactor power response is fairly close to the data, with RETRAN slightly lower. The post-trip prediction of RCS pressure (Figure 4.6.1-4), however, is not as close, as pressure is significantly underpredicted. The minimum predicted pressure is 1782 psig, compared to 1913 psig at the plant. The disagreement is due to the fact that the coolant temperatures predicted by RETRAN are several degrees lower than the data. This causes a greater pressurizer outsurge and RCS depressurization. The underprediction of temperatures can be attributed to the steam generator heat transfer in the RETRAN model. The greater effective heat transfer area in the steam generators which is predicted by RETRAN leads to excessive post-trip heat transfer in the simulation and a more rapid cooldown of the primary system.

The predicted pressurizer level response is compared to the data in Figure 4.6.1-5. The level response is similar to the RCS pressure, as would be expected. The initial insurge is slightly less than the data because the primary coolant heats up and expands less in the RETRAN calculation than in the actual transient prior to reactor trip.

The RCS temperature response is shown in Figures 4.6.1-6 through 4.6.1-13. The RCS temperatures, in general, compare favorably to the data prior to reactor trip. The loop A hot leg temperature is slightly low due to a lower reactor power prediction, but the loop A cold leg temperature prediction is close to the data. The loop B temperatures also compare well, although the decrease in loop B temperature is overpredicted by RETRAN. The post-trip temperature prediction is lower than the data, as discussed above.

The SG pressure response is shown in Figures 4.6.1-14 and 4.6.1-15. The immediate post-trip pressure prediction trends the data closely and the post-trip prediction undershoots the data temporarily. This action would tend to overcool the RCS temperatures slightly but not enough to account for the total difference in the temperature predictions.

SG level responses are given in Figures 4.6.1-16 and 4.6.1-17. The trend of the predicted level for each generator is similar to the data, indicating that the initial inventory and the feedwater boundary condition is reasonably accurate for this simulation. The SG level comparison indicates that the secondary inventory is not the cause of the excessive primary-to-secondary heat transfer.

Table 4.6.1-1


Oconee Nuclear Station Unit 3
Reactor Trip From Three
Reactor Coolant Pump Operation
July 23, 1985

Sequence of Events

<u>Event Description</u>	<u>Plant</u>	<u>Time (sec)</u>	<u>RETRAN</u>
ICS module fails, reducing A MFW flow, and B MFW flow increases to compensate*	0		0
B MFW flow limited by Btu limits*	1		1
Feedwater to reactor cross limits active*	8		8
Operators put MFW control in manual*	18		18
Reactor trip on high RCS pressure	22.5		24.1
Second makeup valve opened to increase flow*	36		36
Second HPI pump started to increase flow*	38		38
Second makeup valve close and pump secured*	53		53
End of simulation	N/A		180

Note: Asterisks designate boundary conditions

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION



ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-2

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-3

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-4

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION





Figure 4.6.1-5

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION



ONS3 7/23/85 TRIP FROM 3 RCP OPERATION





Figure 4.6.1-7

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




SOLID LINE = T HOT

DASHED LINE = T COLD

RETRAN

Figure 4.6.1-8

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION



SOLID LINE = T HOT

DASHED LINE = T COLD

PLANT DATA

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-10

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-11

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION





Figure 4.6.1-12

SOLID LINE = T HOT

DASHED LINE = T COLD

RETRAN

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION



SOLID LINE = T HOT

DASHED LINE = T COLD

PLANT DATA

Figure 4.6.1-13

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-14

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-15

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-16

ONS3 7/23/85 TRIP FROM 3 RCP OPERATION




Figure 4.6.1-17

5.0 McGUIRE/CATAWBA RETRAN BENCHMARK ANALYSES

The eight plant transients selected for benchmarking the McGuire/Catawba RETRAN model include a broad spectrum of initial conditions, initiating events, and transient evolutions. A large set of plant transient monitor data is recorded, typically at a one second frequency, during a transient. The simulation is conducted by first initializing the RETRAN model as close as possible to the plant initial conditions. Next, boundary conditions such as actuation of interfacing pumps and valves and operator actions are identified and modeled. In some instances a data void or an atypical plant response, due for example to a spurious valve opening, may require assuming a boundary condition. The simulation is then performed for a duration that includes the plant parameter responses of interest. The results of the simulation are then compared to the plant data for a set of parameters that characterize the overall plant response. The end result provides an assessment of the capability of the McGuire/Catawba RETRAN model and the RETRAN-02 code to simulate certain thermal-hydraulic phenomena and the category of transients typical of the benchmarked event.

5.1 Loss of Secondary Heat Transfer

5.1.1 McGuire Nuclear Station - Unit 2
Loss of Main Feedwater from 30% Power
June 10, 1983

Transient Description

McGuire Unit 2 was operating at 30% full power when main feedwater was inadvertently isolated. Primary temperature and pressure quickly began to rise due to the loss of feedwater, and after approximately 65 seconds, the turbine control valves spuriously closed, running the unit back to about 70 MWe. The operator then opened the control valves, and turbine load was restored at approximately 90 seconds. The unit then tripped on low-low SG level at 152 seconds. The AFW pumps started on low-low SG level, except for one motor-driven pump which was started manually. Pressurizer pressure and level reached maximum values of 2274 psig and 47%, respectively, while the post-trip minimum

values were 2083 psig and 23%. At approximately 400 seconds primary temperature was stable at 552°F (5°F below the no-load target) and at approximately 500 seconds steam line pressure was also stable at approximately 1030 psig (62 psi below the no-load target). Pressurizer pressure was restored to its initial value at approximately 900 seconds.

Discussion of Important Phenomena

Several important phenomena occurred during the transient which challenged the capability of RETRAN and the McGuire/Catawba RETRAN model to accurately simulate the plant response. These phenomena include primary-to-secondary heat transfer, main steam relief, steam generator level response, non-equilibrium pressurizer behavior, and the effect of pressurizer spray. These phenomena will be important, each to a varying degree for most of the simulations discussed in this section of the report. Therefore, they will only be discussed in great detail in this first benchmark analysis.

Secondary pressure control has a major impact on plant transient response since primary-to-secondary heat transfer is mainly determined by steam generator saturation temperature. This is due to the constraint that the tube bundle is always covered during power operation, so that the heat transfer area is fixed. Following reactor trip the tube bundle may become partially uncovered, however, the reduction in reactor power more than offsets the reduction in heat transfer area. Primary-to-secondary heat transfer is also directly impacted by a reduction in feedwater flow. This is particularly significant due to a

Post-trip.

secondary pressure control is accomplished by the Steam Dump System, the main steam line PORVs, and the main steam code safety relief valves. Typically only the steam dump to condenser valves are required, but the other steam relief capabilities are demanded as required. The Steam Dump System modulates to reduce RCS T-ave to the no-load setpoint of 557°F following reactor trip.

Accurate simulation of the steam generator inventory distribution and the indicated level response are also important since low steam generator level is often the cause of reactor trip. Steam generator level is sensitive to mismatches in steam and feed flows, and also to pressure disturbances due to

the shrink and swell effect. Steam generator boundary conditions and both the static and dynamic effects on the pressure difference type level instrumentation affect the rate of level change.

Changes in primary-to-secondary heat transfer feed back on the primary system as an expansion or contraction in RCS volume as indicated by pressurizer level. RCS pressure responds to changes in pressurizer level as the pressurizer steam volume is compressed or expanded. Accurate simulation of pressurizer phenomena is important since these phenomena determine the RCS pressure response.

Non-equilibrium effects accompanying the compression of the steam bubble during the pressurizer refilling phase are the most important of these. The efficiency of the pressurizer spray in desuperheating/condensing the steam bubble has a great effect on the RCS pressure response. Heat transfer between the liquid and vapor regions at the interface can be important, as can heat transfer to the pressurizer vessel. The importance of these phenomena can vary significantly, and is transient specific.

Model Description and Boundary Conditions

The one-loop McGuire Unit 2 RETRAN model was utilized for this analysis since the plant response among the four loops was essentially symmetrical.

Several modifications to the base model were necessary to simulate the primary and secondary pressure response. The closure of the turbine control valves, combined with the response of the Steam Dump System, resulted in an erratic steam pressure response prior to reactor trip. In order to simulate the transient accurately, it was necessary to construct a RETRAN control system which controls the position of the control valves, and hence steam flow, in order to match pre-trip steam line pressure data. Secondly, since the Condenser Dump System is designed to control steam flow to stabilize primary temperature at the no-load temperature of 557°, and since plant data shows that the temperature dropped several degrees below this value (post-trip), it was necessary to develop a control system similar to the one mentioned above to match the post-trip steam line pressure response. Thirdly, the plant pressurizer pressure shows an unexpected pressure response due to atypical

pressurizer spray operation. Therefore, a control system was developed which regulates spray flow to achieve an accurate pressure response during the short duration (approximately 65 seconds) of spray actuation.

The initial conditions were matched to plant data as shown in the following table. RCS flow was chosen in order to match plant ΔT .

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	29.7% (1012.4 MWt)	29.7% (1012.4 MWt)
RCS Pressure	2238 psig	2238 psig
PZR Level	36.4%	36.5%
T-ave	566.6°F	566.6°F (ave)
ΔT	18.8°F	19.1°F (ave)
Steam Line Pressure	1050 psig	1050 psig (ave)
SG Level	48.0%	47.8% (ave)
MFW Temperature	344°F	344°F (ave)
MFW Flow	4.0×10^6 lbm/hr	4.2×10^6 lbm/hr

The problem boundary conditions include cycle-specific post trip delayed neutron power and decay heat, MFW flow, and AFW flow. As stated above, secondary pressure is also controlled as a boundary condition, as well as pre-trip pressurizer spray valve position. Normalized reactor power is input as described in Section 4.1.1. MFW and AFW flow versus time was obtained from plant transient monitor data. Charging and letdown flows are assumed to have little effect on the transient and are not modeled.

Simulation Results

The simulation begins with MFW isolation and continues for 900 seconds. The simulation is terminated when most plant parameters have stabilized and the phenomena of interest have occurred. The sequence of events is given in Table 5.1.1 and the comparisons of RETRAN predictions and plant data are shown in Figures 5.1.1-1 through 5.1.1-7.

The comparison of the predicted reactor power to plant data is shown in Figure 5.1.1-1. Prior to reactor trip, there is a slight drop in power due to moderator feedback associated with the increase in RCS temperature. The moderator feedback was not modeled, however, the deviation between predicted power and plant data is small (less than 2%). The difference in the predicted trip time (160 seconds) and actual trip time (152 seconds) is due to a slight deviation between predicted SG level and plant data, which will be discussed later.

The pressurizer pressure comparison is shown in Figure 5.1.1-2. The reduction in heat transfer associated with the loss of feedwater causes RCS temperature and pressure to rise quickly. At 2260 psig, pressurizer pressure is moderated by spray actuation. The spike and subsequent decrease in pressure to approximately 2200 psig is due to changes in turbine control valve position. The pressure then increases again until a few seconds before reactor trip when it drops slightly due to a reduction in steam pressure and T-ave. The RETRAN results trend all of these pressure variations well with a slight under-prediction at approximately 100 seconds. The post-trip predicted pressure also trends the data well, although it is offset lower than the plant data.

The pressurizer level comparison is shown in Figure 5.1.1-3. The predicted level is in quite good agreement with plant data - typically within 3%. The increase in the level data near the end of the transient is most likely due to charging which was neglected in the simulation.

RCS T-ave and ΔT comparisons are shown in Figures 5.1.1-4 and 5.1.1-5. The predicted temperatures are very similar to the plant data throughout the duration of the simulation, with maximum deviations no greater than approximately 3°F.

As discussed in the modeling section, it was necessary to match steam line pressure to plant data, as shown in Figure 5.1.1-6. The unusual pre-trip pressure response results in erratic SG levels in both the predicted level and plant data, as shown in Figure 5.1.1-7. The downward spike in plant data at

152 seconds is due to the level in one SG reaching the low-low level trip setpoint of 12%. This trips the reactor 8 seconds before the predicted trip time. Both the predicted level and the plant data are below 3% for the rest of the simulation.

Table 5.1-1

McGuire Nuclear Station Unit 2

Loss of Main Feedwater

June 10, 1983

Sequence of Events

<u>Event Description</u>	Time (sec)	
	<u>Plant</u>	<u>RETRAN</u>
Feedwater isolation*	0	0
PZR spray on	**	12
Turbine control valves closed*	65	64
Steam line PORVs open	69	69
Maximum RCS pressure	72	74
Steam line PORVs closed	**	75
PZR spray off	**	75
All PZR heaters on	**	87
PZR backup heaters off	**	135
Reactor trip on low-low SG level	152	160
Turbine trip	152	160
AFW actuated	153	161
Condenser dump banks 1 and 2 open*	**	161
PZR backup heaters on	**	165
Condenser dump bank 2 closed*	**	169
End of simulation	N/A	900

Notes: Single asterisk designates boundary conditions

Double asterisks indicate plant data not available

MNS-2 LOSS OF MAIN FEEDWATER

8/18/83 EVENT




Figure 5.1.1-1

MNS-2 LOSS OF MAIN FEEDWATER

6/10/83 EVENT




Figure 5.1.1-2

MNS-2 LOSS OF MAIN FEEDWATER

6/18/83 EVENT




Figure 5.1.1-3

MNS-2 LOSS OF MAIN FEEDWATER

8/18/83 EVENT




Figure 5.1.1-4

MNS-2 LOSS OF MAIN FEEDWATER

6/18/83 EVENT




Figure 5.1.1-5

MNS-2 LOSS OF MAIN FEEDWATER

6/18/83 EVENT




Figure 5.1.1-6

MNS-2 LOSS OF MAIN FEEDWATER

6/18/83 EVENT




Figure 5.1.1-7

5.1.2 McGuire Nuclear Station Unit 2
Loss of Main Feedwater to One Steam Generator
June 24, 1985

Transient Description

McGuire Unit 2 was operating at 100% when CF-28, the MFW isolation valve to the lower nozzle on SG "C", failed closed. Level began to decrease due to the mismatch between steam flow and feed flow. The reactor tripped on low-low narrow range level in SG "C". The low-low level signal started both motor-driven AFW pumps. Flow from both pumps was throttled by the operators to maintain flow in the unaffected SGs near the no-load setpoint and to recover level in SG "C". MFW flow was isolated as designed on low RCS average temperature coincident with reactor trip. Pressurizer pressure and level dropped due to the post-trip coolant contraction. Level stabilized near the no-load setpoint while pressure was recovered by the pressurizer heaters. Minimum values reached were 23.5% and 1987 psig. The condenser dump valves and steam line PORVs controlled secondary pressure after reactor trip, stabilizing it at approximately 1070 psig. Narrow range level was eventually recovered in SG "C", reaching the no-load setpoint approximately 45 minutes post trip, after decreasing to a minimum of approximately 20% wide range.

Discussion of Important Phenomena

Aside from the general stabilization response common to most reactor trips, the transient exhibited several responses characteristic to an asymmetric loss of heat sink. First, the narrow range level in the affected steam generator dropped due to the mismatch of steam and feed flows, ultimately causing a reactor trip at 39 seconds at a setpoint of 40%. Careful modeling of both the static and dynamic effects on pressure difference type level instrumentation is necessary to accurately predict the rate of level decrease and the time at which reactor trip occurs. The decrease in feedwater flow to the affected steam generator caused an increase in the preheater temperature. This reduced the primary-to-secondary temperature difference results in a small primary

side ΔT decrease through SG "C". This caused RCS average temperature in loop "C" to increase, and ΔT in loop "C" to decrease, with respect to their steady-state pre-trip values.

Model Description

The plant response during this event showed definite asymmetry in loop "C" with respect to the loops to which MFW flow was not isolated prematurely. Therefore a two-loop McGuire Unit 2 model was used for the analysis. This model is very similar to the McGuire Unit 1 model but has unit-specific primary loop flow and loss coefficient modeling. The RCS flow specified in the simulation was chosen to match ΔT . To account for differences in recorded lift setpoints, the four steam line PORVs were modeled as separate junctions. The plant initial conditions were matched as follows:

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	100% (3411 MWt)	100% (3411 MWt)
PZR Pressure	2235 psig	2235 psig
PZR Level	59.2%	59.2%
T-ave	588.1°F	588.1°F (ave)
ΔT	56.0°F	56.1°F (ave)
Steam Line Pressure	1011 psig	1011 psig (ave)
SG Level	66.3%	66.3% (ave)
MFW Temperature	439.4°F	439.7°F (ave)
MFW Flow	15.1×10^6 lbm/hr	15.1×10^6 lbm/hr

The problem boundary conditions used are cycle-specific post-trip delayed neutron power and decay heat, MFW flow, and AFW flow. Normalized reactor power is input as described in Section 4.1.1. MFW and AFW flow vs. time information was input from transient monitor data. Charging and letdown flows were deemed to have little effect on the transient and are not modeled.

Simulation Results

The simulation begins with a steady-state condition a few seconds before SG "C" MFW flow perturbations start and continues for 15 minutes. The simulation is terminated when pressurizer pressure has recovered to its pre-trip value, the other parameters having previously stabilized. The sequence of events is given in Table 5.1.2-1, and the results of the simulation are compared to the plant data in Figures 5.1.2-1 through 5.1.2-10.

The pressurizer pressure response (Figure 5.1.2-1) shows the prediction increasing slightly above the data during the coolant expansion prior to reactor trip. [

] The RETRAN prediction is slightly lower on reactor trip due to an undershoot in steam line pressure. The repressurization rates trend closely until approximately 250 second when the plant data begins to decrease. This decrease is due to the reopening of SV-19, the loop A steam line PORV, at 1082 psig. This spurious actuation was not modeled in the simulation. The remaining discrepancy between the RETRAN prediction and the plant data is possibly due to an uncertainty about the number of pressurizer heaters in operation during the transient. Prior to reactor trip, heater groups A, B, and D were in manual control, but no record was kept of whether they were on or off. Typically, heaters are placed in manual control so that they can be energized to compensate for spray flow used to equalize the pressurizer and RCS boron concentrations. Depending on the spray flow, one, two, or three heater groups may be necessary to keep from depressurizing. Since the simulation models all heater groups as being on, it is postulated that the slower repressurization in the data may be due to one or more heater groups being in manual control and off.

The pressurizer level response (Figure 5.1.2-2) trends the data closely until the second opening of SV-19, discussed above. The deviation caused by this drop in the data is maintained through the remainder of the simulation.

The steam line pressure responses (Figures 5.1.2-3 and 4) exhibit the same general shape, peaking sharply at turbine trip and steam dump opening and settling out to ~ 1070 psig. RETRAN underpredicts the initial peak and the

initial minimum by ~ 10 -15 psig. The observed reseal setpoints of the steam line PORVs were approximately 30 psi below the nominal value. The sharpness of the steam line pressure decrease in the prediction with respect to the data suggests that the operators may have changed the condenser dump valve control mode, from RCS average temperature control to steam header pressure control, sometime prior to steam line PORV closure. This manual action is part of the normal reactor trip response, is not recorded, and cannot be simulated accurately with respect to time of occurrence. With the dump valves in pressure control mode, they would close to smooth the steam pressure transient as the PORVs remained open below their nominal reseal setpoint. The other obvious difference between the predictions and data is the already discussed reopening of SV-19, which was caused by the dump valve closure.

SG NR level (Figures 5.1.2-5 and 6) predictions and data trend closely before reactor trip and during the sharp level drop immediately after trip. The spiking in the level predictions at approximately 80 seconds is associated with the steam pressure decrease caused by closure of two of the four steam line PORVs.

The RCS average temperature response (Figures 5.1.2-7 and 8) shows close agreement between predictions and data. The slight perturbation in the data around 300 seconds is caused by the spurious opening and closing of SV-19. RETRAN correctly predicts the pre-trip rise in loop "C" temperature due to the increase in preheater temperature after feedwater isolation.

The RCS ΔT (Figures 5.1.2-9 and 10) prediction agrees closely with the data. The loop "C" graph shows the decrease in ΔT due to the increase in cold leg temperature discussed above.

Table 5.1.2-1
McGuire Nuclear Station Unit 2
Partial Loss of Main Feedwater
June 24, 1985
Sequence of Events

<u>Event Description</u>	<u>Time (sec)</u>	
	<u>Plant</u>	<u>RETRAN</u>
SG "C" feedwater isolated	0	0
Rx trip on SG "C" low-low level	39	44
Condenser dump banks #1 and #2 open	43	44
SV-13 begins to open	43	49
SV-1 begins to open	49	50
SV-19 begins to open (first time)	49	*
Condenser dump bank #2 begins to close	49	53
SV-13 fully open	49	57
SV-1 fully open	55	58
Condenser dump bank #2 fully closed	52-64	58
Condenser dump bank #1 begins to close	55	63
Low T-ave MFW isolation signal	64	67
SV-19 fully open (first time)	64	*
Condenser dump bank #1 fully closed	67-82	**
SV-1 begins to close	76	73
SV-13 begins to close	100	73
SV-1 fully closed	108	81
SV-13 fully closed	108	81
SV-19 begins to close (first time)	126	*
SV-19 fully closed (first time)	132	*
Three condenser dump bank #1 valves begin to open	141-157	**
SV-19 begins to open (second time)	239	*
SV-19 fully open (second time)	254	*
Three condenser dump bank #1 valves reclose	268-311	**
SV-19 begins to close (second time)	336	*
SV-19 fully closed (second time)	342	*
End of simulation	N/A	900

Note: * SV-19 did not open in the simulation.

SV-1, 3, and 19 are the PORVs in steam lines "D", "B", and "A"

** Condenser dump bank #1 valves never fully close in the simulation

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-1

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-2

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-3

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-4

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-5

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-6

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-7

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-8

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/86 EVENT




Figure 5.1.2-9

MNS-2 PARTIAL LOSS OF MAIN FEEDWATER

6/24/85 EVENT




Figure 5.1.2-10

5.2 Excessive Secondary Heat Transfer

5.2.1 Catawba Nuclear Station - Unit 2

Steam Line PORV Failures

June 27, 1986

Transient Description

Catawba Unit 2 was operating at a stable condition of 24% full power when the unit was manually tripped per the Loss of Control Room test procedure. Control of the unit was then manually transferred to the auxiliary shutdown panel (ASP). The transfer of control to the ASP resulted in several valves automatically repositioning. During this time, the steam generator MSIVs closed, pressurizer heater banks A and B turned off, and the B MFW pump turbine tripped. Both motor-driven and the turbine-driven AFW pumps were automatically started on low-low level in all four SGs. Although the primary system temperature was gradually decreasing, pressurizer level fell rapidly due to a large difference between makeup and letdown resulting from the realignment of several flow control valves. Pressurizer level decreased from approximately 25% to 18% in the first five minutes post-trip. AFW flow recovered SG levels to 23% from a low of 13%.

The operators at the ASP are required to verify that the steam line PORV controllers are set such that they will not immediately open when the controlling breakers are energized. However, the PORV controllers had been modified and the controls not clearly labeled. The operators, unaware of the changes to the controller, increased valve demand while attempting to increase the lift setpoint above the actual steam line pressure. When the control breakers were energized approximately 270 seconds post trip, all four steam line PORVs opened and remained open until control was transferred back to the control room approximately six minutes later. The PORV openings resulted in a rapid depressurization of the secondary with an accompanying cooldown of the primary system. Pressurizer pressure and level went offscale low (1700 psig and 0%) approximately two minutes later. As primary and secondary pressure

decreased, safety injection signals were generated first on low-pressurizer pressure (1845 psig) and then on low steam line pressure (725 psig). However, safety injection actuation did not occur until control of the unit was transferred back to the control room. During the cooldown, the pressurizer emptied and RCS subcooling was temporarily lost.

Approximately eleven minutes after the manually initiated reactor trip, control was transferred back to the control room. Safety injection actuated and the steam line PORVs automatically closed on transfer back to the control room. Safety injection flow was sufficient to recover RCS pressure to approximately 1230 psig and pressurizer level to 33% five and a half minutes later.

Discussion of Important Phenomena

The transient being analyzed challenged the capability of RETRAN and the McGuire/Catawba RETRAN model to accurately simulate the plant response. The phenomena of interest in the simulation include excessive primary-to-secondary heat transfer, main steam relief, and primary system voiding.

The primary-to-secondary heat transfer rate controls the degree of overcooling and depressurization which may occur in the primary system. The ability to accurately model main steam relief and excessive heat transfer from the primary system is important in modeling primary system shrinkage, loss of subcooling, and void formation and elimination.

Model Description and Boundary Conditions

The plant response during the transient showed little asymmetry between loops so the one-loop Catawba Unit 2 RETRAN model was used for the analysis. The parameters used as initial conditions were matched, where possible, to the plant data. The McGuire RETRAN base model was modified to represent the important differences between McGuire Unit 1 and Catawba Unit 2. The RCS flow specified in the simulation was chosen in order to match plant ΔT . The initial conditions were matched to plant data as shown in the following table.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	24% (819 MWt)	24% (819 MWt)
PZR Pressure	2235 psig	2235 psig
PZR Level	29.0%	29.0%
T-ave	560.4°F	560.4°F
ΔT	14.9°F	14.9°F
Steam Line Pressure	1027 psig	1027 psig
SG Level	49.6%	49.6%
MFW Flow	3.1×10^6 lbm/hr	N/A
MFW Temperature	320.0°F	320.0°F

The problem boundary conditions include cycle specific post-trip delayed neutron power and decay heat, AFW flow, auxiliary steam loads, charging and letdown flows, and safety injection flow. The pressurizer heater banks were individually modeled to accurately reflect their status during the simulation. Control of the MSIVs was on elapsed time to simulate closure upon control being transferred to the ASP. The steam line PORVs were also controlled on elapsed time to simulate their modulation on transfer of control. The steam line PORV

[]

The charging and letdown flows were based on plant transient monitor data, and were modeled individually, as opposed to a net difference, in order to better simulate their impact on pressurizer level and RCS average temperature.

The safety injection flows used in the simulation represent best estimate flows determined by RETRAN simulation of the ECCS pumps and associated piping. Safety injection flow from the two HHSI pumps and the two IHSI pumps was controlled on elapsed time to accurately simulate their start and stop times during the transient.

Simulation Results

The simulation begins with the manual reactor trip required by the Loss of Control Room test procedure and continues for 20 minutes. The simulation is terminated at the point where pressurizer level and system pressure have stabilized and most plant parameters have returned to stable conditions. At the end of the simulation, pressurizer pressure and T-ave have not returned to their nominal post-trip values due to the severity of the primary system cooldown. The sequence of events is given in Table 5.2.1-1, and the results of the simulation are compared to the plant data in Figures 5.2.1-1 through 5.2.1-9.

The pressurizer pressure response, as shown in Figure 5.2.1-1, indicates that the initial RETRAN predicted pressure response trends very closely to the plant data until pressurizer pressure indication goes offscale low at 1700 psig. Upon opening the steam line PORVs, pressurizer pressure decreases at a rate equivalent to the plant response. The low pressurizer pressure safety injection signal is generated at similar times with RETRAN leading the plant response by 20 seconds. Both RETRAN and plant pressure indications go offscale low at nearly equivalent times as shown in Figure 5.2.1-1. The wide range RCS pressure prediction closely trends the plant response throughout the entire simulation as shown in Figure 5.2.1-2. A minimum system pressure of 710 psig occurs at approximately 678 seconds. Safety injection flow is sufficient to recover and maintain system pressure to approximately 1230 psig throughout the remainder of the simulation.

The pressurizer level response as shown in Figure 5.2.1-3 is very similar to the pressure response. Predicted level does not initially fall to the level indicated by the plant data. Low pressurizer level alarm and level off-scale low occur at times equivalent to the plant response. The RETRAN level recovery occurs approximately 60 seconds sooner than the plant. This is attributed to a slightly larger RETRAN safety injection flow than that indicated by the plant data as shown in Figure 5.2.1-9.

The reactor coolant system temperature response closely matches plant data. T-ave, like pressurizer pressure and level, does not decrease as rapidly in the first seconds post-trip as the plant data indicates. The predicted T-ave matches the plant trend from approximately 60 seconds after reactor trip until the steam line PORVs open. RETRAN and plant T-ave indications go offscale low (530°F) together as shown in Figure 5.2.1-4. Wide range hot leg and cold leg temperature indications, Figures 5.2.1-5 and 5.2.1-6, trend closely with the plant data throughout the entire simulation. The minimum RCS temperature of 475°F occurs 1200 seconds post-trip as shown in Figure 5.2.1-6.

The steam line pressure response is presented in Figure 5.2.1-7. Pressure increases approximately 20 psi above the plant data after reactor trip and remains slightly higher for approximately four and one-half minutes post-trip. The effect of the higher secondary side pressure is reflected in the RETRAN pressurizer pressure and level and primary system temperature having values slightly higher than the plant data during this time period. Upon opening the steam line PORVs, RETRAN pressure decreases at a rate equivalent to the plant data. A low steam line pressure SI signal is safety generated at a time equivalent to the plant response as shown in Table 5.2.1-1. RETRAN pressure increases slightly above the indicated plant condition and remains elevated from the time the PORVs close until the end of the simulation.

SG level response is shown in Figure 5.2.1-8. Level quickly falls below the low-low level setpoint upon reactor trip, resulting in the actuation of all three AFW pumps. RETRAN underpredicts the level during the first four minutes post-trip. The RETRAN level trends with the plant data during the time interval in which the steam line PORVs are open. Upon PORV closure, both RETRAN and plant level indications go offscale low. However, the plant data indicates a quicker level recovery than RETRAN beginning at 720 seconds, [

Table 5.2.1-1

Catawba Nuclear Station Unit 2
 Steam Line PORV Failures
 June 27, 1986


<u>Event Description</u>	<u>Sequence of Events</u>	
	<u>Plant</u>	<u>RETRAN</u>
Manual reactor trip	0	0
PZR heater banks A and D on	11	8
AFW actuation on low-low SG level	18	25
MSIV closure and PZR heater bank A off on transfer of control of ASP*	38	38
PZR heater bank B off on transfer of control to ASP*	48	48
Steam line PORVs open*	288	288
PZR heater banks C and D off on level < 17.2%	302	305
T-avg offscale low (530°F)	413	415
Low PZR pressure (1845 psig)	445	425
safety injection signal generated		
PZR pressure offscale low (1700 psig)	485	473
Low steam line pressure (725 psig)	**	485
safety injection signal generated		
Safety injection actuation on transfer of control to control room*	655	655
Minimum RCS pressure	655	675
Steam line PORVs close on transfer of control to control room*	671	671
PZR level on-scale (>0%)	790	726
Safety injection manually terminated*	995	995
End of simulation	N/A	1200

Note: Single asterisk designate boundary conditions

Double asterisks indicate plant data unavailable

CNS-2 STEAM LINE PORV FAILURE

8/27/86 EVENT



CNS-2 STEAM LINE PORV FAILURE

8/27/86 EVENT




Figure 5.2.1-2

CNS-2 STEAM LINE PORV FAILURE

6/27/88 EVENT




Figure 5.2.1-3

CNS-2 STEAM LINE PORV FAILURE

6/27/88 EVENT




Figure 5.2.1-4

CNS-2 STEAM LINE PORV FAILURE

6/27/86 EVENT

5-40




Figure 5.2.1-5

CNS-2 STEAM LINE PORV FAILURE

6/27/86 EVENT




Figure 5.2.1-6

CNS-2 STEAM LINE PORV FAILURE

8/27/86 EVENT




Figure 5.2.1-7

CNS-2 STEAM LINE PORV FAILURE

8/27/88 EVENT




Figure 5.2.1-8

CNS-2 STEAM LINE PORV FAILURE

8/27/86 EVENT




Figure 5.2.1-9

5.3 Loss of Forced Circulation

5.3.1 McGuire and Catawba Nuclear Stations Reactor Coolant Pump Flow Coastdown Tests

Transient Description

The pre-critical startup testing at each McGuire and Catawba unit included a number of RCP flow coastdown tests. These tests are conducted to confirm that the flow coastdown characteristics will not result in unacceptable DNBRs for the limiting FSAR transients. The tests are performed under isothermal conditions at approximately 555°F and 2250 psig with the reactor subcritical. Tests were initiated with both four and three pumps in operation, and then either one pump or all pumps were simultaneously tripped. The notation "X/Y" is used to describe a test with "X" pumps tripped from a "Y" pumps operating initial condition. At both McGuire units 4/4, 1/4, 3/3, and 1/3 tests were conducted. At Catawba only the 4/4 and 1/4 tests were conducted. For all tests data were documented for a period of 10 seconds.

Discussion of Important Phenomena

The rate that the RCP coasts down is determined primarily by the size of the pump flywheel and the modeling of the pump frictional torque. With one or more pumps remaining in operation during the coastdown (i.e. 1/4, 1/3 tests), the dynamic interaction between the pumps comes into play as the operating pumps deliver a higher flowrate consistent with the pump head/flow characteristic curve. Parameters of interest are the decrease rate of the loop flow in the coasting down loop and of the core flow, and the increase rate of loop flow in an active loop.

Model Description and Boundary Conditions

Due to the isothermal nature of the flow coastdown tests, the RETRAN model used in these benchmarks has been simplified and consists solely of the primary loop with all thermal modeling deleted. A one-loop model is used for the 4/4 coastdown benchmarks, and a three-loop model is used for the 1/4, 3/3, and 1/3

benchmarks. In order to show consistency between the models, the 4/4 coastdown was modeled with the four, three and two loop models. Unit specific models were developed to determine if the minor differences between units impacted the coastdown response as predicted by RETRAN. The differences between Catawba Unit 2 RCPs and those in the other three units are explicitly accounted for. The initial coolant temperatures during the tests varied from 555°F to 558°F, and are matched in the simulations. Initial four-pump flowrates are also unit specific. Initial three-pump loop flowrates agreed well with the available data.

Simulation Results

The comparisons of the predicted pump coastdown flowrates and the plant test data are given in Figures 5.3.1-1 through 5.3.1-11. It is evident that in some of the plant test data the data is not very smooth at low flowrates. This is due to the data acquisition system which did not have high resolution and has a larger uncertainty at low flow rates. An analysis of the Catawba Unit 1 4/4 test was undertaken first since the test data was available for 24 seconds. The results of these runs are shown in Figure 5.3.1-1. The curve labeled "OLD-PUMP" is the prediction of the original RCP model. It is evident that RETRAN predicts a slower flow coastdown than the data. Based on this result, the RETRAN pump model was [


]The result of the revised pump model is labeled "NEW-PUMP". The revised model closely matches the plant data. The revised pump model is used in all subsequent pump coastdown analyses presented, and a similar modeling approach will be used in all future MNS/CNS RETRAN model applications. Figure 5.3.1-2 shows that RETRAN predicts identical results for a 4/4 coastdown regardless of whether the primary loops are lumped into one, two, or three loops. Figure 5.3.1-3 shows predicted flow coastdowns for the 4/4 tests for all four units. The results indicate that the unit-specific modeling, including the different RCP modeling for Catawba 2, has only a very small impact on the coastdown. Based on this result, the remaining flow coastdown analyses were only performed using models of McGuire 1 and Catawba 2. McGuire 2 and Catawba 1 are essentially identical to the McGuire 1 model with respect to primary loop design. The comparison of the predicted 4/4 coastdowns to the plant test data are shown in Figures 5.3.1-4 and 5.3.1-5. RETRAN accurately predicts the coastdowns, with a maximum deviation of approxi- (continued on next page)

mately 2% of initial flow. The comparison can also be interpreted as the RETRAN prediction leading or lagging the data by approximately 0.5 seconds at 10 seconds. Figure 5.3.1-1 shows that beyond 10 seconds the maximum deviation increases to only 3% of initial flow at 24 seconds, or that RETRAN leads the data by about 3 seconds at 24 seconds.

The comparisons between the predicted and measured flow coastdowns for the 1/4 tests are given in Figures 5.3.1-6 through 5.3.1-8. In each figure the prediction of either the flow in the loop with the tripped pump or of the core flow compares well with the plant test data. No data exists for the core flow during the Catawba 2 test. A maximum deviation of 5% in loop flow and 2.5% in core flow occurs, even with the obvious uncertainty in the test data at low flows. The comparison to 3/3 tests conducted at McGuire Units 1 & 2 is shown in Figure 5.3.1-9. Again, the agreement with the test data is very good, with a maximum deviation of 2% of the initial flow. The 1/3 test comparisons shown in Figures 5.3.1-10 and 5.3.1-11 have an interesting result. RETRAN predicts loop and core flowrates that are very nearly the average of the higher McGuire 1 results and the lower McGuire 2 results. A maximum deviation of approximately 3% is indicated.

The revised RCP model, which was revised in order to agree with the Catawba Unit 1 4/4 flow coastdown test data, has been shown to consistently and accurately simulate the plant test data for the various tests. Future applications with the revised model are therefore appropriate.

CNS-1 - 4/4 PUMP COASTDOWN



MNS-1 - 4/4 PUMP COASTDOWN




Figure 5.3.1-2

MNS/CNS - 4/4 PUMP COASTDOWN






Figure 5.3.1-3

RET/CNS1 RET/CNS2
 RET/MNS1 RET/MNS2

MNS-1&2 / CNS-1 - 4/4 PUMP COASTDOWN



CNS-2 - 4/4 PUMP COASTDOWN



MNS-1&2 / CNS-1 - 1/4 PUMP COASTDOWN




Figure 5.3.1-6

— CNS-1 ····· MNS-1 - - - MNS-2 - - - RETRAN
 FLOW IN LOOP WITH TRIPPED PUMP

MNS-1&2 / CNS-1 - 1/4 PUMP COASTDOWN





Figure 5.3.1-7

CNS-2 - 1/4 PUMP COASTDOWN



— CNS-2 - - - - - RETRAN
FLOW IN LOOP WITH TRIPPED PUMP

Figure 5.3.1-8

MNS UNITS 1 & 2 - 3/3 PUMP COASTDOWN




Figure 5.3.1-9

5-56

— MNS-1

..... MNS-2

----- RETRAN

MNS UNITS 1 & 2 - 1/3 PUMP COASTDOWN




Figure 5.3.1-10

— MNS-1 - - - MNS-2 . . . RETRAN
FLOW IN LOOP WITH TRIPPED PUMP

MNS UNITS 1 & 2 - 1/3 PUMP COASTDOWN




Figure 5.3.1-11

— MNS-1 - - - - MNS-2 - - - - RETRAN
CORE FLOW

5.3.2 McGuire and Catawba Nuclear Stations Natural Circulation Testing

Transient Description

Two types of natural circulation testing that are useful for benchmarks were conducted during the initial startup testing at McGuire Unit 1 and Catawba Unit 1. At both units steady-state natural circulation tests were conducted with the unit at approximately 1% or 3% full power. The pertinent test result is the ΔT between hot leg and cold leg temperatures. It should be pointed out that there exists some degree of uncertainty in the true core power during such tests, and therefore the 1% and 3% power values are very approximate. Steady-state natural circulation is simulated by maintaining the reactor power stable at plateaus of 5%, 3%, 2%, 1%, and 0.5% full power, and allowing loop flowrates and loop ΔT s to stabilize.

The second type of testing was conducted only at McGuire Unit 1 and was performed to evaluate the plant response to isolating two SGs in sequence after achieving a stable natural circulation condition with the reactor critical at approximately 1% power. SGs were isolated by closing the MSIV, isolating feedwater, and isolating blowdown. The transition from all four SGs steaming to three, and to two, demonstrated the capability to remove decay heat in a natural circulation mode with only two SGs steaming.

A RETRAN simulation of this test enables a comparison of the resulting loop ΔT s and the repressurization rate of the SGs following isolation. The natural circulation flowrates predicted by RETRAN, for which test data are unavailable, are also presented.

Discussion of Important Phenomena

The steady-state natural circulation flowrate results from a balance between the driving head due to the difference in density between the hot leg and the cold leg in combination with the elevation difference between the thermal centers, and loop frictional losses. The balance changes as reactor power changes, and also changes as the number of SGs that are steaming changes. A

key phenomenon is the elevation of the thermal center in the SG, which is determined by the distribution of primary-to-secondary heat transfer. Another important phenomenon is the loop frictional loss at the low loop flowrates characteristic of natural circulation.

SG isolation results in a situation where the isolated SG can function as a heat sink only as long as the hot leg temperature exceeds the SG saturation temperature. Since no energy is being extracted from the SG (with the exception of leakage past the isolation valves and losses to ambient) the SG temperature will asymptotically approach the hot leg temperature, and the SG pressure will correspondingly increase. Following SG isolation, the natural circulation flowrate should decrease as the ΔT in that loop decreases. For a constant reactor power level the ΔT and loop flowrates in actively steaming loops should increase when other loops are isolated. This occurs since more energy must be transferred in the non-isolated loops, which requires a higher ΔT , and a higher ΔT causes higher natural circulation flow.

Model Description and Boundary Conditions

The steady-state natural circulation simulations use the one-loop McGuire Unit 1 RETRAN model since there is no loop asymmetry. Starting from an initialization at full power, the reactor and the reactor coolant pumps are tripped. The reactor power is then maintained at power plateaus of 5%, 3%, 2%, 1%, and 0.5% full power, and natural circulation conditions are allowed to stabilize. Steam header pressure is controlled at 1055 psig to maintain T-cold at 553°F, which is typical of plant test conditions. SG level is controlled at 38% with AFW.

The natural circulation with SG isolation test simulations require a three-loop McGuire Unit 1 RETRAN model. The two loops that are sequentially isolated are modeled as separate loops, with the remaining loops lumped. The test initial conditions were approximately 1% power with T-ave at 515°F and an initial ΔT of 20°F. The SG in loop 1 was isolated and the simulation was run for 1800 seconds. This is referred to as the "1/4 steam generators isolated" case. A second simulation isolated the SG in loop 2 1200 seconds after the loop 1 SG was isolated. This is referred to as the "2/4 steam generators isolated" case.

This simulation was then continued for an additional 1800 seconds. In both simulations steam header pressure was controlled to maintain T-cold at 515°F. AFW was also controlled to maintain SG level at 38% in active SGs.

Simulation Results

The predicted steady-state natural circulation ΔT vs. reactor power is shown in Figure 5.3.2-1. Also shown are four plant test data points. Although the available data are limited, the trend of increasing ΔT with power is consistent, and the magnitude also compares well considering the aforementioned uncertainty in test data power level. Figure 5.3.2-2 shows the corresponding predicted relationship between loop flow and power level.


The comparisons of the 1/4 steam generators isolated case are shown in Figures 5.3.2-3 through 5.3.2-12. Figures 5.3.2-3 and 5.3.2-4 show the loop ΔT plant data and simulation results, respectively. The plant data starts with a ΔT of 20°F, and after 1800 seconds the active loop ΔT has increased to 22.5°F and the isolated loop has decreased to 8°F. In the simulation the ΔT starts at 22°F and after 1800 seconds the active loop has increased to 27°F and the isolated loop has decreased to 3°F. Figure 5.3.2-5 shows the comparison of the rate of decrease in the isolated loop ΔT . Figure 5.3.2-6 shows the comparison of the rate of increase in the active loop ΔT . Figures 5.3.2-7 and 5.3.2-8 show SG pressure data and predictions, respectively. In the plant data the isolated SG pressure increases by 100 psi in 1800 seconds, whereas RETRAN predicts a pressure increase of 200 psi. A comparison of the rates of pressure increase in the isolated SG is given in Figure 5.3.2-9.

The comparisons of ΔT and isolated SG pressure responses are consistent in that RETRAN predicts a more rapid loss of heat sink. The source of this difference can be one or a combination of many causes, such as the assumed RETRAN power level being too high, the plant SG not being well isolated, or the RETRAN heat transfer being too high following isolation. Figure 5.3.2-10 shows the asymptotic approach to loss of heat sink (loss of ΔT) as predicted by RETRAN. Figure 5.3.2-11 shows the increase in ΔT in the active loops. Figure 5.3.2-12 shows the corresponding changes in the active loop natural circulation flow-rates following isolation.

The comparisons of the 2/4 steam generators isolated case are shown in Figures 5.3.2-13 through 5.3.2-23. Figures 5.3.2-13 and 5.3.2-14 show the loop ΔT plant data and the simulation results, respectively. The plant ΔT data for the second isolated SG decreases from 19°F to 13°F in 1800 seconds. The ΔT in the two active loops increases from 21°F to 23.5°F. In the simulation the ΔT in the second isolated SG decreases from 26.5°F to 4°F in 1800 seconds. The ΔT in the two active loops is predicted to increase from 26.5°F to 34°F. Figures 5.3.2-15 through 5.3.2-17 show the ΔT comparisons between RETRAN and plant data in each loop. In each figure it is evident that the trend is similar but the rates of change and the magnitudes are much greater in RETRAN. Figures 5.3.2-18 and 5.3.2-19 show the steam generator pressure data and predictions, respectively. In the plant the second isolated steam generator pressure increased by 70 psi in 1800 seconds, whereas RETRAN predicts a pressure increase of 230 psi.

The above discussion regarding the potential causes of the differences between plant data and predictions in the 1/4 test remain valid for the 2/4 test. The predicted loop ΔT responses following isolation of the second SG are shown in Figures 5.3.2-20 through 5.3.2-22. The characteristic asymptotic approach to loss of heat sink in the isolated SGs is evident, as is the increased ΔT in the active loop. Figure 5.3.2-23 shows the corresponding changes in the loop natural circulation flowrates. In both the 1/4 and the 2/4 cases the important phenomena are predicted, with only the rate of change and the magnitudes differing from the available plant data.

MNS/CNS STEADY-STATE NATURAL CIRCULATION



NATURAL CIRCULATION DELTA-T VS. POWER
CURVE IS RETRAN PREDICTED

O - MNS-1 8/30/81
X - MNS-1 9/1/81
Δ - MNS-1 8/28/81
∇ - CNS-1 1/19/85

Figure 5.3.2-1

MNS/CNS STEADY-STATE NATURAL CIRCULATION





Figure 5.3.2-2

NATURAL CIRCULATION FLOW VS. POWER
CURVE IS RETMAN PREDICTED

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED




ISOLATED & ACTIVE LOOPS DELTA-T
PLANT DATA

Figure 5.3.2-3

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED



ISOLATED & ACTIVE LOOPS DELTA-T
RETRAN PREDICTION

Figure 5.3.2-4

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-5

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED





Figure 5.3.2-6

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED



MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-8

----- ISOLATED SG - - - - - ACTIVE SGs
RETRAN PREDICTION

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-9

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-10

T-HOT & T-COLD IN THE ISOLATED LOOP
RETRAN PREDICTION

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-11

T-HOT & T-COLD IN THE ACTIVE LOOPS
RETRAN PREDICTION

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

1/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-12

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-13

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED





Figure 5.3.2-14

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED



DELTA-T IN THE PREVIOUSLY ISOLATED LOOP

Figure 5.3.2-15

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-16

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-17

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED





Figure 5.3.2-18

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED

5-81



MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED





Figure 5.3.2-20

T-HOT & T-COLD IN THE PREVIOUSLY ISOLATED LOOP
RETRAN PREDICTION

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED



T-HOT & T-COLD IN THE SECOND ISOLATED LOOP
RETRAN PREDICTION

Figure 5.3.2-21

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-22

T-HOT & T-COLD IN THE ACTIVE LOOPS
RETRAN PREDICTION

MNS-1 NATURAL CIRCULATION W/ SG ISOLATION

2/4 STEAM GENERATORS ISOLATED




Figure 5.3.2-23

5.3.3 McGuire Nuclear Station - Unit 1
Reactor Coolant Pump Trip at 89% Power
June 6, 1984

Transient Description

McGuire Unit 1 was operating at 89% full power when the RCP "C" bus feeder breaker opened. The reactor tripped almost immediately on low reactor coolant flow in loop C since reactor power was greater than 48% full power. All control stations except rod control were in automatic at the time of the event. Pressurizer pressure and level decreased post-trip due to the loss of heat source and continued feedwater addition to the SGs. Charging and letdown continued after the trip with the net difference between the two at approximately 13 gpm. Both banks of condenser dump valves initially opened post-trip to cool the unit down to the no-load temperature of 557°F. One condenser dump valve stuck open post-trip. Upon reactor trip, steam line pressure increased sharply resulting in the lifting of two of the four steam line PORVs. Flow in the affected loop decreased with RCP coastdown and then reversed due to the driving force of the remaining three RCPs. MFW was isolated on low reactor coolant average temperature of 564°F. AFW was initiated on low-low level in all four SGs.

Pressurizer pressure reached a minimum value of 1976 psig approximately 145 seconds post trip. Pressurizer level reached a minimum level of 24% at 220 seconds post-trip. T-ave was stabilized at 550°F approximately three minutes post-trip.

Discussion of Important Phenomena

The phenomenon of interest in this simulation is the effect of a RCP coastdown during a trip from a high power level. Reactor trip on low flow in one loop occurs immediately after a single RCP trip. Reverse flow in the affected loop is quickly established due to the net driving force of the three remaining RCPs. After flow reversal, the hot leg temperature decreases as the cooler fluid from the steam generator tube bundle flows back through the hot leg. T-ave in the remaining loops is unaffected by the flow reversal.

Model Description and Boundary Conditions

The two-loop McGuire Unit 1 RETRAN model was used for the analysis due to the asymmetric nature of the pump trip. RCS flow was specified in the simulation in order to match ΔT . The parameters used as initial conditions were matched to the plant data as follows:

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	89% (3036 MWt)	89% (3036 MWt)
PZR Pressure	2228.0 psig	2228.0 psig
PZR Level	59.4%	59.4%
T-ave	560.4°F	560.4°F
ΔT	52.1°F	52.1°F
Steam Line Pressure	1036 psig	1036 psig
SG Level	64.4%	64.4 % (ave)
MFW Flow	1.33×10^6 lbm/hr	1.34×10^6 lbm/hr
MFW Temperature	429.5°F	429.5°F

The problem boundary conditions used included cycle specific post-trip delayed neutron power and decay heat, MFW, and AFW flow. Transient monitor steam dump valve performance data was insufficient in providing a full understanding of the valves operation. One condenser dump valve was noted to have stuck open during the transient and was modeled as such. The use of RETRAN best estimate steam dump bank performance resulted in secondary pressures much lower than those indicated by plant data. With the unavailability of complete plant valve position data and the discrepancy in results between RETRAN using the best estimate steam dump performance and the plant data, steam line pressure data was input as a boundary condition during the simulation in order to better match the actual plant performance.

Simulation Results

The simulation begins with the single RCP trip and continues for three minutes. The simulation is terminated after all major plant parameters have returned to nominal post-trip conditions. The sequence of events is given in Table 5.3.3-1. The results of the simulation are compared to the plant data in Figures 5.3.3-1 through 5.3.3-13.

The pressurizer pressure response is shown in Figure 5.3.3-1. The comparison indicates good agreement between RETRAN and the actual plant response. From approximately 20-50 seconds, RETRAN slightly underpredicts the plant pressurizer pressure. RETRAN and plant pressure trend together during the remainder of the simulation, with RETRAN slightly underpredicting pressure at the end of the simulation.

The pressurizer level response, like pressurizer pressure, indicates a similar trend with the plant data as shown in Figure 5.3.3-2. RETRAN pressurizer level trends closely with the plant data immediately after the reactor trip. From approximately 10-40 seconds, RETRAN underpredicts pressurizer level. RETRAN and plant level compare well throughout the remainder of the simulation.

The reactor coolant average temperature response for the unaffected loop is presented in Figure 5.3.3-3. Under normal operating conditions, bypass flow from the hot and cold legs is diverted through their respective RTD manifolds and back into the pump suction piping. The net pressure differences between hot leg and pump suction piping and cold leg and pump suction piping provide the necessary driving force required for the RTD Bypass System to work. The low flow and stagnant flow conditions existing in the affected loop after pump trip yield invalid RTD indications, and therefore the affected loop average temperature results are not presented. T-ave in the unaffected loop is relatively unaffected by the flow coastdown and reversal. The RETRAN prediction trends very closely with the plant data in the unaffected loop throughout the simulation.

The wide range hot leg temperature response for the affected and unaffected loops are presented in Figures 5.3.3-4 and 5.3.3-5, respectively. The RETRAN predictions closely match the plant data throughout the entire simulation. The wide range cold leg temperature response for the affected and unaffected loops are shown in Figures 5.3.3-6 and 5.3.3-7, respectively. During the initial 40 seconds of the simulation, the RETRAN temperatures are a few degrees less than the plant data. The trend then reverses and RETRAN predicts a slightly higher cold leg temperature throughout the remainder of the simulation.

The steam line pressure response for the affected and unaffected loop are shown in Figures 5.3.3-8 and 5.3.3-9, respectively. Steam line pressure immediately increases post-trip due to the turbine trip and loss of steam load. The plant response resulted in the lifting of two of the four steam line PORVs. The pressure trends of both the affected and unaffected loops are nearly identical. Steam line pressure in the affected loop was controlled to match the plant data boundary condition. The use of the steam pressure boundary condition was necessary due to the unavailability of steam dump system operational data for the transient. The control system utilized varied the steam dump valve positions in order to match steam line pressure data.

The SG level comparisons for the affected and unaffected loops are shown in Figures 5.3.3-10 and 5.3.3-11, respectively. The RETRAN levels remain above the plant data during the first 40 seconds post-trip as the steam line pressure increases. The level prediction in the affected loop remains below the plant response throughout most of the simulation. The level prediction in the unaffected loop stabilizes early and trends with the plant data throughout the simulation.

The effects of the RCP trip on the flow in the affected and unaffected loops are presented in Figures 5.3.3-12 and 5.3.3-13, respectively. As shown in Figure 5.3.3-12, the RETRAN RCP coasts down in a time nearly equivalent to the plant data. Flow reversal is established approximately 20 seconds after the pump trip and stabilizes at approximately 28% of its pre-trip value. Reverse flow indication from the plant data is not available due to flow instrumen-

tation limitations. The subsequent increase in loop flow in the unaffected loop is shown in Figure 5.3.3-13. Flow in the unaffected loop stabilizes at approximately 107% of its pre-trip flow.

Table 5.3.3-1

McGuire Nuclear Station Unit 1
 Reactor Coolant Pump Trip at 89% Full Power
 June 6, 1984

Sequence of Events

<u>Event Description</u>	Time (sec)	
	<u>Plant</u>	<u>RETRAN</u>
Reactor coolant pump trip	0	0
Reactor trip and turbine trip	1	1
Auxiliary feedwater actuation on low-low steam generator levels		
Affected loop flow stagnation and reversal	16	20
Steam line PORVs open	28	**
Steam line PORVs close	54	**
End of simulation	N/A	180

Note: Two asterisks indicate that steam line PORV operation was not modeled due to assuming a steam line pressure boundary condition.

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-1

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT

5-93




Figure 5.3.3-2

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-3

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-4

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-5

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-6

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-7

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-8

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-9

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-10

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-11

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-12

MNS-1 REACTOR COOLANT PUMP TRIP

6/6/84 EVENT




Figure 5.3.3-13

5.3.4 McGuire Nuclear Station - Unit 1
Loss of Offsite Power
August 21, 1984

Transient Description

McGuire Unit 1 was operating at 100% full power when the reactor tripped on a spurious high power range flux rate. The RCPs tripped on underfrequency at 24 seconds following reactor trip. At approximately 48 seconds the switchyard computer opened essentially all breakers connecting the unit to normal power supplies. The emergency diesels started due to the blackout condition and assumed essential loads. All three AFW pumps also started. The unit entered a natural circulation mode and cooled down to approximately 518°F cold leg temperature at 1200 seconds. Stable natural circulation conditions developed as indicated by a constant ΔT . The excessive cooldown was due to continuously decreasing steam header pressure.

Discussion of Important Phenomena

The important phenomena that occurred during this transient are related to the transition from forced circulation cooling to natural circulation. Following RCP coastdown, a balance develops between the natural circulation driving head and loop frictional losses at the reduced flow condition. The distribution of heat transfer in the SGs determines the elevation of the thermal center and the driving force for natural circulation. Reactor vessel flow distributions change due to the absence of pump head and the development of buoyancy driven flow. The coupling between the primary and secondary during the cooldown phase of the transient is also a phenomenon of interest.

Model Description and Boundary Conditions

The plant responses during the transient showed little asymmetry between loops so a one-loop RETRAN model was used for the analysis. The RCS flow specified in the simulation was chosen in order to match ΔT . The parameters used as initial conditions were matched, where possible, to the plant data.

Initial Conditions

	<u>Model</u>	<u>Plant</u>
Power Level	100% (3411 MWt)	100% (3411 MWt)
Pressurizer Pressure	2229 psig	2229 psig (ave)
Pressurizer Level	60.8%	60.8%
T-ave	587.3°F	587.3°F
ΔT	56.8°F	56.8°F
Steam Line Pressure	1008 psig	1008 psig (ave)
SG Level	66.7% NR	66.7% NR (ave)
MFW Flow	15.1×10^6 lbm/hr	15.1×10^6 lbm/hr
MFW Temperature	437.6°F	437.6°F (ave)

The McGuire RETRAN model was constructed to McGuire Unit 1 dimensions and therefore required few changes to accurately simulate the McGuire Unit 1 transient. The major change was to the steam dump system. The steam dump system in the base RETRAN model uses narrow range primary coolant temperatures as a basis for control. These indications are sensed in the RTD bypass manifold and are invalid when forced flow is lost. Since it is unclear how steam dump was being controlled, and since the steam line pressure data indicates that substantial depressurization occurred, the simulation controls steam line pressure to match the plant pressure data.

The problem boundary conditions used are cycle specific post-trip delayed neutron power and decay heat, MFW, AFW, and charging and letdown flows. The pressurizer heater banks were modeled to reflect their status as recorded on plant transient data.

Simulation Results

The simulation begins with the reactor trip caused by a voltage spike and continues for 1200 seconds. The long term trends of key plant parameters have been established by that time. The sequence of events is given in Table 5.3.4-1. The comparison of RETRAN predictions to plant data are given in Figures 5.3.4-1 through 5.3.4-10.

Plant steam line pressure data used as a boundary condition to control the Steam Dump System are shown in Figure 5.3.4-1. The SG level comparison is shown in Figure 5.3.4-2. It is apparent that the RETRAN model predicts the plant level data very well when using the plant AFW flow data.

Pressurizer pressure, shown in Figure 5.3.4-3, tracked the trend of the plant data following the development of an offset of 100-150 psig (plant data higher) at about 200 seconds. The cause of this offset can be understood by examining the comparisons of pressurizer level and RCS temperature predictions and data. The pressurizer level prediction trends the plant data following the development of an offset of about 10%. This indication implies that the total system volume is somewhat low after natural circulation is established. The source of this volume discrepancy is apparent when the ΔT (Figure 5.3.4-5), T-hot (Figure 5.3.4-6), T-cold (Figure 5.3.4-7), and upper head temperature (Figure 5.3.4-8) comparisons are evaluated. T-cold predictions are very similar to plant data as expected due to matching the steam line pressure data. However, the T-hot and ΔT data both have a 10°F offset, which is consistent with the volume discrepancy observed in the pressurizer level figure. This offset occurs when loop ΔT stabilizes during natural circulation. The loop ΔT predicted by RETRAN is smaller and stabilizes sooner than the actual plant data for this transient. Therefore, RETRAN also predicts a lower T-hot. In addition, the reactor vessel upper head temperature predicted by RETRAN does not increase as much as plant data. Nevertheless, the transition to natural circulation and the cooldown response are predicted well.

Figure 5.3.4-8 shows a comparison of the prediction of the reactor vessel upper head temperature to an indication from one of five thermocouples installed in the McGuire Unit 1 vessel. McGuire 1 is a T-cold upper head plant, which explains the initial temperature of 555°F. Both the plant data and RETRAN prediction show an increase and then a decrease in the upper head temperature following the establishment of natural circulation. The trends match well, with the data exceeding the RETRAN predicted temperature by approximately 8-10 °F at the peak temperature, before closely agreeing at 1200 seconds. This prediction confirms that the reactor vessel upper head modeling is very adequate for vessel flow patterns during the transition to natural circulation. Normalized reactor coolant flow is shown in Figures 5.3.4-9 and 5.3.4-10. The

flow reduction due to the pump coastdown is similar to the plant response. It should be pointed out that plant data is essentially meaningless once flow has decreased to less than approximately 20% of initial flow due to instrumentation limitations. RETRAN predicts a relatively stable natural circulation flow of about 5% of the initial flow, with the expected slow decrease due to diminishing decay heat.

Table 5.3.4-1

McGuire Nuclear Station Unit 1

Loss of Offsite Power

August 21, 1984

Sequence of Events

<u>Event Description</u>	Time (sec)	
	<u>Plant</u>	<u>RETRAN</u>
Reactor/turbine trip	0	0
PZR heaters on*	1	1
RCPs trip*	24	24
PZR heaters off*	48	48
AFW initiates*	48	48
End of simulation	N/A	1200

Note: Asterisks designate boundary conditions

MNS 1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-1

MNS 1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-2

MNS 1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-3

MNS 1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-4

MNS 1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-5

MNS 1 LOSS OF OFFSITE POWER

9/21/84 EVENT




Figure 5.3.4-6

MNS 1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-7

MNS-1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-8

MNS 1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-9

MNS 1 LOSS OF OFFSITE POWER

8/21/84 EVENT




Figure 5.3.4-10

5.4 Operational Transients Without Reactor Trip

5.4.1 Catawba Nuclear Station - Unit 1

Turbine Trip Test at 68% Power

March 27, 1985

Transient Description

A turbine trip was manually initiated at Catawba Unit 1 with the unit at 68% full power to demonstrate the effectiveness of plant control systems to stabilize the plant without tripping the reactor. Upon closure of the turbine stop valves, a transitional mismatch between the reactor heat generation and secondary heat sink occurred, causing the RCS temperature and pressure to rise. The Rod Control System automatically inserted rods to reduce reactor power and the Condenser Dump and Atmospheric Dump Systems relieved steam. RCS temperature and pressure dropped, and the pressurizer heaters were actuated to restore RCS pressure.

The maximum pressurizer pressure and level were 2326 psig and 57% respectively, while the minimum values were 2124 psig and 33%. The pressurizer PORVs and safety valves were not challenged, nor were the steam line safety valves. The rods were placed in manual control at approximately 230 seconds, and the power was stabilized at approximately 18%. The pressurizer heaters restored primary pressure and SG level was stabilized at approximately 40%. Pressurizer pressure control was transferred to manual at an unknown time during the transient, resulting in a pressure overshoot to 2270 psig at 900 seconds.

Discussion of Important Phenomena

Of primary importance in this transient are the actions of the Rod Control System in reducing core power and the Steam Dump System in reducing primary temperature and pressure. Also of importance is the control of pressurizer pressure. Pressurizer spray is initiated early in the transient during the initial RCS pressurization. Shortly thereafter, during primary depressurization, the pressurizer heaters were actuated to restore primary pressure.

Detailed modeling of the pressurizer pressure controller and the controller and the control systems mentioned above, including operator actions which affect these systems, is therefore necessary to achieve accurate results.

Model Description and Boundary Conditions

The one-loop Catawba Unit 1 RETRAN Model was utilized for this analysis since the plant response among the four loops was essentially symmetrical. It was necessary in this analysis to model the Rod Control System, the load rejection controller, and the atmospheric steam dump valves.

The RCS flow specified in the simulation was chosen to match plant ΔT . The initial conditions were matched to plant data as shown in the following table:

	<u>Model</u>	<u>Plant</u>
Power Level	66.5% (2268.3 MWt)	66.5% (2268.3 MWt)
PZR Pressure	2226 psig	2226 psig
PZR Level	48.4%	48.4%
T-ave	578.6°F	578.6°F (ave)
ΔT	40.3°F	40.3°F (ave)
Steam Line Pressure	1034 psig	1034 psig (ave)
SG Level	58%	57% (ave)
MFW Flow	9.6×10^6 lbm/hr	10.3×10^6 lbm/hr
MFW Temperature	400°F	400°F (ave)

The problem boundary conditions include MFW flow and the reference T-ave (T-ref) as a function of time. When the simulated reactor power matched the actual power data following stabilization, the simulated control rod position was held constant to represent the transition to manual rod control. Charging and letdown flows are assumed to have little effect on the transient and are not modeled. Also, since plant data indicates that the pressurizer backup

heaters did not deenergize, these heaters were left energized in the simulation. Finally, the Bank 4 atmospheric dump valves were blocked closed until 13 seconds in the simulation to match the actual opening time.

Simulation Results

The simulation begins with the manual turbine trip and continues for 900 seconds. The simulation is terminated when most plant parameters have stabilized and the phenomena of interest have occurred. The sequence of events is given in Table 5.4-1 and the comparisons of RETRAN predictions and plant data are shown in Figures 5.4.1-1 through 5.4.1-7.

The comparison of the predicted reactor power to the plant data is shown in Figure 5.4.1-1. The reactor runback rate compares well until a deviation occurs at 90 seconds. This deviation is caused by a difference in the times at which the rod insertion speed slows due to a decrease in the power mismatch signal input to the Rod Control System. The consistent slopes of the power trends indicate that the reactivity insertion rates compare well.

The pressurizer pressure and level comparisons are shown in Figures 5.4.1-2 and 5.4.1-3. An initial insurge and pressurization accompanies the reduction in secondary heat sink following turbine trip. Subsequently, the repressurization due to pressurizer heaters occurs. The pressure prediction and level prediction generally trend the data well. RCS T-ave and ΔT comparisons are shown in Figures 5.4.1-4 and 5.4.1-5. The predicted temperatures are very similar to the plant data throughout the duration of the simulation, with maximum deviations no greater than approximately 3°F. Insights into these deviations can be obtained from the steam line pressure comparisons.

The steam line pressure data, shown in Figure 5.4.1-6, indicates that several atypical events occurred following turbine trip. One of the Bank 2 condenser dump valves (SB-24) unexpectedly closed 13 seconds into the transient, thereby maintaining the pressure above the predicted pressure for the first 125 seconds of the transient. An additional discrepancy occurs at 190 seconds when the pressure increases due to the premature closure, and subsequent cycling, of

another one of the Bank 2 valves (SB-6). Neither of these events were simulated.

The SG level comparison is shown in Figure 5.4.1-7. Since MFW flow data is used in the simulation, this figure provides a good indication of the RETRAN SG level model. The level trend is predicted very well throughout the duration of the simulation. Some differences are to be expected due to the effect of SG pressure differences between the prediction and data.

Table 5.4-1
Catawba Nuclear Station Unit 1
Turbine Trip Test
March 27, 1985

Sequence of Events

<u>Event Description</u>	Time (sec)	
	<u>Plant</u>	<u>RETRAN</u>
Turbine trips	0	0
MFW runback initiated*	1	1
PZR spray on	6	4
Condenser dump banks 1-3 open	6	3
Control rod insertion begins/reactor runback initiated	**	1
Atmospheric dump bank 4 opens*	13	13
SB-24 (one of three valves in condenser dump bank 2) closed	13	-
Maximum RCS pressure	14	15
Atmospheric dump bank 5 opens	17	16
Maximum PZR Level	36	29
PZR spray off	42	30
PZR control heaters on	**	48
PZR backup heaters on	74	52
Atmospheric dump bank 5 closed	74	35
Atmospheric dump bank 4 closed	103	114
Condenser dump bank 3 closed	131	227
SB-6 (one of three valves in condenser dump bank 2) closes, then cycles	227	-
Control rod insertion stops	230	280
SB-15 (one of three valves in condenser dump bank 2) closed	503	-
PZR control heaters off	**	688
End of simulation	N/A	900

Note: Single asterisk designates boundary conditions
Double asterisks indicate plant data not available

CNS-1 TURBINE TRIP TEST

3/27/85 EVENT




Figure 5.4.1-1

CNS-1 TURBINE TRIP TEST

3/27/85 EVENT




Figure 5.4.1-2

CNS-1 TURBINE TRIP TEST

3/27/85 EVENT




Figure 5.4.1-3

CNS-1 TURBINE TRIP TEST

3/27/85 EVENT




Figure 5.4.1-4

CNS-1 TURBINE TRIP TEST

3/27/85 EVENT




Figure 5.4.1-5

CNS-1 TURBINE TRIP TEST

3/27/85 EVENT




Figure 5.4.1-6

CNS-1 TURBINE TRIP TEST

3/27/85 EVENT




Figure 5.4.1-7

6.0 SUMMARY

The contents of this report focus on demonstrating analytical capability in the area of safety analysis, and the validation of transient thermal-hydraulic models. Detailed plant and core simulation models have been developed using the RETRAN-02 and VIPRE-01 codes. The level of detail used in the RETRAN plant models obviates the need for extensive nodalization sensitivity studies for the intended applications. The adequacy of the VIPRE core model and nodalization has been demonstrated by sensitivity studies. Both RETRAN and VIPRE have proven to have the required capabilities and necessary flexibility for a wide range of simulation needs.

Validation of the Oconee and McGuire/Catawba RETRAN models has been achieved by benchmarking to a spectrum of plant transient events. Station operating histories were reviewed to obtain transient data characterized by differing initiating events and subsequent phenomena, with emphasis on the more severe events. It should be noted that no benchmark analyses were withheld from the report due to the quality of the comparison between the simulation and the plant data. It is evident that the agreement between the RETRAN predictions and plant data varies from reasonable to excellent. Key thermal-hydraulic phenomena are typically predicted accurately with respect to data trends, and in most cases also with respect to quantitative values. RETRAN is particularly capable of simulating the coupling between primary and secondary and the effects of interfacing systems in an integrated and consistent manner. The benchmark analyses have been presented with discussions on the approach used by the analyst and identification of any unknown or atypical aspect of the plant transient which required an assumption or special treatment. A complete set of pertinent results have been plotted for each benchmark in order to show an overall comparison of the RETRAN prediction to data.

The nine transients selected for validating the Oconee RETRAN model encompass a broad range of thermal-hydraulic phenomena. The events initiated at both full and partial power, with one event initiating from a three-pump initial condition. Asymmetric loop conditions, both pre- and post-trip, are included. Primary flow distributions during a wide range of partial-pump operating conditions and during natural circulation are also included. The most extensively benchmarked phenomena are those associated with disturbances in primary-to-secondary heat transfer. Transients resulting in both steam generator dryout and overfill are simulated and show steam generator level indication comparisons. The steam generator response to excessive steaming and subsequent overcooling is included. The reactor response to both slow and step reactivity insertions is included. The only phenomena for which plant data are unavailable are those associated with a loss of primary coolant. These phenomena are represented to some extent by the RCS inventory shrinkage caused by overcooling in several of the transients.

The eight transient events selected for validating the McGuire/Catawba RETRAN model also cover a wide range of thermal-hydraulic phenomena. The events initiate at both full and partial power, and also at 1-3% power under natural circulation conditions. The dynamic response of the reactor to control rod insertion is included. Asymmetric conditions with up to three out of four loops with different secondary boundary conditions are included. A transition to natural circulation is included as well as primary flow distributions with various combinations of operating pumps. Of particular interest are the phenomena resulting from changes in feedwater flow and loss of steam generator pressure control. The impact of a reduction in feedwater on heat transfer, including heat transfer in the preheater, is benchmarked. Modeling of steam generator inventory indication and distribution, important due to the approach to trip setpoints, is validated. An absence of loss of coolant data is compensated for by data from a rapid overcooling event that caused the pressurizer to empty.

Validation of a VIPRE core thermal-hydraulic model is performed with a code-to-code comparison with COBRA-IIIC/MIT for the Oconee model. Additional VIPRE validation analyses have been separately documented in other Duke Power reports. Axial and radial nodalization sensitivity studies demonstrate the acceptability of model detail. Nearly identical consistency is shown between the local thermal-hydraulic conditions and DNBR values predicted by the two codes when similar correlations and modeling detail are maintained. VIPRE modeling assumptions to be utilized in future applications are discussed.

The results of development and analysis activities summarized in this report constitute the Duke Power Company response to Generic Letter 83-11. The current status of analytical model validation and technical capabilities in the areas of transient system and core thermal-hydraulic analysis has been presented. Analytical model development is viewed as an ongoing program. Benefiting from the excellent flexibility of the RETRAN and VIPRE codes, the models detailed in this report will continue to be enhanced as additional modeling improvements occur, and as further experience and data are obtained.

Appendix A was added in Revision 2 to describe the Framatome Advanced Nuclear Products Mk-B11 fuel assembly with M5 cladding in use at Oconee. Use of the BWU-Z CHF correlation applicable to the Mk-B11 design was also included.

Appendix B was added in Revision 3 to describe the modeling of the Oconee replacement steam generators with RETRAN-3D.

Appendix C was added in Revision 3 to address the conditions and limitations of the RETRAN-3D SER on the application of RETRAN-3D for Oconee transient simulation modeling.

APPENDIX A

METHODOLOGY REVISIONS FOR Mk-B11 FUEL

This appendix contains non-LOCA thermal-hydraulic transient analysis methodology revisions related to the Mk-B11 fuel assembly design. This fuel design is characterized by smaller diameter fuel pins and mixing vane grids, relative to the current fuel design. Four lead test assemblies began operation in Oconee Unit 2, Cycle 16 in May 1996. The information included in this appendix is in addition to that presented in Section 2.3 of the main body of this report.

Fuel Assembly Description

The Mk-B11 fuel assembly consists of spacer grids, end fittings, fuel rods, and guide tubes. The lower and upper end grids are made of Inconel, while the six intermediate spacer grids are made of Zircaloy-4. The intermediate spacer grids are comprised of one non-mixing vane grid type and five mixing vane grid types. Each fuel assembly is a 15 by 15 array containing 208 fuel rods, 16 control rod guide tubes, and one incore instrument guide tube. The fuel rod consists of dished-end, cylindrical pellets of uranium dioxide clad in cold-worked Zircaloy-4. The fuel assembly and fuel rod dimensions, and other related fuel parameters used in the thermal-hydraulic analyses are given in Table A-1. A drawing of the Mk-B11 fuel assembly is shown in Figure A-1.

VIPRE Models

The various VIPRE models described in Section 2.3 of the main body of this report are used for the Mk-B11 thermal-hydraulic analyses with the VIPRE-01 thermal-hydraulic computer code described in Reference A-1. The models are updated to reflect the Mk-B11 fuel parameters listed in Table A-1.

Code Option and Input Selections

Thermal-Hydraulic Correlations:

The main body of the report describes the bulk void model used in the Oconee VIPRE model. Since the original submittal of this report, EPRI has modified the VIPRE code such that the Zuber-Findlay model is applicable only to void fractions below 85%. In the event that the void

fraction exceeds this limit, the Armand or Smith bulk void fraction model are used. The results of sensitivity studies listed in Table 16 of Reference A-2 show that the minimum DNBR results for these two bulk void fraction models differ by only 0.1% from the Zuber-Findlay minimum DNBR results. Therefore, this VIPRE code modification will change the bulk void model from what was approved previously by the NRC if the void fraction increases above 85%. The effect of this modeling change is insignificant.

Turbulent Mixing Correlations:

The turbulent mixing factor has increased due to the presence of mixing vane grids. The value used for this in the VIPRE model for Mk-B11 has been determined by the fuel vendor based on predictions of mixing test results.

Pressure Losses:

The pressure losses are calculated in the code as described in the main body of this report using the spacer grid form loss coefficients for the Mk-B11 fuel assembly.

Critical Heat Flux Correlation

The BWU-Z form of the BWU critical heat flux correlation with the Mk B11V multiplier described in Reference A-3 has been reviewed and approved by the NRC for use in Mk-B11 analyses. The range of applicability of the BWU-Z correlation is:

Pressure, psia	400 to 2465
Mass velocity, 10^6 lbm/hr-ft ²	0.36 to 3.55
Quality, %	less than 74

The design DNBR limit using the VIPRE-01 code has been determined as a function of pressure ranges for Mk-B11 fuel as stated in Reference A-4.

<u>Pressure (psia)</u>	<u>Design DNBR</u>
400 to 700	1.59
700 to 1000	1.20
1000 to 2465	1.19

The statistical core design methodology (SCD) of Reference A-4 may also be used. The SCD methodology is generally used unless the analysis parameters are not bounded by the ranges

considered in the methodology. A typical SCD limit using VIPRE-01 with the BWU-Z correlation and the Mk-B11 multiplier of 0.98 is 1.33 for pressures above [1600] psi.

Hot Channel Factors

The hot channel factor is the B&W power factor, F_q . The power factor, F_q , is computed statistically from the average or overall variation on rod diameter, enrichment, and fuel weight per rod. It is applied to the heat generation rate in the pin; thus it will have an effect on all terms that are computed from this heat rate with the exception of the heat flux for DNB ratio computation. The value of F_q used is 1.0133 for Mk-B11 fuel.

Table A-1


Mk-B11 Fuel Assembly
Component Dimensions Used for Thermal-Hydraulic Analysis

Fuel Pin Diameter	0.416 in.
Control Rod Guide Tube Diameter	0.530 in.
Instrumentation Guide Tube Diameter	0.554 ⁽¹⁾ /0.567 ⁽²⁾ in.
Effective Pin Pitch	0.568 in.
Assembly Flow Area	42.331 in. ²
Assembly Wetted Perimeter	300.742 in.
Unit Channel Flow Area	0.185 in. ²
Unit Channel Wetted Perimeter	1.309 in.
Unit Channel Heated Perimeter	1.309 in.
Control Rod Guide Tube Channel Flow Area	0.164 in. ²
Control Rod Guide Tube Channel Wetted Perimeter	1.399 in.
Control Rod Guide Tube Heated Perimeter	0.982 in.
Instrumentation Guide Tube Channel Flow Area	0.159 in. ²
Instrumentation Guide Tube Channel Wetted Perimeter	1.418 in.
Instrumentation Guide Tube Channel Heated Perimeter	0.982 in.
Peripheral Channel Flow Area	0.254 in. ²
Peripheral Channel Wetted Perimeter	1.309 in.
Peripheral Channel Heated Perimeter	1.309 in.
Corner Channel Flow Area	0.337 in. ²
Corner Channel Wetted Perimeter	0.655 in.
Corner Channel Heated Perimeter	0.655 in.
Active Fuel Length	143.05 in.

(1) Above lowest intermediate spacing grid and between intermediate spacing grids

(2) Below the lowest intermediate spacing grid and above the top intermediate spacing grid

Figure A-1
Mk-B11 Fuel Assembly



References

- A-1 VIPRE-01: A Thermal-Hydraulic Code For Reactor Cores, EPRI NP-2511-CCM-A, Vol. 1-4, Battelle Pacific Northwest Laboratories, August 1989.
- A-2 Letter, H. B. Tucker (Duke) to U. S. NRC, Topical Report DPC-NE-3000 Response to Request for Additional Information, February 20, 1990
- A-3 The BWU Critical Heat Flux Correlations Applications to the Mk-B11 and Mk-BW17 MSM Designs, Addendum 1 to BAW-10199P-A, Babcock and Wilcox, Lynchburg, Virginia, September 1996.
- A-4 Duke Power Company Thermal-Hydraulic Statistical Core Design Methodology, DPC-NE-2005P-A, Revision 3, September 2002

APPENDIX B

METHODOLOGY REVISION FOR OCONEE REPLACEMENT STEAM GENERATORS

ROTSG Design Description

This appendix describes the Oconee RETRAN model revisions necessary for simulation of the replacement once-through steam generators (ROTSGs) being manufactured by Babcock & Wilcox Canada (BWC). The first pair of ROTSGs are scheduled for installation in Oconee Unit 1 in 2003. The other two Oconee units are scheduled for replacement outages in 2004. The design of the ROTSGs enables what is characterized as a "like-for-like" replacement due to the close similarity in the performance of the component. Due to the similarity of the ROTSGs with respect to the original OTSGs, the RETRAN modeling is also maintained very similar. The new RETRAN models for the ROTSGs will be inserted into the Oconee RETRAN model described in Chapter 2 of this report. The significant design differences are as follows. Figure B-1 shows a comparison of the OTSG and ROTSG designs.

- 1) Flow-restricting orifices in the steam outlet nozzles
- 2) Inconel-690 tubes
- 3) 15,631 vs. 15,531 tubes
- 4) Thinner pressure vessel / wider downcomer
- 5) Thinner tubesheets resulting in 3.625 inch longer heated tube length
- 6) 1.2% greater heat transfer area
- 7) More water in the steam generator.

Other than the ROTSG dimensional design data, Duke is also using steady-state thermal-hydraulic data provided by BWC as the reference data for the ROTSG initial conditions. These data included the pressure distribution, void fraction distribution, steam superheat profile, and water masses. The BWC simulations are three-dimensional, whereas RETRAN predictions are one-dimensional, so when comparing the results of the two codes it must be recognized that there is some approximation.

RETRAN-3D Code

The Electric Power Research Institute's (EPRI) RETRAN-3D code (Reference B-1) is used for the Oconee RETRAN Model with ROTSGs. Previous modeling described in the body of this report with the original OTSGs used the EPRI RETRAN-02 code. RETRAN-3D was approved by the NRC in the SER dated January 25, 2001 (Reference B-2). The most significant change in the Oconee RETRAN methodology resulting from this RETRAN code version change is in the two-phase modeling of the secondary side of the steam generators. With RETRAN-02 the

secondary side is modeled using [

] All of the details of the transition to using RETRAN-3D instead of RETRAN-02 for Oconee modeling are presented. It is noted that the three-dimensional core model capability in RETRAN-3D is not included in this methodology, as well as some of the other new models. The conditions and limitations in the NRC's SER for RETRAN-3D are addressed in Appendix C.

ROTSG Nodalization

The ROTSG nodalization is shown in Figure B-2. This nodalization can be compared to the OTSG nodalization in Figure 2.2-1. The only significant difference is that the [

]

Details of RETRAN-3D Modeling

The selection of RETRAN-3D models, code options, and other input specifications for the Oconee RETRAN Model with ROTSGs is presented and justified. The sequence of the presentation that follows is consistent with the RETRAN-3D input file card sequence in Volume 3 Revision 5 of the EPRI RETRAN-3D code documentation. Volume 3 Revision 6 of the EPRI RETRAN-02 code documentation is used as the point of reference for RETRAN-02 code models, options, and input. Only those models, options, and input that differ from RETRAN-02 modeling as described in the body of this report are presented. The RETRAN-3D models that replace RETRAN-02 models (i.e., the RETRAN-02 models are no longer available to the user - such as the heat transfer correlation package and the numerical solution method), and have been reviewed and approved by the NRC during the generic review of RETRAN-3D, are not presented. ROTSG design dimensional data input to the RETRAN-3D code, such as the length of the ROTSG tubes or the thickness of the shell, are not considered methodology, and similar to the body of this report are not included.

Card 01000Y - Problem Control and Description Data

[]

W30-I IHTMAP - (heat transfer map option flag) = 2 - Custom modification to allow condensation heat transfer with the forced convection heat transfer map.

Application: RETRAN-3D analyses for ROTSGs use this option.

Technical Justification: The NRC-approved RETRAN-02 methodology for Oconee uses the forced convection heat transfer map with a custom modification to allow use of condensation correlations when appropriate. A similar custom modification has been made to RETRAN-3D to allow access to the condensation correlations in combination with the forced convection heat transfer correlations set by setting IHTMAP=2. The condensation correlations are used whenever a conductor surface temperature is below the saturation temperature and steam is present.

W38-I JFLAG - (average volume flow calculation option) = 0 - arithmetic average

Application: This option is applicable to all junctions except those with momentum flux turned off.

Technical Justification: The arithmetic average option for the calculation of the average volume flow is the vendor recommendation.

Card 08XXXXY - Junction Data

W17-I IFRJ - (slip flow regime/orientation flag) = (any value 0-9) - vertical flow path
= -99 - no slip

Application: For the [], this flag is set to a value of 0-9 since the flowpaths are vertically oriented. For all other junctions where two-phase conditions may develop this flag is set to -99 to deactivate the algebraic slip model. These junctions will then have equal liquid and vapor velocities if two-phase conditions develop.

Technical Justification: See Card 01000Y above for discussion regarding use of the []. This flag is necessary to control which junctions use this model, and also to designate the vertical orientation of these junctions in the ROTSG secondary.

W21-R ANGLJ1 - (angle of junction relative to the "from" volume)
W22 -R ANGLJ2 - (angle of junction relative to the "to" volume)

Application: The following junctions have been assigned the following angles to correctly adjust the momentum flux terms.

Technical Justification: Vendor recommendations for modeling the indicated junction angles are the basis for the selected values.

Card 15XXXY - Conductor Data

W5-I IMCL (indicator for selecting heat transfer correlations at left surface) = 41 or 48. Custom modification to allow the Dittus-Boelter forced convection heat transfer correlation to either liquid or steam to be specified, regardless of the local property conditions adjacent to the left conductor wall

Application: IMCL = 41 will select the Dittus-Boelter forced convection to liquid heat transfer correlation. IMCL = 48 will select the Dittus-Boelter forced convection to vapor heat transfer correlation. These are custom coding changes used to select one of these correlations regardless of the local fluid conditions adjacent to a conductor. [

References

- B-1 RETRAN-3D- A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems, EPRI, NP-7450(A), Volumes 1-4, Revision 5, July 2001
- B-2 Letter, S. A. Richards (NRC), to G. L. Vine (EPRI), Safety Evaluation Report on EPRI Topical Report NP-7450(P), Revision 4, "RETRAN-3D - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems", January 25, 2001

Figure B-1

OTSG / ROTSG Comparison




Figure B-2
ROTSG Nodalization





Figure B-3

ROTSG Void Fraction Comparison



APPENDIX C

EVALUATION OF RETRAN-3D SER CONDITIONS AND LIMITATIONS FOR THE OCONEE RETRAN MODEL WITH ROTSGs

Purpose

This appendix evaluates the conditions and limitations in the RETRAN-3D SER (Reference C-1) for the application of RETRAN-3D to the Oconee Nuclear Station with replacement steam generators (ROTSGs). The results of this evaluation demonstrate that the use of the RETRAN-3D code for this application, as described in Appendix B, has been appropriately justified and is within the SER conditions and limitations. Therefore, the approval for use of RETRAN-3D as stated in the SER for the scope of approval specified in the SER can be credited. The Duke version of the RETRAN-3D code actually used is described first, including details on the custom code modifications that have been incorporated.

Description of the RETRAN-3D Code Version Used and Duke Code Modifications

RETRAN-3D MOD003.1DKE is the current Duke Power version of the standard Electric Power Research Institute (EPRI) RETRAN-3D MOD003.1 code, the NRC-approved code. This EPRI version includes the revisions agreed to during the SER review process. The Duke Power version, designated by the suffix "DKE", consists of two types of revisions to the standard EPRI version. The first type of revision is code error corrections. Duke periodically updates the code version in use to include error corrections obtained from Computer Simulation & Analysis, Inc. (CSA), the EPRI contractor for the RETRAN-3D code. The second type of revision is Duke custom code modifications purchased from CSA to address Duke-specific modeling needs. Each of these custom code changes are described in detail for NRC review and approval. The error corrections are not presented. All error corrections and code modifications are developed and controlled under CSA's Appendix B QA program. All Duke RETRAN-3D versions used for safety-related applications are certified and controlled under Duke's Appendix B software quality assurance program (Reference C-2). Any future modifications to the RETRAN-3D code versions used by Duke for safety-related applications that constitute significant model revisions or new models will be submitted for NRC review and approval. Code modifications that consist of error corrections or user features will be implemented under QA processes, but will not be submitted for NRC review.

<u>Duke Code Modification #1</u>	Allow Access to the Condensation Heat Transfer Correlations With the Forced Convection Heat Transfer Map
----------------------------------	---

Initialization of the ROTSGs using RETRAN-3D uses the forced convection heat transfer map. This is selected by setting variable IHTMAP on the 01000Y card to a value of zero. This standard forced convection option does not allow access to the condensation heat transfer correlations in RETRAN-3D. A code modification was implemented to allow access to the


condensation heat transfer correlations by setting IHTMAP to a value of 2. This option gives the forced heat transfer map, but allows condensation heat transfer to be modeled when appropriate for the local conditions present. This can be important in several transient conditions, such as when the primary water flowing through the steam generator tubes cools to below the secondary saturation temperature. In this situation an appropriate condensation heat transfer coefficient will be selected from the heat transfer correlation set. The technical justification for this code modification is that it allows a correct heat transfer correlation to be used for situations when condensation heat transfer occurs. This modification is functionally equivalent to a similar update made to RETRAN-02, which has been reviewed and approved for use by the NRC.

Duke Code Modification #2 Allow the User to Specify the Dittus-Boelter Heat Transfer Correlation for a Specific Conductor

The RETRAN-3D heat transfer correlation package selects an appropriate heat transfer correlation for each conductor surface based on fluid conditions in adjacent volumes. Under some conditions it is useful to be able to select a specific correlation for a given conductor surface rather than using the code-selected correlation. This code modification allows the user to specify either the Dittus-Boelter liquid or vapor correlation for the left surface of a particular conductor. This will then override the code-selected correlation. Word IMCL on Card 15XXXY is set to a value of 41 to specify the liquid correlation, and to a value of 48 to specify the vapor correlation at the left surface of a conductor. The need for this modeling capability arose during analyses of the ROTSG upper shell heat transfer following a steam line break. Due to water carryout into the steam outlet annulus (the volume adjacent to the upper shell), the heat transfer was potentially too high for an analysis in which less heat transfer was conservative. This code modification allowed specifying use of the Dittus-Boelter correlation for vapor to conservatively model the heat transfer to the shell conductor. The code modification also allows specification of the Dittus-Boelter correlation for liquid as another modeling option. The technical justification for this code modification is that a capability to specify a heat transfer correlation for specific applications is appropriate.

Duke Code Modification #3

Duke Code Modification #4



Duke Code Modification #5



Evaluation of RETRAN-3D SER Conditions and Limitations

1. Multidimensional neutronic space-time effects cannot be simulated as the maximum number of dimensions is one. Conservative usage has to be demonstrated.

Staff Position: RETRAN-3D has been modified to include a 3-dimensional nodal kinetics model based on the analytic nodalization method similar to accepted codes. The code has been assessed by calculation of the response of the SPERT prompt-critical tests and has been confirmed by the staff by comparisons with calculations performed with the NESTLE and TORT codes. The staff concludes that the code can adequately predict the response to prompt-critical events such as the PWR rod ejection accident and the BWR rod drop accident. If void generation occurs from an initially un-voided case, the user will have to justify crediting this negative feedback in the analysis.

The code was used by a participant in the Nuclear Energy Agency's International Standard Problem calculation of a hypothetical main steam line break (MSLB) at the Three Mile Island Unit 1 plant. The results of the calculation comparison indicates that RETRAN-3D is comparable to any of the other participating codes.

RETRAN-3D is approved for main steam line break analyses subject to the following conditions. Thermal-hydraulic effects can have a large impact on the cross section evaluation and thus on the resulting power distribution and magnitude. Therefore, the licensee must justify the primary side nodalization for mixing in the vessel and core. The licensee must also evaluate the uncertainties in the modeling.

Duke Position: The RETRAN-3D three-dimensional kinetics model is not used.

2. There is no source term in the neutronics and the maximum number of energy groups is two. The space-time options assume an initially critical system. Initial conditions with zero fission power cannot be simulated by the kinetics. The neutronic models should not be started from subcritical or with zero fission power without further justification.

Staff Position: The basic models in RETRAN-3D are unchanged and, therefore, this condition of use applies.

Duke Position: Duke does not analyze from subcritical or zero fission power initial conditions.

3. A boron transport model is unavailable. User input models will have to be reviewed on an individual basis.

Staff Position: As noted previously in this report, boron transport is handled as a "contaminant" by the "general transport model." This model uses first order accurate upwind difference scheme with an implicit temporal differencing. This approach is well known for being highly diffusive, especially if the Courant limit is exceeded. Since RETRAN-3D has the same model as RETRAN-02 MOD003 and subsequent versions that have been approved for use, the RETRAN-3D model is also approved with the caveat that the potential to produce misleading results with this scheme necessitates careful review of the results for any case where boron transport/dilution is important.

Duke Position: Previously approved in RETRAN-02 and for Duke applications using RETRAN-02.

4. Moving control rod banks are assumed to travel together The BWR plant qualification work shows that this is an acceptable approximation.

Staff Position: The control bank limitation is applied only to the one-dimensional kinetics model. The staff agrees that the 3-dimensional kinetics model need not be restricted in this way.

Duke Position: Resolved per the Staff Position

5. The metal-water heat generation model is for slab geometry The reaction rate is therefore under-predicted for cylindrical cladding. Justification will have to be provided for specific analyses.

Staff Position: The basic models in RETRAN-3D are unchanged and, therefore, this condition of use applies. However, since RETRAN-3D is not being reviewed for loss-of-coolant accident analysis, where core uncover and heatup are significant, this condition does not occur in the transients for which application of RETRAN-3D has been reviewed.

Duke Position: Duke does not use the metal-water heat generation model.

6. Equilibrium thermodynamics is assumed for the thermal-hydraulics field equations although there are nonequilibrium models for the pressurizer and the subcooled boiling region.

Staff Position: The RETRAN-3D five equation model permits thermal-hydraulic nonequilibrium between the liquid and vapor phases. While it allows subcooled liquid and saturated steam to be concurrently present, it does not account for subcooled liquid and superheated vapor being concurrently present. Use of the code is not approved for LOCA. Also, the user must be aware of this limitation and avoid conditions which will place subcooled liquid and superheated vapor in contact.

Duke Position: Duke does not use the RETRAN-3D five equation model.

7. While the vector momentum model allows the simulation of some vector momentum flux effects in complex geometry the thermal-hydraulics are basically one-dimensional.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this comment still applies.

Duke Position: As described in Appendix B, Duke is proposing to use the vector momentum option with junction angle input for certain junctions where the momentum flux terms are considered to be potentially important. It is acknowledged that the thermal-hydraulics are basically one-dimensional. Duke's use of this model is based on vendor recommendations.

8. Further justification is required for the use of the homogeneous slip options with BWRs.

Staff Position: RETRAN-3D has five slip equation options for the user to choose from, three of which are retained from RETRAN-02 for compatibility. The recommended model options are based on the Chexal-Lellouche drift flux correlation. The first is the algebraic slip model, which

is approved for use with BWR bundle geometry as given in condition (9). The second is a form of the dynamic slip model that uses the Chexal-Lellouche drift flux correlation to evaluate the interfacial friction approved in condition (10). The user must justify the use of any other slip options.

Duke Position: Duke is not modeling BWRs.

9. The drift flux correlation used was originally calibrated to BWR situations and the qualification work for both this option and for the dynamic slip option only cover BWRs. The drift flux option can be approved for BWR bundle geometry if the conditions of (16) are met.

Staff Position: The Chexal-Lellouche drift flux model has been used in comparisons with FRIGG-2 and FRIGG-4 void fraction data and is acceptable for use in BWR bundle geometry.

Duke Position: Duke is not modeling BWRs.

10. The profile effect on the interphase drag (among all the profile effects) is neglected in the dynamic slip option. Form loss is also neglected for the slip velocity. For the acceptability of these approximations refer to (17).

Staff Position: Form loss terms have been included in the RETRAN-3D dynamic slip model. The Taugl form of the dynamic slip equation also includes profile effects in the interphase drag model. These RETRAN-3D model improvements adequately address the concerns and the model is approved for use when the Chexal-Lellouche model is used to compute the interphase friction. Approval is subject to the conditions given in (16) for the Chexal-Lellouche drift flux correlation. Users must justify use of any other dynamic slip option.

Duke Position: Duke is not using the dynamic slip option.

11. Only one-dimensional heat conduction is modeled. The use of the optional gap linear thermal expansion model requires further justification.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use still applies.

Duke Position: Duke is not using the optional linear gap thermal expansion model.

12. Air is assumed to be an ideal gas with a constant specific heat representative of that at containment conditions. It is restricted to separated and single-phase vapor volumes. There are no other noncondensables.

Staff Position: RETRAN-3D has been extended to include a general noncondensable gas capability which resolves the original concern. However, the noncondensable gas flow model is approved for use subject to the following restriction.

As noted in Section 111.3.0 of the RETRAN-3D Theory Manual (Reference 4), none of the models available for calculating critical flow are appropriate when noncondensable gases are present. Consequently, the code automatically bypasses the critical flow model when noncondensable gases are present in a junction. Users must confirm that noncondensable flows do not exceed appropriate critical flow values or justify use of values that may exceed critical flow values.

Duke Position: Duke is not using the noncondensable gas flow model.

13. The use of the water properties polynomials should be restricted to the subcritical region. Further justification is required for other regions.

Staff Position: For enthalpies less than approximately 820 Btu/lbm, the difference between the ASME and RETRAN-3D curve fit values of the specific volume range from less than 0.2 percent to approximately 1.3 percent for pressures ranging from 0.1 to 6,000 psia. Further, for enthalpies greater than 820 Btu/lbm and pressures greater than 4200 psia, the differences in specific volume are also less than 1.0 percent. RETRAN-3D is approved for use with PWR ATWS analyses where the peak pressure resides in the regions described above.

For enthalpies greater than 820 Btu/lbm and pressures between 3200 and 4200 psia, the differences in specific volume increase as the enthalpy increases and the pressure decreases. The maximum error of approximately 3.8 percent occurs at the critical point. PWR ATWS analysis using RETRAN-3D in this region will require additional justification that the difference in specific volume does not adversely affect the calculation of the peak pressure.

Duke Position: Duke will address the above condition if an application encounters conditions in the region of concern.

14. A number of regime-dependent minimum and maximum heat fluxes are hardwired. The use of the heat transfer correlations should be restricted to situations where the pre-CHF heat transfer or single-phase heat transfer dominates.

Staff Position: RETRAN-3D contains both the "forced convection option" contained in RETRAN-02 which is the basis for this restriction, and a second option referred to as the "combination heat transfer map." If the first option is chosen, the "forced convection option," approval is granted only for use in pre-CHF and single-phase heat transfer regimes. If the second option is chosen, the "combination heat transfer map," then there are no discontinuities between successive heat transfer regimes and the appropriate heat transfer value should result. Therefore, the combination heat transfer option is approved for use.

Duke Position:

- []
15. The Bennett flow map should only be used for vertical flow within the conditions of the data base and the Beattie two-phase multiplier option requires qualification work

Staff Position: The Beattie two-phase multiplier has been removed from RETRAN-3D. The Govier horizontal flow map has been added to supplement the Bennett map for vertical flow and is acceptable.

Duke Position: Resolved per the Staff Position.

16. No separate effects comparison have been presented for the algebraic slip option and it would be prudent to request comparisons with the FRIGG tests before the approval of the algebraic slip option.

Staff Position: The algebraic slip option has been modified to include the Chexal-Lellouche drift flux model. Use of the Chexal-Lellouche drift flux model for BWR and PWR applications within the range of conditions covered by the steam-water database used to develop and validate the model is approved. The model has been qualified with data from a number of steady-state and two-component tests. While the small dimensions of the fuel assembly are covered, as noted previously in this safety evaluation, the data for large pipe diameters, such as reactor coolant system pipes, are not extensive and use of the Chexal-Lellouche model will need justification. Assessment work indicates that the model tends to under-predict the void profile in the range of 12 to 17 MPa. In addition, the accuracy of the model in the range of 7.5 to 10 Mpa, which covers BWR ATWS conditions, has not been fully demonstrated. Results of analyses using the model in these ranges must be carefully reviewed.

The Chexal-Lellouche correlation cannot be used in situations where CCFL is important unless validation for appropriate geometry and expected flow conditions is provided.

Duke Position:

[]

17. While FRIGG test comparisons have been presented for the dynamic slip option the issues concerning the Schrock-Grossman round tube data comparisons should be resolved before the dynamic slip option is approved. Plant comparisons using the option should also be required.

Staff Position: Assessment analyses (Reference 4), have shown that "the issues concerning the Schrock-Grossman round tube data comparisons" (actually the Bennett round tube data) are due to early prediction of CHF, which is nearly independent of the slip model used. Since the issue raised in the limitation is not related to the dynamic slip model, the limitation is considered to be resolved. The dynamic slip model is approved for use as given in condition (10).

Duke Position: Resolved per the Staff Position.

18. The nonequilibrium pressurizer model has no fluid boundary heat losses, cannot treat thermal stratification in the liquid region and assumes instantaneous spray effectiveness and a constant rainout velocity. A constant UA is used and flow detail within the component cannot be simulated. There will be a numerical drift in energy due to the inconsistency between the two-region and the mixture energy equations but it should be small. No comparisons were presented involving a full or empty pressurizer. Specific application of this model should justify the lack of fluid boundary heat transfer on a conservative basis.

Staff Position: The concern raised in this limitation of use is partially resolved in RETRAN-3D. Wall heat transfer can be included in the RETRAN-3D pressurizer model. Including wall heat transfer resolves this concern.

While the model does not directly account for thermal stratification, its effects can be included by use of normal nodes below the pressurizer volume. The user will have to justify the lack of thermal stratification or the use of normal nodes below the pressurizer should there be an indication that it would be important in the analysis.

The mixture and two-region energy equations are consistent for the implicit solution method where the mixture energy equation is used with the vapor-region energy equation. This eliminates inconsistency between the two-region and mixture energy equations and the concern regarding a potential drift in the region energies.

The staff notes that when a pressurizer fills or drains, a single region exists for which the normal pressure equation of state is used. Lack of numerical discontinuities in validation analyses of filling and draining pressurizers indicates that the model is functioning properly. It is the responsibility of the code user to justify any numerical discontinuity in the pressurizer during a filling or draining event.

The pressurizer model has options that require user-supplied parameters. Users must provide justification for these model parameters.

Duke Position: Duke is not proposing any changes in modeling the pressurizer with RETRAN-3D relative to the previous NRC-approved RETRAN-02 modeling in DPC-NE-3000-PA. The good modeling practices in the Staff Position are noted.

19. The non-mechanistic separator model assumes quasi-statics (time constant approximately few tenths of seconds) and uses GE BWR6 carryover/carryunder curves for default values. Use of default curves has to be justified for specific applications. As with the pressurizer a constant L/A is used. The treatment in the off normal flow quadrant is limited and those quadrants should be avoided. Attenuation of pressure waves at low flow/low quality conditions are not simulated well. Specific applications to BWR pressurization transients under those conditions should be justified.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies.

Duke Position: Duke does not use the separator model.

20. The centrifugal pump head is divided equally between the two junctions of the pump volume. Bingham pump and Westinghouse pump data are used for the default single-phase homologous curves. The SEMISCALE MOD-1 pump and Westinghouse Canada data are for the degradation multiplier approach in the two-phase regime. Use of the default curves has to be justified for specific applications. Pump simulation should be restricted to single-phase conditions.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies.

Duke Position: As noted in the Staff Position, the basic model in RETRAN-3D is unchanged from RETRAN-02. Duke is not proposing any changes in modeling the reactor coolant pumps with RETRAN-3D relative to the previous NRC-approved RETRAN-02 modeling in DPC-NE-3000-PA, Section 2.2.6.2.

21. The jet pump model should be restricted to the forward flow quadrant as the treatment in the other quadrants is conceptually not well founded. Specific modeling of the pump in terms of volumes and junctions is at the user's discretion and should therefore be reviewed with the specific application.

Staff Position: Subsequent revisions of RETRAN-02 addressed this limitation. Since RETRAN-3D has the same model as RETRAN-02 MOD003, and subsequent versions, their acceptance applies to RETRAN-3D.

Duke Position: Duke does not model BWR jet pumps.

22. The non-mechanistic turbine model assumes symmetrical reaction staging, maximum stage efficiency at design conditions, a constant UA and a pressure behavior dictated by a constant loss coefficient. It should only be used for quasi-static conditions and in the normal operating quadrant.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies.

Duke Position: Duke does not use the turbine model.

23. The subcooled void model is a nonmechanistic profile fit using a modification of EPRI recommendations for the bubble departure point. It is used only for the void reactivity computation and has no direct effect on the thermal-hydraulics. Comparisons have only been presented for BWR situations. The model should be restricted to the conditions of the qualification data base. Sensitivity studies should be requested for specific applications. The profile blending algorithm used will be reviewed when submitted as part of the new manual (MOD003) modifications.

Staff Position: The profile blending algorithm approved for RETRAN-02 MOD003 is used in RETRAN-3D therefore this condition has been satisfied.

Duke Position: Resolved per the Staff Position.

24. The bubble rise model assumes a linear void profile, a constant rise velocity (but adjustable through the control system), a constant UA, thermodynamic equilibrium, and makes no attempt to mitigate layering effects. The bubble mass equation assumes zero junction slip which is contrary to the dynamic and algebraic slip model. The model has limited application and each application must be separately justified.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies. However, the layering effects encountered in RETRAN-02 can be eliminated using the RETRAN-3D stack model. This partially resolves the concern by resolving the layering limitation through use of the stack model.

Duke Position: As noted in the Staff Position, the basic model in RETRAN-3D is unchanged from RETRAN-02. Duke is not proposing any changes in using the bubble rise model with RETRAN-3D relative to the previous NRC-approved RETRAN-02 modeling in DPC-NE-3000-PA, Section 2.2.6.4. Duke does not currently stack bubble rise volumes, but if future modeling does, the stack model will be used.

25. The transport delay model should be restricted to situations with a dominant flow direction.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies. The appropriate application of the model is for one-dimensional flow. The user will have to justify use of this option in the absence of a dominant flow direction.

Duke Position: As noted in the Staff Position, the basic model in RETRAN-3D is unchanged from RETRAN-02. Duke is not proposing any changes in using the transport delay model with RETRAN-3D relative to the previous NRC-approved RETRAN-02 modeling in DPC-NE-3000-PA, Section 2.2.7.4. The limitation with applying this model without a dominant flow direction is well known and is avoided.

26. The stand-alone auxiliary DNBR model is very approximate and is limited to solving a one-dimensional steady-state simplified HEM energy equation. It should be restricted to indicating trends.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies.

Duke Position: Duke does not use the auxiliary DNBR model.

27. Phase separation and heat addition cannot be treated simultaneously in the enthalpy transport model. For heat addition with multidirectional, multifunction volumes the enthalpy transport model should not be used without further justification. Approval of this model will require submittal of the new manual (MOD003) modifications.

Staff Position: A number of the simplifying assumptions in the RETRAN-02 enthalpy transport model have been eliminated in RETRAN-3D which now allows multiple inlet and outlet flows


and eliminates the simplifying assumptions related to mass distribution and pressure change effects. This condition has been adequately addressed.

Duke Position: Resolved per the Staff Position

28. The local conditions heat transfer model assumes saturated fluid conditions, one-dimensional heat conduction and a linear void profile. If the heat transfer is from a local condition volume to another fluid volume, that fluid volume should be restricted to a non-separated volume. There is no qualification work for this model and its use will therefore require further justification.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies.

Duke Position:



29. The initializer does not absolutely eliminate all ill-posed data and could have differences with the algorithm used for transient calculations. A null transient computation is recommended. A heat transfer surface area adjustment is made and biases are added to feedwater inlet enthalpies in order to justify steady-state heat balances. These adjustments should be reviewed on a specific application basis.

Staff Position: The over-specified condition is identified by the RETRAN-3D steady-state input checking, resolving the concern regarding ill-posed data. The user must still run null transients to ensure that unwanted control or trip actions are not affecting the transient solution.

RETRAN-3D has available a low power steady-state steam generator initialization option that eliminates the heat conductor area change used in the RETRAN-02 initialization scheme. When this option is used, no adjustments are made to the heat transfer area and this specific concern is resolved. However, either the pressure or temperature is adjusted on the secondary side. These adjustments should be reviewed by the user on a specific application basis. The low power steady-state initialization option is approved for use.

Duke Position: Resolved per the Staff Position.

30. Justification of the extrapolation of FRIGG data or other data to secondary-side conditions for PWRs should be provided. Transient analysis of the secondary side must be substantiated. For any transients in which two-phase flow is encountered in the primary all the two-phase flow models must be justified.

Staff Position: The Chexal-Lellouche correlation is approved for use with PWR applications as stated in conditions (10) and (16). The user must justify choosing any other two-phase flow correlation.

Duke Position:

31. The pressurizer model requires model qualification work for the situations where the pressurizer either goes solid or completely empties.

Staff Position: The pressurizer model is approved for use with filling and draining events as given in condition (18).

Duke Position: Resolved per the Staff Position

32. Transients which involve three-dimensional space-time effects such as rod ejection transients would have to be justified on a conservative basis.

Staff Position: The 3-dimensional kinetics model, as noted in limitation 1 above, satisfies this limitation.

Duke Position: Resolved per the Staff Position. Duke is not using the three-dimensional model.

33. Transients from subcritical, such as those associated with reactivity anomalies should not be run.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies.

Duke Position: Duke is not running any transients from subcritical.

34. Transients where boron injection is important, such as steamline break will require separate justification for the user-specified boron transport model.

Staff Position: The generalized transport model was added to RETRAN-3D to provide the capability to track materials such as boron. Specific application of the model to steam line break transients must be justified by the user. The model is approved for use as given in condition (3).

Duke Position: The generalized transport model is unchanged from RETRAN-02 relative to its use for modeling boron transport. The generalized transport model was approved in the SER for RETRAN-02 MOD005.0 dated November 1, 1991. Duke's use of this model for Oconee

emergency boron injection is documented in topical report DPC-NE-3005-PA, "UFSAR Chapter 15 Transient Analysis Methodology," Revision 1, Section 15.3.1.1.3. This topical report was approved by the NRC with SERs dated October 1, 1998 and May 25, 1999. No further NRC review is necessary.

35. For transients where mixing and cross flow are important, the use of various cross flow loss coefficients has to be justified on a conservative basis.

Staff Position: The basic model in RETRAN-3D is unchanged and, therefore, this condition of use applies.

Duke Position: Duke models mixing and cross flow in the reactor vessel during transients and accidents in which loop asymmetry is important. Duke's modeling for Oconee is documented in topical report DPC-NE-3005-PA, "UFSAR Chapter 15 Transient Analysis Methodology," Revision 1, Section 15.2.1.1. This topical report was approved by the NRC with SERs dated October 1, 1998 and May 25, 1999. No further NRC review is necessary.

36. ATWS events will require additional submittals.

Staff Position: RETRAN-3D is approved for PWR ATWS analyses as given in condition (13).

Duke Position: Resolved per the Staff Position.

37. For PWR transients where the pressurizer goes solid or completely drains, the pressurizer behavior will require comparison against real plant or appropriate experimental data.

Staff Position: The pressurizer model is approved for use with filling and draining events as noted in the discussion of conditions (18) and (31).

Duke Position: Resolved per the Staff Position

38. PWR transients, such as steam generator tube rupture, should not be analyzed for two-phase conditions beyond the point where significant voiding occurs on the primary side.

Staff Position: The use of slip models for PWR applications is approved for use as given in conditions (16) and (30).

Duke Position: In the Oconee steam generator tube rupture UFSAR Chapter 15 analysis significant voiding does not occur on the primary side. However, significant voiding can occur on the primary side for steam line break events. Duke's UFSAR Chapter 15 steam line break modeling for Oconee is documented in topical report DPC-NE-3005-PA, "UFSAR Chapter 15 Transient Analysis Methodology," Revision 1, Chapter 15. This topical report was approved by the NRC with SERs dated October 1, 1998 and May 25, 1999. Duke's UFSAR Chapter 6 steam line break mass and energy release modeling for Oconee is documented in topical report DPC-NE-3003-PA, "Mass and Energy Release and Containment Response Methodology," Chapter 5. This topical report was approved by the NRC with SER dated March 15, 1995. Modeling of two-

[No further NRC review is necessary.

39. BWR transients were asymmetry leads to reverse jet pump flow such as the one recirculation pump trip, should be avoided.

Staff Position: As noted in the discussion of condition (21), this is resolved.

Duke Position: Duke does not model BWRs.

40. Organizations with NRC-approved RETRAN-02 methodologies can use the RETRAN-3D code in the RETRAN-02 mode without additional NRC approval, provided that none of the new RETRAN-3D models listed in the definition are used. Organizations with NRC-approved RETRAN-02 methodologies must obtain NRC approval prior to applying any of the new RETRAN-3D models listed above for UFSAR Chapter 15 licensing basis applications. Organizations without NRC-approved RETRAN-02 methodologies must obtain NRC approval for such methodologies or a specific application before applying the RETRAN-02 code or the RETRAN-3D code for UFSAR Chapter 15 licensing basis applications. Generic Letter 83-11 provides additional guidance in this area. Licensees who specifically reference RETRAN-02 in their technical specifications will have to request a Technical Specification change to use RETRAN-3D.

Duke Position: The submittal of DPC-NE-3000-P, Revision 3, includes the use of the [

] The SER on p. 33 also states that use of the "new control blocks added to improve functionality" requires NRC review and approval. The new control blocks in RETRAN-3D are the following:

ABS - Absolute value
F2D - Two-dimensional interpolation
RAT - Rate
STF - Second-order transfer function

None of these new control block models have yet been incorporated into any of the Duke RETRAN models used for licensing basis applications. However, use of some of these new control block models in the future is likely to enhance and simplify applications. Since all of these new control blocks consist of well-founded arithmetic and mathematical formulas, similar to the control blocks included in RETRAN-02, it is not understood why NRC approval prior to their use is necessary. Duke requests NRC approval to use the new RETRAN-3D control blocks for future applications consistent with their formulation.

41. RETRAN may be used for BWR ATWS subject to the following restrictions: The licensee must validate the chosen void model over the range of pressure, channel inlet flow, and inlet subcooling encountered during the transient that are outside the range of conditions for which assessment is available. Furthermore, the licensee should validate the choice of steam separator model and evaluate its use relative to steam separator performance data relevant to the conditions

present during the ATWS simulation. The licensee must also evaluate the uncertainties in the modeling. See Condition (16) and the Staff Position for related information.

Duke Position: Duke does not model BWRs.

42. The RETRAN-3D five-equation, or nonequilibrium, model uses flow regime maps and flow pattern dependent heat transfer and interfacial area models to simulate the heat and mass transfer processes between phases. A licensee wishing to apply the five-equation model will have to justify its use outside areas of operation where assessment has been documented. This may include either separate effects or integral systems assessment that cover the range of conditions encountered by the application of interest. An assessment of the uncertainties must also be provided. The model is approved subject to these conditions.

Duke Position: Duke does not use the five-equation model for licensing basis applications.

43. Assessment performed in support of use of RETRAN-3D must also address consistency between the RETRAN-3D calculations and any auxiliary calculations that are a part of the overall methodology, such as, departure from nucleate boiling or critical power ratio.

Duke Position: Duke uses results from RETRAN-3D analyses for input to other codes to perform core power distribution analyses, detailed core thermal-hydraulic analysis of the departure from nucleate boiling phenomenon, fuel rod and pellet thermal and mechanical behavior analyses, and containment thermal and structural response to high-energy line breaks. The details of these other methodologies have been submitted and approved by the NRC as appropriate. Any revisions to these methodologies, including any changes due to the use of RETRAN-3D in place of RETRAN-02, will be submitted for NRC review prior to their use for licensing basis applications.

44. The staff concludes that the lack of a detailed RETRAN-3D specific user guideline document mandates a statement on the user's experience and qualification with the code when analyses are submitted in support of licensing actions. This statement is expected to be consistent with the guidance of Generic Letter 83-11.

Duke Position: It is noted that Volume 3 of the EPRI RETRAN-3D documentation set has been enhanced subsequent to the NRC SER to include a significant amount of user guidelines regarding modeling option selection, in particular for the new RETRAN-3D models and options. Revision 3 to DPC-NE-3000-P fully describes Duke's use of the RETRAN-3D code for simulating the Oconee Nuclear Station with replacement steam generators. This revision is submitted for NRC review with the intent of maintaining the documentation of the Duke RETRAN methodology current, along with the main purpose of obtaining NRC review and approval for the transition from RETRAN-02 to RETRAN-3D for Oconee. This topical report revision extends Duke's response to Generic Letter 83-11. Duke's current level of RETRAN user experience is 15 engineers with a total of 144 years of experience with RETRAN-02 and RETRAN-03/-3D.

45. Assessment of the RETRAN-3D code for the models not explicitly approved in this safety evaluation will be the responsibility of the licensee or applicant. In addition, application of the

RETRAN-02 or RETRAN-3D codes for best estimate analysis of UFSAR Chapter 15 licensing basis events may require additional code and model assessment, and an evaluation of uncertainties to assure accurate prediction of best estimate response. This condition is based on the absence, in the best estimate analysis approach, of the conservative assumptions in traditional UFSAR Chapter 15 licensing basis analyses. For each use of RETRAN-3D in a licensing calculation, it will be necessary for a valid approach to assessment to be submitted, which is expected to include a PIRT for each use of the code and the appropriate assessment cases and their results. The scope of the PIRT and validation/assessment will be commensurate with the complexity of the application.

Duke Position: Duke has previously received NRC review and approval for application of the RETRAN-02 code to the licensing basis applications for non-LOCA transients and accidents for the Oconee Nuclear Station. The three RETRAN-related topical reports and associated NRC SERs supporting Oconee are:

DPC-NE-3000-PA, Revision 2, "Thermal-Hydraulic Transient Analysis Methodology", December 2000. SERs are dated 11/15/91 (Revision 0), 8/8/94 (Revision 1), and 12/27/95 (Revision 2)

DPC-NE-3003-PA, "Mass and Energy Release and Containment Response Methodology", November 1997. SER is dated 3/15/95

DPC-NE-3005-PA, Revision 1, "UFSAR Chapter 15 Transient Analysis Methodology, August 1999. SERs are dated 10/1/98 (Revision 0) and 5/25/99 (Revision 1)

These topical reports have all being revised and submitted for NRC review to address the Oconee replacement steam generators and use of the RETRAN-3D code for Oconee non-LOCA transient and accident analyses. Based on the close similarity of the replacement and original steam generators, the transient thermal-hydraulic behavior will be very similar. The only significant difference will be for the main steam line break analysis, in which the flow restricting orifices in the replacement steam generators steam outlet nozzles will effectively reduce the maximum break size and the blowdown rate.

activity was presented and reviewed by the NRC during the review of earlier revisions of DPC-NE-3000. [] has been incorporated into the Duke version of the RETRAN-3D code as described in Revision 3 to DPC-NE-3000-P.

In summary, Duke has previously obtained NRC review for RETRAN-02 modeling of Oconee with the original steam generators. Substantial validation and assessments comparisons were associated with the previous revisions to DPC-NE-3000. The designs of the original and replacement steam generators are very similar, and the transient performance will be very similar except for the response to large steam line break accidents. Revision 3 describes the use of RETRAN-3D for modeling Oconee with replacement steam generators. []

[] Duke is not proposing to use this model for best-estimate licensing applications. The traditional conservative approach will continue to be used for licensing applications. A PIRT is not being submitted due to the previous NRC approval of the Duke RETRAN methodology topical reports, the limited scope of changes in the methodologies, the similarity of the designs of the new and replacement Oconee steam generators, the use of only one new RETRAN-3D model, and the assessment that has been performed to justify use of the one new model.

References

- C-1 Letter, S. A. Richards (NRC), to G. L. Vine (EPRI), Safety Evaluation Report on EPRI Topical Report NP-7450(P), Revision 4, "RETRAN-3D - A Program for Transient Thermal-Hydraulic Analysis of Complex Fluid Flow Systems", January 25, 2001
- C-2 RETRAN-3D MOD003.1DKE, SDQA-30218-NGO, Duke Power, October 30, 2001