

March 14, 2005

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: ST. LUCIE UNIT 2 - CORRECTION TO NRC SAFETY EVALUATION FOR
ISSUANCE OF AMENDMENT NO. 138 REGARDING CHANGE IN
METHODOLOGY AND INCREASE IN STEAM GENERATOR TUBE PLUGGING
LIMIT (TAC NO. MC1566)

Dear Mr. Stall:

By letter dated January 31, 2005, the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 138 to Renewed Operating License No. NPF-16. This amendment consists of changes to the Technical Specifications to permit operation with a reduced reactor coolant system flow corresponding to a steam generator tube plugging level of 30 percent per steam generator. The analysis performed to support this change utilized the Westinghouse Reload Safety Evaluation Methodology (WCAP-9272). This amendment also includes the transition to WCAP-9272 as the reload analysis methodology for St. Lucie Unit 2.

The Florida Power & Light Company staff informed the NRC staff of inaccuracies regarding the discussion of the control room ventilation system operation in the isolation mode and the need for editorial corrections in Tables 1 and 2 to the safety evaluation (SE) supporting the amendment. We have resolved this by revising the appropriate wording in the SE and correcting the tables. The corrected SE page and Tables 1 and 2 are included as an enclosure to this letter. Revisions are identified by lines in the margin. This letter, with its enclosure, should be attached to the subject SE to document the resolution of the issue.

If you or your staff have any questions concerning the resolution of this matter, please contact me at 301-415-3974.

Sincerely,

/RA/

Brendan T. Moroney, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-389

Enclosure: As stated

cc w/enclosure: See next page

Mr. J. A. Stall
Florida Power and Light Company

ST. LUCIE PLANT

cc:
Senior Resident Inspector
St. Lucie Plant
U.S. Nuclear Regulatory Commission
P.O. Box 6090
Jensen Beach, Florida 34957

Craig Fugate, Director
Division of Emergency Preparedness
Department of Community Affairs
2740 Centerview Drive
Tallahassee, Florida 32399-2100

M. S. Ross, Managing Attorney
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Marjan Mashhadi, Senior Attorney
Florida Power & Light Company
801 Pennsylvania Avenue, NW.
Suite 220
Washington, DC 20004

Mr. Douglas Anderson
County Administrator
St. Lucie County
2300 Virginia Avenue
Fort Pierce, Florida 34982

Mr. William A. Passetti, Chief
Department of Health
Bureau of Radiation Control
2020 Capital Circle, SE, Bin #C21
Tallahassee, Florida 32399-1741

Mr. William Jefferson, Jr.
Site Vice President
St. Lucie Nuclear Plant
6351 South Ocean Drive
Jensen Beach, Florida 34957-2000

Mr. G. L. Johnston
Plant General Manager
St. Lucie Nuclear Plant
6351 South Ocean Drive
Jensen Beach, Florida 34957

Mr. Terry Patterson
Licensing Manager
St. Lucie Nuclear Plant
6351 South Ocean Drive
Jensen Beach, Florida 34957

David Moore, Vice President
Nuclear Operations Support
Florida Power and Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. Rajiv S. Kundalkar
Vice President - Nuclear Engineering
Florida Power & Light Company
P.O. Box 14000
Juno Beach, FL 33408-0420

Mr. J. Kammel
Radiological Emergency
Planning Administrator
Department of Public Safety
6000 Southeast Tower Drive
Stuart, Florida 34997

March 14, 2005

Mr. J. A. Stall
Senior Vice President, Nuclear and
Chief Nuclear Officer
Florida Power and Light Company
P.O. Box 14000
Juno Beach, Florida 33408-0420

SUBJECT: ST. LUCIE UNIT 2 - CORRECTION TO NRC SAFETY EVALUATION FOR
ISSUANCE OF AMENDMENT NO. 138 REGARDING CHANGE IN
METHODOLOGY AND INCREASE IN STEAM GENERATOR TUBE PLUGGING
LIMIT (TAC NO. MC1566)

Dear Mr. Stall:

By letter dated January 31, 2005, the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 138 to Renewed Operating License No. NPF-16. This amendment consists of changes to the Technical Specifications to permit operation with a reduced reactor coolant system flow corresponding to a steam generator tube plugging level of 30 percent per steam generator. The analysis performed to support this change utilized the Westinghouse Reload Safety Evaluation Methodology (WCAP-9272). This amendment also includes the transition to WCAP-9272 as the reload analysis methodology for St. Lucie Unit 2.

The Florida Power & Light Company staff informed the NRC staff of inaccuracies regarding the discussion of the control room ventilation system operation in the isolation mode and the need for editorial corrections in Tables 1 and 2 to the safety evaluation (SE) supporting the amendment. We have resolved this by revising the appropriate wording in the SE and correcting the tables. The corrected SE page and Tables 1 and 2 are included as an enclosure to this letter. Revisions are identified by lines in the margin. This letter, with its enclosure, should be attached to the subject SE to document the resolution of the issue.

If you or your staff have any questions concerning the resolution of this matter, please contact me at 301-415-3974.

Sincerely,

/RA/

Brendan T. Moroney, Project Manager, Section 2
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-389

Enclosure: As stated

cc w/enclosure: See next page

DISTRIBUTION:

| | | | | |
|------------|-----------|----------|------------|------------------------|
| PUBLIC | EHackett | LLund | PClifford | AAttard |
| PDII-2 R/F | MMarshall | RJenkins | JLazevnick | JMunday, RII |
| OGC | BMoroney | RDennig | MBlumberg | UShoop, EDO |
| ACRS | JArroyo | TBoyce | EMurphy | BClayton (paper copy) |
| DLPM DRP | DCoe | SSun | BHarvey | GHill (2 paper copies) |

ADAMS Accession No.: ML050730385

NRR-

028

| OFFICE | PDII-2/PE | PDII-2/PM | PDII-2/LA | PDII-2/SC |
|--------|---------------|---------------|---------------|---------------|
| NAME | JArroyo | BMoroney | BClayton | MMarshall |
| DATE | 03 / 14 /2005 | 03 / 14 /2005 | 03 / 14 /2005 | 03 / 14 /2005 |

The licensee assumed the control room is isolated 30 seconds after the LOOP. The licensee also assumed the operators act to un-isolate the control room and initiate filtered air makeup 90 minutes after the start of the event in order to maintain positive pressure and air quality within the control room. By observing the radiation monitors located in the outside air intake ducts, the licensee stated that operators are assumed to be able to identify and open the outside air intake with the lesser amount of radiation. The licensee assessed the dose from the filtered makeup contribution using the dispersion factors for the more favorable air intake location throughout the rest of the 30-day duration of the dose calculation.

In Question 19 of the RAI letter dated July 9, 2004, the staff asked how the operators would be able to continuously observe radiation monitor levels at each intake throughout the 30-day event period to ensure that the less contaminated intake is always being used to pressure the control room during wind shifts and changing release rates from multiple release pathways. In its RAI response to the staff dated September 21, 2004, the licensee committed to revising plant procedures to identify the need for operators to be aware of changing meteorological conditions and how such changes may affect which outside air intake path provides the lower radiation levels.

During the entire course of the event, the licensee assumed unfiltered inleakage enters the control room. At the beginning of the event, prior to control room isolation, the licensee modeled unfiltered inleakage using the dispersion factors associated with the less favorable control room intake location. Following control room isolation, when both control room intakes are closed, the licensee used a dispersion factor corresponding to the midpoint between both control room intake locations (for closest MSSV/ADV releases). At the time when the operators are assumed to un-isolate the control room by opening the more favorable air intake, the licensee used the dispersion factor for the more favorable control room intake location.

In Question 23 of the RAI letter dated July 9, 2004, the staff inquired why the licensee did not model the unfiltered inleakage pathway using the most limiting dispersion factors associated with the bounding potential unfiltered inleakage pathway for the duration of the event. In its RAI response to the staff dated September 21, 2004, the licensee stated that Unit 2 unfiltered inleakage testing demonstrated that a large portion of the control room unfiltered inleakage comes from the B switchgear room which is fed from fans that take suction in the vicinity of the south control room intake. Since the atmospheric dispersion factors for the south control room intake are lower than the other possible receptor points, assigning the unfiltered inleakage to other possible receptor points is conservative.

Staff qualitatively reviewed the inputs to the ARCON96 computer runs and found them generally consistent with site configuration drawings and staff practice. The two potential release pathways (i.e., the condenser and the closest MSSV/ADV) were modeled as ground-level point sources with the difference in heights between the release point and receptor taken into consideration. The building area used to model building wake effects was conservatively set equal to zero. The staff made an independent evaluation of the resulting atmospheric dispersion estimates by running the ARCON96 computer model and obtained similar results.

TABLE 1

SGTR DBA ANALYSIS ASSUMPTIONS (CONTINUED)

| | |
|---|------------------------------|
| Pre-incident iodine spike activity (60 μ Ci/gm dose equivalent I-131) | Reference 7, Table 2.4-3 |
| Coincident spike appearance rate, based on | Reference 7, Table 2.4-5 |
| RCS letdown flow rate (120F, 2250 psia), gpm | 150.0 |
| RCS letdown demineralizer efficiency | 4 |
| RCS mass, lbm | 452,000 |
| RCS leakage, gpm | 11 |
| Coincident spike multiplier | 335 |
| Release duration, hrs | |
| Ruptured SG | 8 |
| Unaffected SG | 8 |
| Liquid Masses, lbm | |
| RCS | 475,385 (pre-incident spike) |
| RCS | 452,000 (Coincident spike) |
| SG | 105,000 (minimum) |
| SGTR integrated mass releases | Reference 7, Table 2.4-2 |
| Break Flow Flash Fraction, % | |
| Pre-trip (up to 379.2 sec) | 17.19 |
| Post-trip | 6.6 |
| Primary-to-secondary leakage | |
| Ruptured SG, gpm | .15 |
| To unaffected SG, gpd | .15 |
| Duration, hours | 12 |
| Chemical form release fractions | |
| Elemental | 0.97 |
| Organic | 0.03 |
| Steam partition coefficient in SGs | |
| Ruptured SG (flashed flow) | 1.0 |
| Ruptured (non-flashed flow) | 100 |
| Intact SG | 100 |

Table 2

**St. Lucie Unit 2 Control Room Relative Concentration (X/Q) Values
Steam Generator Tube Rupture Accident**

| TIME FRAME | RELEASE POINT | X/Q VALUES (sec/m ³) | | | | |
|--------------------------------------|-------------------------------|----------------------------------|-----------------------|-----------------------|-----------------------|-----------------------|
| | | 0 TO 2 HOURS | 2 TO 8 HOURS | 8 TO 24 HOURS | 1 TO 4 DAYS | 4 TO 30 DAYS |
| Prior to CR Isolation | Condenser ^a | 2.47×10^{13} | - | - | - | - |
| | Closest MSSV/ADV ^a | 6.69×10^{13} | - | - | - | - |
| During CR Isolation | Closest MSSV/ADV ^b | 3.11×10^{13} | - | - | - | - |
| After Initiation of Filtered Make-up | Closest MSSV/ADV ^c | 1.88×10^{13} | 1.46×10^{13} | 5.98×10^{14} | 4.23×10^{14} | 3.19×10^{14} |

^a The receptor is assumed to be the north CR intake

^b The receptor is assumed to be the midpoint between the CR intakes

^c The receptor is assumed to be the south CR intake