

Exelon Nuclear
200 Exelon Way
Kennett Square, PA 19348

www.exeloncorp.com

TS 6.9.1.12

March 15, 2005

U.S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington DC 20555

Limerick Generating Station, Unit 2
Facility Operating License No. NPF-85
NRC Docket No. 50-353

Subject: Issuance of the Core Operating Limits Report
For Reload 8, Cycle 9, Revision 0

Dear Sir/Madam:

Enclosed is a copy of the Core Operating Limits Report (COLR) for Limerick Generating Station, Unit 2, Reload 8, Cycle 9, Revision 0. Revision 0 of this report incorporates the revised cycle specific parameters resulting from the new core configuration implemented during the LGS, Unit 2 (2R08) refueling outage.

This COLR is being submitted to the NRC in accordance with LGS, Unit 2 Technical Specifications (TS) Section 6.9.1.12.

If you have any questions, please do not hesitate to contact us.

Very truly yours,





David P. Helker
Manager, Licensing and Regulatory Affairs
Exelon Generation Company, LLC

Enclosure

cc: S. J. Collins, Regional Administrator, Region I, USNRC
S. Hansell, USNRC Senior Resident Inspector, LGS
T. Tate, Senior Project Manager [LGS], USNRC

CORE OPERATING LIMITS REPORT
FOR
LIMERICK GENERATING STATION UNIT 2
RELOAD 8, CYCLE 9

Prepared By:  Date: 3/10/05
G. Rubinaccio
Preparer

Reviewed By:  Date: 3/11/05
W. P. Gassmann
Independent Reviewer


Approved By:  Date: 3/11/05
J. J. Tusar
Manager - BWR Design (GNF)

Table of Contents

	Page
1.0 Terms and Definitions	5
2.0 References	6
3.0 General Information	7
4.0 MAPLHGR Limits	8
5.0 MCPR Limits	9
6.0 Linear Heat Generation Rate Limits	14
7.0 Control Rod Block Setpoints	19
8.0 Turbine Bypass Valve Parameters	20
9.0 Modes of Operation	21

List of Tables

	Page
Table 4-1 MAPLHGR Versus Average Planar Exposure All Fuel Types	8
Table 4-2 MAPLHGR Single Loop Operation (SLO) Reduction Factor	8
Table 5-1 Operating Limit Minimum Critical Power Ratio (OLMCPR)	10
Table 6-1 Linear Heat Generation Rate Limits	14
Table 6-2 LHGR Single Loop Operation (SLO) Reduction Factor	14
Table 7-1 Rod Block Monitor Setpoints	19
Table 7-2 Reactor Coolant System Recirculation Flow Upscale Trip	19
Table 8-1 Turbine Bypass System Response Time	20
Table 8-2 Minimum Required Bypass Valves To Maintain System Operability	20

List of Figures

	Page
Figure 5-1 Power Dependent MCPR Limit Adjustments and Multipliers	11
Figure 5-2 Power Dependent MCPR Limit Adjustments and Multipliers – TBVOOS	12
Figure 5-3 Flow Dependent MCPR Limits MCPR(F)	13
Figure 6-1 Power Dependent LHGR Multiplier LGHRFAC(P)	15
Figure 6-2 Power Dependent LHGR Multiplier LHGRFAC(P) – TBVOOS	16
Figure 6-3 Flow Dependent LHGR Multiplier LHGRFAC(F)	17
Figure 6-4 Flow Dependent LHGR Multiplier LHGRFAC(F) –SLO	18

1.0 Terms And Definitions

ARTS	APRM and RBM Technical Specification Analysis
DTSP	Rod Block Monitor Downscale Trip Setpoint
End of Rated (EOR)	The cycle exposure at which reactor power is equal to 3458 MWth with recirculation system flow equal to 100%, all control rods fully withdrawn, all feedwater heating in service and equilibrium Xenon.
FFWTR	Final Feedwater Temperature Reduction
FWHOOS	Feedwater Heaters Out of Service
HTSP	Rod Block Monitor High Trip Setpoint
ICF	Increased Core Flow
ITSP	Rod Block Monitor Intermediate Trip Setpoint
LHGR	Linear Heat Generation Rate
LHGRFAC(F)	ARTS LHGR thermal limit flow dependent adjustments and multipliers
LHGRFAC(P)	ARTS LHGR thermal limit power dependent adjustments and multipliers
LTSP	Rod Block Monitor Low Trip Setpoint
MAPLHGR	Maximum Average Planar Linear Heat Generation Rate
MCPR	Minimum Critical Power Ratio
MCPR(P)	ARTS MCPR thermal limit power dependent adjustments and multipliers
MCPR(F)	ARTS MCPR thermal limit flow dependent adjustments and multipliers
MELLLA	Maximum Extended Load Line Limit Analysis
OLMCPR	Operating Limit Minimum Critical Power Ratio
RCF	Rated Core Flow
RPTOOS	Recirculation Pump Trip Out of Service
SLMCPR	Safety Limit Minimum Critical Power Ratio
SLO	Single Loop Operation
TBVOOS	Turbine Bypass Valves Out of Service

2.0 References

1. "Technical Specifications and Bases for Limerick Generating Station Unit 2", Docket No. 50-353, License No. NPF-85.
2. "Supplemental Reload Licensing Report for Limerick Generating Station Unit 2 Reload 8 Cycle 9", Global Nuclear Fuel Document No. 0000-0031-7705-SRLR, Revision 0, January 2005.
3. "GE14 Fuel Design Cycle-Independent Analyses for Limerick Generating Station Units 1 and 2", GE-NE-L12-00884-00-01P, March 2001.
4. "OPL-3 Transient Protection Parameters Verification for Reload Licensing Analyses for Limerick 2 Reload 8 Cycle 9", TODI 04-00254
5. "ARTS Flow-Dependent Limits with TBVOOS for Peach Bottom Atomic Power Station and Limerick Generating Station", GENE Document NEDC-32847P, June 1998.
6. "General Electric Standard Application for Reactor Fuel", NEDE-24011-P-A-14, June 2000 and U.S. Supplement NEDE-24011-P-A-14-US, June 2000.
7. "Power Range Neutron Monitoring System Setpoint Calculations Limerick Generating Station, Units 1 & 2 Mod. No. P00224", LE-0107, Rev. 0, March 2000.
8. "Limerick 1 and 2 Off-Rated Analyses Below the PLU Power Level", GE Nuclear Document No. GE-NE-0000-0037-3253-R0, March 2005.
9. "Fuel Bundle Information Report for Limerick Generating Station Unit 2 Reload 8 Cycle 9", Global Nuclear Fuel Document No. 0000-0031-7705-FBIR, January 2005.

3.0 General Information

This report provides the following cycle-specific parameter limits for Limerick Generating Station Unit 2 Cycle 9:

- Maximum Average Planar Linear Heat Generation Rate (MAPLHGR)
- Minimum Critical Power Ratio (MCPR)
- Single Loop Operation (SLO) MCPR adjustment
- ARTS MCPR thermal limit adjustments and multipliers (MCPR(P) or MCPR(F))
- ARTS LHGR thermal limit multipliers (LHGRFAC(P) or LHGRFAC(F))
- Rod Block Monitor (RBM) setpoints
- MAPLHGR single loop operation reduction factor
- LHGR single loop operation reduction factor
- Linear Heat Generation Rate (LHGR)
- Turbine Bypass Valve parameters
- Reactor Coolant System Recirculation Flow Upscale Trips

These values have been determined using NRC-approved methodology (Reference 6), and are established such that all applicable limits of the plant safety analysis are met.

This report is prepared in accordance with Technical Specification 6.9.1.9 of Reference 1. Preparation of this report was performed in accordance with Exelon Nuclear, Nuclear Fuel Management T&RM NF-AB-120-3600.

The data presented in this report is valid for all licensed operating domains on the operating map, including:

- Maximum Extended Load Line Limit down to 81% of rated core flow during full power operation
- Increased Core Flow (ICF) up to 110% of rated core flow
- Final Feedwater Temperature Reduction (FFWTR) up to 105°F during cycle extension operation
- Feedwater Heater Out of Service (FWHOOS) up to 60°F feedwater temperature reduction at any time during the cycle prior to cycle extension.

Further information on the cycle specific analyses for Limerick 2 Cycle 9 and the associated operating domains discussed above is available in Reference 2.

4.0 MAPLHGR Limits

The MAPLHGR limits provided in Tables 4-1 and 4-2 are referenced in Technical Specifications 3.2.1. The limiting MAPLHGR value for the most limiting lattice (excluding natural uranium) of each fuel type as a function of average planar exposure is given in Table 4-1 (References 2). The limiting MAPLHGR value is the same for all fuel types in the Limerick Unit 2 Cycle 9 core. Table 4-1 is used when hand calculations are required as specified in Technical Specification 3.2.1. For single loop operation, a reduction factor is used which is shown in Table 4-2 (Reference 2).

TABLE 4-1
MAPLHGR Versus Average Planar Exposure
All Fuel Types
(Reference 2)

Average Planar Exposure (GWD/ST)	MAPLHGR Limit (kW/ft)
0.0	12.82
14.51	12.82
19.13	12.82
57.61	8.00
63.50	5.00

TABLE 4-2
MAPLHGR Single Loop Operation (SLO) Reduction Factor
(Reference 2)

SLO Reduction Factor	0.80
-----------------------------	-------------

5.0 MCPR Limits

The MCPR values provided in Table 5-1 are referenced in Technical Specification 3.2.3. Table 5-1 is derived from the Reference 2 analyses and is valid for all Cycle 9 fuel types and operating domains. Table 5-1 includes treatment of these MCPR limits for SLO. Bounding MCPR values are also provided for inoperable Recirculation Pump Trip or inoperable Steam Bypass System. These two options represent the Equipment Out of Service conditions. The cycle exposure that represents EOR is given in the latest verified and approved Cycle Management Report or an associated Engineering Change Request.

ARTS provides for power- and flow-dependent thermal limit adjustments and multipliers, which allow for a more reliable administration of the MCPR thermal limit. The flow-dependent adjustment MCPR(F) is sufficiently generic to apply to all fuel types and operating domains (References 2 and 5). In addition, there are also two sets of power-dependent MCPR multipliers for use with the Turbine Bypass Valves in service and TBVOOS conditions (Reference 8). Section 8.0 contains the conditions for Turbine Bypass Valve Operability. These adjustments and multipliers are shown in Figures 5-1 through 5-3 and are referred to by Technical Specification 3.2.1. The MCPR(P) curves are independent of recirculation pump trip operability (Reference 8).

TABLE 5-1
Operating Limit Minimum Critical Power Ratio (OLMCPR)
(Reference 2)

		TBV In Service and RPT In Service		TBV out of Service (TBVOOS)		RPT Out of Service (RPTOOS)	
		OPT. B ($\tau=0$) ⁽¹⁾	OPT. A ($\tau=1$) ⁽¹⁾	OPT. B ($\tau=0$) ⁽¹⁾	OPT. A ($\tau=1$) ⁽¹⁾	OPT. B ($\tau=0$) ⁽¹⁾	OPT. A ($\tau=1$) ⁽¹⁾
Two Loop Operation	BOC to EOR - 2600 MWd/ST	1.32	1.35	1.37	1.40	1.40	1.51
Two Loop Operation	EOR - 2600 MWd/ST to EOC	1.37	1.40	1.42	1.45	1.46	1.63
Single Loop Operation	BOC to EOR - 2600 MWd/ST	1.44 ⁽²⁾	1.44 ⁽²⁾	1.44 ⁽²⁾	1.44 ⁽²⁾	1.44 ⁽²⁾	1.53
Single Loop Operation	EOR - 2600 MWd/ST to EOC	1.44 ⁽²⁾	1.44 ⁽²⁾	1.44	1.47	1.48	1.65

Notes:

1. When Tau does not equal 0 or 1, determine OLMCPR via linear interpolation.
2. OLMCPR limit set by the Single Loop Operation Recirculation Pump Seizure Analysis (Reference 2).
3. This table is valid for all Cycle 9 fuel types.

FIGURE 5-1

Power Dependent MCPR Limit Adjustments And Multipliers

This Figure Is Valid For All Operating Domains except TBVOOS
(References 2 and 8)




FIGURE 5-2

Power Dependent MCPR Limit Adjustments And Multipliers - TBVOOS

This Figure Is Valid For The TBVOOS
Operating Domain
(References 2 and 8)





FIGURE 5-3

Flow Dependent MCPR Limits MCPR(F)

This Figure Is Valid For All Operating Domains
(References 2 and 5)



6.0 Linear Heat Generation Rate Limits

The maximum UO₂ LHGR value for each fuel type for use in Technical Specification 3.2.4 is provided in Table 6-1 below. The LHGR is an exposure dependent value. Due to the proprietary nature of these values only the maximum UO₂ LHGR for each fuel type is listed in Table 6-1.

ARTS provides for power- and flow-dependent thermal limit multipliers, which allow for a more reliable administration of the LHGR thermal limits. There are two sets of flow-dependent LGHR multipliers for dual-loop and single-loop operation (References 2, 3, and 5). In addition, there are also two sets of power-dependent LHGR multipliers for use with the Turbine Bypass Valves in service and TBVOOS conditions (Reference 8). Section 8.0 contains the conditions for Turbine Bypass Valve Operability. The LHGR multipliers are shown in Figures 6-1 through 6-4 and are referred to by Technical Specification 3.2.4. Thermal limit monitoring must be performed with the more limiting LHGR limit resulting from the power- and flow-biased calculation. The LHGRFAC(P) curves are independent of recirculation pump trip operability (Reference 8).

**TABLE 6-1
Linear Heat Generation Rate Limits
(Reference 9)**

FUEL TYPE	MAXIMUM VALUE
GE14	13.4 kW/ft

**TABLE 6-2
LHGR Single Loop Operation (SLO) Reduction Factor
(Reference 2)**

SLO Reduction Factor ¹	0.80
-----------------------------------	-------------

¹ Applied through Figure 6-4

FIGURE 6-1

Power Dependent LHGR Multiplier LHGRFAC(P)

This Figure Is Valid For All Operating Domains except TBVOOS
(References 2 and 8)




FIGURE 6-2

Power Dependent LHGR Multiplier LHGRFAC(P) - TBVOOS

This Figure Is Valid For The TBVOOS
Operating Domain
(References 2 and 8)




FIGURE 6-3

Flow Dependent LHGR Multiplier LHGRFAC(F)

This Figure Is Valid For All Operating Domains
Excluding Single Loop Operation
(References 2, 3 and 5)





FIGURE 6-4

Flow Dependent LHGR Multiplier LHGRFAC(F) - SLO

This Figure Is Valid For Single Loop Operation
(References 2 and 5)



7.0 Control Rod Block Setpoints

Technical Specification Limiting Condition for Operation number 3.3.6 requires control rod block instrumentation channels shall be OPERABLE with their trip setpoints consistent with the values shown in the Trip Setpoint column of Technical Specification Table 3.3.6-2. The Reactor Coolant System Recirculation Flow Upscale Trip is a cycle-specific value and as such is found in Table 7-2 of this COLR. Table 7-2 lists the Nominal Trip Setpoint and Allowable Value. These setpoints are set high enough to allow full utilization of the enhanced ICF domain up to 110% of rated core flow. Additionally, the ARTS Rod Block Monitor provides for power-dependent RBM trips. The trip setpoints/allowable values and applicable RBM signal filter time constant data are shown in Table 7-1. These values are for use with Technical Specification 3.3.6.

TABLE 7-1
Rod Block Monitor Setpoints¹
(References 2 and 7)

	Nominal Trip Setpoint	Allowable Value
LTSP	121.5%	121.5%
ITSP	116.5%	116.5%
HTSP	111.0%	111.7%
DTSP	92.0%	89.0%

Notes:

1. These setpoints (with Rod Block Monitor filter time constant between 0.1 seconds and 0.55 seconds) are based on a cycle-specific rated RWE MCPR limit which is less than or equal to the minimum cycle OLMCPR (see COLR references 2 and 7).

TABLE 7-2
Reactor Coolant System Recirculation Flow Upscale Trip
(Reference 7)

Nominal Trip Setpoint	113.4%
Allowable Value	115.6%

8.0 Turbine Bypass Valve Parameters

The operability requirements for the steam bypass system for use in Technical Specifications 3.7.8 and 4.7.8.C are found in Tables 8-1 and 8-2 (Reference 5 and 10). If these requirements cannot be met, the MCPR, MCPR(P) and LHGRFAC(P) limits for inoperable Steam Bypass System, known as Turbine Bypass Valve Out Of Service, must be used.

TABLE 8-1
Turbine Bypass System Response Time
(Reference 4)

Maximum delay time before start of bypass valve opening following generation of the turbine bypass valve flow signal	0.11 sec
Maximum time after generation of a turbine bypass valve flow signal for bypass valve position to reach 80% of full flow (includes the above delay time)	0.31 sec

TABLE 8-2
Minimum Required Bypass Valves To Maintain System Operability
(Reference 8)

Reactor Power	No. of Valves in Service
$P \geq 30\%$	7

9.0 Modes Of Operation

Limerick Generating Station has been analyzed to operate with a number of operational flexibility features, including Increased Core Flow, Maximum Extended Load Line Limit, Coastdown, EOC Recirculation Pump Trip and Option A/B MCPR Limits. Limerick Generating Station has also been analyzed to operate with a number of equipment out-of-service conditions, including Turbine Bypass Valves OOS, Single Loop Operation, Feedwater Heating OOS, and Final Feedwater Temperature Reduction. Operation is allowed in any combination of these operational flexibility features and equipment out-of-service conditions, with one **EXCEPTION**, which is that Limerick may **NOT** operate with EOC-Recirculation Pump Trip out-of-service in conjunction with Turbine Bypass Valves OOS.