



SEAL INJECTION FLOW (GPM)
Figure 3.5.5-1 (page 1 of 1)
Seal Injection Flow Limits

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>SR 3.5.5.1</p> <hr/> <p style="text-align: center;">NOTE</p> <p>Not required to be performed until 4 hours after the Reactor Coolant System pressure stabilizes at ≥ 2215 psig and ≤ 2255 psig.</p> <hr/> <p>Verify manual seal injection throttle valves are adjusted to give a flow within the limits of Figure 3.5.5-1.</p>	<p>18 months</p>