



Progress Energy

Crystal River Nuclear Plant
Docket No. 50-302
Operating License No. DPR-72

Ref: ITS 5.7.1.2

March 10, 2005
3F0305-01

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

Subject: Crystal River Unit 3 – February 2005 Monthly Operating Report

Dear Sir:

Florida Power Corporation, doing business as Progress Energy Florida, Inc., hereby submits the Crystal River Unit 3 (CR-3) February 2005 Monthly Operating Report in accordance with CR-3 Improved Technical Specification 5.7.1.2.

If you have any questions regarding this submittal, please contact Mr. Sid Powell, Supervisor, Licensing and Regulatory Programs at (352) 563-4883.

Sincerely,

A handwritten signature in cursive script, appearing to read 'J. A. Franke'.

J. A. Franke
Plant General Manager

JAF/ff

Attachment

xc: Regional Administrator, Region II
Senior Resident Inspector
NRR Project Manager

Progress Energy Florida, Inc.
Crystal River Nuclear Plant
15760 W. Power Line Street
Crystal River, FL 34428

JE24

APPENDIX A
OPERATING DATA REPORT

DOCKET NO. 50-302
UNIT NAME FLCRP-3
DATE March 1, 2005
COMPLETED BY J. E. Lane *J. E. Lane*
TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD (Month/Year): February 2005

	MONTH	YEAR TO DATE	CUMULATIVE
1 DESIGN ELECTRICAL RATING (MWe-Net)	860		
2 MAXIMUM DEPENDABLE CAPACITY (MWe-Net)	838		
3 NUMBER OF HOURS REACTOR WAS CRITICAL	672.0	1,416.0	176100.3
4 NUMBER OF HOURS THE GENERATOR WAS ON LINE	672.0	1,416.0	173728.6
5 UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
6 NET ELECTRICAL ENERGY GENERATED (MWH)	578,738	1,219,255	136,371,565

APPENDIX B UNIT SHUTDOWNS

DOCKET NO. 50-302
 UNIT NAME FLCRP-3
 DATE March 1, 2005
 COMPLETED BY J. E. Lane
 TELEPHONE (352) 795-6486 x3698

REPORTING PERIOD: February 2005

No.	Date	Type F: Forced S: Scheduled	Duration (Hours)	Reason (1)	Method of Shutting Down (2)	Cause / Corrective Actions
						Comments
None						

SUMMARY:

Crystal River Unit 3 operated the entire month without an outage.

(1) Reason:

A-EQUIPMENT FAILURE (Explain)
 B-MAINTENANCE OR TEST
 C-REFUELING
 D-REGULATORY RESTRICTION
 E-OPERATOR TRAINING / LICENSE EXAMINATION
 F-ADMINISTRATIVE
 G-OPERATIONAL ERROR (Explain)
 H-OTHER (Explain)

(2) Method

1-MANUAL
 2-MANUAL TRIP / SCRAM
 3-AUTO TRIP / SCRAM
 4-CONTINUATION
 5-OTHER (Explain)