

April 20, 2005

LICENSEE: Exelon Generation Company, LLC

FACILITY: Byron Station, Unit 1

SUBJECT: SUMMARY OF MARCH 21, 2005, MEETING WITH EXELON NUCLEAR REGARDING THE PERFORMANCE OF THE 1C LOOP STOP ISOLATION VALVE AT BYRON STATION, UNIT 1 (TAC NO. MC6312)

On March 21, 2005, a Category 1 public meeting was held between the Nuclear Regulatory Commission (NRC) and representatives of Exelon Nuclear, the licensee for Byron Station, Unit 1 at the NRC Region III offices in Lisle, Illinois. The purpose of the meeting was to exchange information with the NRC regarding the licensee's decision to postpone maintenance on a cold leg loop stop isolation valve (LSIV). A list of attendees is provided as Enclosure 1.

The licensee presented information (see Enclosure 2) that included: the chronology of the decision to postpone the maintenance, the performance history of the valve, industry experience with this type of valve, analyses performed, and future plans for monitoring and inspection. The licensee also included several photographs of LSIV components and markups.

The potential degraded condition of the IC LSIV was brought to the attention of the NRC through a petition for enforcement action submitted on March 2, 2005, under 10 CFR 2.206. Information obtained at the meeting on the condition of the valve and the potential for it to generate loose parts which could find their way into the reactor coolant system, was used by the NRC in its deliberations to determine whether immediate actions needed to be taken prior to the unit restarting from the current refueling outage as requested by the petitioner. The remaining issues discussed in the 2.206 petition will be evaluated through the 2.206 petition process.

Please direct any inquiries to Donna Skay at 301-415-1322 or George Dick at 301-415-3019.

/RA/

George F. Dick, Senior Project Manager, Section 2
Project Directorate III-2
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. STN 50-454

Enclosures: 1. List of Attendees
2. Licensee Handouts

cc w/encls: See next page

April 20, 2005

LICENSEE: Exelon Generation Company, LLC

FACILITY: Byron Station, Unit 1

SUBJECT: SUMMARY OF MARCH 21, 2005, MEETING WITH EXELON NUCLEAR REGARDING THE PERFORMANCE OF THE 1C LOOP STOP ISOLATION VALVE AT BYRON STATION, UNIT 1 (TAC NO. MC6312)

On March 21, 2005, a Category 1 public meeting was held between the Nuclear Regulatory Commission (NRC) and representatives of Exelon Nuclear, the licensee for Byron Station, Unit 1 at the NRC Region III offices in Lisle, Illinois. The purpose of the meeting was to exchange information with the NRC regarding the licensee's decision to postpone maintenance on a cold leg loop stop isolation valve (LSIV). A list of attendees is provided as Enclosure 1.

The licensee presented information (see Enclosure 2) that included: the chronology of the decision to postpone the maintenance, the performance history of the valve, industry experience with this type of valve, analyses performed, and future plans for monitoring and inspection. The licensee also included several photographs of LSIV components and markups.

The potential degraded condition of the IC LSIV was brought to the attention of the NRC through a petition for enforcement action submitted on March 2, 2005, under 10 CFR 2.206. Information obtained at the meeting on the condition of the valve and the potential for it to generate loose parts which could find their way into the reactor coolant system, was used by the NRC in its deliberations to determine whether immediate actions needed to be taken prior to the unit restarting from the current refueling outage as requested by the petitioner. The remaining issues discussed in the 2.206 petition will be evaluated through the 2.206 petition process.

Please direct any inquiries to Donna Skay at 301-415-1322 or George Dick at 301-415-3019.

/RA/

George F. Dick, Senior Project Manager, Section 2
Project Directorate III-2
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. STN 50-454

- Enclosures: 1. List of Attendees
- 2. Licensee Handouts

cc w/encls: See next page

DISTRIBUTION

PUBLIC	RidsNrrACRS	RidsNrrDlpm [TMarsh,JLyons]	FAkstulewicz
PDI-1 R/F	RidsNrrDlpmLpdiiii2	RidsNrrLAPCoates	TMensah
FOrr	GRoach,RIII	DKernRIII	RidsNrrPMGDick
CMiller,Rgl	RidsNrrOgcRp	JDixon-Herrity,RIV	RidsRgn3Mailcenter
RidsNrrPMKJabbour	JSchiffgens	RidsNrrDipmlrob	RidsNrrLASLittle
RidsNrrPMDSkay	DPassehl,RIII	AMohseni	RidsNrrDlpmLpdiiii
RSkokowski	DTERao	TScarborough,RIII	SCollins,RI
AStone,RIII	MSatorius,RIII	RidsNrrDlpmLpdi1	AGarmoe,RIII
RidsNrrDlpmLpdi	UShoop	BQuigley	SBrock, OGC

Package No.: ML051170104

Accession No.: ML050820530

Enclosure 2: ML050810513

OFFICE	PDI-1/PM	PDIII-2/LA	PDIII-2/SC
NAME	GDick	PCoates	GSuh
DATE	04/19/05	4/19/05	4/20/05

OFFICIAL RECORD COPY

Byron/Braidwood Stations

cc:

Dwain W. Alexander, Project Manager
Westinghouse Electric Corporation
Energy Systems Business Unit
Post Office Box 355
Pittsburgh, PA 15230-0355

Joseph Gallo
Gallo & Ross
1025 Connecticut Ave., NW, Suite 1014
Washington, DC 20036

Howard A. Learner
Environmental Law and Policy
Center of the Midwest
35 East Wacker Dr., Suite 1300
Chicago, IL 60601-2110

U.S. Nuclear Regulatory Commission
Byron Resident Inspectors Office
4448 N. German Church Road
Byron, IL 61010-9750

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
801 Warrenville Road
Lisle, IL 60532-4351

Ms. Lorraine Creek
RR 1, Box 182
Manteno, IL 60950

Chairman, Ogle County Board
Post Office Box 357
Oregon, IL 61061

Mrs. Phillip B. Johnson
1907 Stratford Lane
Rockford, IL 61107

George L. Edgar
Morgan, Lewis and Bockius
1800 M Street, NW
Washington, DC 20036-5869

Attorney General
500 S. Second Street
Springfield, IL 62701

Illinois Emergency Management
Agency
Division of Disaster Assistance &
Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Byron Station Plant Manager
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

Site Vice President - Byron
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

U.S. Nuclear Regulatory Commission
Braidwood Resident Inspectors Office
35100 S. Rt. 53, Suite 79
Braceville, IL 60407

Chairman
Will County Board of Supervisors
Will County Board Courthouse
Joliet, IL 60434

Braidwood Station Plant Manager
Exelon Generation Company, LLC
35100 S. Rt. 53, Suite 84
Braceville, IL 60407-9619

Ms. Bridget Little Rorem
Appleseed Coordinator
117 N. Linden Street
Essex, IL 60935

Mr. Barry Quigley
3512 Louisiana
Rockford, IL 61108

Byron/Braidwood Stations

cc:

Document Control Desk - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Braidwood, Byron
and LaSalle
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Site Vice President - Braidwood
Exelon Generation Company, LLC
35100 S. Rt. 53, Suite 84
Braceville, IL 60407-9619

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President of Operations - Mid-West
Pressurized Water Reactors
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director - Licensing and Regulatory
Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Regulatory Assurance Manager - Braidwood
Exelon Generation Company, LLC
35100 S. Rt. 53, Suite 84
Braceville, IL 60407-9619

Regulatory Assurance Manager - Byron
Exelon Generation Company, LLC
4450 N. German Church Road
Byron, IL 61010-9794

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and
Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

MEETING BETWEEN NRC AND

EXELON NUCLEAR

ATTENDANCE LIST

MARCH 21, 2005

NRC

D. Skay, NRR
T. Scarbrough, NRR
D. Terao, NRR
J. Lyons, NRR
R. Skokowski, Region III
A. Stone, Region III
D. Passehl, Region III
M. Satorius, Region III
A. Garmoe, Region III
G. Roach, Region III
A. Mohseni, NRR (by phone)
G. Suh, NRR (by phone)
S. Brock, OGC (by phone)
F. Orr, NRR (by phone)
U. Shoop, OEDO (by phone)
G. Dick, NRR (by phone)
F. Akstulewicz, NRR (by phone)

LICENSEE

B. Smith, Exelon
P. Shier, Exelon
T. Fluck, Exelon
J. Bauer, Exelon
K. Jury, Exelon
J. Benjamin, Exelon
B. Adams, Exelon
W. Grundmann, Exelon
S. Kuczynski, Exelon
D. Chrzanowski, Exelon
T. Matty, Westinghouse

OTHERS

A. Settles, Illinois Bureau of Nuclear Safety
B. Quigley, self