

March 22, 2005

Mr. David A. Christian
Sr. Vice President and Chief Nuclear Officer
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060-6711

SUBJECT: SURRY POWER STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS
ON ELIMINATION OF REQUIREMENTS FOR HYDROGEN MONITORS USING
THE CONSOLIDATED LINE ITEM IMPROVEMENT PROCESS (TAC NOS.
MC4393 AND MC4394)

Dear Mr. Christian:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment Nos. 239 and 238 to Renewed Facility Operating License Nos. DPR-32 and DPR-37 for the Surry Power Station, Unit Nos. 1 and 2. The amendments change the Technical Specifications (TS) in response to your letter dated September 8, 2004.

These amendments revise the TS by eliminating the requirements associated with hydrogen monitors. The changes support the implementation of a revision to Title 10 of the *Code of Federal Regulations* (10 CFR), Section 50.44, "Combustible gas control for nuclear power reactors." A notice of availability for this TS improvement using the consolidated line item improvement process was published in the *Federal Register* on September 25, 2003 (68 FR 55416).

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

Stephen Monarque, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-280 and 50-281

Enclosures:

1. Amendment No. 239 to DPR-32
2. Amendment No. 238 to DPR-37
3. Safety Evaluation

cc w/encls: See next page

March 22, 2005

Mr. David A. Christian
Sr. Vice President and Chief Nuclear Officer
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060-6711

SUBJECT: SURRY POWER STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS
ON ELIMINATION OF REQUIREMENTS FOR HYDROGEN MONITORS USING
THE CONSOLIDATED LINE ITEM IMPROVEMENT PROCESS (TAC NOS.
MC4393 AND MC4394)

Dear Mr. Christian:

The U.S. Nuclear Regulatory Commission has issued the enclosed Amendment Nos. 239 and 238 to Renewed Facility Operating License Nos. DPR-32 and DPR-37 for the Surry Power Station, Unit Nos. 1 and 2. The amendments change the Technical Specifications (TS) in response to your letter dated September 8, 2004.

These amendments revise the TS by eliminating the requirements associated with hydrogen monitors. The changes support the implementation of a revision to Title 10 of the *Code of Federal Regulations* (10 CFR), Section 50.44, "Combustible gas control for nuclear power reactors." A notice of availability for this TS improvement using the consolidated line item improvement process was published in the *Federal Register* on September 25, 2003 (68 FR 55416).

A copy of the Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

/RA/

Stephen Monarque, Project Manager, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-280 and 50-281

Enclosures:

1. Amendment No. 239 to DPR-32
 2. Amendment No. 238 to DPR-37
 3. Safety Evaluation
- cc w/encls: See next page
Distribution: See next page

Package No.: ML050900123

TS: ML050900345

ADAMS Accession No.: ML050840168

NRR-058

OFFICE	PDIV-1/PE	PDIV-1/PM	PDII-1/PM	PDII-2/LA	OGC	PDII-1/SC
NAME	MThorpe-Kavanaugh	WReckley	SMonarque	EDunnington	WDR(nlo)	JNakoski
DATE	1/19/2005	2/4/2005	2/2/2005	2/1/2005	2/4/2005	3/22/2005

OFFICIAL RECORD COPY

SUBJECT: SURRY POWER STATION, UNITS 1 AND 2 - ISSUANCE OF AMENDMENTS
ON ELIMINATION OF REQUIREMENTS FOR HYDROGEN MONITORS USING
THE CONSOLIDATED LINE ITEM IMPROVEMENT PROCESS (TAC NOS.
MC4393 AND MC4394)

DATED: March 22, 2005

DISTRIBUTION:

PUBLIC

PDII-1 R/F

RidsNrrDlpmLpdii (EHackett)

RidsNrrDlpmLpdii-1 (JNakoski)

RidsNrrPMLSMonarque

EDunnington (Hard Copy)

RidsOgcRp

RidsAcrsAcnwMailCenter

G. Hill (4), TWFN, 5/C/3

TBoyce

RidsRgn2MailCenter (K. Landis)

RidsNrrDlpmDpr

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-280

SURRY POWER STATION, UNIT NO. 1

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 239
Renewed License No. DPR-32

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated September 8, 2004, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Renewed Facility Operating License No. DPR-32 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 239, are hereby incorporated in the renewed license.

The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

John A. Nakoski, Chief, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 22, 2005

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-281

SURRY POWER STATION, UNIT NO. 2

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 238
Renewed License No. DPR-37

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated September 8, 2004, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Renewed Facility Operating License No. DPR-37 is hereby amended to read as follows:

(B) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 238, are hereby incorporated in the renewed license.

The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 60 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

/RA/

John A. Nakoski, Chief, Section 1
Project Directorate II
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 22, 2005

ATTACHMENT TO
LICENSE AMENDMENT NO. 239 TO
RENEWED FACILITY OPERATING LICENSE NO. DPR-32
LICENSE AMENDMENT NO. 238 TO
RENEWED FACILITY OPERATING LICENSE NO. DPR-37
DOCKET NOS. 50-280 AND 50-281

Replace the following pages of the Appendix A Technical Specifications with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Remove Pages

TS 3.7-2
TS 3.7-3
TS 4.1-9d

Insert Pages

TS 3.7-2
TS 3.7-3
TS 4.1-9d

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 239 TO

RENEWED FACILITY OPERATING LICENSE NO. DPR-32

AND

AMENDMENT NO. 238 TO RENEWED FACILITY OPERATING LICENSE NO. DPR-37

VIRGINIA ELECTRIC AND POWER COMPANY

SURRY POWER STATION, UNIT NOS. 1 AND 2

DOCKET NOS. 50-280 AND 50-281

1.0 INTRODUCTION

By letter dated September 8, 2004 (ADAMS Accession No. ML042650363), the Virginia Electric and Power Company (the licensee) submitted a request for changes to the Surry Power Station, Units 1 and 2, Technical Specifications (TS). The proposed changes would delete the TS requirements associated with hydrogen monitors.

The Nuclear Regulatory Commission (NRC) has revised 10 CFR 50.44, "Standards for Combustible Gas Control System in Light-Water-Cooled Power Reactors." The amended standards eliminated the requirements for hydrogen recombiners and relaxed the requirements for hydrogen and oxygen monitoring. In letters dated December 17, 2002, and May 12, 2003, the Nuclear Energy Institute (NEI) Technical Specification Task Force (TSTF) proposed to remove requirements for hydrogen recombiners and hydrogen and oxygen monitors from the standard technical specifications (STS) (NUREGs 1430 - 1434) on behalf of the industry to incorporate the amended standards. This proposed change is designated TSTF-447.

The NRC staff prepared a model safety evaluation (SE) for the elimination of requirements from TS for containment hydrogen recombiners and hydrogen and oxygen monitors. Public comment was solicited (67 FR 50374, published August 2, 2002) in accordance with the Consolidated Line Item Improvement Process (CLIP). The use of the CLIP in this matter is intended to help the NRC to efficiently process amendments that propose to remove the hydrogen recombiner and hydrogen and oxygen monitor requirements from TS. Licensees of nuclear power reactors to which this model applies were informed (68 FR 55416; September 25, 2003) that they could request amendments conforming to the model and, in such requests, should confirm the applicability of the SE to their reactors and provide the requested plant-specific verifications and commitments.

Enclosure

2.0 REGULATORY EVALUATION

Regulatory Issue Summary 2000-06, "Consolidated Line Item Improvement Process for Adopting Standard Technical Specification Changes for Power Reactors," was issued on March 20, 2000. The CLIIIP is intended to improve the efficiency of NRC licensing processes. This is accomplished by processing proposed changes to the STS in a manner that supports subsequent license amendment applications. The CLIIIP includes an opportunity for the public to comment on proposed changes to the STS following a preliminary assessment by the NRC staff and a finding that the change will likely be offered for adoption by licensees. The NRC staff evaluates any comments received for a proposed change to the STS and either reconsiders the change or proceeds with announcing the availability of the change for proposed adoption by licensees. Those licensees opting to apply for the subject change to TS are responsible for reviewing the NRC staff's evaluation, referencing the applicable technical justifications, and providing any necessary plant-specific information. Each amendment application made in response to the notice of availability would be processed and noticed in accordance with applicable rules and NRC procedures.

The Commission's regulatory requirements related to the content of TS are set forth in 10 CFR 50.36. This regulation requires that the TS include items in five specific categories. These categories include: 1) safety limits, limiting safety system settings, and limiting control settings; 2) limiting conditions for operation (LCOs); 3) surveillance requirements; 4) design features; and 5) administrative controls. However, the regulation does not specify the particular TS to be included in a plant's license.

Additionally, 10 CFR 50.36(c)(2)(ii) sets forth four criteria to be used in determining whether an LCO is required to be included in the TS. These criteria are as follows:

1. Installed instrumentation that is used to detect, and indicate in the control room, a significant abnormal degradation of the reactor coolant pressure boundary.
2. A process variable, design feature, or operating restriction that is an initial condition of a design-basis accident or transient analysis that either assumes the failure of or presents a challenge to the integrity of a fission product barrier.
3. A structure, system, or component that is part of the primary success path and which functions or actuates to mitigate a design-basis accident or transient that either assumes the failure of or presents a challenge to the integrity of a fission product barrier.
4. A structure, system, or component which operating experience or probabilistic risk assessment has shown to be significant to public health and safety.

Existing LCOs and related surveillances included as TS requirements that satisfy any of the criteria stated above must be retained in the TS. Those TS requirements that do not satisfy these criteria may be relocated to other licensee-controlled documents.

As part of the rulemaking that revised 10 CFR 50.44, the Commission retained requirements for ensuring a mixed atmosphere, inerting Mark I and II containments, and providing hydrogen

control systems capable of accommodating an amount of hydrogen generated from a metal-water reaction involving 75 percent of the fuel cladding surrounding the active fuel region in Mark III and ice condenser containments. The Commission eliminated the design-basis loss-of-coolant accident (LOCA) hydrogen release from 10 CFR 50.44 and consolidated the requirements for hydrogen and oxygen monitoring to 10 CFR 50.44 while relaxing safety classifications and licensee commitments to certain design and qualification criteria. The Commission also relocated without change the hydrogen control requirements in 10 CFR 50.34(f) to 10 CFR 50.44 and the high point vent requirements from 10 CFR 50.44 to 10 CFR 50.46a.

3.0 TECHNICAL EVALUATION

The ways in which the requirements and recommendations for combustible gas control were incorporated into the licensing bases of commercial nuclear power plants varied as a function of when plants were licensed. Plants that were operating at the time of the Three Mile Island (TMI), Unit 2 accident are likely to have been the subject of confirmatory orders that imposed the combustible gas control functions described in NUREG-0737, "Clarification of TMI Action Plan Requirements," as obligations. The issuance of plant-specific amendments to adopt these changes, which would remove hydrogen recombiner and hydrogen and oxygen monitoring controls from TS, supersede the combustible gas control specific requirements imposed by post-TMI confirmatory orders.

3.1 Hydrogen Monitoring Equipment

Section 50.44(b)(1), the STS, and plant-specific TS currently contain requirements for monitoring hydrogen. Licensees have also made commitments to design and qualification criteria for hydrogen monitors in Item II.F.1, Attachment 6 of NUREG-0737 and Regulatory Guide (RG) 1.97, "Instrumentation for Light-Water-Cooled Nuclear Power Plants to Assess Plant and Environs Conditions During and Following an Accident." The hydrogen monitors are required to assess the degree of core damage during a beyond design-basis accident and confirm that random or deliberate ignition has taken place. If an explosive mixture that could threaten containment integrity exists during a beyond-design-basis accident, then other severe accident management strategies, such as purging and/or venting, would need to be considered. The hydrogen monitors are needed to implement these severe accident management strategies.

With the elimination of the design-basis LOCA hydrogen release, hydrogen monitors are no longer required to mitigate design-basis accidents and, therefore, the hydrogen monitors do not meet the definition of a safety-related component as defined in 10 CFR 50.2. RG 1.97 recommends classifying the hydrogen monitors as Category 1. RG 1.97 Category 1 is intended for key variables that most directly indicate the accomplishment of a safety function for design-basis accident events and, therefore, are items usually addressed within TS. As part of the rulemaking to revise 10 CFR 50.44, the Commission found that the hydrogen monitors no longer meet the definition of Category 1 in RG 1.97. The Commission concluded that Category 3, as defined in RG 1.97, is an appropriate categorization for the hydrogen monitors because the monitors are required to diagnose the course of beyond-design-basis accidents. Hydrogen monitoring is not the primary means of indicating a significant abnormal degradation of the reactor coolant pressure boundary. Section 4 of Attachment 2 to SECY-00-0198, "Status Report on Study of Risk-Informed Changes to the Technical Requirements of 10 CFR Part 50

(Option 3) and Recommendations on Risk-Informed Changes to 10 CFR 50.44 (Combustible Gas Control),” found that the hydrogen monitors were not risk significant. Therefore, the NRC staff finds that hydrogen monitoring equipment requirements no longer meet any of the four criteria in 10 CFR 50.36(c)(2)(ii) for retention in TS and, therefore, may be relocated to other licensee-controlled documents. However, because the monitors are required to diagnose the course of beyond-design-basis accidents, each licensee should verify that it has, and make a regulatory commitment to maintain, a hydrogen monitoring system capable of diagnosing beyond-design-basis accidents.

The elimination of Post-Accident Sampling System requirements from some plant-specific TS (and associated CLIP notices) indicated that during the early phases of an accident, safety-grade hydrogen monitors provide an adequate capability for monitoring containment hydrogen concentration. The NRC staff has subsequently concluded that Category 3 hydrogen monitors also provide an adequate capability for monitoring containment hydrogen concentration during the early phases of an accident.

4.0 VERIFICATIONS AND COMMITMENTS

As requested by the NRC staff in the notice of availability for this TS improvement, the licensee has addressed the following plant-specific verifications and commitments.

- 4.1 Each licensee should verify that it has, and make a regulatory commitment to maintain, a hydrogen monitoring system capable of diagnosing beyond-design-basis accidents.

The licensee has verified that it has a hydrogen monitoring system capable of diagnosing beyond-design-basis accidents. The licensee has committed to maintain the hydrogen monitors within its Technical Requirements Manual. The licensee will implement this commitment within 60 days of issuance of the amendment.

The NRC staff finds that reasonable controls for the implementation and for subsequent evaluation of proposed changes pertaining to the above regulatory commitments are provided by the licensee’s administrative processes, including its commitment management program. Should the licensee choose to incorporate a regulatory commitment into the emergency plan, final safety analysis report, or other document with established regulatory controls, the associated regulations would define the appropriate change-control and reporting requirements. The NRC staff has determined that the commitments do not warrant the creation of regulatory requirements that would require prior NRC approval of subsequent changes. The NRC staff has agreed that NEI 99-04, Revision 0, “Guidelines for Managing NRC Commitment Changes,” provides reasonable guidance for the control of regulatory commitments made to the NRC staff. (See Regulatory Issue Summary 2000-17, “Managing Regulatory Commitments Made by Power Reactor Licensees to the NRC Staff,” dated September 21, 2000.) The commitments should be controlled in accordance with the industry guidance or comparable criteria employed by a specific licensee. The NRC staff may choose to verify the implementation and maintenance of these commitments in a future inspection or audit.

5.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Virginia State official was notified of the proposed issuance of the amendments. The State official had no comment.

6.0 ENVIRONMENTAL CONSIDERATION

The amendments change a requirement with respect to installation or use of a facility component located within the restricted area as defined in 10 CFR Part 20 and changes surveillance requirements. The NRC staff has determined that the amendments involve no significant increase in the amounts, and no significant change in the types, of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendments involve no significant hazards consideration, and there has been no public comment on such finding (70 FR 2902). Accordingly, the amendments meet the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b) no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendments.

7.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of these amendments will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributor: W. Reckley

Date: March 22, 2005

Surry Power Station, Units 1 & 2

cc:

Ms. Lillian M. Cuoco, Esq.
Senior Counsel
Dominion Resources Services, Inc.
Building 475, 5th Floor
Rt. 156, Rope Ferry Road
Waterford, Connecticut 06385

Mr. Richard H. Blount, II
Site Vice President
Surry Power Station
Virginia Electric and Power Company
5570 Hog Island Road
Surry, Virginia 23883-0315

Senior Resident Inspector
Surry Power Station
U. S. Nuclear Regulatory Commission
5850 Hog Island Road
Surry, Virginia 23883

Chairman
Board of Supervisors of Surry County
Surry County Courthouse
Surry, Virginia 23683

Dr. W. T. Lough
Virginia State Corporation Commission
Division of Energy Regulation
Post Office Box 1197
Richmond, Virginia 23218

Dr. Robert B. Stroube, MD, MPH
State Health Commissioner
Office of the Commissioner
Virginia Department of Health
Post Office Box 2448
Richmond, Virginia 23218

Office of the Attorney General
Commonwealth of Virginia
900 East Main Street
Richmond, Virginia 23219

Mr. Chris L. Funderburk, Director
Nuclear Licensing & Operations Support
Dominion Resources Services, Inc.
Innsbrook Technical Center
5000 Dominion Blvd.
Glen Allen, Virginia 23060-6711

Mr. Jack M. Davis
Site Vice President
North Anna Power Station
Virginia Electric and Power Company
Post Office Box 402
Mineral, Virginia 23117-0402

Mr. William R. Matthews
Vice President - Nuclear Operations
Virginia Electric and Power Company
Innsbrook Technical Center
5000 Dominion Boulevard
Glen Allen, Virginia 23060-6711