

Comments on the North Anna Draft Environmental Impact Statement  
Public Meeting February 17, 2005

These written comments were provided at the public meeting and will be entered into the transcript for the meeting. The comments will be treated as if the individual actually spoke at the meeting.

Name:

Comment:

When I was part of the construction efforts for Byron Nuclear Plants 1 & 2, their natural draft cooling ~~towers~~ towers were praised & touted as the largest & most northern towers yet constructed. And fully capable of handling the waste heat from the 2 plants.

One ~~unrealized~~ issue that they didn't take into account, however, was the impact of humid air - result was that at ~~most~~ the hottest & most humid (August) days (when the power ~~was~~ was most needed), Com Ed had to back down their outputs by about 5-8% for those days. Towers didn't

work as well as planned. So (while I support the ideas of Dominion),

I believe we should carefully re-visit the calculations on heat removal - just to make sure we're accounting for the relevant factors & make sure there's still some margin.

John Daily

Hanover Co. Resident