

Plant Status Report

Plant: Point Beach Nuclear Plant

Date: Wednesday, May 05, 2004

Operations Report (Summary of Last 24 Hours of Operations):
Unit 1 is in refueling shutdown (Mode 6). Unit 2 is at 100% power.

Days Without LTA: 591

Homeland Security Condition: Yellow

Unit 1				Unit 2			
PWR Mode	PWR Level	MWE (Gross)	MWE (Net)	PWR Mode	PWR Level	MWE (Gross)	MWE (Net)
6	0%	0	0	1	100%	542.1	520.1
Days On Line: 0		Days Since Last Reactor Trip: 292		Days On Line: 166		Days Since Last Reactor Trip: 298	

Technical Specification Action Conditions

Item	Unit	Condition	Out of Service		Length (Hr/Days)	Tech Spec Number	Expires		Responsibility	Equip Expected RTS Date
			Date	Time			Date	Time		
Source Range Audible Count Rate	1	Out of service.	5/3/04	2221	Immediate	3.9.2.C	No Expiration	None	B. Dungan	5/5/04
2RC-508, U2C RMW Supply	2	Out of service.	11/9/03	0749	31 Days	3.6.3.A	5/23/04	1600	M. Rosseau	8/27/04
IOPS	2	Out of service.	5/3/04	2123	72 Hours	TLCO 3.7.6	5/5/04	1700	5/5/04	B. Dungan

Major Equipment Out of Service or Degraded

Item	Unit	Condition	Date	Time	Work Order Number	Due Date	Responsibility
NONE							

Operational Problems / Concerns

Item	Unit	Condition	Actions Needed	Due Date	Responsibility
C-01 Buzzer	0	Buzzer doesn't work, no sound.	Replace buzzer.	5/4/04	J. Helbing
2RC-508, U2C Reactor Makeup Supply	2	Valve comes off shut seat momentarily when RMW pump starts.	Coordinate plan with Plant Manager.	5/7/04	C. Hill
Unit 2, Excess Letdown Flow	2	Inadequate excess letdown flow.	Open and inspect, 2CV-285.	5/7/04	N. Stuart
2RE-215, 2HX-46 Air Ejector Gas Monitor	2	Elevated indication, temperature related.	4 step action plan is developed. Scheduled completion is 5/14/04.	5/14/04	B. Carberry
2TE-2259, 2P-28B SGFP Discharge Temperature Element	2	Minor steam leak.	Prepare work package to repair leak weekend of 05/22/04. WO Initiation Tag #204297	5/7/04	J. Brander

Aggregate Review of Issues

Item	Unit	Condition	Actions Planned	Due Date	Responsibility
NONE					

Plant Status Report

Reportable Events
Inadvertent TSAC 3.9.2.C, Source Range Audible Count Rate

Outstanding Operability Determinations
NONE
Protected Equipment
2P-29, Aux Feedwater Turbine-Driven Pump / P-38A/B Aux Feedwater Motor-Driven Pump / P-32A,B,C,D,E,F Service Water Pumps / K-2A/B Instrument Air Compressors / K-3A/B Service Air Compressors / G-02/G-03/G-04 Emergency Diesel Generators / Unit 1 Nozzle Dam Panels and Associated Equipment
Load Changes (Planned or Unplanned)
NONE

Reactor Coolant System Leakage		
	Unit 1	Unit 2
Unidentified (gpm)	0 (No leak rate determined due to draindown)	0.12
Identified (gpm)	0	0.03
Major Tests and Evolutions Scheduled in Next 24 Hours		
Unit 2, 2RMP 9071-1, 2RMP 9071-2, Train A/B undervoltage relays.		
Unit 2, 2ICP 2.1, reactor protection and safeguards analog. (White)		
Unit 2, 2P-11A, component cooling water pump maintenance.		
U#2, 2P-15R, SI PUMP, MAINT.		