

1.62E-4 = 5.1 x B/L YELLOW  
AFW P-38A, G01, 1B42, SW VLV, U#1 S/D

# Plant Status Report

Plant: Point Beach Nuclear Plant

Date: Thursday, May 06, 2004

Operations Report (Summary of Last 24 Hours of Operations):  
Unit 1 is in refueling shutdown (Mode 6). Unit 2 is at 100% power.

Days Without LTA: 592

Homeland Security Condition: Yellow

Unit 1				Unit 2			
PWR Mode	PWR Level	MWE (Gross)	MWE (Net)	PWR Mode	PWR Level	MWE (Gross)	MWE (Net)
6	0%	0	0	1	100%	544.2	522.0

Days On Line: 0      Days Since Last Reactor Trip: 293      Days On Line: 167      Days Since Last Reactor Trip: 299

### Technical Specification Action Conditions

Item	Unit	Condition	Out of Service		Length (Hr/Days)	Tech Spec Number	Expires		Responsibility	Equip Expected RTS Date
			Date	Time			Date	Time		
Source Range Audible Count Rate	1	Out of service. RTS 05/06 01:02	5/3/04	2221	Immediate	3.9.2.C	No Expiration	None	B. Dungan	5/5/04
1B-42, PAB Safeguards MCC	1	Out of service.	5/4/04	1619	No Expiration	3.8.9.A	No Expiration	None	J. Brander	5/8/04
2RC-508, U2C RMW Supply	2	Out of service.	11/9/03	0749	31 Days	3.6.3.A	5/23/04	1600	M. Rosseau	8/27/04
IOPS	2	Out of service.	5/3/04	2123	72 Hours	TLCO 3.7.6	5/6/04	2123	B. Dungan	5/5/04

### Major Equipment Out of Service or Degraded

Item	Unit	Condition	Date	Time	Work Order Number	Due Date	Responsibility
G-01, Emergency Diesel Generator	0	Out of service due to 1B-42 MCC work.	5/4/04	2238	IWP 01-128*E-BR	5/8/04	J. Brander
1T-6A, Boric Acid Tank W/Heater	1	Out of service. Needs recirc and sample.	5/5/04	0000	None	5/5/04	Operations

### Operational Problems / Concerns

Item	Unit	Condition	Actions Needed	Due Date	Responsibility
C-01 Buzzer	0	Buzzer doesn't work, no sound.	Replace buzzer.	5/4/04	J. Helbing
2RC-508, U2C Reactor Makeup Supply	2	Valve comes off shut seat momentarily when RMW pump starts.	Coordinate plan with Plant Manager.	5/7/04	C. Hill
Unit 2, Excess Letdown Flow	2	Inadequate excess letdown flow.	Open and inspect, 2CV-285.	5/7/04	N. Stuart
2RE-215, 2HX-46 Air Ejector Gas Monitor	2	Elevated indication, temperature related.	4 step action plan is developed. Scheduled completion is 5/14/04.	5/14/04	B. Carberry
2TE-2259, 2P-28B SGFP Discharge Temperature Element	2	Minor steam leak.	WO 0408028. Prepare work package to repair leak weekend of 05/22/04.	5/7/04	J. Brander
2P-15B, Safety Injection Pump	2	Missing setscrews on retaining nut - operable but degraded.	WO 0408109. Install setscrews.	5/5/04	N. Stuart

# Plant Status Report

Aggregate Review of Issues					
Item	Unit	Condition	Actions Planned	Due Date	Responsibility
NONE					

Reportable Events
AOP-13C, Severe Weather Entry. Courtesy call to NRC.

Outstanding Operability Determinations
NONE
Protected Equipment
2P-29, Aux Feedwater Turbine-Driven Pump / P-38A/B Aux Feedwater Motor-Driven Pump / P-32A,B,C,D,E,F Service Water Pumps / K-2A/B Instrument Air Compressors / K-3A/B Service Air Compressors / G-02/G-03/G-04 Emergency Diesel Generators / Unit 1 Nozzle Dam Panels and Associated Equipment
Load Changes (Planned or Unplanned)
NONE

Reactor Coolant System Leakage		
	Unit 1	Unit 2
Unidentified (gpm)	0 (No leak rate determined due to draindown)	0.09
Identified (gpm)	0	0.03
Major Tests and Evolutions Scheduled in Next 24 Hours		
Unit 2, 2RMP 9071-1, 2RMP 9071-2, Train A/B undervoltage relays. (Pending)		
Unit 2, 2P-15B, safety injection pump, repair of setscrews.		
IT-07D, E, F, G, service water pump testing.		
TS-EP-001, power availability verifications.		