



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

MAR 23 2005

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

Gentlemen:

In the Matter of) Docket No.50-390
Tennessee Valley Authority)

WATTS BAR NUCLEAR PLANT (WBN) UNIT 1 - CYCLE 6 STEAM GENERATOR
(SG) TUBE INSPECTION - 15 DAY REPORT

This letter fulfills the reporting requirements contain in Technical Specification 5.9.9, *SG Tube Inspection Report*. In accordance with Technical Specification 5.9.9, listed below are the number of steam generator tubes that were plugged or sleeved during the WBN Unit 1 Cycle 6 refueling outage.

RESULTS OF WBN SG INSERVICE INSPECTION		
SG Number	Number of Tubes	
	Plugged	Sleeved
1	124	118
2	183	28
3	120	0
4	179	134
Totals	606	280

A047

U.S. Nuclear Regulatory Commission
Page 2

MAR 23 2005

There are no regulatory commitments associated with this submittal. If you have any questions concerning this letter, please contact me at (423) 365-1824.

Sincerely,



P. L. Pace
Manager, Site Licensing
and Industry Affairs

Cc: NRC Resident Inspector
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

Mr. D. V. Pickett, Project Manager
U.S. Nuclear Regulatory Commission
MS O8G9
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2738

U.S. Nuclear Regulatory Commission
Region II
Sam Nunn Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303