

April 29, 2005

LICENSEE: Omaha Public Power District (OPPD)
FACILITY: Fort Calhoun Station, Unit 1
SUBJECT: SUMMARY OF MEETING TO DISCUSS RESUBMITTAL OF THE
MEASUREMENT UNCERTAINTY UPRATE FOR FORT CALHOUN STATION

On March 3, 2005, the Nuclear Regulatory Commission (NRC) staff conducted a closed meeting with OPPD to discuss its resubmittal of the measurement uncertainty uprate (MUR). A list of attendees is attached. The non-proprietary version of the presentation slides are in ADAMS under Accession No. ML050630097.

During the implementation of the MUR in January 2004, OPPD experienced discrepancies in the main feedwater flow readings from the CROSSFLOW system. As a result OPPD was not able to implement the CROSSFLOW system and requested to have the authorized power level returned to the level prior to the approval of the MUR amendment. OPPD with its contractors have resolved the problems with the use of the CROSSFLOW system at the Fort Calhoun Station. OPPD discussed its proposed solution to the discrepancies found in the flow measurements. OPPD stated it will resubmit the MUR amendment in late March 2005. The amendment will justify a new power level based on the revised analysis and testing performed on the CROSSFLOW system. OPPD noted that they believe the new proposal, in general, will be bounded by the previous approval, and therefore the NRC staff review can be limited only to the proposed changes from the previous amendment request. The NRC staff noted that this approach seems reasonable but they will need the submittal to make that determination.

As a result of the meeting the NRC staff requested several actions of OPPD to support our review.

The staff requested that OPPD provide the following:

1. Provide the CROSSFLOW feedwater flow uncertainty calculation for NRC review.
2. The license amendment request (LAR) should include an explanation of the phrase "fully developed flow" as noted in CENPD-397-P-A, Revision 1, as it has been replaced by the phrase "stable flow where the fluid is also subcooled and isothermal."
3. The LAR should include the basis for concluding that the requested 1.5 percent uprate is bounded by analyses previously submitted and approved.

In addition the NRC staff agreed to provide the following:

1. Verify that a global bounding statement for a 1.5 percent uprate will be acceptable.
2. Verify that OPPD's implementation of ISA S67.04.02 (Method 3) was adequately addressed in the previous request for additional information responses and the safety evaluation report for Amendment 224. (Note: these documents were References 5, 6, and 7 in the draft LAR).

The NRC staff thanked OPPD for the presentation and asked OPPD to keep us informed of the progress of the amendment.

/RA/

Alan Wang, Project Manager, Section 2
Project Directorate IV
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket No. 50-285

Attachment: List of Meeting Attendees

cc w/att: See next page

In addition the NRC staff agreed to provide the following:

1. Verify that a global bounding statement for a 1.5 percent uprate will be acceptable.
2. Verify that OPPD's implementation of ISA S67.04.02 (Method 3) was adequately addressed in the previous request for additional information responses and the safety evaluation report for Amendment 224. (Note: these documents were References 5, 6, and 7 in the draft LAR).

The NRC staff thanked OPPD for the presentation and asked OPPD to keep us informed of the progress of the amendment.

/RA/

Alan Wang, Project Manager, Section 2
 Project Directorate IV
 Division of Licensing Project Management
 Office of Nuclear Reactor Regulation

Docket No. 50-285

Attachment: List of Meeting Attendees

cc w/att: See next page

DISTRIBUTION:

PUBLIC	TMensah
PDIV-2 Reading	RTadessee
RidsNrrPMAWang	RidsRgn4MailCenter(MHay)
RidsOgcRp	SMiranda
RidsAcrcAcnwMailCenter	EMarinos
RidsNrrDlpm(TMarsH/JLyons)	IAhmed
RidsNrrDlpmPdiv(HBerkow)	CGrimes
RidsNrrLALFeizollahi	JCalvo

Non-Prop. Slides: ML050630097
Meeting Notice: ML050490282
ACCESSION NO.: ML050880143

Prop. Slides: ML050630092
PKG: ML050880159
NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC	EEIB/SC
NAME	ABWang:sp	LFeizollahi	RGramm	EMarinos
DATE	4/04/05	3/30/05	4/29/05	4/29/05

OFFICIAL RECORD COPY

Ft. Calhoun Station, Unit 1

cc:

Winston & Strawn
ATTN: James R. Curtiss, Esq.
1400 L Street, N.W.
Washington, DC 20005-3502

Chairman
Washington County Board of Supervisors
P.O. Box 466
Blair, NE 68008

Mr. John Hanna, Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 310
Fort Calhoun, NE 68023

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-4005

Ms. Sue Semerera, Section Administrator
Nebraska Health and Human Services
Systems
Division of Public Health Assurance
Consumer Services Section
301 Centennial Mall, South
P.O. Box 95007
Lincoln, NE 68509-5007

Mr. David J. Bannister, Manager
Fort Calhoun Station
Omaha Public Power District
Fort Calhoun Station FC-1-1 Plant
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. John B. Herman
Manager - Nuclear Licensing
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
P.O. Box 550
Fort Calhoun, NE 68023-0550

Mr. Daniel K. McGhee
Bureau of Radiological Health
Iowa Department of Public Health
401 SW 7th Street, Suite D
Des Moines, IA 50309

Mr. R. T. Ridenoure
Division Manager - Nuclear Operations
Omaha Public Power District
Fort Calhoun Station FC-2-4 Adm.
Post Office Box 550
Fort Calhoun, Nebraska 68023-0550

**CLOSED MEETING WITH
OMAHA PUBLIC POWER DISTRICT (OPPD)**

LIST OF ATTENDEES

March 3, 2005

OPPD

S. Gambhir
J. Gasper
T. Matthews

Westinghouse

C. T. French
J. McInerney

AMAG

V. Askari
A. Lopez

NRC

C. Grimes
J. Calvo
E. Marinos
A. Wang
I. Ahmed
S. Miranda