

4.5 CONCRETE CONTAINMENT TENDON PRESTRESS ANALYSIS

Item	Locator	Comment	Justification
1	4.5.1	Clarify requirements for evaluating existing TLAA	10CFR54 does not require TLAA's to be created to address this aging effect; however analyses/calculations to address the aging effect of loss of prestress in containment tendons generally exist and generally meet the definition of a TLAA as given by 10CFR54.3.
2	4.5.2.1.1, 4.5.2.1.2, 4.5.3.1.2, Table 4.5-1	Update acceptance criteria	Updated to meet the requirement per ASME Section XI, Sub-section IWL Acceptance criteria
3	4.5.2.1.3	Acknowledge GALL as guidance rather than requirement.	ISG 1
4	4.5.3.1.3	Address evaluations outside GALL guidance	ISG 1
5	4.5.6	Update Reference 4	Editorial
6	Table 4.5-1	10 CFR 54.21(c)(1)(i) and 10 CFR 54.21(c)(1)(ii) Examples are repeat information , so it should be consolidated in one item.	Updated to meet the requirement per ASME Section XI, Sub-section IWL Acceptance criteria

4.5 CONCRETE CONTAINMENT TENDON PRESTRESS ANALYSIS

Review Responsibilities

Primary - Branch responsible for structural engineering

Secondary - None

4.5.1 Areas of Review

The prestressing tendons in prestressed concrete containments lose their prestressing forces with time due to creep and shrinkage of concrete, and relaxation of the prestressing steel. During the design phase, engineers estimate these losses to arrive at the end of operating life (Refs. 1 and 2), normally forty years. The operating experiences with the trend of prestressing forces indicate that the prestressing tendons lose their prestressing forces at a rate higher than predicted due to sustained high temperature (Ref. 3). Thus, it is necessary to **ensure that the applicant addresses existing** ~~perform~~ TLAs for the extended period of operation.

The adequacy of the prestressing forces in prestressed concrete containments is reviewed for the period of extended operation.

4.5.2 Acceptance Criteria

The acceptance criteria for the area of review described in Subsection 4.5.1 of this review plan section delineate acceptable methods for meeting the requirements of the NRC's regulations in 10 CFR 54.21(c)(1).

4.5.2.1 Time-Limited Aging Analysis

Pursuant to 10 CFR 54.21(c)(1)(i) - (iii), an applicant must demonstrate one of the following:

- (i) The analyses remain valid for the period of extended operation;
- (ii) The analyses have been projected to the end of the extended period of operation; or
- (iii) The effects of aging on the intended function(s) will be adequately managed for the period of extended operation.

Accordingly, the specific options for satisfying the acceptance criterion are:

4.5.2.1.1 10 CFR 54.21(c)(1)(i)

The existing prestressing force evaluation remains valid because (1) losses of the prestressing force are less than the predicted losses as evidenced from the trend lines constructed from the recent inspection, (2) the period of evaluation covers the period of extended operation, and (3) the trend lines of the measured prestressing forces remain above the **minimum required prestress force specified at anchorage** ~~predicted lower limit (PLL)~~ for each group of tendons for the period of extended operation.

4.5.2.1.2 10 CFR 54.21(c)(1)(ii)

The **trend line** predicted lower limits (PLLs) of prestressing forces for each group of tendons developed for 40 years of operation should be extended to 60 years. The applicant should demonstrate that the trend lines of the measured prestressing forces will stay above the PLLs and the design Minimum Required Value (MRV) in the CLB for each group of tendons during the period of extended operation (Ref. 4). If this cannot be done, the applicant should develop a systematic plan for retensioning selected tendons so that the trend lines will remain above the **minimum required prestress force specified at anchorage** PLLs for each group of tendons during the period of extended operation, or perform a reanalysis of containment to demonstrate design adequacy.

4.5.2.1.3 10 CFR 54.21(c)(1)(iii)

In Chapter X of the GALL report (Ref. 4), the staff has evaluated a program that assesses the concrete containment tendon prestressing forces, and has determined that it is an acceptable aging management program to address concrete containment tendon prestress according to 10 CFR 54.21(c)(1)(iii), except for operating experience. The GALL report recommends further evaluation of the applicant's operating experience related to the containment prestress force. **However, the GALL report contains one acceptable way and not the only way to manage aging for license renewal.**

The GALL report may be referenced in a license renewal application, and should be treated in the same manner as an approved topical report. In referencing the GALL report, an applicant should indicate that the material referenced is applicable to the specific plant involved and should provide the information necessary to adopt the finding of program acceptability as described and evaluated in the report. An applicant should also verify that the approvals set forth in the GALL report for the generic program apply to the applicant's program.

4.5.2.2 FSAR Supplement

The specific criterion for meeting 10 CFR 54.21(d) is:

The summary description of the evaluation of TLAAs for the period of extended operation in the FSAR supplement is appropriate such that later changes can be controlled by 10 CFR 50.59. The description should contain information associated with the TLAAs regarding the basis for determining that the applicant has made the demonstration required by 10 CFR 54.21(c)(1).

4.5.3 Review Procedures

For each area of review described in Subsection 4.5.1 of this review plan section, the following review procedures should be followed:

4.5.3.1 Time-Limited Aging Analysis

For a concrete containment prestressing tendon system, the review procedures, depending on the applicant's choice of 10 CFR 54.21(c)(1)(i), (ii), or (iii), are:

4.5.3.1.1 10 CFR 54.21(c)(1)(i)

The results of a recent inspection to measure the amount of prestress loss are reviewed to ensure that the reduction of prestressing force is less than the predicted loss in the existing analysis. The reviewer verifies that the trend line of the measured prestressing force when plotted on the predicted prestressing force curve shows that the existing analysis will cover the period of extended operation.

4.5.3.1.2 10 CFR 54.21(c)(1)(ii)

The reviewer reviews the trend lines of the measured prestressing forces to ensure that individual tendon lift-off forces (rather than average lift-off forces of the tendon group) are considered in the regression analysis, as discussed in IN 99-10 (Ref. 3). Either the reviewer verifies that the trend lines will stay above the *minimum required* ~~PLL~~ prestressing forces for each group of tendons during the period of extended operation or, if the trend lines fall below the *minimum required prestressing forces* ~~PLL~~ during this period, the reviewer verifies that the applicant has a systematic plan for retensioning the tendons to ensure that the trend lines will return to being, and remain, above the *minimum required prestressing forces* ~~PLL~~ for each group of tendons during the period of extended operation. If the applicant chooses to reanalyze the containment, the reviewer verifies that the design adequacy is maintained in the period of extended operation.

4.5.3.1.3 10 CFR 54.21(c)(1)(iii)

An applicant may reference the GALL report in its license renewal application, as appropriate. The review should verify that the applicant has stated that the report is applicable to its plant with respect to its program that assesses the concrete containment tendon prestressing forces. The reviewer verifies that the applicant has identified the appropriate program as described and evaluated in the GALL report. The reviewer also ensures that the applicant has stated that its program contains the same program elements that the staff evaluated and relied upon in approving the corresponding generic program in the GALL report.

The GALL report recommends further evaluation of the applicant's operating experience related to the containment prestress force. The applicant's program should incorporate the relevant operating experience that occurred at the applicant's plant as well as at other plants. The applicant should consider applicable portions of the experience with prestressing systems described in Information Notice 99-10 (Ref. 3). Tendon operating experience could vary among plants with prestressed concrete containments. The difference could be due to the prestressing system design (for example, button-heads, wedge or swaged anchorages), environment, or type of reactor (PWR or BWR). The reviewer reviews the applicant's program to verify that the applicant has adequately considered plant-specific operating experience.

If the applicant does not reference the GALL report in its renewal application, additional staff evaluation is necessary to determine whether the applicant's program is acceptable for this area of review.

4.5.3.2 FSAR Supplement

The reviewer verifies that the applicant has provided information, to be included in the FSAR supplement, that includes a summary description of the evaluation of tendon prestress TLAA. Table 4.5-1 of this review plan section contains examples of acceptable FSAR supplement information for this TLAA. The reviewer verifies that the applicant has provided a FSAR supplement with information equivalent to that in Table 4.5-1.

The staff expects to impose a license condition on any renewed license to require the applicant to update its FSAR to include this FSAR supplement at the next update required pursuant to 10 CFR 50.71(e)(4). As part of the license condition, until the FSAR update is complete, the applicant may make changes to the programs described in its FSAR supplement without prior NRC approval, provided that the applicant evaluates each such change pursuant to the criteria set forth in 10 CFR 50.59.

As noted in Table 4.5-1, an applicant need not incorporate the implementation schedule into its FSAR. However, the review should verify that the applicant has identified and committed in the license renewal application to any future aging management activities, including enhancements and commitments to be completed before the period of extended operation. The staff expects to impose a license condition on any renewed license to ensure that the applicant will complete these activities no later than the committed date.

4.5.4 Evaluation Findings

The reviewer verifies that the applicant has provided sufficient information to satisfy the provisions of this review plan section and that the staff's evaluation supports conclusions of the following type, depending on the applicant's choice of 10 CFR 54.21(c)(1)(i), (ii), or (iii), to be included in the staff's safety evaluation report:

The staff concludes that the applicant has provided an acceptable demonstration, pursuant to 10 CFR 54.21(c)(1), that, for the concrete containment tendon prestress TLAA, [choose which is appropriate] (i) the analyses remain valid for the period of extended operation, (ii) the analyses have been projected to the end of the period of extended operation, or (iii) the effects of aging on the intended function(s) will be adequately managed for the period of extended operation. The staff also concludes that the FSAR supplement contains an appropriate description of the concrete containment tendon prestress TLAA evaluation for the period of extended operation as reflected in the license condition.

4.5.5 Implementation

Except in those cases in which the applicant proposes an acceptable alternative method, the method described herein will be used by the staff in its evaluation of conformance with NRC regulations.

4.5.6 References

1. Regulatory Guide 1.35, Rev. 3, "Inspection of Ugrouted Tendons in Prestressed Concrete Containments," July 1990.
2. Regulatory Guide 1.35.1, "Determining Prestressing Forces for Inspection of Prestressed Concrete Containments," July 1990.
3. NRC Information Notice 99-10, "Degradation of Prestressing Tendon Systems in Prestressed Concrete Containments," April 1999.
4. NUREG-1801, "Generic Aging Lessons Learned (GALL)," U.S. Nuclear Regulatory Commission, **July 2001. Revision 1, September 2005.**

Table 4.5-1. Examples of FSAR Supplement for Concrete Containment Tendon Prestress TLAA Evaluation

10 CFR 54.21(c)(1)(i) and 10 CFR 54.21(c)(1)(ii) Example

TLAA	Description of Evaluation	Implementation Schedule*
Concrete containment tendon prestress	The prestressing tendons are used to impart compressive forces in the prestressed concrete containments to resist the internal pressure inside the containment that would be generated in the event of a LOCA. The prestressing forces generated by the tendons diminish over time due to losses in prestressing forces in the tendons and in the surrounding concrete. The prestressing force evaluation has been determined to remain valid to the end of the period of extended operation, and the trend lines of the measured prestressing forces will stay above the minimum required prestressing force PLLs for each group of tendons to the end of this period.	Completed

10 CFR 54.21(c)(1)(ii) Example

TLAA	Description of Evaluation	Implementation Schedule*
Concrete containment tendon prestress	The prestressing tendons are used to impart compressive forces in the prestressed concrete containments to resist the internal pressure inside the containment that would be generated in the event of a LOCA. The prestressing forces generated by the tendons diminish over time due to losses in prestressing forces in the tendons and in the surrounding concrete. The prestressing forces have been reevaluated, showing that the trend lines of the measured prestressing forces will stay above the PLLs for each group of tendons to the end of the period of extended operation.	Completed

10 CFR 54.21(c)(1)(iii) Example

TLAA	Description of Evaluation	Implementation Schedule*
Concrete containment tendon prestress	The prestressing tendons are used to impart compressive forces in the prestressed concrete containments to resist the internal pressure inside the containment that would be generated in the event of a LOCA. The prestressing forces generated by the tendons diminish over time due to losses of prestressing forces in the tendons and in the surrounding concrete. The aging management program developed to monitor the prestressing forces should ensure that, during each inspection, the trend lines of the measured prestressing forces show that they meet the requirements of 10 CFR 50.55a(b)(2)(ix)(B). If the trend lines cross the minimum required prestressing force PLLs, corrective actions will be taken. The program will also incorporate any plant-specific and industry operating experience.	Program should be implemented before the period of extended operation.

* An applicant need not incorporate the implementation schedule into its FSAR. However, the reviewer should verify that the applicant has identified and committed in the license renewal application to any future aging management activities to be completed before the period of extended operation. The staff expects to impose a license condition on any renewed license to ensure that the applicant will complete these activities no later than the committed date.

This Page Intentionally Left Blank