COLOR TABLE-4 DRIVER-L4

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

L P TURBINE A

L P TURBINE B

PLANT HEATING STEAM

TURB TRIP (WESTINGHOUSE)

EVAPORATOR HEATING SYSTEM

HEATER E-4A

HEATER E-4B

HEATER E-3A

HEATER E-3B

HEATER E-2A

HEATER E-2B

HEATER E-1A

HEATER E-1B

CONDENSER

NITROGEN

THIS DWG.

DRAIN COOLER E-7A

TO FLOOR DRAIN SYSTEM

NOTE:

FOR FEEDWATER HEATERS LG'S,LT'S & LS'S PIPING VALVING SEE M-206 SH.2.

RED=IN SCOPE FOR LR

BLACK=NOT IN SCOPE

REV.	DATE	DESCRIPTION	BY	CK	APP
24	96-08 04	REVISED TO REFLECT AS-BUILT. REF. CAP 020891 AND DCR 01-312.	ALB		RTD
23	11-12 03	REVD TO SHOW AS BUILT CONFIG OF SHELL DRAINS FOR FEEDWATER HTRS E-1A &C-2A PER CHECKOFF AND DCR 03-098	DHB		HMS

Consumers Energy

PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
EXTRACTIONS, HEATER VENTS & DRAINS SYSTEMS

LR-M-206 | 1A | 24

...\LR-M206-1A.DGN 03/21/2005 10:15:14 AM

C21

COLOR TABLE-1 DRIVER-L

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\LR-M206-1B.dgn 03/21/2005 10:16:57 AM

CONDENSER E-10

ALL PIPING & EXPANSION JOINTS WITHIN THE CONDENSER ARE PROVIDED BY INGERSOL-RAND

DRAIN COOLER E-7A

DRAIN COOLER E-7B

NOTES:

1. THERE ARE TWO SPARE CONDENSER CONNECTIONS #29, ONE ON THE EAST AND ONE ON THE WEST SIDE OF THE CONDENSER. BOTH ARE SPARES.

REV.	DATE	DESCRIPTION	BY	CK	APP
29	89-15 84	REVISED TO ADD MV-HE058828 THRU HE058826 PER DCR 84-396	DMB		DMK
28	11-12 83	REVISED OFF PAGE REFERENCE PER CAR#2362 AND DCR 83-878	DMB	RLR	HMS

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
EXTRACTIONS, HEATER VENTS & DRAINS SYSTEMS

LR-M-206 | REV. NO. 18 | SH. NO. 29

C22

COLOR TABLE-3 DRIVER-L3

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.



REV.	DATE	DESCRIPTION	BY	CK	APP
33	96-23 02	REVISED LOCATION OF SPOOL PIECE PER CAMDESIGN AND DCR 02-156	DMB		JSE
32	84-26 02	REVISED TO ADD VALVE PER DCR 02-272	DMB	GH	

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
EXTRACTIONS, HEATER VENTS & DRAINS SYSTEMS

LR-M-206 | IC | 33

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\LR-M206-1C.DGN 03/21/2005 10:26:23 AM

C23

COLOR TABLE-3 DRIVER-L3

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.



E-1A
(E-1B)



E-4A
(E-4B)



E-2A
(E-2B)



E-5A
(E-5B)



E-3A
(E-3B)



E-6A
(E-6B)

NOTE:
1. ALL VALVE NO'S ARE "HED".

REV	DATE	DESCRIPTION	BY	APP
3	1-17-05	ADDED VALVE NO. 50814 (50815) PER WALKDOWN & DCR-M3-816.	ALB	

Consumers Energy
PALISADES PLANT
M206-2.DGN

PIPING & INSTRUMENT DIAGRAM
STEAM GENERATOR BLOWDOWN
MODIFICATION

LR-M206 | 2 | 3

P&ID

RED = IN SCOPE FOR LR
BLACK = NOT IN SCOPE

...\LR-M206-2.dgn 03/21/2005 10:27:48 AM

C24

COLOR TABLE-I DRIVER-L

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\LR-M207-1.dgn 03/21/2005 10:29:12 AM

STM. GEN. E-50A) PPC DIGITAL PTS.

SIGNAL	PT. ID.	CHANNEL
PRESSURE	RPSAI05 D	A
LEVEL	RPSAI08 D	
PRESSURE	RPSBI05 D	B
LEVEL	RPSBI08 D	
PRESSURE	RPSCI05 D	C
LEVEL	RPSCI08 D	
PRESSURE	RPSDI05 D	D
LEVEL	RPSDI08 D	

STM. GEN. E-50B) PPC DIGITAL PTS.

SIGNAL	PT. ID.	CHANNEL
PRESSURE	RPSAI06 D	A
LEVEL	RPSAI09 D	
PRESSURE	RPSBI06 D	B
LEVEL	RPSBI09 D	
PRESSURE	RPSCI06 D	C
LEVEL	RPSCI09 D	
PRESSURE	RPSDI06 D	D
LEVEL	RPSDI09 D	

NOTES:
1. SHOWN FOR CV 0781; CV 0788, CV 0779 & CV 0782 ARE IDENTICAL.
2. SX-0779 THRU SX-0782 ARE HYDROSTATIC TEST TAPS
3. CV-0779 MV-CAG15
   CV-0788 MV-CAG16
   CV-0781 MV-CAG14
   CV-0782 MV-CAG13
4. TEMPORARY PRESSURE GAUGES MAY BE INSTALLED ON MV-MS522 AND MV-MS526 PER EOP-9 ANC-2.

REV.	DATE	DESCRIPTION	BY	CK	APP
82	10-15-03	REVISED TO REMOVE TH-16-831 PER CAP037081 AND DCN 83-888	DMB		RTO
81	05-13-02	REVISED TO CORRECT VALVE POSITIONS PER DCN 82-311	DMB		

Consumers Energy
PALISADES PLANT
PIPING & INSTRUMENT DIAGRAM
FEEDWATER & CONDENSATE SYSTEM

DRAWING NUMBER	SHT. NO.	REV.
LR-M-207	1	82

C25

COLOR TABLE-2 DRIVER-L2

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\LR-M207-1A.dgn 03/21/2005 10:30:10 AM

HEATER E6B

HEATER E6A

STEAM GENERATOR FEED PUMPS

P-1B

P-1A

F-46

F-47

CHEMICAL ADDITION T-36

COOLER SC1-8710-C

CORROSION PRODUCT MONITOR M-97

NOTES:
1. REFER TO P&ID M-225 FOR CONTROL AIR SYSTEM DETAILS.
2. ON LOSS OF AIR VALVES FAIL AS-IS AND WILL NOT CLOSE ON CHP SYS LO PRESS. OR WITH CONTROLLER.

REV.	DATE	DESCRIPTION	BY	CK	APP
53	02-19 04	REVISED VALVE POSITION FOR FW303 AND 286 TO CLOSED PER DCP 04-863	DMB		TJS
52	03-31 03	REVS TO REMOVE SW8782A,B,C, PS8713, SW8784A,B,C & PS8711 PER EAR-01-0856 AND DCN 03-221	DMB		NTN

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM FEEDWATER & CONDENSATE SYSTEM

LR-M-207 1A 53

C26

COLOR TABLE-2 DRIVER-L2

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

HOTWELL

DRAIN COOLER E7A

DRAIN COOLER E7B

AIR EJECTOR INTER & AFTER CONDENSERS

MAIN TURBINE GLAND SEAL CONDENSER

FAST MAKE-UP FOR MAIN STM. DUMP

MAKEUP FOR COND. FILL & MAX. BLOW DOWN

NOTES:
1. REFER TO P&ID M-225 FOR CONTROL AIR SYSTEM DETAILS

REV.	DATE	DESCRIPTION	BY	CK	APP
36	94-24 01	REVISED TO ADD MV-CO815 PER DCR 94-322	DMB		JSE
35	89-12 01	REVISED TO ADD CO-681/8 PER EAR-88-8388 AND DCR 91-219	DMB		

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
FEEDWATER & CONDENSATE SYSTEM

LR-M-207 | 18 | 36

...\LR-M207-1B.dgn 03/21/2005 10:32:05 AM

C27

COLOR TABLE-1 DRIVER-L

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.



REV.	DATE	DESCRIPTION	BY	CK	APP
46	06-28-04	REVISED TO ADD EQUIPMENT ID PER DCR 04-2782.	ALB		MTN
45	06-12-03	REVISED TO ADD PX-8788 AND PX-8789 PER DCR 03-485	DMB		RTO

Consumers Energy

PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
FEEDWATER & CONDENSATE SYSTEM

LR-M-207 | IC | 46

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M207-1C.dgn 03/21/2005 10:43:03 AM

C28

COLOR TABLE-1 DRIVER-L

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE



...\dwgrev2-lr\LR-M207-1D.dgn 03/21/2005 10:45:19 AM

C29

COLOR TABLE-2 DRIVER-L2

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M207-2.dgn 03/21/2005 10:46:41 AM

NOTES
1. FOR LEVEL TRANSMITTER AND DIFFERENTIAL PRESSURE TRANSMITTER INPUTS TO FOGG/AFAS SEE P & ID M-207(0) SHEET 1.
FOGG A MEANS STEAM GENERATOR E-50B IS ISOLATED.
FOGG B MEANS STEAM GENERATOR E-50A IS ISOLATED.
2. REMOVE STRAINER INTERNALS DURING NORMAL OPERATION.
3. DELETED PER CAP23541 AND CAN1362
4. ALL AUXILIARY FEEDWATER SYSTEM SIGNALS TO THE CRITICAL FUNCTIONS MONITOR (CFM) EXCEPT AUX VALVE POSITION, ORIGINATE FROM THE BAILEY CABINETS J-1651 AND J-1652. CONNECTIONS ARE MADE AT THE CFM ISOLATION CABINETS
5. VALVE POSITION INDICATION NOT PROVIDED WITH HCV 1151 BEING NORMALLY LOCKED IN THE "OPEN" POSITION PER SC-92-841.

P-8C PUMP COOLING

REV.	DATE	DESCRIPTION	BY	CK	APP
34	10-27-03	REVISED PER CLASSIFICATION REP CAP1362, CAP23541 AND DCR 03-0894	DMB		SSO
33	04-02-03	REVISED TO ADD PX-8798 PER DCR 03-222	DMB		JDA

Consumers Energy
PALISADES PLANT
PIPING & INSTRUMENT DIAGRAM
AUXILIARY FEEDWATER SYSTEM
LR-M207-2.DGN
LR-M-207 REV. NO. 2 REV. NO. 34

C30

COLOR TABLE-2 DRIVER-L2

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

NOTES:

1) THE NON-CRITICAL SW RETURN HEADER IS IN BOUNDARY OF LR. THE BRANCH LINES COMING OFF THE HEADER ARE IN BOUNDARY OF LR UP TO AND INCLUDING THEIR RESPECTIVE ISOLATION VALVES DUE TO BEING CAPABLE OF ISOLATION BY OPERATOR ACTION.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE



NOTES:
1. ALL VALVES ON THIS SHEET HAVE "SWS" (SERVICE WATER SYSTEM) SUFFIX, UNLESS OTHERWISE NOTED.
2. LOCATION OF ULTRASONIC FLOWMETER INSTALLED AND REMOVED PER SPECIAL TEST T-216.
3. THIS DRAWING HAS BEEN AFFECTED BY A TM INCORPORATED INTO SOP-19 ATTACHMENT 4 WHICH INSTALLS A HOSE TO PROVIDE ALTERNATE COOLING WATER TO C-1B3A/B.
4. REMOVE INTERNALS FROM CX-SW412 PER EAR-81-0831. CLOSE VALVES MV-SW712, MV-SW713 & MV-SW648.

REV.	DATE	DESCRIPTION	BY	CK	APP
81	03-16-84	REVISED SW339 TO OPEN PER CAP84159 AND DCR 84084	DMB		MTN
80	10-08-83	REVISE PCV-0886 SYMBOL PER DCR 83-661	DMB	SSO	RTO

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
NON-CRITICAL SERVICE WATER SYSTEM

LR-M-208 | 1 | 81

...\dwgrev2-lr\LR-M208-1.dgn 03/21/2005 10:53:34 AM

C31

COLOR TABLE-2 DRIVER-L2

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M208-1A.dgn 03/21/2005 10:55:49 AM

C32

PLANT AIR COMPRESSORS

NOTES:
1. ALL VALVES ON THIS SHEET HAVE "SW" (SERVICE WATER SYSTEM) PREFIX, UNLESS OTHERWISE NOTED.
2. SC 98-153 PERMITS ¾" OFFSET FOR EXPANSION JOINT.
3. EXPANSION JOINT HAS 7" UNEXTENDED HEIGHT PER SC 98-153
4. MV-SW-278 & MV-SW279 THROTTLED PER SERVICE WATER FLOW VERIFICATION TEST T-216.
5. FOR DIESEL LUBE OIL AND JACKET WATER COOLING SEE P&ID M-214 SH.1.
6. DELETED
7. FLANGED CONNECTIONS NOTED ARE FOR FC-956 TEMPORARY COOLING.
8. TEMPORARY gP GAUGES WILL BE INSTALLED DURING PERFORMANCE OF PROCEDURE SWS-1-4.
9. THIS IS A BLIND COUPLING WHICH ISOLATES THE PIPING FROM YC-1A OR YC-1B.
10. A TM HAS BEEN APPROVED TO ALLOW HOSES TO BE CONNECTED TO MV-SW758 AND MV-SW759 TO PROVIDE MAKE-UP WATER TO THE SPENT FUEL POOL PER PC50-5

REV.	DATE	DESCRIPTION	BY	CK	APP
54	6-29-04	REMOVED TE/TI FROM YHX-27A&B AND ADDED TO M-218 SH.1 PER CAP 040646 AND DCR 04-342.	ALB		TJS
53	12-18-03	REVISED PER MOD-03-817 AND DCR 03-764			
		REVISED TO ADD XJ-8883, XJ-8882 & XJ-8884 PER DCR 02-747	DMB		MTN

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
SERVICE WATER SYSTEM

DRAWING NUMBER: LR-M-208 | REV. NO.: 1A | REV.: 54

COLOR TABLE-4 DRIVER-L4

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.



RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M208-1B.DGN 03/21/2005 10:57:59 AM

C33

COLOR TABLE-1 DRIVER-L

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M209-1.DGN 03/21/2005 10:59:28 AM

C34

NOTE:
1. AMPLIFIERS & LIGHTS ARE PRESENTLY RETIRED IN PLACE.

DETAIL "A"

DETAIL "B" (P-50D)

⊛ PRIMARY COOLANT PUMPS INSTRUMENTATION
(REFER TO M-214 FOR LUBE OIL SYSTEM INSTRUMENTATION)

P-50B (P-1B)
P-50A (P-1A)
P-50D (P-2B)
P-50C (P-2A)

E-58 LETDOWN HEAT EXCHANGER

INTERNAL HEAT EXCHANGERS SEE DETAIL "A"
INTERNAL HEAT EXCHANGERS SEE DETAIL "B"

SEAL LEAKAGE DPCT (D-5) M-218 SH.2

SEAL FLUSH M-203 SH 2 (F-5)

CONTROLLED BLEED OFF TO CVCS M-202 SH 1 (C-6)

REACTOR SHIELD COOLING SYSTEM M-221 SH 1 (E-8)

CONTAINMENT SUMP M-204 SH.1A (E-1)

CCW SUPPLY HEADER M-209 SH.3 (D-8)

CCW RETURN HEADER M-209 SH.3 (A-3)

REV.	DATE	DESCRIPTION	BY	DE	APP
62	04-12 2003	REVISED PER EAR-2001-0009 AND DCR 03-269.	RLR		MTN
61	03-11 03	REVISED TO ADD EQUIP. ID CC 2812 PER EAR-03-0015 AND DCR 03-132	DMB		MTN

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
COMPONENT COOLING SYSTEM

LR-M-209 | 1 | 62

COLOR TABLE-2 DRIVER-L2

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.



RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M209-2.DGN 03/21/2005 11:00:53 AM

C35

COLOR TABLE-3 DRIVER-L3

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

COMPONENT COOLING WATER HEAT EXCHANGERS

COMPONENT COOLING CIRCULATING PUMPS

COMPONENT COOLING SURGE TANK T-3

WASTE GAS COMPRESSOR C-54

CHARGING PUMPS COOLING

WASTE GAS COMPRESSORS AFTER COOLERS

VACUUM DEGASIFIER VACUUM PUMPS SEAL WATER COOLER C-51

VENT GAS COLLECTION HEADER

NOTES:
1.) MV-CC-154 THROTTLED
2.) CV-8915 AIR TO CLOSE LOWER PORT TO VENT GAS COLLECTION HEADER.
4.) DELETED PER EAR-99-0166
5.) TEMPORARY INSTRUMENT MAY BE INSTALLED FOR FI-8938 PER CCS-1-5.

REV.	DATE	DESCRIPTION	BY	CH	APP
49	04-12 04	REVISED TO REMOVE MV-CC187 & 188 PER CAN03378,CAN03379 AND DCN 94-135	DMB		MTN
48	04-03 03	REVISED TO ADD PX-8985 - 8987 PER DCN 03-222	DMB	CH	JDA

Consumers Energy
PALISADES PLANT
LR-M2P9-3.DGN

PIPING & INSTRUMENT DIAGRAM
COMPONENT COOLING SYSTEM

DRAWING NUMBER	REV. NO.	SH. NO.
LR-M-209	3	49

...\dwgrev2-lr\LR-M209-3.DGN 03/21/2005 11:09:35 AM

C36

COLOR TABLE-4 DRIVER-L4

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

CONTROLLED CHEM. LAB. DRAIN TANK T-76

CONTROLLED CHEM. LAB. DRAIN PUMP P-61

EQUIPMENT DRAIN TANK T-80

EQUIPMENT DRAIN PUMPS P-75 A & B

P-75A

P-75B

T-961

CRDM LEAKOFF

CRD SEAL LEAKAGE RESERVOIR EL. 598' (CONTAINMENT)

NOTES:
1. ALL VALVES ON THIS PRINT ARE CRV PREFIX UNLESS OTHERWISE NOTED.
2. A TM FOR TEST RIG INSTALLATION HAS BEEN APPROVED AND INCORPORATED INTO RT-71L, WHICH IS PERFORMED EACH REFUELING OUTAGE. MV-CRV622A (D-4)

REV.	DATE	DESCRIPTION	BY	CK	APP
43	04-38 03	REVISED TO ADD NOTE 2 FOR TM PER DCR 03-242	DMB	CH	DMK TJS
42	04-24 02	REVISED TO ADD PI-1088 PER DCR 02-585			

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
RADIOACTIVE WASTE TREATMENT SYSTEM
CLEAN

LR-M-210 | 1 | 43

...\dwgrev2-lr\LR-M210-1.DGN 03/21/2005 11:10:46 AM

C37

COLOR TABLE-4 DRIVER-L4

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.



NOTE:
1. ALL VALVES ON THIS PRINT ARE CRV__ PREFIX UNLESS OTHERWISE NOTED.
2. RUD-1818 REMOVED TO ALLOW CONTAINMENT VENT PATH

REV.	DATE	DESCRIPTION	BY	CK	APP
20	03-18-03	REV'D TO REMOVE PT-1005 AND CRV-647A PER EAR-01-0424 AND DCR 02-151	DMB		PFB
19	03-07-02	REVISED MV-CRV515 TO GLOBE VALVE PER EAR-99-0174 AND DCR 02-129	DMB	MTN	

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
RADIOACTIVE WASTE TREATMENT SYS
CLEAN

DRAWING NO.	REV. NO.	SHT. NO.
LR-M-210	1A	20

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M210-1A.DGN 03/21/2005 11:12:20 AM

C38

COLOR TABLE-4 DRIVER-L4

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.



RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M210-1B.DGN 03/21/2005 11:13:54 AM

C39

COLOR TABLE-4 DRIVER-L4

THIS DRAWING IS COLOR CODED FOR LICENSE RENEWAL.



NOTE:
ALL VALVES ON THIS PRINT ARE CRW PREFIX UNLESS OTHERWISE NOTED.

REV.	DATE	DESCRIPTION	BY	CK	APP
14	97-28 03	REVISED A-1529 TO EX-1529 PER DCR 03-527	DMB		RTD
13	03-82 99	CHANGED SV-1849 AND SC-1854 TO NO FROM NE PER DCR 99-142	DMB	JGD	

Consumers Energy
PALISADES PLANT

PIPING & INSTRUMENT DIAGRAM
RADIOACTIVE WASTE TREATMENT SYSTEM CLEAN

LR-M-210 | IC | 14

RED=IN SCOPE FOR LR
BLACK=NOT IN SCOPE

...\dwgrev2-lr\LR-M210-1C.DGN 03/21/2005 11:15:32 AM

C49