

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF MARCH 11, 2005, MEETING WITH ENERGY NORTHWEST ON THE RISK-INFORMED DIESEL GENERATOR ALLOWED COMPLETION TIME EXTENSION (TAC NO. MC3203)

On March 11, 2005, representatives of Energy Northwest met with the Nuclear Regulatory Commission (NRC) staff to discuss the risk-informed diesel generator allowed completion time extension.

Energy Northwest outlined the new design since the last phone call and reviewed their draft responses to the NRC staff questions. The NRC staff indicated concerns with differences between Energy Northwest's submittal and that approved for River Bend Station. Energy Northwest explained that they cannot match River Bend's response exactly due to differences in the design and in their docketed station blackout response. Meeting the risk and deterministic concerns also led them to this new approach. The NRC staff questioned, from a deterministic standpoint, that the battery capacity can be extended from 4 to 6 hours without revising the station blackout analysis which was done for only 4 hours (condensate water inventory and heat loads in the pump rooms, switchgear and battery rooms).

Energy Northwest commented that they will revise their responses to address the staff's concerns, comments and questions. The NRC staff stated that follow up communication will be required once the design is complete, so that open issues can be resolved. Finally, Energy Northwest discussed the proposed schedule for completion of the design. Energy Northwest was appreciative of the staff's feedback. The meeting concluded with the staff expressing their appreciation for the presentation.

An attendance list is enclosed.

Brian Benney, Project Manager, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Meeting Attendees

cc w/encl: See next page

LICENSEE: Energy Northwest

FACILITY: Columbia Generating Station

SUBJECT: SUMMARY OF MARCH 11, 2004, MEETING WITH ENERGY NORTHWEST ON THE RISK-INFORMED DIESEL GENERATOR ALLOWED COMPLETION TIME EXTENSION (TAC NO. MC3203)

On March 11, 2005, representatives of Energy Northwest met with the Nuclear Regulatory Commission (NRC) staff to discuss the risk-informed diesel generator allowed completion time extension.

Energy Northwest outlined the new design since the last phone call and reviewed their draft responses to the NRC staff questions. The NRC staff indicated concerns with differences between Energy Northwest's submittal and that approved for River Bend Station. Energy Northwest explained that they cannot match River Bend's response exactly due to differences in the design and in their docketed station blackout response. Meeting the risk and deterministic concerns also led them to this new approach. The NRC staff questioned, from a deterministic standpoint, that the battery capacity can be extended from 4 to 6 hours without revising the station blackout analysis which was done for only 4 hours (condensate water inventory and heat loads in the pump rooms, switchgear and battery rooms).

Energy Northwest commented that they will revise their responses to address the staff's concerns, comments and questions. The NRC staff stated that follow up communication will be required once the design is complete, so that open issues can be resolved. Finally, Energy Northwest discussed the proposed schedule for completion of the design. Energy Northwest was appreciative of the staff's feedback. The meeting concluded with the staff expressing their appreciation for the presentation.

An attendance list is enclosed.

Brian Benney, Project Manager, Section 2  
Project Directorate IV  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket No. 50-397

Enclosure: Meeting Attendees

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

PDIV-2 Reading

RidsNrrDlpm (TMarsh/JLyons)

RidsNrrDlpmPdiv (HBerkow)

RidsNrrPMBBenney

RidsNrrLALFeizollahi

RidsAcrsAcnwMailCenter

RidsOgcRp

RTadesse, EDO

RidsRgnIVMailCenter(BJones)

C. Doutt

TMensah

OChopra

TFord

BTjader

Package: ML050960231

Meeting Notice No.: ML050600027

ADAMS Accession No.: ML050960137

NRC-001

OFFICE	PDIV-2/PM	PDIV-2/LA	PDIV-2/SC
NAME	BBenney: JF	LFeizollahi	RGramm
DATE		4/07/05	

DOCUMENT NAME: E:\Filenet\ML050960137.wpd

OFFICIAL RECORD COPY

# **MEETING WITH ENERGY NORTHWEST**

**March 11, 2005**

## **ATTENDANCE LIST**

### **ENERGY NORTHWEST**

D. Coleman  
G. Cullen  
M. Rice  
D. Rhoads  
A. Chaing

### **NRC**

B. Benney  
O. Chopra  
B. Tjader  
C. Doult  
T. Ford

Columbia Generating Station

cc:

Mr. W. Scott Oxenford (Mail Drop PE04)  
Vice President, Technical Services  
Energy Northwest  
P. O. Box 968  
Richland, WA 99352-0968

Mr. Dale K. Atkinson (Mail Drop PE08)  
Vice President, Nuclear Generation  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Mr. Albert E. Mouncer (Mail Drop PE01)  
Vice President, Corporate Services/  
General Counsel/CFO  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Mr. William A. Horin, Esq.  
Winston & Strawn  
1400 L Street, N.W.  
Washington, DC 20005-3502

Chairman  
Energy Facility Site Evaluation Council  
P.O. Box 43172  
Olympia, WA 98504-3172

Mr. Matt Steuerwalt  
Executive Policy Division  
Office of the Governor  
P.O. Box 43113  
Olympia, WA 98504-3113

Mr. Douglas W. Coleman (Mail Drop PE20)  
Manager, Regulatory Programs  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Ms. Lynn Albin  
Washington State Department of Health  
P.O. Box 7827  
Olympia, WA 98504-7827

Mr. Gregory V. Cullen (Mail Drop PE20)  
Supervisor, Licensing  
Energy Northwest  
P.O. Box 968  
Richland, WA 99352-0968

Technical Services Branch Chief  
FEMA Region X  
130 228<sup>th</sup> Street S.W.  
Bothell, WA 98201-9796

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011-4005

Chairman  
Benton County Board of Commissioners  
P.O. Box 190  
Prosser, WA 99350-0190

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P.O. Box 69  
Richland, WA 99352-0069

March 2005