

April 13, 2005

Mr. Christopher M. Crane, President
and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2 - CORRECTION
TO ISSUANCE OF AMENDMENTS (TAC NOS. MC3413 AND MC3414)

Dear Mr. Crane:

On March 15, 2005, the Nuclear Regulatory Commission (Commission) issued Amendment No. 224 to Facility Operating License No. DPR-29 and Amendment No. 219 to Facility Operating License No. DPR-30 for the Quad Cities Nuclear Power Station, Units 1 and 2, respectively. The amendments revised the Technical Specifications (TSs) in response to your application dated June 10, 2004, as supplemented by letters dated July 19 and July 21, 2004, and January 21, 2005.

Based on discussions between your staff and the Commission staff on April 1, 2005, we are reissuing a corrected copy of TS page 3.3.6.1-5 to reflect previous changes made to this page per Amendment Nos. 219 and 213 issued on February 18, 2004. The TS page markup submitted on June 10, 2004, that was used for Amendment Nos. 224 and 219 did not have the previously approved changes made to the Main Steam Line Pressure-Low allowable value. The enclosed TS page 3.3.6.1-5 corrects this allowable value to be " \geq 791 psig" as previously reviewed and approved.

We regret any inconvenience this may have caused.

Sincerely,

/RA/

Lawrence Rossbach, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-254 and 50-265

Enclosure: As stated

cc w/encl: See next page

April 13, 2005

Mr. Christopher M. Crane, President
and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2 - CORRECTION
TO ISSUANCE OF AMENDMENTS (TAC NOS. MC3413 AND MC3414)

Dear Mr. Crane:

On March 15, 2005, the Nuclear Regulatory Commission (Commission) issued Amendment No. 224 to Facility Operating License No. DPR-29 and Amendment No. 219 to Facility Operating License No. DPR-30 for the Quad Cities Nuclear Power Station, Units 1 and 2, respectively. The amendments revised the Technical Specifications (TSs) in response to your application dated June 10, 2004, as supplemented by letters dated July 19 and July 21, 2004, and January 21, 2005.

Based on discussions between your staff and the Commission staff on April 1, 2005, we are reissuing a corrected copy of TS page 3.3.6.1-5 to reflect previous changes made to this page per Amendment Nos. 219 and 213 issued on February 18, 2004. The TS page markup submitted on June 10, 2004, that was used for Amendment Nos. 224 and 219 did not have the previously approved changes made to the Main Steam Line Pressure-Low allowable value. The enclosed TS page 3.3.6.1-5 corrects this allowable value to be " \geq 791 psig" as previously reviewed and approved.

We regret any inconvenience this may have caused.

Sincerely,
/RA/

Lawrence Rossbach, Project Manager, Section 2
Project Directorate III
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-254 and 50-265

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	OGC, O15B18	PD3-2 r/f	ACRS, T2E26
AMohseni	GHill (4), T5C3	GSuh	TBoyce, O-12H2
LRossbach	MRing, RIII	PCoates	

ADAMS Package: ML050970128

Correction Ltr: ML050970125

TS Page: ML0501050432

OFFICE	PM:LPD3-2	PM:LPD3-2	LA:LPD3-2	SC:LPD3-2
NAME	WMacon	MBanerjee	PCoates	GSuh
DATE	4/12/05	4/12/05	4/12/05	4/13/05

OFFICIAL RECORD COPY

Quad Cities Nuclear Power Station Units 1 and 2

cc:

Site Vice President - Quad Cities Nuclear Power Station
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Quad Cities Nuclear Power Station Plant Manager
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Regulatory Assurance Manager - Quad Cities
Exelon Generation Company, LLC
22710 206th Avenue N.
Cordova, IL 61242-9740

Quad Cities Resident Inspectors Office
U.S. Nuclear Regulatory Commission
22712 206th Avenue N.
Cordova, IL 61242

David C. Tubbs
MidAmerican Energy Company
One River Center Place
106 E. Second, P.O. Box 4350
Davenport, IA 52808-4350

Vice President - Law and Regulatory Affairs
MidAmerican Energy Company
One River Center Place
106 E. Second Street
P.O. Box 4350
Davenport, IA 52808

Chairman
Rock Island County Board of Supervisors
1504 3rd Avenue
Rock Island County Office Bldg.
Rock Island, IL 61201

Regional Administrator
U.S. NRC, Region III
801 Warrenville Road
Lisle, IL 60532-4351

Illinois Emergency Management Agency
Division of Disaster Assistance & Preparedness
110 East Adams Street
Springfield, IL 62701-1109

Document Control Desk - Licensing
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Senior Vice President - Nuclear Services
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President of Operations - Mid-West Boiling Water Reactor
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Vice President - Licensing and Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Director - Licensing and Regulatory Affairs
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Associate General Counsel
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

Manager Licensing - Dresden, Quad Cities and Clinton
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555