

April 13, 2005

Mr. Christopher M. Crane, President  
and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2 - CORRECTION  
TO ISSUANCE OF AMENDMENTS (TAC NOS. MC3413 AND MC3414)

Dear Mr. Crane:

On March 15, 2005, the Nuclear Regulatory Commission (Commission) issued Amendment No. 224 to Facility Operating License No. DPR-29 and Amendment No. 219 to Facility Operating License No. DPR-30 for the Quad Cities Nuclear Power Station, Units 1 and 2, respectively. The amendments revised the Technical Specifications (TSs) in response to your application dated June 10, 2004, as supplemented by letters dated July 19 and July 21, 2004, and January 21, 2005.

Based on discussions between your staff and the Commission staff on April 1, 2005, we are reissuing a corrected copy of TS page 3.3.6.1-5 to reflect previous changes made to this page per Amendment Nos. 219 and 213 issued on February 18, 2004. The TS page markup submitted on June 10, 2004, that was used for Amendment Nos. 224 and 219 did not have the previously approved changes made to the Main Steam Line Pressure-Low allowable value. The enclosed TS page 3.3.6.1-5 corrects this allowable value to be " $\geq$  791 psig" as previously reviewed and approved.

We regret any inconvenience this may have caused.

Sincerely,

**/RA/**

Lawrence Rossbach, Project Manager, Section 2  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-254 and 50-265

Enclosure: As stated

cc w/encl: See next page

April 13, 2005

Mr. Christopher M. Crane, President  
and Chief Nuclear Officer  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: QUAD CITIES NUCLEAR POWER STATION, UNITS 1 AND 2 - CORRECTION  
TO ISSUANCE OF AMENDMENTS (TAC NOS. MC3413 AND MC3414)

Dear Mr. Crane:

On March 15, 2005, the Nuclear Regulatory Commission (Commission) issued Amendment No. 224 to Facility Operating License No. DPR-29 and Amendment No. 219 to Facility Operating License No. DPR-30 for the Quad Cities Nuclear Power Station, Units 1 and 2, respectively. The amendments revised the Technical Specifications (TSs) in response to your application dated June 10, 2004, as supplemented by letters dated July 19 and July 21, 2004, and January 21, 2005.

Based on discussions between your staff and the Commission staff on April 1, 2005, we are reissuing a corrected copy of TS page 3.3.6.1-5 to reflect previous changes made to this page per Amendment Nos. 219 and 213 issued on February 18, 2004. The TS page markup submitted on June 10, 2004, that was used for Amendment Nos. 224 and 219 did not have the previously approved changes made to the Main Steam Line Pressure-Low allowable value. The enclosed TS page 3.3.6.1-5 corrects this allowable value to be " $\geq$  791 psig" as previously reviewed and approved.

We regret any inconvenience this may have caused.

Sincerely,  
**/RA/**

Lawrence Rossbach, Project Manager, Section 2  
Project Directorate III  
Division of Licensing Project Management  
Office of Nuclear Reactor Regulation

Docket Nos. 50-254 and 50-265

Enclosure: As stated

cc w/encl: See next page

DISTRIBUTION:

PUBLIC	OGC, O15B18	PD3-2 r/f	ACRS, T2E26
AMohseni	GHill (4), T5C3	GSuh	TBoyce, O-12H2
LRossbach	MRing, RIII	PCoates	

ADAMS Package: ML050970128

Correction Ltr: ML050970125

TS Page: ML0501050432

OFFICE	PM:LPD3-2	PM:LPD3-2	LA:LPD3-2	SC:LPD3-2
NAME	WMacon	MBanerjee	PCoates	GSuh
DATE	4/12/05	4/12/05	4/12/05	4/13/05

**OFFICIAL RECORD COPY**

Quad Cities Nuclear Power Station Units 1 and 2

cc:

Site Vice President - Quad Cities Nuclear Power Station  
Exelon Generation Company, LLC  
22710 206th Avenue N.  
Cordova, IL 61242-9740

Quad Cities Nuclear Power Station Plant Manager  
Exelon Generation Company, LLC  
22710 206th Avenue N.  
Cordova, IL 61242-9740

Regulatory Assurance Manager - Quad Cities  
Exelon Generation Company, LLC  
22710 206th Avenue N.  
Cordova, IL 61242-9740

Quad Cities Resident Inspectors Office  
U.S. Nuclear Regulatory Commission  
22712 206th Avenue N.  
Cordova, IL 61242

David C. Tubbs  
MidAmerican Energy Company  
One River Center Place  
106 E. Second, P.O. Box 4350  
Davenport, IA 52808-4350

Vice President - Law and Regulatory Affairs  
MidAmerican Energy Company  
One River Center Place  
106 E. Second Street  
P.O. Box 4350  
Davenport, IA 52808

Chairman  
Rock Island County Board of Supervisors  
1504 3rd Avenue  
Rock Island County Office Bldg.  
Rock Island, IL 61201

Regional Administrator  
U.S. NRC, Region III  
801 Warrenville Road  
Lisle, IL 60532-4351

Illinois Emergency Management Agency  
Division of Disaster Assistance & Preparedness  
110 East Adams Street  
Springfield, IL 62701-1109

Document Control Desk - Licensing  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Senior Vice President - Nuclear Services  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Vice President of Operations - Mid-West Boiling Water Reactor  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Vice President - Licensing and Regulatory Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Director - Licensing and Regulatory Affairs  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Associate General Counsel  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555

Manager Licensing - Dresden, Quad Cities and Clinton  
Exelon Generation Company, LLC  
4300 Winfield Road  
Warrenville, IL 60555