

5.0 ADMINISTRATIVE CONTROLS

5.6 Reporting Requirements

The following reports shall be submitted in accordance with 10 CFR 50.4.

5.6.1 Deleted

5.6.2 Annual Monitoring Report

-----NOTE-----
A single submittal may be made that combines sections common to Units 1 and 2.

The Annual Monitoring Report covering the operation of the units during the previous calendar year shall be submitted by April 30 of each year. The report shall include summaries, interpretations, and analyses of trends of the results of the radiological environmental monitoring program for the reporting period. The material provided shall be consistent with the objectives outlined in the Offsite Dose Calculation Manual (ODCM), and in 10 CFR 50, Appendix I, Sections IV.B.2, IV.B.3, and IV.C.

5.6 Reporting Requirements

5.6.2 Annual Monitoring Report (continued)

The Annual Monitoring Report shall include the results of analyses of all radiological environmental samples and of all environmental radiation measurements taken during the period pursuant to the locations specified in the table and figures in the ODCM, as well as summarized and tabulated results of these analyses and measurements. In the event that some individual results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted in a supplementary report as soon as possible.

The Annual Monitoring Report shall also include The Radioactive Effluent Release Report covering the operation of the units in the previous year and submitted in accordance with 10 CFR 50.36a.

The submittal shall combine sections common to all units at the station; however, for units with separate radwaste systems, the submittal shall specify the releases of radioactive material from each unit. The report shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste released from the units. The material provided shall be consistent with the objectives outlined in the ODCM and Process Control Program and in conformance with 10 CFR 50.36a and 10 CFR 50, Appendix I, Section IV.B.1.

5.6.3 Deleted

5.6.4 CORE OPERATING LIMITS REPORT (COLR)

a. Core operating limits shall be established prior to each reload cycle, or prior to any remaining portion of a reload cycle, and shall be documented in the COLR for the following:

- (1) LCO 2.1.1, "Safety Limits (SLs)"
- (2) LCO 3.1.1, "Shutdown Margin (SDM)"
- (3) LCO 3.1.3, "Moderator Temperature Coefficient (MTC)"
- (4) LCO 3.1.5, "Shutdown Bank Insertion Limits"
- (5) LCO 3.1.6, "Control Bank Insertion Limits"
- (6) LCO 3.2.1, "Heat Flux Hot Channel Factor ($F_q(Z)$)"
- (7) LCO 3.2.2, "Nuclear Enthalpy Rise Hot Channel Factor ($F_{\Delta H}^N$)"