






**MAINE YANKEE
FINAL STATUS SURVEY RELEASE RECORD
FR-0111 YARD WEST EXCAVATIONS
SURVEY UNIT 17**

Prepared By:	<u></u> FSS Engineer - Signature <u>Dale Randall</u> Printed Name	Date: <u>4-4-05</u>
Reviewed By:	<u></u> FSS Specialist - Signature <u>Larry Dockins</u> Printed Name	Date: <u>4/4/05</u>
Reviewed By:	<u></u> Independent Review - Signature <u>C.A. Olsen</u> Printed Name	Date: <u>4 April 05</u>
Approved By:	<u></u> Superintendent, FSS - Signature <u>George Pillsbury</u> Printed Name	Date: <u>4/5/05</u>
Approved By:	<u></u> FSS, MOP - Signature <u>JAMES R. PARKER</u> Printed Name	Date: <u>4/5/05</u>

**MAINE YANKEE
FINAL STATUS SURVEY RELEASE RECORD
FR-0111 YARD WEST EXCAVATIONS
SURVEY UNIT 17**

A. SURVEY UNIT DESCRIPTION

FR-0111, Yard West Excavations Survey, Unit 17 was located southeast of the former Containment Building. The 1,563 m² area was bordered on the north by FR-0111 Survey Unit 18, on the west by FR-0111 Survey Unit 13 and FR-0100 Survey Units 2 and 3. Survey Area FR-0200 borders the unit to the East. The survey unit was centered near coordinates 407,386 N and 623,930 E using Maine State Coordinate System (West Zone) NAD 1927. The location of the survey unit in relation to the Containment Building and the surrounding FR-0111 survey units is shown on map FR0111U17-SITE (Attachment 1). Details for the survey unit's size and topography are shown on map FR0111U17-INFO.

B. SURVEY UNIT DESIGN INFORMATION

Survey Unit 17 met the LTP Revision 4 definition for a Class 1 survey unit. The survey unit design parameters are shown in Table 1. Given a relative shift of 0.8, it was determined that 40 direct measurements were required for the Sign Test. The measurement locations were based on a systematic square grid with a random start point as illustrated on map FR0111U17-DIRT (Attachment 1). Direct measurements (soil samples) were collected from required locations and analyzed with laboratory gamma spectroscopy instrumentation.

In accordance with the LTP, scans covering 100% of the 1,563 m² area were required for the Class 1 survey unit. This was accomplished by use of an *in situ* gamma spectroscopy detector (ISOCS) configured at a 2 or 3-meter distance from the surface to obtain overlapping 12 m² or 28 m² fields of view, respectively. The ISOCS detector was positioned perpendicular to the surface. Locations of the 95 survey scans are shown on maps FR0111U17-SCAN and FR0111U17-CONC.

The ISOCS scans were configured to ensure 100% scan coverage of all exposed surfaces within Survey Unit 17. The survey instruments used are listed by model and serial number in Attachment 2 (Table 2-1). Scan MDCs are also listed in Attachment 2 (Table 2-2) and are compared to the DCGL, the investigation level, and the DCGL_{EMC}. The scan MDC is less than the scan investigation level, thus providing high confidence (95% or higher) that an elevated area would be detected in the scanning process. Further, since the investigation level was always less than the design DCGL_{EMC}, no EMC sample size adjustment was necessary.

TABLE 1
SURVEY UNIT DESIGN PARAMETERS

Survey Unit	Design Criteria	Basis
Area	1,563 m ²	Class 1, < 2,000 m ²
Number of Direct Measurements Required	40	Based on an LBGR of 1.2 pCi/g, sigma ¹ of 1.33 pCi/g, and a relative shift of 0.8. Type I = Type II = 0.05
Sample Area	39.1 m ²	1,563 m ² / 40 = 39.1 m ²
Sample Grid Spacing	6.2 m	(39.1) ^{1/2}
Scan Grid Area	ISOCS scan 2 and 3-meters	See Section B
Area Factor	1.6	Class 1 Area, LTP Table 6-12
Scan Area	1,563 m ²	Class 1 Area – 100%
Scan Investigation Level	1.0 pCi/g Cs-137 0.36 pCi/g Co-60	ISOCS investigation levels with detector at 2-meter and 3-meter heights (Reference 3)
DCGL	2.39 pCi/g Cs-137 0.86 pCi/g Co-60	Reference 1
Design DCGL _{EMC}	3.82 pCi/g Cs-137 1.38 pCi/g Co-60	DCGL x Area Factor for Class 1 survey unit, per LTP Section 5.6.3

C. SURVEY RESULTS

A total of 40 direct measurements were performed in Survey Unit 17. Five samples contained detectable Cs-137 levels of residual activity below the DCGL. In addition, one sample contained detectable levels of Co-60 (this sample did not contain detectable levels of Cs-137). All other measurements were below the MDA. The results are presented in Table 2.

ISOCS gamma scans were performed at 95 locations using an investigation level of 1.0 pCi/g Cs-137 and 0.36 pCi/g Co-60 for the 28 m² and 12 m² field of view. Twelve of the locations scanned consisted of primarily concrete media, the balance were soil scan measurements. Media-appropriate geometries were applied to each ISOCS measurement. The gamma scans were performed for a sufficient count time to achieve a Minimum Detectable Activity (MDA) below the respective investigation levels. All identified scan activity levels were below the investigation levels. Therefore, no investigation surveys were performed as a result of the scan surveys.

¹ LTP Revision 4, Table 5-1C for RCA Yard West, R0100

TABLE 2
DIRECT MEASUREMENTS

Sample Number	Cs-137 (pCi/g)	Uncert. (pCi/g)	Co-60 (pCi/g)	Uncert. (pCi/g)	Unitized Value of Unity Rule
FR0111171S001	< 4.72E-02		< 4.91E-02		7.68E-02
FR0111171S002	< 4.54E-02		< 5.62E-02		8.43E-02
FR0111171S003	< 4.35E-02		< 4.63E-02		7.20E-02
FR0111171S004	< 4.55E-02		< 4.82E-02		7.51E-02
FR0111171S005	< 4.26E-02		< 4.89E-02		7.47E-02
FR0111171S006	< 5.57E-02		< 5.54E-02		8.77E-02
FR0111171S007	< 6.25E-02		< 6.00E-02		9.59E-02
FR0111171S008	< 5.62E-02		< 6.04E-02		9.37E-02
FR0111171S009	1.85E-01	3.66E-02	< 4.59E-02		1.31E-01
FR0111171S010	< 4.95E-02		< 5.01E-02		7.90E-02
FR0111171S011	< 4.92E-02		< 4.24E-02		6.99E-02
FR0111171S012	< 5.91E-02		< 5.84E-02		9.26E-02
FR0111171S013	< 5.98E-02		< 6.46E-02		1.00E-01
FR0111171S014	< 4.74E-02		< 4.58E-02		7.31E-02
FR0111171S015	< 5.56E-02		< 5.00E-02		8.14E-02
FR0111171S016	< 5.07E-02		< 5.31E-02		8.30E-02
FR0111171S017	< 6.38E-02		< 5.85E-02		9.47E-02
FR0111171S018	< 4.37E-02		< 4.51E-02		7.07E-02
FR0111171S019	< 4.26E-02		< 4.80E-02		7.36E-02
FR0111171S020	< 5.62E-02		< 6.23E-02		9.60E-02
FR0111171S021	< 4.51E-02		< 5.09E-02		7.81E-02
FR0111171S022	< 4.53E-02		< 4.18E-02		6.76E-02
FR0111171S023	< 5.96E-02		< 6.35E-02		9.88E-02
FR0111171S024	< 5.38E-02		< 5.52E-02		8.67E-02
FR0111171S025	1.13E-01	2.95E-02	< 6.48E-02		1.23E-01
FR0111171S026	< 5.94E-02		< 5.95E-02		9.40E-02
FR0111171S027	1.69E-01	4.03E-02	< 6.16E-02		1.42E-01
FR0111171S028	8.54E-01	8.41E-02	< 6.62E-02		4.34E-01
FR0111171S029	1.41E-01	3.66E-02	< 6.24E-02		1.31E-01
FR0111171S030	< 3.77E-02		< 4.04E-02		6.28E-02
FR0111171S031	< 4.96E-02		9.34E-02	2.94E-02	1.29E-01
FR0111171S032	< 4.62E-02		< 4.24E-02		6.86E-02
FR0111171S033	< 5.12E-02		< 5.27E-02		8.27E-02
FR0111171S034	< 5.18E-02		< 5.81E-02		8.92E-02
FR0111171S035	< 5.34E-02		< 5.82E-02		9.00E-02
FR0111171S036	< 4.82E-02		< 4.97E-02		7.80E-02
FR0111171S037	< 6.23E-02		< 6.06E-02		9.65E-02
FR0111171S038	< 6.28E-02		< 5.77E-02		9.34E-02
FR0111171S039	< 6.69E-02		< 6.32E-02		1.01E-01
FR0111171S040	< 5.34E-02		< 3.93E-02		6.80E-02
Mean	8.21E-02		5.48E-02		9.80E-02
Median	5.34E-02		5.53E-02		8.72E-02
Standard Deviation	1.29E-01		9.87E-03		5.78E-02
Range	3.77E-02 to 8.54E-01		3.93E-02 to 9.34E-01		6.28E-02 to 4.34E-01

“<” indicates MDA value. Bold indicates positive detection value.

D. SURVEY UNIT INVESTIGATIONS PERFORMED AND RESULTS

Based on the scan results, no investigations were required.

E. SURVEY UNIT DATA ASSESSMENT

An analysis of the direct sample measurement results, including the mean, median, standard deviation, and sample result range, is provided in Table 2. Positively detected values are bolded in the table. Since Co-60 and Cs-137 are the primary nuclides of concern, non-detect values for these nuclides were assumed to be present at the MDA. Of the 40 soil samples collected, five identified detectable Cs-137 activity below the DCGL value of 2.39 pCi/g. In addition, one sample contained detectable levels of Co-60 (this sample did not contain detectable levels of Cs-137). All other values were below the MDA. Table 2 lists the greater of the identified sample activity or MDA for each sample. The mean and median activities were less than the DCGLs for Cs-137 and Co-60. The average of the DCGL unity fractions was 0.098, indicating that the direct measurements averaged 9.8% of the DCGL limit.

For illustrative purposes, as indicated in LTP Section 5.9.3, a simplified general retrospective dose estimate can be calculated from the average residual contamination level by subtracting the mean fallout Cs-137 value (0.19 pCi/g)² for disturbed soil from the survey unit sample mean activity (0.082 pCi/g). This would equate to an annual dose rate of 0.0 mrem/year. Taking into account the average residual contamination level for Co-60, the annual dose rate would equate to 0.49 mrem/year³. For purposes of demonstrating compliance with the radiological criteria for license termination and the enhanced State criteria, background activity was not subtracted from the sample analysis activity values.

² See Attachment E to Maine Yankee Procedure PMP 6.7.8 (Reference 2).

³ This annual dose equivalent is based on LTP Table 6-11 which shows the RA contaminated soil contribution (for soils contaminated at the DCGL) to be 7.67 mrem/y. Therefore, the annual dose rate would equate to

$$\text{Annual Dose Rate} = 7.67 \times \left(\frac{0.0548}{0.86} \right) = 0.49 \text{ mrem / y}$$

F. ADDITIONAL DATA EVALUATION

Attachment 4 provides additional data evaluation associated with this survey unit, including relevant statistical information. Based on survey unit direct measurement data, this attachment provides the Sign Test Summary, Quantile Plot, Histogram, and Retrospective Power Curve.

1. The Sign Test Summary provides an overall summary of design input (Table 1) and resulting calculated values used to determine the required number (N) of direct measurements (per LTP Section 5.4.2). The Sign Test Summary is a separate statistical analysis that also calculates the mean, median, and standard deviation of the direct measurements.

The critical value and the result of the Sign Test are provided in the Sign Test Summary table, as well as a listing of the key release criteria. The direct measurements clearly pass the Sign Test. In addition, all other key release criteria have been satisfied. The sample standard deviation is smaller than the design sigma; therefore, no additional samples were required.

2. The Quantile Plot was generated from the unity data listed in Table 2. The data set and plot are consistent with expectations for a Class 1 survey unit. All of the measurements are below the DCGLs of 2.39 pCi/g for Cs-137 and 0.86 pCi/g for Co-60 for land inside the restricted area.
3. A Histogram Plot was also developed based on the unity data values. This plot shows a log-normal distribution with one outlier.
4. A Retrospective Power Curve was constructed, based on FSS results. The curve shows that this survey unit having a mean residual activity at a small fraction of the DCGL has a high probability ("power") of meeting the release criteria. Thus, it can be concluded that the direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

G. CHANGES IN INITIAL SURVEY UNIT ASSUMPTIONS ON EXTENT OF RESIDUAL ACTIVITY

The survey was designed as a Class 1 land survey area; the FSS results were consistent with that classification. The direct measurement sample standard deviation was less than the design sigma. Thus, a sufficient number of sample measurements were taken and no additional measurements were required.

H. LTP CHANGES SUBSEQUENT TO SURVEY UNIT FSS

The FSS of Survey Unit 17 was designed, performed, and evaluated in the March 2005 time frame. The design was performed to the criteria of the LTP Revision 4 (Reference 1). No subsequent LTP changes with potential impact to this survey unit need to be evaluated.

I. CONCLUSION

The FSS of this survey unit was designed based on the LTP designation as a Class 1 area. The survey design parameters are presented in Table 1. The required number of direct measurements was determined for the Sign Test in accordance with the LTP. As presented in Table 2, all direct measurements were less than the DCGLs of 2.39 pCi/g Cs-137 and 0.86 pCi/g Co-60. No measurements exceeded the unitized DCGL.

A Sign Test Summary analysis demonstrated that the Sign Test criteria were satisfied. The direct measurement sigma was determined to be less than that used for design, thus indicating that a sufficient number of samples was taken.

The Retrospective Power Curve shown in Attachment 4 confirmed that sufficient samples were taken to support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and the data quality objectives were met. Attachment 4 also revealed that direct measurement data represented essentially a log-normal distribution with one outlier.

The scan survey design for this survey unit was developed in accordance with the LTP Revision 4 (Reference 1) with significant aspects of the design discussed in Section B and Table 1. ISOCS scans performed in a systematic grid pattern throughout the survey unit did not identify activity above the scan investigation levels. Therefore, no investigations were required as a result of the scan process.

It is concluded that FR-0111 Survey Unit 17 meets the release criteria of 10CFR20.1402 and the State of Maine enhanced criteria.


J. REFERENCES


1. Maine Yankee License Termination Plan, Revision 4, February 28, 2005 provided by Maine Yankee letter to the NRC, MN-05-010
2. Maine Yankee Procedure PMP 6.7.8, FSS Data Processing and Reporting, Attachment E, Approach for Dealing With Background Radioactivity for Maine Yankee Final Status Surveys
3. Maine Yankee Calculation No. EC-003-04, Use of Canberra In Situ Object Counting System (ISOCS) for FSS Surveys

Attachment 1

Survey Unit Maps


Survey Area Name: Site Location







Note: Points outside the area are necessary to ensure overlapping scan coverage. However, they may be moved in to the boundary's edge.





Maine Yankee Decommissioning Team	Maine Yankee Decommissioning Project Survey Map			Map ID # FR0111U17-SCAN
Survey Type:	Characterization	Turnover	Final Status Survey	Survey Area Name: Scan Locations


Survey Type: ☐ Characterization

☐ Turnover


☒ Final Status Survey

Survey Area Name: Concrete Scans





FR-0111-17, Revision 0
Page 13 of 21



0,0
ref.

Attachment 2

Survey Unit Instrumentation

TABLE 2-1

INSTRUMENT INFORMATION

ISOCS Detectors (Field Measurements)

Detector No.	MDC (pCi/g)
7605	0.169 to 0.308
7607	0.128 to 0.454
7780	0.090 to 0.316

HPGe Detectors (Laboratory Analysis)

Detector No.	MDC (pCi/g)
FSS1	0.037 to 0.067
FSS2	0.037 to 0.066

TABLE 2-2

**INSTRUMENT SCAN MDC, DCGL,
INVESTIGATION LEVEL AND DCGL_{EMC}**

Parameter	Instrument: ISOCS	Comments
Scan MDC	0.090 to 0.454 pCi/g	
DCGL	2.39 pCi/g Cs-137 0.86 pCi/g Co-60	Approved DCGL for land areas inside the Restricted Area, (Reference 1)
Investigation Level (ISOCS @ 2 and 3 m)	1.0 pCi/g Cs-137 0.36 pCi/g Co-60	(Reference 3)
Design DCGL _{EMC}	3.82 pCi/g Cs-137 1.38 pCi/g Co-60	DCGL x Area Factor for Class 1 survey unit, per LTP Section 5.6.3

Attachment 3


Investigation Table
(not Used)

Attachment 4
Statistical Data

Survey Package FR0111 Unit 17 UNITY Soil Sign Test Summary

Evaluation Input Values		Comments
Survey Package:	FR0111	
Survey Unit:	17	
Evaluator:	DR	
DCGL _w :	1.00E+00	Unity
DCGL _{emc} :	1.60E+00	
LBGR:	5.00E-01	
Sigma:	5.56E-01	(1.33 pCi/g /2.39 pCi/g)
Type I error:	0.05	
Type II error:	0.05	
Nuclide:	UNITY	
Soil Type:	N/A	
Calculated Values		Comments
Z _{1-α} :	1.645	
Z _{1-β} :	1.645	
Sign p:	0.788145	
Calculated Relative Shift:	0.8	
Relative Shift Used:	0.8	Uses 3.0 if Relative Shift is >3
N-Value:	33	
N-Value+20%:	40	
Sample Data Values		Comments
Number of Samples:	40	
Median:	8.72E-02	
Mean:	9.80E-02	
Net Sample Standard Deviation:	5.78E-02	
Total Standard Deviation:	5.78E-02	Sum of samples and reference
Maximum:	4.34E-01	
Sign Test Results		Comments
Adjusted N Value:	40	
S+ Value:	40	
Critical Value:	25	
Sign test results:	Pass	
Criteria Satisfaction		Comments
Sufficient samples collected:	Pass	
Maximum value <DCGL _w :	Pass	
Median value <DCGL _w :	Pass	
Mean value <DCGL _w :	Pass	
Maximum value <DCGL _{emc} :	Pass	
Total Standard Deviation <=Sigma:	Pass	
Criteria comparison results:	Pass	
Final Status		Comments
The survey unit passes all conditions:	Pass	SU Passes


FR0111-17 Quantile Plot



One-Sample T-Test Report

Page/Date/Time 2 3/21/05 8:20:32 AM
Database
Variable C2

Plots Section



One-Sample T-Test Power Analysis

Page/Date/Time 2 3/21/05 8:21:45 AM

Chart Section

