

BHTP CHF Correlation Extensions and Extrapolations BAW-10241P, Rev. 1

Richard L. Harne Thermal-Hydraulic Technology Framatome ANP, Inc.

> NRC Offices, Rockville, MD May 3, 2005

BHTP DNB Correlation Extensions and Extrapolations, BAW-10241P, Rev.1

Agenda

? Comparison of BAW-10241P, Rev.1 to Previously Approved EMF-92-153, Rev.1

? Technical Review Schedule Need

AREV

EMF-92-153, Revision 1

- ? EMF-92-153, Revision 1
 - Correlation range extensions and extrapolations deemed
 necessary for supporting plant operation
 - HTP: Departure From Nucleate Boiling Correlation for High Thermal Performance Fuel
 - Application T/H Code: XCOBRA-IIIC
 - SER: January 2005

ARE\



- ? HTP Range Extensions
 - [] CHF data points from [] CHF tests in original correlation
 - 1.141 CHF Design Limit
 - [] additional CHF data points examined for 1400, 1000, and 600 psia covering [] of [] CHF tests
 - 1000 and 600 psia data dropped because of limited coverage across only 5 CHF tests, leaving [] data points
 - 3 data points for 1400 psia dropped, leaving [] data points
 - 2 points at low flow
 - 1 point at high thermodynamic quality
 - Extensions Granted in SER
 - Low Pressure

TRANSFORMED AND

- Low Mass Flow Rate
- High Thermodynamic Quality

EMF-92-153, Revision 1

? HTP Range Extrapolations

- Demonstrated the conservative behavior of the correlation predictions under high thermodynamic quality conditions below the original lower quality limit
 - SER granted the elimination of the lower quality limit
- Demonstrated the conservative behavior of the correlation predictions under pressures greater than the original high pressure limit
 - The proposed extension was modified during the review process
 - SER granted the specific and limited application of the correlation above the higher pressure limit
 - "When pressures greater than the upper pressure limit of 2425 psia but less than 2600 psia are encountered, all of the local coolant conditions are calculated at the upper pressure limit of 2425 psia using the NRC-approved thermal-hydraulic code and then used in the calculation of the HTP CHF."

HEAT IN COMPANY AND

RE\



BAW-10241, Revision 1

- ? BAW-10241, Revision 1
 - BHTP DNB Correlation Applied with LYNXT
 - Application T/H Code: LYNXT
 - Submitted: March 2005

BAW-10241, Revision 1

BHTP Range Extensions

RE

ENTRA TRANSFORME

- [] CHF data points from [] CHF tests in original correlation
- 1.132 CHF Design Limit
- [] additional CHF data points examined for 1400, 1000, and 600 psia covering [] of [] CHF tests
- 1000 and 600 psia data dropped because of limited coverage across only 5 CHF tests, leaving [] data points
- 3 data points for 1400 psia dropped, leaving [] data points
 - 2 points at low flow
 - 1 point at high thermodynamic quality
- Extensions requested, using data
 - Low Pressure
 - Low Mass Flow Rate
 - High Thermodynamic Quality



? BHTP Range Extrapolations

RE\

HEALING ON EVANIOUS

- The original HTP CHF correlation application for the additional [] data points was ~10% conservative.
- The BHTP CHF correlation application for the additional
 -] data points was roughly ~24% conservative.
- Therefore, the analytical conclusions observed for the HTP correlation are appropriate for the BHTP correlation extensions in lower quality and higher pressure.
- Framatome ANP is requesting the same extensions for lower quality and higher pressure.
 - Elimination of the lower thermodynamic quality limit.
 - "When pressures greater than the upper pressure limit of 2425 psia but less than 2600 psia are encountered, all of the local coolant conditions are calculated at the upper pressure limit of 2425 psia using the NRC-approved thermal-hydraulic code and then used in the calculation of the BHTP CHF."





? The requested application ranges for the BHTP correlation are consistent with those granted for the HTP correlation

		HTP	BHTP
		EMF-92-153, Rev.1	BAW-10241, Rev.1
		(Granted in SER)	(Requested in Submittal)
Extensions			
System Pressure	psia	1385 - 2425	1385 - 2425
Mass Flow Velocity	Mlb _m /ft²	0.498 - 3.573	0.492 - 3.549
Thermodynamic Quality		Up to 0.515	Up to 0.512
Extrapolations			
High Pressure	psia	Limited and Specific Application up to <2600 psia ¹	Limited and Specific Application up to <2600 psia ¹
Thermodynamic Quality		No Lower Limit ²	No Lower Limit ²

¹: When pressures greater than the upper pressure limit of 2425 psia but less than 2600 psia are encountered, all of the local coolant conditions are calculated at the upper pressure limit of 2425 psia using the NRC-approved thermal-hydraulic code and then used in the calculation of the HTP (or BHTP) CHF.

²: Any other extrapolation requires a plant-specific review (according to SER)

A UNIT OF EAND IN



- ? Entergy's ANO-1 Cycle 20 (startup Fall 2005) will contain the Mark-B-HTP fuel design requiring the use of the BHTP CHF correlation
- ? The generation of the 2 RC pump operating condition DNB-based safety limits (Tech Specs) revealed some situations where the local coolant mass velocity fell below the 0.897 Mlb_m/hr-ft² lower velocity limit from BAW-10241(A) Revision 0.
- ? Framatome ANP has requested in BAW-10241, Rev.1 the same correlation extensions and extrapolations for the BHTP correlation that were granted for the HTP correlation.
- ? Framatome ANP has requested an NRC review with an SER by August 1, 2005 to support plant operation.

BHTP DNB Correlation Extensions and Extrapolations, BAW-10241P, Rev.1

VICTOR PORT