

Richard Anderson
Vice President-Nuclear

440-280-5579
Fax: 440-280-8029

April 12, 2005
PY-CEI/NRR-2877L

United States Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555


Perry Nuclear Power Plant
Docket No. 50-440
License No. NPF-58
Monthly Operating Report

Ladies and Gentlemen:

Attached is the March 2005 Monthly Operating Report for Perry Unit 1. Page 1 is the Operating Data Report and page 2 is the Unit Shutdowns Report. This report is submitted in accordance with Technical Specification 5.6.4 and Generic Letter 97-02, "Revised Contents of the Monthly Operating Report."

If you have questions or require additional information, please contact Ms. Toni Phelps at (440) 280-7660.

Very truly yours,



Attachment

cc: NRC Region III Administrator
NRC Project Manager
NRC Resident Inspector

JE24

OPERATING DATA REPORT

UNIT: Perry
DATE: 4/7/05

1. Docket: 50-440
2. Unit Name: Perry Nuclear Power Plant
3. Reporting Period March 2005
4. Utility Contact: T. Phelps
5. Telephone: 440-280-7660
6. Design Electrical Rating (Net MWe): 1260
7. Maximum Dependable Capacity (Net MWe): 1235

| | <u>This Month</u> | <u>Yr-to-Date</u> | <u>Cumulative</u> |
|----------------------------------|-------------------|-------------------|----------------------|
| 8. Hours Reactor was Critical | <u>0.0</u> | <u>653.2</u> | <u>121,322.6</u> |
| 9. Hours Generator On-Line | <u>0.0</u> | <u>624.4</u> | <u>118,515.5</u> |
| 10. Unit Reserve Shutdown Hours | <u>0.0</u> | <u>0.0</u> | <u>0.0</u> |
| 11. Net Electrical Energy (MWeH) | <u>0.0</u> | <u>670,633.0</u> | <u>136,026,390.0</u> |

UNIT SHUTDOWNS REPORT MONTH – MARCH 2005

DOCKET NO: 50-440
 NAME: Perry Nuclear Power Plant
 DATE: 4/7/05
 CONTACT: T. Phelps
 TELEPHONE: (440) 280-7660

| No. | Date | Type 1 | Duration Hours | Reason 2 | Method 3 | Cause and Corrective Action to Prevent Recurrence |
|-------|---------|-----------|-------------------|-------------|-------------|--|
| 05-02 | 2/22/05 | S | 912.0 | C | 4 | The plant entered refuel outage #10 on February 22, 2005 @0001 |

SUMMARY: The Perry Nuclear Power plant commenced refuel outage #10 on 2/22/05 and continued to perform refuel outage activities through the month of March.

1. TYPE:

F: Forced
 S: Scheduled

2. REASON:

A - Equipment Failure (explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory
 E - Operating Training &
 License Examination
 F - Administrative
 G - Operational Error (explain)
 H - Other (explain)

3. METHOD:

1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continuation
 5 - Other