

RDB received 4/15/05

From: Kimball M. Strickland <kmstrick@execpc.com>
To: <nrcprep@nrc.gov>
Date: Fri, Apr 15, 2005 4:56 PM
Subject: Response from "Comment on NRC Documents"

①

70 FR 19125

4/12/05

Below is the result of your feedback form. It was submitted by

Kimball M. Strickland (kmstrick@execpc.com) on Friday, April 15, 2005 at 16:55:50

Document_Title: Proposed Generic Communication 7590-01
Grid Reliability and the Impact on Plant Risk and the Operability of Offsite Power

Comments: The proposed generic letter references 10 CFR 50 Appendix A GDC-17 criteria as design requirements (see Requested Information Items 1-4). Plants licensed prior to 1971 (when Appendix A GDCs were published) may not be required to comply with GDC-17. In particular, the emergency power provisions of earlier AEC draft GDCs did not address offsite power reliability. In the Requested Information section, please clarify how plants that are not licensed to nor required to meet the provisions of GDC-17 should address design criteria that do not apply to their facility.

organization:

address1: 2005 Berringer Rd

address2:

city: Manitowoc

state: WI

zip: 54220

country: USA

phone: 920-682-6318

SISP Review Complete

Template = ADM-013

E-RIDS = ADM-03

Add A. Markley (AWM)

Mail Envelope Properties (42602A5A.8A9 : 14 : 30889)

Subject: Response from "Comment on NRC Documents"
Creation Date: Fri, Apr 15, 2005 4:55 PM
From: Kimball M. Strickland <kmstrick@execpc.com>

Created By: kmstrick@execpc.com

Recipients

nrc.gov
twf2_po.TWFN_DO
NRCREP

Post Office

twf2_po.TWFN_DO

Route

nrc.gov

Files

MESSAGE
Mime.822

Size

1155
1863

Date & Time

Friday, April 15, 2005 4:55 PM

Options

Expiration Date: None
Priority: Standard
Reply Requested: No
Return Notification: None

Concealed Subject: No
Security: Standard