

Britt T. McKinney
Vice President-Nuclear Site Operations

PPL Susquehanna, LLC
769 Salem Boulevard
Berwick, PA 18603
Tel. 570.542.3149 Fax 570.542.1504
btmckinney@pplweb.com

*RDB Rec'd 3:20 on 4/19/05
aws*



APR 12 2005

Mr. Michael Lesar
Chief Rules and Directives Branch
Office of Administration
Mail Stop T-6D59
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

*(4)
2/28/05
70 FR 9682*

**SUSQUEHANNA STEAM ELECTRIC STATION
COMMENTS ON OFFICE OF NUCLEAR
REGULATORY RESEARCH DRAFT REPORT
ENTITLED, "STATION BLACKOUT RISK
EVALUATION FOR NUCLEAR POWER PLANTS"
PLA-5881**

**Docket Nos. 50-387
and 50-388**

This letter is in response to the Federal Register Notice of February 28, 2005 that requested comments on an Office of Nuclear Regulatory Research draft report entitled, "Station Blackout Risk Evaluation for Nuclear Power Plants." PPL Susquehanna, LLC has reviewed the draft report and offers the following clarification on Table 4-1, "EPS Configurations at U.S. Commercial Nuclear Power Plants."

In Table 4-1 in the column titled, "EPS Success Criteria" on Page 21, this column indicates that only one diesel generator is required for "success." The single diesel generator success criterion is true at Susquehanna SES for only diesel generators A and B but not for diesel generators C and D.

If you have any questions, please contact C. T. Coddington at (610) 774-4019.

B. T. McKinney

Copy: NRC Region I
Mr. A. J. Blamey, NRC Sr. Resident Inspector
Mr. R. V. Guzman, NRC Project Manager
Mr. R. Janati, DEP/BRP

*SISP Review Complete
Template = ADM-013*

E-RIDS = ADM-03

Add D. Rasmussen (DMR)