

From: Thomas Alexion *NRR*
To: Rebecca Nease *RNV*
Date: 7/14/03 4:33PM
Subject: Re: Add'l info from ANO

Rebecca,

My comments are as follows:

1. I had an addition subpart for the licensee to address the effect of thermoplastic cables to safely S/D Unit 2.
2. I had additional subparts to also provide the timeline for operator actions, and to provide the raw simulator data and evaluator sheets.
3. I thought the list was supposed to be for all cables in the area.
4. I had an additional subpart to address why the particular coating was chosen.

But I will defer to SPLB on these comments.

Tom

✓>>> Rebecca Nease 07/14/03 03:46PM >>> *RNV*
NRC Reg Conf Attendees,

Attached is a list of items we requested the licensee provide to us. I intend to include this with the meeting summary. Please review them to make sure I worded the requests as you meant them to be. If you have any questions or comments, you may respond to this e-mail, or call me at 817-860-8154. *Rel*

CC: Mark Salley

DDD-1

ANO REGULATORY CONFERENCE QUESTIONS

The following are what, in the regulatory conference, we asked the licensee to provide. Please review and confirm:

75

1