

**PRIORITY ATTENTION REQUIRED MORNING REPORT - REGION I****Morning Report Date: APR 28, 2005****Licensee/Facility:**

DOMINION NUCLEAR CONNECTICUT, INC.  
Millstone  
Waterford, Connecticut  
Dockets: 050-00245  
[1] GE-3

**Notification:**

MR Number: 1-2005-0002  
Date: 04/27/2005  
Call from SRI

**Subject:** Millstone 1 Flanders Line Fire

**Discussion:**

On Wednesday, April 27, 2005, at approximately 06:45 a.m., Millstone Unit 1 lost power to the spent fuel pool pumps when a transient caused the Flanders Line main breaker to open and automatically re-close. The licensee observed smoke, some arcing, and small flames on a utility pole located outside the protected area. The spent fuel pools pumps were returned to service when power was restored at 08:59 am.

During this short period no significant increase in spent fuel pool temperature occurred. It should be noted that the time to boil for the Unit 1 spent fuel pool is in excess of several days.

**Contact:**

PRINCE, ROBERT J

**Org:**

R1

**Phone No:**

(610) 337-5376

**Email:**

RJP4@nrc.gov