

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.3.6	Not used	
SR 3.6.3.7	<p>-----NOTE----- This surveillance is not required when the penetration flow path is isolated by a leak tested blank flange.</p> <hr/> <p>Perform leakage rate testing for containment purge, hydrogen purge and containment pressure relief valves with resilient seals.</p>	18 months
SR 3.6.3.8	Verify each automatic containment isolation valve that is not locked, sealed or otherwise secured in position, actuates to the isolation position on an actual or simulated actuation signal.	18 months
SR 3.6.3.9	Not used.	
SR 3.6.3.10	Not used.	
SR 3.6.3.11	Not used.	

(continued)